

Afton 8843G and Afton 8332G

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years of Manufacture	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
OPW	61T Series	Drop Tube	No	Jan. 1978	All	No	0-100%	No
OPW	61SO Series / 71SO Series	Overfill Valve	ULC: MH27238, MH21147	61SO: Oct. 1987, 71SO: Aug. 2006	All	No	0-100%	No
OPW	233 Series	Extractor	No	Jan. 1978	All	No	0-100%	No
OPW	61JSK-4410	Jack Screw Kit	No	May 2004	All	No	0-100%	No
OPW	61Fstop-2000	Overfill Valve	UL & ULC MH25724	Oct. 1994	All	No	0-100%	No
OPW	634B-0160	2" fill cap	No	March 1957	All	No	0-100%	No
OPW	1-2100 Series, Multiports, P500 and P700 Series, 1C-3100 Series	Spill Containers	ULC: MH27236	Edge: May 2008, others Jan. 1994	All	NO	0-100%	No
OPW	C075A, C10A, C15A, C20A	Flexible Pipe	UL: MH16678	2011	All	No	0-100%	No
OPW	SMA Series, DPC Series, SBC Series	Pipe Couplings	UL: MH16678	SMA/DPC: 2007 SBC: 2011	All	No	0-100%	No

For tanks and piping please list only double walled products

(Insert a company logo below if available)

Manufacturer: **OPW Retail Fuels**
 Corporate: **3250 Highway 70 Business West**
 Headquarters: **Smithfield, NC 27577**
 Address:
 Phone: **919 209 2443**
 Email: chuck.liebal@opwglobal.com

I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

Charles Liebal

Product Manager

Print Name

Title



5/10/2016