

Ethanol

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years Manufactured	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
OPW	523V and 623V Series	Pressure Vacuum Vent	MH19391	523V: Feb. 1998, 623V: Sept. 2003	All	No	0-100%	No
OPW	CXXA Double Wall Piping	Pipe	MH16678	2011 for CxxA 2006 for Cxx	All	No	0-100%	No
OPW	DPC-2150/DPC-2200, SBC-2150, SBC-2200	Coupling	MH16678	2005 for DPC 2011 for SBC	All	No	0-100%	No
OPW	SPC-0150, SPC-0200, SPC-0300, SMA-1515, SMA-1520, SMA-2020, SMA-3030	Coupling	MH16678	1997	All	No	0-100%	No
OPW	STF-1515, STF-2020, STF-2215, STF-2020	Tees	MH16678	1997	All	No	0-100%	No
OPW	SEF-1515, SRE-2015, SEF-2020, SEF-3030	Elbow	MH16678	1997	All	No	0-100%	No
OPW	MBS, DBS, TSS, TSM, TSD, TSMF, TSDF, TRFS Series	Tank Sump	MH19391 ULC: MH27190	July 1997	All	No	0-100%	No
OPW	DS, DSW, FDS, DFS Series	Dispenser Sump	MH19391 ULC: MH27190	July 1997	All	No	0-100%	No
OPW	EBF, DEB, REF	Entry Fitting	MH19391	REF: Nov. 2011, others: Aug. 1997	All	No	0-100%	No

Ethanol

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years Manufactured	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
OPW	1-2100 Series, Multiports, 1C-3100 Series	Spill Containers	ULC: MH27236	Edge: May 2008, others Jan. 1994	All	No	0-100%	No
OPW	60V Series	Vapor Shear Valve	MH25684	April 1993	All	No	0-100%	No
OPW	10 Series, 10P Series	Emergency Shear Valve	MH6535 ULC: MH27238	10: Nov. 1955, 10P: Oct. 2007	All	No	0-100%	No
OPW	10P-0152E85	Emergency Shear Valve	MH6535	July 2010	All	No	0-100%	No
OPW	61SALP-1020-EVR, 633T-8076	Fill Adaptors	No	61SALP: Oct. 2002, 633T: Aug. 1985	All	No	0-100%	No
OPW	61VSA-1020-EVR, 1611AVB-1625	Vapor Adaptor	No	61VSA: Oct. 2002, 1611: Sept. 1983	All	No	0-100%	No
OPW	634TT-7085, 1711T-7085-EVR, 634LPC-0400, 1711LPC-030	Adaptor Caps	No	LPC: April 2002, Others: Oct. 2002	All	No	0-100%	No
OPW	62M Series	Monitoring Cap	MH19391	April 1998	All	No	0-100%	No
OPW	61SO Series / 71SO Series	Overfill Valve	ULC: MH27238, MH21147	61SO: Oct. 1987, 71SO: Aug. 2006	All	No	0-15%	No
OPW	61SOM, 71SOM Series	Overfill Valve	ULC: MH27238, MH21147	61SO: Oct. 1987, 71SO: Aug. 2006	All	No	0-100%	No
OPW	6111 & 61TP Series	Tank Bottom	No	6111: July 1988, 61TP:	All	No	0-15%	No

Ethanol

Manufacturer's Affirmative Statement of Compatibility
 (As required by California Code of Regulations section 2631(k))

		Protectors		July 1979				
OPW	61T Series	Drop Tube	No	Jan. 1978	All	No	0-15%	No
OPW	61T-SS Series	Stainless Steel Drop Tube	No	Oct 2012	All	No	0-100%	No
OPW	233 Series	Extractor	No	Jan. 1978	All	No	0-100%	No
OPW	FCxx Series	Flex Connector	UL & ULC: MH48310	April 2003	All	No	0-100%	No

For tanks and piping please list only double wall products

(Insert a company logo below if available)

Manufacturer: OPW FCS
 Corporate Headquarters
 Address: **3250 Highway 70 Business West Smithfield, NC 27577**
 Phone: **919 934 2786**
 Email: cliebal@opwfcs.com

I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

 Charles Liebal
 Print Name


 Manufacturer's Authorized Signature

 Product Manager
 Title

 7/19/12
 Date