Renewable Diesel

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years Manufactured	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
Western Fiberglass, Inc.	TAP, OCT and TAPQ Series	Single Wall Tank Sump	MH 19409	1987 to Present	36", 42", 48" and Custom	Gray Fiberglass Exterior	R1 to R100	No
Western Fiberglass, Inc.	DWTAP, DWOCT and DWTAPQ Series	Double Wall Tank Sump	MH 19409	2004 to Present	36", 42", 48" and Custom	Gray Fiberglass Exterior	R1 to R100	No
Western Fiberglass, Inc.	PI1100, PI1101, PI4500, PI5500	Double Wall Piping	MH 19284	1995 to Present	0.75", 1.0", 1.5", 2.0"	Flexible Piping, Gray or White Exterior	R1 to R100	No
Western Fiberglass, Inc.	DMA Series	Single Wall Dispenser Sump	MH 17921	1987 to Present	0711 to 1836 or Custom	Gray Fiberglass Exterior	R1 to R100	No
Western Fiberglass, Inc.	DW DMA Series	Double Wall DIspenser Sump	MH 17921	2004 to Present	0711 to 1836 or Custom	Gray Fiberglass Exterior	R1 to R100	No
Western Fiberglass, Inc.	TR Series	Single Wall Transition Sump	MH 19409	1987 to Present	Any Size	Gray Fiberglass Exterior	R1 to R100	No
Western Fiberglass, Inc.	DWTR Series	Double Wall Transition Sump	MH 19409	2004 to Present	Any Size	Gray Fiberglass Exterior	R1 to R100	No
Western Fiberglass, Inc.	CoFlow Series	Hydrostatic Monitoring System	None	2004 to Present	Sump System / Pipe System	Metal Canister w/Clear Tubing	R1 to R100	No

❖ Please complete and submit form to Cory Hootman of the SWRCB at chootman@waterboards.ca.gov.

Renewable Diesel

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

For **tanks and piping** please list only double wall products

(Insert a company logo below if available)

Manufacturer: Western Fiberglass, Inc.
Corporate Headquarters Address: 1555 Copperhill Parkway, Santa Rosa, CA 95403
Phone: (707) 523-2050
Email: sales@westernfg.com

I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

Michael E. Lewis
Print Name

CEO
Title

Manufacturer's Authorized Signature

4/24/12
Date