

## State Water Resources Control Board

### UST CASE CLOSURE REVIEW SUMMARY REPORT

#### Agency Information

Agency Name: Santa Ana Regional Water Quality Control Board, Region 8 (Regional Water Board)	Address: 3737 Main Street, Suite 500, Riverside, CA 92501
Agency Caseworker: Valerie Jahn-Bull	Case No.: 83601874T

#### Case Information

USTCF Claim No.: 12690	Global ID: T0607100231
Site Name: Inco Service Station	Site Address: 796 West 5 <sup>th</sup> Street San Bernardino, CA 92410
Responsible Party (RP): William Bland	Address: Private Address
USTCF Expenditures to Date: \$857,629	Number of Years Case Open: 21

URL: [http://geotracker.waterboards.ca.gov/profile\\_report.asp?global\\_id=T0607100231](http://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T0607100231)

#### Summary

The Low-Threat Underground Storage Tank Case Closure Policy (Policy) contains general and media-specific criteria, and cases that meet those criteria are appropriate for closure pursuant to the Policy. This case meets all of the required criteria of the Policy. A summary evaluation of compliance with the Policy is shown in **Attachment 1: Compliance with State Water Board Policies and State Law**. The Conceptual Site Model upon which the evaluation of the case has been made is described in **Attachment 2: Summary of Basic Case Information (Conceptual Site Model)**. Highlights of the case follow:

An unauthorized leak was reported in April 1991. In May 1995, three gasoline USTs were removed. Soil vapor extraction was conducted from March 2001 through May 2009, intermittently, removing a reported 27,545 pounds of petroleum hydrocarbon vapor. Soil vapor extraction continued from June 2011 through March 2012, which removed an additional 2,493 pounds of TPHg and 30,038 gallons of impacted groundwater. The remediation system has been subsequently removed. According to groundwater data, water quality objectives (WQO) have been achieved for all constituents.

The petroleum release is limited to the shallow soil. According to data available in GeoTracker, there is no California Department of Public Health (CDPH) regulated supply wells or surface water bodies within 250 feet of the Site. No other water supply wells have been identified within 250 feet of the Site in files reviewed. Water is provided to water users near the Site by the San Bernardino Valley Water District. The groundwater is not currently being used as a source of drinking water, and it is highly unlikely that the shallow groundwater will be used as a source of drinking water in the foreseeable future. Other designated beneficial uses of groundwater are not threatened and it is highly unlikely that they will be considering these factors in the context of the site setting..

Corrective actions have been implemented and additional corrective actions are not necessary. Any remaining petroleum hydrocarbon constituents do not pose a significant risk to human health, safety or the environment.

**Rationale for Closure under the Policy**

- General Criteria: The case meets all eight Policy general criteria.
- Groundwater Specific Criteria: Groundwater Exclusion. It appears this Site does not contain sufficient mobile constituents to cause groundwater to exceed the groundwater criteria in the Policy. Therefore, the Site shall be considered a low-threat site for the groundwater medium.
- Vapor Intrusion to Indoor Air: The case meets Policy Criterion 2a by Scenario 3a. The maximum benzene concentration is less than 100 µg/L, the minimum depth to groundwater is greater than 5 feet, and is overlain by soil containing less than 100 mg/kg of TPHg.
- Direct Contact and Outdoor Air Exposure: The case meets Policy Criterion 3a. Maximum concentrations in soil are less than those in Policy Table 1 for Commercial/Industrial sites and the concentration limits for a Utility Worker are not exceeded.

**Objections to Closure and Responses**

According to the GeoTracker Closure Review page, the County objects to UST case closure because the extent of contamination in soil has not been defined.

RESPONSE: The extent of contamination is adequately defined by the existing monitoring well network and boreholes. The Case meets all the Policy criteria.

**Recommendation for Closure**

Based on available information, residual petroleum hydrocarbons at the Site do not pose a significant risk to human health, safety, or the environment, and the case meets the requirements of the Policy. Accordingly, the Fund Manager recommends that the case be closed. The State Water Board is conducting public notification as required by the Policy. San Bernardino County has the regulatory responsibility to supervise the abandonment of monitoring wells.

*Lisa Babcock*

\_\_\_\_\_  
Lisa Babcock, P.G. 3939, C.E.G. 1235

*6/5/13*

\_\_\_\_\_  
Date

Prepared by: Kirk Larson, P.G.

**ATTACHMENT 1: COMPLIANCE WITH STATE WATER BOARD POLICIES AND STATE LAW**

The case complies with the State Water Resources Control Board policies and state law. Section 25296.10 of the Health and Safety Code requires that sites be cleaned up to protect human health, safety, and the environment. Based on available information, any residual petroleum constituents at the site do not pose significant risk to human health, safety, or the environment.

**The case complies with the requirements of the Low-Threat Underground Storage Tank (UST) Case Closure Policy as described below.<sup>1</sup>**

<p><b>Is corrective action consistent with Chapter 6.7 of the Health and Safety Code and implementing regulations?</b>          The corrective action provisions contained in Chapter 6.7 of the Health and Safety Code and the implementing regulations govern the entire corrective action process at leaking UST sites. If it is determined, at any stage in the corrective action process, that UST site closure is appropriate, further compliance with corrective action requirements is not necessary. Corrective action at this site has been consistent with Chapter 6.7 of the Health and Safety Code and implementing regulations and, since this case meets applicable case-closure requirements, further corrective action is not necessary, unless the activity is necessary for case closure.</p>	<p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>
<p><b>Have waste discharge requirements or any other orders issued pursuant to Division 7 of the Water Code been issued at this case?</b></p>	<p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>
<p><b>If so, was the corrective action performed consistent with any order?</b></p>	<p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p>
<p><b><u>General Criteria</u></b>          General criteria that must be satisfied by all candidate sites:</p> <p><b>Is the unauthorized release located within the service area of a public water system?</b></p> <p><b>Does the unauthorized release consist only of petroleum?</b></p> <p><b>Has the unauthorized (“primary”) release from the UST system been stopped?</b></p> <p><b>Has free product been removed to the maximum extent practicable?</b></p> <p><b>Has a conceptual site model that assesses the nature, extent, and mobility of the release been developed?</b></p>	<p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>

<sup>1</sup> Refer to the Low-Threat Underground Storage Tank Case Closure Policy for closure criteria for low-threat petroleum UST sites.  
[http://www.waterboards.ca.gov/board\\_decisions/adopted\\_orders/resolutions/2012/rs2012\\_0016atta.pdf](http://www.waterboards.ca.gov/board_decisions/adopted_orders/resolutions/2012/rs2012_0016atta.pdf)

<p><b>Has secondary source been removed to the extent practicable?</b></p> <p><b>Has soil or groundwater been tested for MTBE and results reported in accordance with Health and Safety Code Section 25296.15?</b></p> <p><b>Nuisance as defined by Water Code section 13050 does not exist at the site?</b></p> <p><b>Are there unique site attributes or site-specific conditions that demonstrably increase the risk associated with residual petroleum constituents?</b></p>	<p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>
<p><b><u>Media-Specific Criteria</u></b>        Candidate sites must satisfy all three of these media-specific criteria:</p> <p><b>1. Groundwater:</b>        To satisfy the media-specific criteria for groundwater, the contaminant plume that exceeds water quality objectives must be stable or decreasing in areal extent, and meet all of the additional characteristics of one of the five classes of sites:</p> <p><b>Is the contaminant plume that exceeds water quality objectives stable or decreasing in areal extent?</b></p> <p><b>Does the contaminant plume that exceeds water quality objectives meet all of the additional characteristics of one of the five classes of sites?</b></p> <p>If YES, check applicable class: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> 4 <input type="checkbox"/> 5</p> <p><b>For sites with releases that have not affected groundwater, do mobile constituents (leachate, vapors, or light non-aqueous phase liquids) contain sufficient mobile constituents to cause groundwater to exceed the groundwater criteria?</b></p>	<p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p> <p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA</p>
<p><b>2. Petroleum Vapor Intrusion to Indoor Air:</b>        The site is considered low-threat for vapor intrusion to indoor air if site-specific conditions satisfy all of the characteristics of one of the three classes of sites (a through c) or if the exception for active commercial fueling facilities applies.</p> <p><b>Is the site an active commercial petroleum fueling facility?</b>        Exception: Satisfaction of the media-specific criteria for petroleum vapor intrusion to indoor air is not required at active commercial petroleum fueling facilities, except in cases where release characteristics can be reasonably believed to pose an unacceptable health risk.</p> <p><b>a. Do site-specific conditions at the release site satisfy all of the applicable characteristics and criteria of scenarios 1 through 3 or all of the applicable characteristics and criteria of scenario 4?</b>        If YES, check applicable scenarios: <input type="checkbox"/> 1 <input type="checkbox"/> 2 <input checked="" type="checkbox"/> 3 <input type="checkbox"/> 4</p>	<p><input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA</p>

<p><b>b. Has a site-specific risk assessment for the vapor intrusion pathway been conducted and demonstrates that human health is protected to the satisfaction of the regulatory agency?</b></p> <p><b>c. As a result of controlling exposure through the use of mitigation measures or through the use of institutional or engineering controls, has the regulatory agency determined that petroleum vapors migrating from soil or groundwater will have no significant risk of adversely affecting human health?</b></p>	<p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p>
<p><b>3. Direct Contact and Outdoor Air Exposure:</b>                  The site is considered low-threat for direct contact and outdoor air exposure if site-specific conditions satisfy one of the three classes of sites (a through c).</p> <p><b>a. Are maximum concentrations of petroleum constituents in soil less than or equal to those listed in Table 1 for the specified depth below ground surface (bgs)?</b></p> <p><b>b. Are maximum concentrations of petroleum constituents in soil less than levels that a site specific risk assessment demonstrates will have no significant risk of adversely affecting human health?</b></p> <p><b>c. As a result of controlling exposure through the use of mitigation measures or through the use of institutional or engineering controls, has the regulatory agency determined that the concentrations of petroleum constituents in soil will have no significant risk of adversely affecting human health?</b></p>	<p><input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA</p>

**ATTACHMENT 2: SUMMARY OF BASIC CASE INFORMATION (Conceptual Site Model)**

**Site Location/History**

- The Site is located at 796 West 5<sup>th</sup> Street in San Bernardino and is a vacant service station.
- The Site is bounded by North H Street to the west, empty lots to the north and east, and West 5<sup>th</sup> Street to the south. The surrounding land use is mixed residential and commercial.
- In December 1990, soil contamination was identified by an environmental investigation.
- Four monitoring wells have been installed and monitored regularly; all wells have been dry since 2003.
- Site map showing the location of the USTs, monitoring wells and site features is provided at the end of this closure review summary.
- Nature of Contaminants of Concern: Petroleum hydrocarbons only.
- Source: UST system.
- Date reported: April 1991.
- Status of Release: USTs removed.
- Free Product: None reported.

**Tank Information**

Tank No.	Size in Gallons	Contents	Closed in Place/ Removed/Active	Date
1	10,000	Gasoline	Removed	May 95
2	8,000	Gasoline	Removed	May 95
3	6,000	Gasoline	Removed	May 95

**Receptors**

- GW Basin: Upper Santa Ana Valley – Bunker Hill.
- Beneficial Uses: Municipal and Domestic Supply.
- Land Use Designation: None Specified. Aerial photograph available on GeoTracker show the land use is mixed commercial and residential in the vicinity of the Site.
- Public Water System: San Bernardino Valley Water District.
- Distance to Nearest Supply Well: According to data available in GeoTracker, there are no public supply wells regulated by CDPH within 250 feet of the defined plume. No other water supply wells were identified within 250 feet of the defined plume in the files reviewed.
- Distance to Nearest Surface Water: There is no identified surface water within 250 feet of the defined plume.

**Geology/Hydrogeology**

- Stratigraphy: The Site is underlain by interbedded and intermixed gravel, sand, with numerous three to five feet thick silty clay to clayey silt lenses; interspersed with coarse grained beds.
- Maximum Sample Depth: 130 feet below ground surface (bgs).
- Minimum Groundwater Depth: 69.80 feet bgs at monitoring well MW-2.
- Maximum Groundwater Depth: 125-130 feet bgs.
- Current Average Depth to Groundwater: 125 - 130 feet bgs.
- Saturated Zones(s) Studied: Approximately 125 - 130 feet bgs.
- Groundwater Flow Direction: Historically, southeast.

**Monitoring Well Information**

Well Designation	Date Installed	Screen Interval (feet bgs)	Depth to Water (feet bgs)
MW-1/VP-1	8/1999	68-88	Dry
MW-2/VP-2	8/1999	74-89	Dry
MW-3/VP-3	8/1999	68-88	Dry
MW-4	11/2000	65-90	Dry
CB-5	1/2010	Grab	125-130

**Remediation Summary**

- Free Product: No free product was documented in GeoTracker.
- Soil Excavation: Unknown
- In-Situ Soil Remediation: Soil vapor extraction was conducted from March 2001 through May 2009, intermittently, removed approximately 27,545 pounds. In May 2009, the rate of TPHg removal was 7.4 pounds/day. Soil vapor extraction was conducted from June 2011 through present, which removed 2,493 pounds of TPHg and 30,038 gallons of contaminated groundwater. The residual petroleum hydrocarbons are confined to fine grained soils between approximately 25 to 35 feet bgs. (EAR, 2010)
- Groundwater Remediation: No groundwater remediation has been conducted

**Most Recent Concentrations of Petroleum Constituents in Soil**

Constituent	Maximum 0-5 feet bgs [mg/kg and (date)]	Maximum 5-10 feet bgs [mg/kg and (date)]
Benzene	<0.001@ 5' in CB-1 (1/2010)	<0.001@ 10' in CB-1 (1/2010)
Ethylbenzene	<0.001@ 5' in CB-1 (1/2010)	<0.001@ 10' in CB-1 (1/2010)
Naphthalene	<0.0018@ 5' in CB-1 (1/2010)	<0.0018@ 10' in CB-1 (1/2010)
PAHs	NA	NA

NA: Not Analyzed, Not Applicable or Data Not Available  
 mg/kg: milligrams per kilogram, parts per million  
 <: Not detected at or above stated reporting limit  
 PAHs: Polycyclic aromatic hydrocarbons

**Most Recent Concentrations of Petroleum Constituents in Groundwater**

Sample	Sample Date	TPHg (µg/L)	Benzene (µg/L)	Toluene (µg/L)	Ethyl-Benzene (µg/L)	Xylenes (µg/L)	MTBE (µg/L)	TBA (µg/L)
MW-1	01/14/2003	<100	<0.3	<0.3	<0.3	<0.5	<2	NA
MW-2	01/14/2003	<100	<0.3	<0.3	<0.3	<0.5	<2	NA
MW-3	01/14/2003	<100	<0.3	<0.3	<0.3	<0.5	<2	NA
MW-4	01/14/2003	<100	<0.3	<0.3	<0.3	<0.5	<2	NA
CB-1	1/8/2010 <sup>a</sup>	ND <sup>c</sup>	ND <sup>c</sup>	ND <sup>c</sup>	ND <sup>c</sup>	ND <sup>c</sup>	ND <sup>c</sup>	ND <sup>c</sup>
<b>WQOs</b>	-	--	<b>1</b>	<b>150</b>	<b>700</b>	<b>1,750</b>	<b>5</b>	<b>1,200<sup>b</sup></b>


NA: Not Analyzed, Not Applicable or Data Not Available  
 µg/L: micrograms per liter, parts per billion  
 <: Not detected at or above stated reporting limit  
 TPHg: Total petroleum hydrocarbons as gasoline  
 MTBE: Methyl tert-butyl ether  
 TBA: Tert-butyl alcohol  
 --: The Regional Water Board, Basin Plan does not have a numeric value for TPHg  
 WQOs: Water Quality Objectives, Regional Water Board, Basin Plan  
<sup>a</sup>: Grab groundwater samples collected in a 2010 confirmation boring assessment.  
<sup>b</sup>: California Department of Public Health, Response Level  
<sup>c</sup>: Detection limits not reported in the 2010 report nor on GeoTracker.

### Groundwater Trends

Soils only case, fine grained soil containing residual petroleum hydrocarbons are between 25 and 35 feet below ground surface. (EAR, 2010)

### Evaluation of Current Risk

- Estimate of Hydrocarbon Mass in Soil: None reported.
- Soil/Groundwater tested for methyl tert-butyl ether (MTBE): Yes, see table above.
- Oxygen Concentrations in Soil Vapor: None reported.
- Plume Length: Soils only case.
- Plume Stable or Decreasing: Yes.
- Contaminated Zone(s) Used for Drinking Water: No.
- Groundwater Risk from Residual Petroleum Hydrocarbons: Groundwater Exclusion: It appears this Site does not contain sufficient mobile constituents to cause groundwater to exceed the groundwater criteria in the Policy and the Site shall be considered a low-threat site for the groundwater medium.
- Indoor Vapor Risk from Residual Petroleum Hydrocarbons: The case meets Policy Criterion 2a by Scenario 3a. The maximum benzene concentration is less than 100 µg/L, the minimum depth to groundwater is greater than 5 feet, and is overlain by soil containing less than 100 mg/kg of TPHg.
- Direct Contact Risk from Residual Petroleum Hydrocarbons: The case meets Policy Criterion 3a. Maximum concentrations in soil are less than those in Policy Table 1 for Commercial/Industrial land use and the concentration limits for a Utility Worker are not exceeded.



**ECR** ENGINEERING  
 CONSTRUCTION &  
 SUPPORT SERVICES  
 4267 TRAIL CREEK ROAD, RIVERSIDE, CA 92506  
 (951) 796-8979 FAX: (951) 715-8775

**Project Name:**  
 INCO GAS  
 796 WEST 5TH STREET  
 SAN BERNARDINO, CA 92410

**SITE PLOT PLAN**

<b>Date:</b>	<b>Job No:</b>	<b>Figure:</b>	<b>Scale:</b>
10/03/01	824858	2	AS SHOWN

**Drawn By:**  
 D. ACHARYA  
**Approved By:**  
 F. BIGONY

