



RICHARD G. SYKES
DIRECTOR OF WATER AND NATURAL RESOURCES
(510) 287-1629
rsykes@ebmud.com

October 28, 2015

BDCP/WaterFix Comments
P.O. Box 1919
Sacramento, CA 95812

SUBJECT: Comments on the Bay Delta Conservation Plan Partially Recirculated Draft Environmental Impact Report/Supplemental Draft Environmental Impact Statement

To Whom It May Concern:

The East Bay Municipal Utility District (EBMUD) appreciates this opportunity to review and provide comments on the Bay Delta Conservation Plan (BDCP) and the Partially Recirculated Draft Environmental Impact Report/Supplemental Draft Environmental Impact Statement (RDEIR/SDEIS). Although our comments in this letter are focused on WaterFix/revised Alternative 4A (Alternative 4A), our prior comments on the BDCP DEIR/DEIS, dated July 28, 2014, have not been addressed, continue to remain relevant, are attached to this letter and incorporated by reference.

Inadequate Information on Revised Project Operations

The RDEIR/SDEIS does not provide adequate information on how the State Water Project (SWP) and Central Valley Project (CVP) will be operated if the proposed Alternative 4A facilities are constructed, nor does it analyze the potentially significant environmental effects of those operations. This is a significant omission as it affects the very underpinning of the environmental analysis contained in the RDEIR/SDEIS. If the Water Fix is approved and constructed, up to 9,000 cubic feet per second (cfs) of water could be diverted in the North Delta at three new points of diversion. This water will be sent underneath the Delta in two new 30-mile long, 40-foot diameter tunnels to the existing SWP and CVP South Delta facilities and pumps. This will enable the SWP and CVP to divert entirely in the North Delta, entirely in the South Delta – as is done now – or in various combinations.

Given the large scale nature of the Alternative 4A components, operation of the new North Delta intakes in conjunction with the existing SWP/CVP South Delta points of diversion will certainly affect Delta flows, hydrodynamics, and water quality and fishery resources. Additional modeling information is needed to fully assess and quantify the impacts of Alternative 4A on Mokelumne River fisheries, existing EBMUD infrastructure (Mokelumne Aqueducts), and Freeport Operations (reverse flows). This is a fundamental gap in analysis in the RDEIR/SDEIS and must be addressed.

BDCP/WaterFix Comments
October 28, 2015
Page 2

EBMUD is providing comments below in the following three distinct areas:

- 1) potential impacts on Mokelumne fisheries,
- 2) potential impacts on EBMUD's Mokelumne water supply aqueducts, and
- 3) potential impacts on EBMUD's water supply at Freeport.

Impacts on Mokelumne River Fisheries from Delta Cross Channel operations

The RDEIR/SDEIS must consider how Alternative 4A will change the operations of the Delta Cross Channel (DCC), and assess how those changes will cause potentially significant environmental effects to the Mokelumne fisheries resources. While the RDEIR/SDEIS recognizes the hazards and low survival of migratory fish passing through the central Delta, the document makes no attempt to assess the potentially significant environmental impacts of the revised DCC operations likely as a result of Alternative 4A.

The operation of the DCC has long been identified as having a potential adverse impact on salmonid migration. For example, in 1989 the Mokelumne River Technical Advisory Committee identified the DCC as a significant factor contributing to straying of Mokelumne River salmonids. In addition, the Lower Mokelumne River Partnership, which includes representatives from California Department of Fish and Wildlife (CDFW), United States Fish and Wildlife Service (USFWS), and National Marine Fisheries Service (NMFS), worked with United States Bureau of Reclamation (USBR) to develop a low-risk study plan looking at the effects of DCC closures on migrating salmon. USBR issued a Finding of No Significant Impacts on the study plan in 2012. Due to limitations related to Delta water quality standards, the planned study closures did not occur. However, D-1641 Rio Vista flow standards have resulted in DCC closures since 2010. In each year the DCC has been closed, the stray rates of Mokelumne River salmonids to the Sacramento River system, primarily to the American River, have been reduced significantly. In addition, as part of the SWRCB Bay Delta Plan update Notice of Preparation in 2012, USFWS, USBR, and CDFW submitted comments supporting continued evaluation of DCC closures to improve salmon returns to both the Sacramento and Mokelumne river systems.

In sum, it is well settled that operation of the DCC can impact Mokelumne River fisheries. Therefore, any new operating regime resulting from Alternative 4A needs to include a full evaluation of the DCC impacts on migrating Mokelumne origin adult salmon, and a commitment to implement measures to mitigate those impacts (i.e., reduce straying) to a level of insignificance in the RDEIR/SDEIS.

Finally, the Mokelumne River is a distinct river system and the Mokelumne fish face conditions that are significantly different than those in the San Joaquin and Sacramento Rivers. Yet the RDEIR/SDEIS lumps the Mokelumne River together with the San Joaquin River, and contains no analysis addressing the project's impacts on the Mokelumne River fishery. It is therefore essential that the RDEIR/SDEIS assess impacts specifically on the Mokelumne fishery, as the Mokelumne River contributes a very high

BDCP/WaterFix Comments

October 28, 2015

Page 3

percentage of non-Sacramento-origin salmonid return in the Central Valley and to the commercial and recreational ocean fishery.

In summary, the RDEIR/SDEIS must consider how Alternative 4A will change the operations of the DCC, and assess how those changes will cause potentially significant environmental effects to the Mokelumne fisheries resources. (Attachment 2 of the attached July 28, 2014 letter provides additional technical comments and recommendations regarding Mokelumne fishery impacts.)

Impacts on EBMUD's Mokelumne Aqueducts

The Mokelumne Aqueducts are a vital link in EBMUD's water supply system, providing virtually all (90% on a long-term basis) of EBMUD's water supply to its East Bay service area and its nearly 1.4 million inhabitants. The Aqueducts traverse the Delta for a distance of approximately 90 miles from Pardee Reservoir in the east to Walnut Creek in the west. In their east-west crossing of the Delta, the Mokelumne Aqueducts pass over Lower Roberts Island, Upper Jones Tract, Woodward Island, and Palm-Orwood Tract. The proposed Alternative 4A twin tunnels would pass directly underneath the existing Mokelumne Aqueducts. For a map of the Mokelumne Aqueduct location relative to the Alternative 4A tunnels, see Attachment 3, Figure 1 of our July 28, 2014 comment letter.

As explained in detail in Attachment 3 of our July 28, 2014 comment letter, the proposed BDCP/Alternative 4A tunnels threaten to expose the existing Mokelumne Aqueducts and their deep foundations to substantial adverse effects resulting from soil settlement/subsidence, undermining, lateral earth movement, construction vibrations and vibration induced settlement. Attachment 3 also provides detailed mitigation measures that will be necessary to protect the existing aqueduct facilities from the project's impacts.

Under CEQA, potential impacts on public services and utility services are an impact area requiring analysis. The RDEIR/SDEIS does not adequately assess the project's impacts on the Mokelumne Aqueducts. Chapter 13.1.5 of the BDCP Conceptual Engineering Report erroneously concludes that "no conflicts are anticipated" with regard to the Mokelumne Aqueduct crossing and Chapter 13.2.5 indicates that the crossings "will be evaluated at the preliminary design level in conjunction with EBMUD." These analyses cannot be deferred to a future date. A thorough assessment of the potential impacts on the Mokelumne Aqueducts must be completed as part of the RDEIR/SDEIS to determine what mitigation measures will be necessary to protect the existing aqueduct facilities, and in turn avoid potential damage and suspension of water service to 1.4 million people in EBMUD's service area.

In addition, the RDEIR/SDEIS also fails to address a likely conflict between a future EBMUD cross-Delta tunnel and the proposed BDCP/Alternative 4A tunnels. EBMUD owns the land and subsurface rights along the alignment of the Mokelumne Aqueducts and has begun planning for a cross-Delta tunnel that could replace its existing above-ground aqueducts. In a telephone conversation on March 12, 2012, and in a follow up

BDCP/WaterFix Comments
October 28, 2015
Page 4

email on March 23, 2012, EBMUD staff discussed with DWR the potential conflicts between a BDCP tunnel and EBMUD's planned cross-Delta tunnel. EBMUD's design for its cross-Delta tunnel places the EBMUD tunnels within an elevation range of -100 feet mean sea level (ft msl) to -143 ft msl. Tunnel design will be developed further in the future, and subsequent design phases may identify a tunnel profile outside of these elevations. Despite prior notification given by EBMUD to DWR, the RDEIR/SDEIS documents fail to note the potential conflict, analyze the resulting environmental impacts, or propose mitigation.

The BDCP/Alternative 4A RDEIR/SDEIS must address this reasonably foreseeable conflict, and EBMUD expects the project to avoid tunneling within the -100 to -143 ft msl elevation range at the site of the tunnel intersection and also to provide an appropriate additional buffer between the two facilities.

Attachment 3 of our July 28, 2014 letter provides additional documentation on EBMUD's water supply facilities. The RDEIR/SDEIS must address how the project proponents will mitigate the environmental impacts on EBMUD's water supply facilities.

Impacts on diversions at Freeport Regional Water Project

EBMUD diverts critical water supplies at the Freeport Regional Water Project (FRWP), constructed and operated by the Freeport Regional Water Authority (FRWA). The FRWP is a drinking water diversion facility on the Sacramento River near Freeport. These diversions provide water supply for the Sacramento County Water Agency most years and to EBMUD during dry years. The Sacramento Regional County Sanitation District (SRCSD) operates a wastewater treatment plant downstream of the FRWA facilities. When the Sacramento River is flowing downstream the water quality at the FRWA facilities is adequate, however, when reverse flows occur, meaning when the Sacramento River is flowing upstream at the FRWA facilities, water quality can be adversely affected and diversions at FRWA must be shut down.

As explained below, Alternative 4A has the potential to increase the magnitude, frequency, and duration of reverse flows at Freeport, causing significant water quality impacts that require the Freeport water supply intake to be shut down more often and for longer intervals of time, thereby directly inhibiting FRWA's ability to divert water. However, the RDEIR/SDEIS fails to address these adverse impacts on operations of the existing FRWA facilities. This is not a new issue. EBMUD raised this issue in an August 26, 2009 letter to Dr. Parviz Nader, Supervising Engineer with DWR, and in EBMUD's BDCP comment dated July 28, 2014.

More specifically, Alternative 4A will likely cause a significant increase in reverse flows on the Sacramento River. Such flow changes would adversely impact FRWA operations as determined by analyzing modeling results performed by DWR, provided to EBMUD, and confirmed through independent modeling performed with DWR's Delta Simulation Model version 2 (DSM2). Although the previous BDCP modeling results showed that

BDCP/WaterFix Comments

October 28, 2015

Page 5

future wetland restoration in certain areas under the long-term BDCP would have mitigated these impacts, those restoration areas have been removed from Alternative 4A and no such mitigation is included. Thus, this potentially significant environmental effect must be fully analyzed and mitigated in the RDEIR/SDEIS.

Specific mitigations should be provided in the EIR/EIS to assure that Alternative 4A operations will not increase the magnitude, frequency, or duration of flow reversals in the Sacramento River at the FRWP. Operations must be managed at all times to avoid increasing the magnitude, frequency, or duration of flow reversals in the Sacramento River above Sutter Slough to avoid impacting the FRWP and EBMUD's water supply. Attachment 4 to our comment letter dated July 28, 2014 provides additional details regarding this issue.

We appreciate this opportunity to provide comments on the BDCP documents. If you have any questions about these comments, please contact Doug Wallace at 510-287-1370.

Sincerely,



Richard G. Sykes
Director of Water and Natural Resources

Attachment

cc: Charles Bonham, California Department of Fish and Wildlife
Mark Cowin, California Department of Water Resources
Randy Fiorini, Delta Stewardship Council
Campbell Ingram, Sacramento – San Joaquin Delta Conservancy
Ren Lohofener, U.S. Fish and Wildlife Service
David Murillo, U.S. Department of Interior, Bureau of Reclamation
Maria Rea, National Marine Fisheries Service

RGS:PGS:dec



RICHARD G. SYKES
DIRECTOR OF WATER AND NATURAL RESOURCES
(510) 287-1629
rsykes@ebmud.com

July 28, 2014

BDCP Comments
Ryan Wulff, NMFS
650 Capitol Mall, Suite 5-100
Sacramento, CA 95814

SUBJECT: Comments on the Bay Delta Conservation Plan and Environmental Impact Report/Environmental Impact Statement

Dear Mr. Wulff:

The East Bay Municipal Utility District (EBMUD) appreciates this opportunity to review and provide comments on the Bay Delta Conservation Plan (BDCP, or Plan) and the draft Environmental Impact Report/Environmental Impact Statement (EIR/EIS). The proposed project is enormous in both scope and complexity and it is critical that all interested and potentially impacted parties have a thorough and realistic understanding of the project's impacts, costs, and funding mechanisms. While EBMUD supports the efforts of DWR and USBR to secure improved supply reliability for the users of the export projects, we continue to be concerned about a number of issues, some of which we commented on when the documents were originally provided as administrative drafts in early 2013, that remain unaddressed.

For the BDCP to be successful, it will require support from a broad constituency. The BDCP must focus on a project that is implementable from financial, technical, and political perspectives. The very slow progress being made on the so-called "near term projects" in the Delta should serve as a cautionary tale for what is truly implementable. Unfortunately, after eight years of struggling to define the project and develop a financing strategy, the BDCP has not demonstrated a clear understanding of legitimate concerns and objections raised by many stakeholders and entities such as the Delta Independent Science Board and the Independent Review Panel. The BDCP and EIR/EIS consistently understate uncertainties and rely on a poorly defined and underfunded "adaptive management" program to address the unknowns at some time in the future.

Despite the clear dedication of the BDCP and EIR/EIS authors in addressing the complexities related to new conveyance and the other conservation measures, the Plan remains incomplete because it does not analyze any version of the portfolio alternative proposed by EBMUD and other stakeholders. BDCP proponents insist that additional storage, water use efficiency, Delta levee improvement, regional coordination, and alternative supplies will be addressed in other processes, but the BDCP is claiming an enormous share of public resources and political attention. We recognize the challenges of moving forward on multiple fronts; however, a narrower focus on the existing BDCP goals is destined to lead to more conflict and delay.

Draft EIR/EIS is Incomplete and Inadequate

The draft EIR/EIS is incomplete and inadequate. It has failed to consider significant impacts and depends on optimistic projections that have no basis in fact. The draft Implementing Agreement (IA), integral to the understanding of how the BDCP will function, is also incomplete and largely based on conjecture about future agreements and conditions. Since the documents are incomplete, the comments that follow are necessarily incomplete and subject to additional comment as a recirculated EIR/supplemental EIS and IA are completed.

Fundamentally flawed modeling

The climate change scenario violates CEQA and NEPA because the No Action Alternative (NAA) assumes certain changes as the result of climate change, and that the export projects' water operations would continue as if the climate changes were not taking place. As a result, under the NAA major California reservoirs are projected to operate to dead pool conditions in approximately 10% of years. Such operations do not reflect what "would reasonably be expected to occur" and do not include "predictable actions" (as required by CEQA and NEPA) that would likely be taken by water managers to avoid such conditions. This years' experience at Folsom Reservoir demonstrates the lengths to which water managers will go to avoid depleting water levels approaching the dead pool. The NAA is unrealistic and no confidence can be placed in the EIR/EIS comparisons between the NAA and the project alternatives. Unfortunately, the flawed modeling fails to meet the CEQA and NEPA standards to provide the public with accurate information on the potential impacts of the project. Attachment 1 provides further discussion and documentation on this technical issue.

Incomplete assessment of Mokelumne fishery impacts

The EIR/EIS documents fail to provide a complete assessment of the potential impacts on the Mokelumne River fisheries as required by CEQA/NEPA. As we have noted previously, the BDCP frequently assumes that the Mokelumne is "part of" either the San Joaquin or Sacramento Rivers. It inappropriately either extrapolates results to the Mokelumne River from studies conducted on those river systems, or combines data from different systems to determine "overall" impacts on a species while failing to identify specific impacts on Mokelumne populations.

Specific to the conservation measures, the only actions directed at the Mokelumne River involve the construction of 1,500 acres of seasonal floodplain which have uncertain benefits. The only modeled result from building the habitat is that it will increase residency time of Mokelumne and Cosumnes River origin water within the central Delta. Increasing the residency time of Mokelumne and Cosumnes River origin water may adversely affect juvenile salmonid survivability, and the EIR/EIS fails to include that potential impact. Throughout the document the poor survival outcome for salmonids migrating via the central Delta is described in detail using results from studies focused on Sacramento origin salmonids, not Mokelumne and Cosumnes.

Likewise, the EIR/EIS discusses the influence of DCC operations on migrating adult fall-run salmon. As far back as 1989 the operation of the DCC was identified as a potential impact to salmonid migration in the first meeting of the multi-agency Mokelumne River Technical Advisory Committee. The Lower Mokelumne River Partnership, which includes representatives from CDFW, USFWS, and NMFS worked with USBR to develop a low-risk study plan looking at the effects of DCC closures on migrating salmon. Moreover, both USFWS and CDFW provided comments supporting continued evaluation of DCC closures to improve salmon returns to both the Sacramento and Mokelumne River systems. Yet, no such evaluations are presented as part of the BDCP nor are any other studies or actions focused on Mokelumne origin salmonids proposed in the document. While the hazards and low survival of migratory fish passing through the central Delta are recognized, no attempt is made to determine or overcome the uncertainties involved in the limited measures targeting the area.

The Mokelumne is a distinct river system and the Mokelumne fish face conditions that are significantly different than those in the San Joaquin and Sacramento Rivers. It is essential that the BDCP assess impacts specifically on the Mokelumne fishery, as the Mokelumne River contributes a very high percentage of non-Sacramento-origin salmonid return in the Central Valley. Attachment 2 provides additional technical comments and recommendations regarding fishery impacts.

Assurances not justified given significant uncertainties

Hidden costs of "No Surprises" assurances: A key component of the BDCP is the assurances that will be granted to the project proponents in the form of long-term operating permits. Under both the federal ESA and the NCCP Act, assurances ("No Surprises" benefits) are available to permittees in exchange for commitments to implement conservation measures in accordance with an approved HCP/NCCP. As described in Chapter 6 in the BDCP, under the No Surprises rule, "[i]f the status of a species addressed under an HCP unexpectedly worsens because of unforeseen circumstances, the primary obligation for implementing additional conservation measures would be the responsibility of the Federal government, other government agencies, or other non-Federal landowners who have not yet developed an HCP." (BDCP at 6-29 through 30 [citing 63 Fed. Reg. 8867].)

The core concern for EBMUD is about how the assurances provided to BDCP permittees might affect non-permittees; specifically, where will the water and funding come from to implement additional measures that may be required? The BDCP leaves many related questions unanswered.

Assurances must be proportional to the certainty that the BDCP will be effective. *See, e.g.,* Fish and Game Code § 2820(f)(1) (listing factors CDFW must consider in determining the level of assurances to be provided to permittees). Unfortunately, the BDCP, a habitat conservation plan/natural community conservation plan of unprecedented scope and complexity, is pervaded by uncertainties regarding costs,

BDCP Comments
July 28, 2014
Pg. 4

funding, operations, conservation measure implementation, conservation measure outcomes, and the “silver bullet” of adaptive management.

As the Independent Review Panel (Panel) noted in its March 2014 review of the draft EIR/EIS, “many of the critical justifications behind the supposed benefits of the conservation measures are highly uncertain.” The Panel further noted; “Uncertainty plus uncertainty is more uncertainty. Uncertainty never averages or cancels out uncertainty.” Given the high uncertainties, it is difficult to imagine how any long-term assurances could be granted to the permittees.

Adaptive management is ill-defined and significantly underfunded: The BDCP relies heavily on the concept of adaptive management. The Panel noted that the “foundation of the BDCP is weak” and the “burden to ensure covered species benefit, if not recovery, depends on adaptive management.”

Adaptive management is defined as a structured, iterative process of decision making in the face of uncertainty, with an aim to reducing uncertainty over time via system monitoring. Critical to adaptive management is effective system monitoring that provides accurate, timely, and useful information for iterative decision making. Unfortunately, the BDCP fails to demonstrate a firm commitment to the adaptive management process. Active ecological monitoring, independent scientific review, and feedback systems are lacking in the BDCP. The adaptive management program offered by the BDCP is ill-defined and lacking in scientific rigor and adequate funding.

For adaptive management to provide any degree of success, it must either be implemented as a specific and mandatory conservation measure, or in some other way be made a firm and clear commitment of the BDCP with appropriate levels of dedicated funding.

In Appendix 8A, costs associated with monitoring actions for many of the conservation measures have been subsumed under a general category of administrative costs. Such an approach heightens the risk of underfunding a critical element of adaptive management. A transparent, comprehensive and dedicated budget must be developed that covers all the adaptive management costs, including active monitoring, independent scientific review, and feedback systems. The budget should also reflect the fact that there is significant uncertainty in the system and the monitoring and review must be sufficient to track the system responses.

EBMUD has extensive experience with biological monitoring of the Mokelumne fishery as well as the costs involved in comprehensive ecosystem monitoring. The cost estimates provided in the BDCP for adaptive management are significantly underestimated and demonstrate a serious misunderstanding of the needs associated with the implementation of an adaptive management program as complex as that required for the BDCP. For example, the cost estimate presented in Appendix 8A-122 for Monitoring Action 16-2 is unrealistically low. The plan estimates a program cost for MA16-2 of \$3.5 million over 5 years, but based on EBMUD’s experience with fish tagging, the cost of tags alone will be

BDCP Comments
July 28, 2014
Pg. 5

about \$4.9 million, not including staff time, data analysis, or camera monitoring equipment. In this one example, the monitoring costs are underestimated by nearly 50%, suggesting a broader concern with the cost estimates of the entire adaptive management program.

A poorly conceived and underfunded adaptive management program is more likely to result in poor performance that will negatively affect covered species and produce unexpected or “unforeseen” circumstances. The inadequate planning for adaptive management increases the risk that government agencies and others will be forced to fund additional measures for protecting the species.

Impact of assurances on water supplies: If USBR provides water from federal facilities as an element of “additional measures” it undertakes in the BDCP, it is reasonable to expect that such action would reduce the water supplies available to CVP contractors that are not BDCP permittees. In the Conservation Strategy chapter (3.4.23.4) there is a reference to “voluntary sellers [of] long-term access to water for the purposes of, among other things, enhancing environmental conditions in the Delta.” However, the existence of such voluntary sellers is speculative and section 3.4.23.1 states that adaptive management actions will be “water-neutral” for BDCP permittees. Therefore, a zero-sum situation might easily ensue in which CVP contractual obligations are directly in conflict with assurances for yield under the BDCP. It is likely that adaptive management will require increased Delta flows and with the “water-neutral” assurance, those increased flows could only derive from non-permittees. The BDCP does not address how such a situation would be managed or resolved.

In a similar vein, water right holders could be subject to the same risk. Despite a commitment from the current Governor that other water users will not be harmed by the BDCP, it can be expected that the BDCP permittees would exert great effort to ensure that their investment “paid off”. Once the BDCP has been permitted, the agencies will be under increased obligation to implement the conservation measures in all circumstances, foreseeable and otherwise. Water right holders could be subject to increased flow releases to meet water quality standards, or to address adverse changes in the status of covered species, as a “backstop” for the assurances granted to BDCP permittees.

Finally, the implementation of additional measures by the federal and state agencies will require funding. The inclusion of “non-Federal landowners” along with the Federal and other parties responsible for funding such measures is of concern for two reasons. First, the term “non-Federal landowners” is not defined, therefore many water users could fall into that category. And second, “non-Federal landowners” are not cited in the language of the rule itself.

As noted below, the failure of Chapter 8 to identify firm funding sources for virtually the entire Plan, let alone procedures for dealing with unforeseen circumstances, leaves open significant questions about whether non-permittee water users could be exposed to costs of BDCP implementation, whether in the form of water supplies or dollar funds.

Unrealistic cost estimates and speculative funding sources

Failure to comply with ESA and NCCPA: The BDCP does not comply with ESA and NCCP Act standards for cost estimates and funding projections. As in previous drafts of the BDCP, Chapter 8 provides inadequate information for a reasoned assessment of how the BDCP will be paid for, and by whom.

At a threshold level, Chapter 8 (Implementation Costs and Funding Sources) does not meet the requirements of the NCCP Act, which requires an Implementation Agreement detailing, among other things: 1) provisions “specifying the actions [CDFW] shall take... if the plan participant fails to provide adequate funding”; and 2) “mechanisms to ensure adequate funding to carry out the conservation actions identified in the plan” (Fish and Game Code Section 2820(b)(3)).

Similarly, the federal ESA requires that HCPs specify “the applicant will ensure that adequate funding for the plan will be provided” for conservation actions that minimize and mitigate impacts on covered species. The statute, applicable case law, and guidance documents provide that the BDCP:

- Must “ensure” funding over the lifetime of the permit;
- Cannot rely on federal funding to “ensure” funding of the plan in light of the “Anti-Deficiency Act and the availability of appropriated funds”;
- Must provide “remedies for failure to meet funding obligations by signatory measures”;
- “Cannot rely on speculative future actions of others” for funding; and
- Must be backed by a guarantee by the applicant to ensure funding for all plan elements.¹

The BDCP meets none of these conditions, and in fact relies on arguments that are expressly in contradiction to the statutory requirements.

In essence, the BDCP will rely on funding from three primary sources: state and federal water contractors, two state water bonds, and continuing and expanded federal appropriations. Each of these three sources is fraught with uncertainties that pose fundamental challenges to the financial viability of the Plan.

State and federal contractors: Chapter 8 provides barely any elaboration on the statement that “funding of CM1 Water Facilities and Operation will come from state and federal contractors.” Critical information is lacking on:

- The respective financial obligation of urban and agricultural contractors;

¹ 16 USC 1539(a)(2)(B)(iii); *National Wildlife Federation v. Babbitt*, 128 F.Supp.2d 1274, 1294-95 (E.D. Cal., 2000); *Southwest Center for Biological Diversity v. Bartel*, 470 F.Supp.2d 1118, 1155 (S.D. Cal., 2006); HCP Handbook, pp. 3-33 to 3-34.

- The ability and willingness to pay on the part of the agricultural contractors, who will use approximately 70% of the yield;
- How the \$2 billion obligation previously assigned to the Friant Water Users will be paid;
- The financial obligation, if any, of the CVP contractors who are not BDCP permittees regarding Level 2 refuge supplies; and
- The respective financial obligation of the CVP and SWP contractors.

On this last point, the Plan states that “The actual funding share that is provided by the state versus federal water contractors for CM1 will be determined near the time that permits are issued for the BDCP.” Delaying important financing decisions to the end of the permitting process effectively precludes the opportunity for the public to identify, evaluate, and communicate any concerns. This is particularly relevant given the possibility that the state (and therefore its taxpayers) might have to be the guarantor of any default by the Plan permittees, or that a statewide water use surcharge might be enacted to cover unmet costs.

State water bonds: The BDCP assumes that two water bonds, totaling more than \$3.7 billion and 91% of the state share of the non-conveyance BDCP costs, will be approved by the voters. Given that the bond bills currently before the legislature dedicate no more than \$1.5 billion to Delta sustainability, this projection of state bond funding for the BDCP is unrealistically optimistic even if a bond measure were to pass.

The case *Southwest Center for Biological Diversity v. Bartel* directly addresses reliance on funding from a future bond requiring voter approval. In the case of *Southwest Ctr. for Biological Diversity v. Bartel*, 470 F.Supp.2d 1118 (S.D. Cal. 2006), the Court noted that “the uncertainty of these ideas is readily apparent,” that such funding is speculative in light of future voter approval requirements, and that relying on future bonds does not meet the requirement to ensure funding of an HCP under the ESA. (See *id.* at 1156.)

Further, under the NCCP Act, the reliance on speculative future funding from state water bonds gives no reasonable assurance of maintaining “rough proportionality between impacts on habitat or covered species and conservation measures” (Fish and Game Code Section 2820(b)(3)(B)). Nor can reliance on speculative future state water bonds meet the requirement for the Implementation Agreement to include mechanisms to ensure adequate funding. Fish and Game Code Section 2820(b)(8).

Continuing and expanded federal appropriations: Several very optimistic assumptions are required to accept the Plan’s projections of future federal funding. The discussion begins with a description of the CVPIA Restoration Fund, and an expectation that this over-subscribed source could be used to fund several conservation measures in the BDCP. In an equally hopeful manner, the Plan projects future federal funding based on past appropriations to a wide variety of existing programs that are already committed to supporting other actions. However, the evidence is entirely in support of the opposite

trend: federal funding for a huge array of discretionary programs has been declining for years, with no sign that a reversal can be expected.

Impacts on EBMUD facilities

Impacts on existing and proposed Mokelumne Aqueducts: The BDCP and EIR/EIS need to address a likely conflict between a future EBMUD cross-Delta tunnel and the proposed BDCP tunnels. EBMUD owns the land and subsurface rights along the alignment of the Mokelumne Aqueducts. Ninety miles of aqueducts traverse the Delta from Pardee Reservoir in the east to Walnut Creek in the west. In their east-west crossing of the Delta, the aqueducts pass over Lower Roberts Island, Upper Jones Tract, Woodward Island, and Palm-Orwood Tract. EBMUD has begun planning for a cross-Delta tunnel that could replace its existing above-ground aqueducts. In a telephone conversation on March 12, 2012, and in a follow up email on March 23, 2012, EBMUD staff discussed with DWR the potential conflicts between a BDCP tunnel and EBMUD's planned cross-Delta tunnel. EBMUD's design for its cross-Delta aqueduct places the EBMUD tunnels within an elevation range of -100 ft msl to -143 ft msl. Tunnel design will be developed further in the future, and subsequent design phases may identify a tunnel profile outside of these elevations. The proposed BDCP tunnels will intersect the EBMUD property, existing aqueducts, and planned cross-Delta tunnel. Despite prior notification given by EBMUD to DWR, the BDCP documents fail to note the potential conflict, analyze the resulting environmental impacts, or propose mitigation. In fact, Chapter 13.1.5 of the BDCP Conceptual Engineering Report – which is the only mention, to our knowledge, of the Mokelumne Aqueduct crossing in the available BDCP documents – erroneously concludes that “no conflicts are anticipated” with regard to the Mokelumne Aqueduct crossing. The BDCP EIR/EIS must address this reasonably foreseeable conflict, and EBMUD expects the BDCP to avoid tunneling within the -100 to -143 msl elevation range at the site of the tunnel intersection and also to provide an appropriate additional buffer between the two facilities.

Attachment 3 provides additional documentation to clarify EBMUD's existing and planned facilities, and it is incorporated into this comment letter by reference. The EIR/EIS must address how the BDCP proponents will mitigate the environmental impacts that will result from conflicts with EBMUD's existing and planned facilities. As explained in detail in Attachment 3, the BDCP tunnel threatens to expose the Mokelumne Aqueducts and their deep foundations to substantial adverse effects resulting from soil settlement/subsidence, undermining, lateral earth movement, construction vibrations and vibration induced settlement. Attachment 3 also provides detailed mitigation measures that will be necessary to protect the existing aqueduct facilities. Protecting this existing infrastructure is especially important given its vital role in the provision of reliable and safe drinking water service to the approximately 1.3 million people within EBMUD's service area. Accordingly, not only is the BDCP tunnel likely to cause significant direct impacts along the Mokelumne Aqueduct and EBMUD's right-of-way, it also poses a significant risk of indirect environmental impacts resulting from the potential suspension of water service that could occur if its impacts on EBMUD's facilities are not appropriately mitigated. For similar reasons, as discussed in Attachment 3, the BDCP

tunnel is also likely to cause significant cumulative impacts when considered in conjunction with EBMUD's future cross-Delta tunnel project. Because the DEIR/EIS failed entirely to consider these significant impacts, a supplemental DEIS/recirculated DEIR must be prepared and made available for public comment. *See* CEQA Guidelines § 15088.5 (setting forth standard for EIR recirculation); 40 C.F.R. § 1502.9(c)(1).

Impacts on Freeport Regional Water Project: The EIR/EIS fails to address adverse impacts that the BDCP intake facilities may have on operations of the existing Freeport Regional Water Project (FRWP) facilities. Modeling simulations performed with DSM2 by DWR, and confirmed by independent DSM2 modeling, show that proposed BDCP operations will cause a significant increase in reverse flows in the Sacramento river in the vicinity of Freeport, and such flow changes will adversely impact FRWP operations. Interruption of FRWP operations poses a risk of indirect environmental impacts resulting from the potential suspension of water service that could occur if FRWP operations were curtailed as the result of reverse flows. The modeling results show that eventual wetland restoration in certain areas will mitigate these impacts, but such restorations should be undertaken concurrently with, or in advance of, the conveyance construction so as not to delay the mitigation. Attachment 4 provides additional details regarding this issue.

Unfounded “optimistic bias” present throughout the documents

In a number of critical aspects, the BDCP relies on optimal conditions and outcomes to achieve its goals. In its draft report released in May, the Delta Independent Science Board states that “Expectations for the effectiveness of conservation actions are too optimistic” for the purposes of counterbalancing any negative impacts of water diversions and changes in flow. In other words, there is well-grounded doubt that the proposed ecosystem measures will be able to contribute to the recovery of the listed species to the extent assumed.

As noted by the Independent Review Panel, the BDCP and EIR/EIS authors used “professional judgment” rather than scientific data to understate or ignore uncertainties and arrive at conclusions that are more positive than the science suggests. Such scientifically unsupported “optimistic bias” present throughout the entire BDCP process is disconcerting. It implies an unwillingness of the project proponents to view the project realistically. The findings of the numerous peer reviews strongly suggest that the EIR/EIS has failed to adhere to best available science as required by the ESA, NCCPA, and Delta Reform Act. It is critical that the EIR/EIS be thorough, non-biased, and realistic. EBMUD is greatly concerned that unjustified assurances granted through the BDCP will result in fiscal and resource responsibilities being shifted to non-BDCP permittees.

Finally, in Chapter 8 the BDCP asserts that “The potential funding sources described in this chapter have been made conservatively. That is, costs may be lower than estimated, or actual funding from state and federal sources may exceed these projections.” This claim is unsubstantiated, and ignores the distinct possibility that costs may be higher than expected, and that actual funding from state and federal sources may be substantially less than the projections. We believe the costs associated with implementing a viable adaptive

BDCP Comments
July 28, 2014
Pg. 10

management program have not been given serious consideration. And on a broader level, the BDCP simply has not been realistic about the range of possible outcomes in cost and performance. The proposed BDCP tunnels are unprecedented in their scale and magnitude, which would seem to heighten the uncertainties over the cost estimates of construction and operation. Nonetheless, the BDCP fails to consider the likely cost overruns and instead notes that "costs may be lower than estimated." The BDCP and draft EIR/EIS rely on unfounded optimistic bias in both restoration effectiveness and financial projections, and therefore fail to comply with the ESA and NCCP Act standards for use of best available science and cost estimates and funding projections.

The following documents are attached:

- Attachment 1 – Report on Review of Bay Delta Conservation Program Modeling
- Attachment 2 – Mokelumne Fisheries
- Attachment 3 – Existing and Future EBMUD Facilities, BDCP Impacts and Proposed Mitigations
- Attachment 4 – BDCP Impacts on Freeport Regional Water Project

We appreciate this opportunity to provide comments on the BDCP documents. If you have any questions about these comments, please contact Doug Wallace at 510-287-1370.

Sincerely,



Richard G. Sykes
Director of Water and Natural Resources

Attachments

cc: Charles Bonham, California Department of Fish and Wildlife
Mark Cowin, California Department of Water Resources
Randy Fiorini, Delta Stewardship Council
Campbell Ingram, Sacramento – San Joaquin Delta Conservancy
Ren Lohofener, U.S. Fish and Wildlife Service
David Murillo, U.S. Department of Interior, Bureau of Reclamation
Maria Rea, National Marine Fisheries Service

RGS:PGS:dec

Attachment 1

Report on Review of Bay Delta Conservation Program Modeling

Report on Review of Bay Delta Conservation Program Modeling

Foreword

Since December 2012, MBK Engineers and Dan Steiner (collectively “Reviewers”) have assisted various parties in evaluating the operations modeling that was performed for the Bay Delta Conservation Plan (BDCP). To assist in understanding BDCP and the potential implications, stakeholders¹ requested that the Reviewers review the CalSim II modeling studies performed as part of the BDCP (hereafter “BDCP Studies” or “BDCP Model”).

An initial review led the Reviewers to conclude that the BDCP Model, which serves as the basis for the environmental analysis contained in the BDCP Environmental Impact Report/Statement (EIR/S), provides very limited useful information to understand the effects of the BDCP. The BDCP Model contains erroneous assumptions, errors, and outdated tools, which result in impractical or unrealistic Central Valley Project (CVP) and State Water Project (SWP) operations. The unrealistic operations, in turn, do not accurately depict the effects of the BDCP.

The Reviewers revised the BDCP Model to depict a more accurate, consistent version of current and future benchmark hydrology so that the effects of the BDCP could be ascertained. The BDCP Model was also revised to depict more realistic CVP and SWP operations upon which to contrast the various BDCP alternatives. The Reviewers made significant efforts to coordinate with and inform the U.S. Bureau of Reclamation (Reclamation) and the California Department of Water Resources (DWR) managers and modelers, and CVP and SWP operators of the Reviewers’ modifications, assumptions, and findings. Where appropriate, the Reviewers also used Reclamation and DWR’s guidance and direction to refine the Reviewers’ analysis.

This Report summarizes: (1) the Reviewers’ independent analysis and review of the BDCP Model, publicly released for the BDCP’s Draft EIR/S in December 2013, (2) the Reviewers’ updates and corrections made to the BDCP Model, and (3) comparisons between the original BDCP Model and the independent Model as revised by the Reviewers.

¹ The entities who funded this report are Contra Costa Water District, East Bay Municipal Utility District, Friant Water Authority, Northern California Water Association, North Delta Water Agency, San Joaquin River Exchange Contractors Water Authority, San Joaquin Tributaries Authority, and Tehama Colusa Canal Authority.

Contents

1	Executive Summary	3
	Purpose of this Report	3
	Key Conclusions	4
	Additional Observations and Recommendations	7
2	Introduction	8
3	Review of BDCP CalSim II Modeling	10
3.1	Climate Change	10
	Implementation of Climate Change	10
	Assessment of Climate Change Assumptions and Implementation	10
	Conclusions Regarding Climate Change Assumptions and Implementation	12
3.2	General Assumptions and Operations	13
	BDCP CalSim II Assumptions	13
	Conclusions Regarding General Assumptions and Operations	14
3.3	Assumptions and Operational Criteria for inclusion of proposed BDCP facilities	14
	Assessment of Assumptions and Operations in coordination with new BDCP facilities	15
	Conclusions Regarding Assumptions and Operations in coordination with new BDCP facilities	18
4	Independent Modeling	20
4.1	Improvements to CalSim II Assumptions	20
	Revisions incorporated by DWR and Reclamation for the 2013 baseline	20
	Additional Revisions to CalSim II Assumptions	21
4.2	Improvements to BDCP Operations	21
4.3	Independent Modeling output and analysis of BDCP Effects	23
5	Comparing Independent Modeling and BDCP Model	27
	Conclusions regarding BDCP effects	27
6	Glossary	28

Technical Appendix

1 EXECUTIVE SUMMARY

Purpose of this Report

The CalSim II model is the foundational model for analysis of the BDCP, including the effects analysis in the Draft BDCP and the impacts evaluation in the Draft BDCP Environmental Impact Report/Statement (EIR/S). Results from CalSim II are used to examine how water supply and reservoir operations are modified by the BDCP. The results are also used by subsequent models to determine physical and biological effects, such as water quality, water levels, temperature, Delta flows, and fish response. Any errors and inconsistencies identified in the underlying CalSim II model are therefore present in subsequent models and adversely affect the results of later analyses based on those subsequent models.

The purpose of this Report is to examine the underlying CalSim II model used in support of the BDCP EIR/EIS and to analyze proposed operational scenarios contained in the BDCP. In undertaking the analysis for this Report, the Reviewers examined the model used in support of BDCP, the 2010 version of the CalSim II Model (BDCP Model), as well as the information contained in the Public Review Draft BDCP, released in December 2013. There are three basic reasons why the BDCP Model cannot be used to determine the effects of the BDCP: 1) the no action alternatives do not depict reasonable operations due to climate change assumptions, 2) operating criteria used in the BDCP Alternative 4 result in unrealistic operations, and 3) updates to CalSim II since the BDCP modeling was performed almost 4 years ago alter model results.

Given that it was not possible to determine how the BDCP may affect CVP and SWP operations or water system flows and conditions using the BDCP Model, independent modeling was performed to assess the potential effects of the BDCP. The first phase of this independent modeling effort was development of an updated without project baseline, which is similar to the no action alternative but with current, improved assumptions. The 2010 version of the CalSim II Model was used as the basis for the BDCP Model. The most recent version of CalSim II is the 2013 version used by DWR in its 2013 State Water Project Water Delivery Reliability Report (2013 CalSim II Model), and has undergone significant revision to not only correct errors in the 2010 model, but also to reflect regulatory changes that adversely affect the accuracy and dependability of the 2010 CalSim II Model. The BDCP was developed and analyzed using the 2010 CalSim II Model, and the changes and improvements reflected in the 2013 CalSim II Model were not used for the BDCP. For the purpose of the Reviewers' analysis and this Report, the 2013 CalSim II Model was further modified to incorporate additional updates, assumptions, and fixes. Some of these most recent Reviewer modifications have been accepted by both DWR and Reclamation, and are now incorporated into the CalSim II models that DWR and Reclamation use in conducting their own analyses. The second phase of the independent modeling effort (described in Section 4.2) incorporated the facilities and operations for the BDCP described as Alternative 4 H3 in the Draft EIR/EIS.

The manner in which the CVP and SWP are operated in the "With Project" and "Without Project" modeling scenarios significantly influences the BDCP "effects analysis". Modeling scenarios must depict how the actual system operates or how it might operate so that realistic effects can be determined. Modeling results from CalSim II are used to examine the effects of BDCP on water supply and reservoir operations, and the modeling results are also used by subsequent models to determine physical and biological effects, such as water quality, water levels, temperature, Delta flows, and fish response. If CalSim II modeling does not appropriately characterize operations in both the "With Project" and "Without Project" scenarios, the effects based on CalSim II will also not be appropriately characterized. The independent model provides a more accurate platform to assess the operations of the BDCP and isolates the effects of the BDCP from climate change. Comparing the results of the independent model to those of the BDCP model reveals significant differences in water operations and potential environmental impacts.

Key Conclusions

Assumptions, errors, and outdated tools used in the BDCP Model results in impractical or unrealistic CVP and SWP operations. Therefore, the BDCP Model provides very limited useful information to illustrate the effects of the BDCP.

Methodology used to incorporate climate change contains errors and does not incorporate reasonably foreseeable adaptation measures:

Climate change assumptions were incorrectly applied, yielding non-sensible results.

Climate change hydrology in the Upper San Joaquin River basin was incorporated incorrectly into the BDCP Model. Although inflow to Millerton Lake is expected to *decrease* under future climate scenarios, the error in the BDCP Model causes the amount of stored water in Millerton Lake to *increase* by inappropriately reducing water deliveries to the Friant Division. BDCP erroneously overestimates Millerton Lake storage, which causes an overestimation of reservoir releases and available water downstream. Because overall CVP operations and the San Joaquin River are interconnected, this error causes problems throughout the CVP system. With the coordinated operations of the CVP and SWP, this error can affect the SWP system.

Incorporation of climate change ignores reasonably foreseeable adaptation measures.

The BDCP Model uses assumed future climate conditions that obscure the effects of implementing the BDCP. The future conditions assumed in the BDCP model include changes in precipitation, temperature, and sea level rise. The result of this evaluation is that the modeled changes in water project operations and subsequent environmental impacts are caused by three different factors: (1) sea level rise; (2) climate change; and (3) implementation of the alternative that is being studied.

Including climate change, without adaptation measures, results in insufficient water needed to meet all regulatory objectives and user demands. For example, the BDCP Model results that include climate change indicate that during droughts, water in reservoirs is reduced to the minimum capacity possible. Reservoirs have not been operated like this in the past during extreme droughts and the current drought also provides evidence that adaptation measures are called for long in advanced to avoid draining the reservoirs. In this aspect, the BDCP Model simply does not reflect a real future condition. Foreseeable adaptations that the CVP and SWP could make in response to climate change include: (1) updating operational rules regarding water releases from reservoirs for flood protection; (2) during severe droughts, emergency drought declarations could call for mandatory conservation and changes in some regulatory criteria similar to what has been experienced in the current and previous droughts; and (3) if droughts become more frequent, the CVP and SWP would likely revisit the rules by which they allocate water during shortages and operate more conservatively in wetter years. The modifications to CVP and SWP operations made during the winter and spring of 2014 in response to the drought supports the likelihood of future adaptations. The BDCP Model is, however, useful in that it reveals that difficult decisions must be made in response to climate change. But, in the absence of making those decisions, the BDCP Model results themselves are not informative, particularly during drought conditions. With future conditions projected to be so dire without the BDCP, the effects of the BDCP appear positive simply because it appears that conditions cannot get any worse (i.e., storage cannot be reduced below its minimum level). However, in reality, the future condition will not be as depicted in the BDCP Model. The Reviewers recommend that Reclamation and DWR develop more realistic operating rules for the hydrologic conditions expected over the next half-century and incorporate those operating rules into any CalSim II Model that includes climate change.

The BDCP Model does not accurately reflect reasonably foreseeable conditions and changes in CVP and SWP operations due to the BDCP:

BDCP's "High Outflow Scenario" is not sufficiently defined for analysis.

The effects of many critical elements of the BDCP cannot be analyzed because those elements are not well-defined. The Reviewers recommend that the BDCP be better defined and a clear and concise operating plan be developed so that the updated CalSim II model can be used to assess effects of the BDCP.

The High Outflow Scenario (HOS) requires additional water (Delta outflow) during certain periods in the spring. The BDCP Model places most of the responsibility for meeting this new additional outflow requirement on the SWP. However, the SWP may not actually be responsible for meeting this new additional outflow requirement. This is because the Coordinated Operations Agreement ("the COA") would require a water allocation adjustment that would keep the SWP whole. Where one project (CVP or SWP) releases water to meet a regulatory requirement, the COA requires a water balancing to ensure the burden does not fall on only one of the projects. The BDCP Model is misleading because it fails to adjust project operations, as required by the COA, to "pay back" the water "debt" to the SWP due to these additional Delta outflow requirements. Unless there is a significant revision to COA, the BDCP Model overstates the impacts of increased Delta outflow on the SWP and understates the effects on the CVP.

Furthermore, after consulting with DWR and Reclamation project operators and managers, the Reviewers conclude that there is no apparent source of CVP or SWP water to satisfy both the increased Delta outflow requirements and pay back the COA "debt" to the SWP without substantially depleting upstream water storage. It appears, through recent public discussions regarding the HOS, that BDCP anticipates additional water to satisfy the increased Delta outflow requirement and to prevent the depletion of cold water pools will be acquired through water transfers from upstream water users. However, this approach is unrealistic. During most of the spring, when BDCP proposes that Delta outflow be increased, agricultural water users are not irrigating. This means that there is not sufficient transfer water available to meet the increased Delta outflow requirements and therefore, additional release of stored water from the reservoirs would be required. Releasing stored water to meet the increased Delta outflow requirements could potentially impact salmonids on the Sacramento and American River systems due to reductions in the available cold water pool.

Simulated operation of BDCP's dual conveyance, coordinating proposed North Delta diversion facilities with existing south Delta diversion facilities, is inconsistent with the project description.

The Draft BDCP and associated Draft EIR/EIS specify criteria for how much flow can be diverted by the new North Delta Diversion (NDD) facilities and specify when to preferentially use either the NDD facilities or the existing South Delta diversion (SDD) facilities. However, the BDCP Model contains an artificial constraint that prevents the NDD facilities from taking water as described in the BDCP project description. In addition to affecting diversions from the NDD, this artificial constraint contains errors that affect the No Action Alternative (NAA) operation. This error has been fixed by DWR and Reclamation in the more recent 2013 CalSim II Model; however, the error remains in the BDCP Model. Additionally, the BDCP Model does not reflect the summer operations of the SDD that are described in the Draft EIR/EIS as a feature of the BDCP project intended to prevent water quality degradation in the south Delta. The net effect of these two errors is that the BDCP Model significantly underestimates the amount of water diverted from the NDD facilities and overestimates the amount of water diverted from the SDD. The

further decrease in flows through the Delta, in comparison to what is presented in the BDCP Draft EIR/EIS, would likely result in even greater degradation in Delta water quality than reported.

The BDCP Model contains numerous coding and data issues that significantly skew the analysis and conflict with actual real-time operational objectives and constraints

Operating rules used in the BDCP Model, specifically regarding Alternative 4, result in impractical or unrealistic CVP and SWP operations. Reservoir balancing rules cause significant drawdown of upstream reservoirs during spring and summer months while targeting dead pool level in San Luis from September through December resulting in artificially low Delta exports and water shortages. CVP allocation rules are set to artificially reduce south of Delta allocations during wetter years resulting in underestimates of diversions at the NDD and the SDD. Operating rules for the Delta Cross Channel Gate do not reflect how the gates may be operated in “With Project” conditions.

Operational logic is coded into the CalSim II model to simulate how DWR and Reclamation would operate the system under circumstances for which there are no regulatory or other definitive rules. This attempt to specify (i.e., code) the logic sequence and relative weighting so that a computer can simulate “expert judgment” of the human operators is a critical element to the CalSim II model. In the BDCP version of the CalSim II model, some of the operational criteria for water supply allocations and existing facilities such as the Delta Cross Channel and San Luis Reservoir are inconsistent with real-world conditions.

The BDCP Model, as modified by the Reviewers, corrected some of the inconsistencies between the operational criteria in the BDCP Model and real-world conditions, and confirmed these changes with CVP and SWP operators. By correcting the operational criteria, the modified BDCP model (Independent Model) output is more accurate and consistent with real-world operational objectives and constraints.

Independent modeling of the BDCP revealed differences in CVP and SWP operations and water deliveries from the analysis disclosed for the Draft EIR/EIS.

The independent model provides a more accurate platform to assess the operations of the BDCP and isolates the effects of the BDCP from climate change. Comparing the results of the independent model to those of the BDCP model reveals significant differences in water operations and potential environmental impacts. The independent model “Without Project” baseline was compared to the independent model’s version of Alternative 4 H3-ELT of the BDCP. The updated changes in water operations from the independent model are compared to changes in operations reported in the BDCP Draft EIR/EIS for the equivalent alternatives. The difference between the updated independent model results and those reported in the BDCP Draft EIR/EIS are presented below.

- The amount of water exported (diverted from the Delta) may be approximately 200 Thousand Acre-Feet (TAF) per year *higher* than the amount disclosed in the Draft EIR/S. This total represents:
 - approximately 40 TAF/yr more water diverted and delivered to the SWP south of Delta contractors, and
 - approximately 160 TAF/yr more water diverted and delivered to the CVP south of Delta contractors.
- The BDCP Model estimates that, under the No Action Alternative at the Early Long Term (NAA – ELT) (without the BDCP), total average annual exports for CVP and SWP combined are estimated to be 4.73 million acre-feet (MAF) and in the Independent Model Future No Action (FNA) combined exports are 5.61 MAF. The BDCP Model indicates an increase in exports of approximately 540 TAF and the Independent Model shows an increase of approximately 750 TAF in Alt 4.

- Delta outflow would decrease by approximately 200 TAF/yr compared to the quantity indicated in the Draft EIR/S.
 - This lesser amount of Delta outflow has the potential to cause more significant water quality and supply impacts for in-Delta beneficial uses and additional adverse effects on species. To determine the potential effects of the reduced amount of Delta outflow, additional modeling is needed using tools such as DSM2.
- The BDCP Model does not accurately reflect the location of the diversions that the SWP and CVP will make from the Delta.
 - When the errors in the BDCP Model are corrected, the Independent Model reveals that the NDD could divert approximately 680 TAF/yr more than what is disclosed in the BDCP Draft EIR/S.
 - Conversely, the quantity of water diverted through the existing SDD would be approximately 460 TAF/yr less than what is projected in the BDCP Draft EIR/S.
 - This difference in the location of diversions has the potential to reduce water quality in the Central and South Delta in ways that were not analyzed in the BDCP Draft EIR/S

Additional Observations and Recommendations

This review identified and remedied several modeling deficiencies that should be used by others as the BDCP and other projects move forward. However, the work done to date by the Reviewers does not capture all of the improvements necessary to depict the effects of the BDCP accurately. There are many operational uncertainties in the BDCP that require attention and must be addressed. The Reviewers offer several recommendations so that future CalSim II modeling of the BDCP will yield more meaningful results.

1. Ensure model operations of existing facilities are consistent with contemporary real world operations to the extent possible.
 - a. Ensure reservoirs are not routinely drawn down to dead pool as part of 'normal' operations.
2. Given the expected changes in hydrologic conditions over the next half century, realistic operating rules for all CVP and SWP facilities, including the BDCP, must be developed.
 - a. Develop a 'drought' operations plan that includes adaptations.
 - b. Alter reservoir flood release operations to match the assumed shift in precipitation patterns.
 - c. Perform a sensitivity analysis using a range of possible future climates.
3. BDCP operations must be defined in a clear and concise manner.
 - a. Transfer water required to make an alternative feasible should be identified so the effects of that transfer can be determined.
 - b. Adaptive management limits and targets must be better defined
 - c. Changes to the existing COA to accommodate the BDCP must be defined.
 - d. Modeled export operations spilt between the north and south intakes must be consistent with the project description.
 - e. Changes in the DCC operations should be defined.
 - f. Refined reservoir balancing rules

The BDCP Model must be revised prior to drawing conclusions regarding the environmental effects of the BDCP. The BDCP Model is an outdated version of the CalSim II model, which contains known errors. Only by incorporating the changes made to date by the Reviewers, incorporating the additional recommended changes above, and potential additional refinements can the effects of the BDCP be determined. Reasonable conclusions can only be drawn once these changes are made to the BDCP Model; therefore, the Reviewers recommend that Reclamation and DWR make these changes.

2 INTRODUCTION

The Public Draft BDCP has been prepared by DWR, with assistance and input from Reclamation and various entities that receive water from the SWP and CVP. The BDCP is being prepared to comply with the federal Endangered Species Act, and certain other federal and state mandates. The BDCP proposes a number of Conservation Measures that, if implemented, are believed to provide some benefit to various species covered by the BDCP in the Delta. The Conservation Measures proposed in the Public Draft BDCP include new conveyance facilities and modified operations of the SWP and CVP, as well as other Conservation Measures addressing water quality, predation, and other habitat-related measures. The BDCP has been in development for several years. DWR also has prepared a Public Draft EIR/EIS in an attempt to satisfy CEQA and NEPA. Both the Public Draft BDCP and the Public Draft EIR/EIS were released for public review and comment in December 2013. This Report analyzes the BDCP as proposed and analyzed in the documents released in December 2013.

The Public Draft EIR/EIS considered several water facility and operational configurations, ultimately identifying "Alternative 4" as the preferred alternative under CEQA. (Public Draft EIR/EIS, Section 3.1.1) In addition to identifying physical facilities, the Public Draft EIR/EIS identifies an operational scenario (Alternative 4, Operation Scenario H) as the proposed operation regime for the new and existing facilities. (Public Draft EIR/EIS, Section 3.1.1, Section 5.3.3.9.) Alternative 4, Operational Scenario H is further divided into four sub-operational scenarios, which vary depending on Fall and Spring Delta outflow requirements. Those sub-scenarios are: Alternative 4 Operational Scenario H1 (Alternative 4 H1); Alternative 4 Operational Scenario H2 (Alternative 4 H2); Alternative 4 Operational Scenario H3 (Alternative 4 H3); and Alternative 4 Operational Scenario H4 (Alternative 4 H4). (Public Draft EIR/EIS, section 5.3.3.9.)

In general the differences between the various operational sub-scenarios are as follows. Alternative 4 H1 does not include enhanced spring outflow requirements or Fall X2 requirements. Alternative 4 H2 includes enhanced spring outflow requirements but not Fall X2 requirements. Alternative 4 H3 does not include enhanced spring outflow requirements but includes Fall X2 requirements. Alternative 4 H4 includes both enhanced spring outflow requirements and Fall X2 requirements. (Public Draft EIR/EIS, section 5.3.3.9.) This Report focuses on Alternative 4 H4 and Alternative 4 H3.

The task of the Reviewers was to review the CalSim II modeling which provides the foundational analysis of the BDCP. Results from CalSim II are used to examine how water supply and reservoir operations are modified by the BDCP, and the results are also used by subsequent models to determine physical and biological effects, such as water quality, water levels, temperature, Delta flows, and fish response. Any errors and inconsistencies identified in the underlying CalSim II model are therefore present in subsequent models and adversely affect the results of later analyses based on those subsequent models.

The model used in support of BDCP is the 2010 version of the CalSim II Model (BDCP Model), as well as the information contained in the Public Review Draft BDCP, released in December 2013. Since its development in 2010, the 2010 version of the CalSim II Model has undergone significant revision to not only correct errors in the model, but also to reflect regulatory changes that adversely affect the accuracy and dependability of the 2010 CalSim II Model. The updated version of CalSim II is the model used by DWR in its 2013 State Water Project Water Delivery Reliability Report (2013 CalSim II Model). The BDCP was developed and analyzed using the 2010 CalSim II Model; the changes and improvements reflected in the 2013 CalSim II Model were not used for the BDCP.

The initial review conducted by the Reviewers led to the conclusion that the BDCP Model provides very limited useful information to illustrate the effects of the BDCP. Assumptions, errors, and outdated tools used in the BDCP Model result in impractical or unrealistic CVP and SWP operations. Because of the unrealistic operations included in the BDCP Model, the Reviewers revised the BDCP Model to depict a more accurate, consistent version of

current and future benchmark hydrology. The BDCP Model was also revised to depict more realistic CVP and SWP operations upon which to contrast the various BDCP alternatives. The Reviewers made significant efforts to coordinate with or inform Reclamation and DWR managers and modelers, and CVP and SWP operators of the Reviewers' modifications, assumptions, and findings. Where appropriate, the Reviewers also used Reclamation's and DWR's guidance and direction to refine the Reviewers' analysis. Although there are many models used to evaluate various effects of BDCP, this analysis and review focused on water operations analysis using the BDCP Model (CalSim II).

Purpose and Use of the CalSim II Model

The CalSim II model is a computer program jointly developed by DWR and Reclamation. CalSim II presents a comprehensive simulation of SWP and CVP operations, and it is used by DWR as a planning tool to predict future availability of SWP water. CalSim II is widely recognized as the most prominent water management model in California, and it is generally accepted as a useful and appropriate tool for assessing the water delivery capability of the SWP and the CVP.

Broadly speaking, the model estimates, for various times of the year, how much water will be diverted, will serve as instream flows (e.g., flow in the rivers at various locations, such as Delta outflow), and will remain in the reservoirs. Within the context of the BDCP, the CalSim II model is also used to estimate the amount of water that will be diverted from BDCP's proposed NDD facilities. Thus, for BDCP, the CalSim II model estimates how much water will be diverted at the NDD facilities, how much flow will remain in the Sacramento River below Hood (the approximate location of the NDD facilities), how much water will be diverted through the existing SDD facilities at Tracy, how much flow will leave the Delta by flowing out to the Bay, and how much water will remain in storage in the reservoirs. The location and timing of the diversion and the amount of water remaining instream are significant because they can cause impacts on species, water quality degradation, and the like.

The coding and assumptions included in the CalSim II model drive the results it yields. Data and assumptions, such as the amount of precipitation runoff at a certain measuring station over time or the demand for water by specific water users over time, are input into the model. The criteria that are used to operate the CVP and the SWP (including current regulatory requirements) are included in the model as assumptions; because of the volume of water associated with the CVP and the SWP, these operational criteria significantly influence the model's results. Additionally, operational logic is coded into the CalSim II model to simulate how DWR and Reclamation would operate the system under circumstances for which there are no regulatory or otherwise definitive rules (e.g., when to move water from upstream storage to south of Delta storage). This attempt to specify (i.e., code) the logic sequence and relative weighting that humans will use as part of their "expert judgment" is a critical element to the CalSim II model.

The model's ability to reliably predict the effects of a proposed action depends on the accuracy of its coding and its representation of operations criteria. In other words, the model's results will be only as good as its data, coding, assumptions, and judgment and knowledge of the modelers. For this reason, a detailed operating plan of existing facilities and the proposed facility is essential to create an accurate model of how a proposed action will change – i.e., affect – existing water operations. In reviewing the BDCP Model it became apparent that coding errors and operating assumptions are inconsistent with the actual purposes and objectives of the CVP and SWP, thus limiting the utility and accuracy of the results. Through collaboration and verification with CVP and SWP operators, the BDCP Model flaws were corrected in the revised BDCP Model (Independent Model) and the potential effects of the BDCP were re-analyzed.

3 REVIEW OF BDCP CALSIM II MODELING

The CalSim II model is the foundational model for analysis of the BDCP, including the effects analysis in the Draft BDCP and the impacts evaluation in the Draft EIR/EIS. Results from CalSim II are used to examine how water supply and reservoir operations are modified by the BDCP, and the results are also used by subsequent models to determine physical and biological effects, such as water quality, water levels, temperature, Delta flows, and fish response. Any errors and inconsistencies identified in the underlying CalSim II model are therefore present in subsequent models and adversely affect the results of later analyses based on those subsequent models.

The Reviewers' analysis of the BDCP Model is summarized in three categories: (3.1) assessment of climate change assumptions, implementation, and effects; (3.2) assessment of general assumptions and operations; and (3.3) assessment of the assumptions and operational criteria for inclusion of the new BDCP facilities. The issues discussed in (3.1) and (3.2) are relevant for all modeling scenarios, both baseline scenarios that do not include BDCP and with project scenarios that evaluate BDCP or the Alternatives. The issues discussed in (3.3) are specific to the inclusion of the BDCP as defined in the Draft Plan and identified as Alternative 4 in the Draft EIR/EIS.

3.1 Climate Change

Implementation of Climate Change

The analysis presented in the BDCP Documents attempts to incorporate the effects of climate change at two future climate periods: the early long term (ELT) at approximately the year 2025; and the late long term (LLT) at approximately 2060. As described in the BDCP documents², other analytical tools were used to determine anticipated changes to precipitation and air temperature that is expected to occur under ELT and LLT conditions. Projected precipitation and temperature was then used to estimate runoff into from the watersheds over an 82-year period of variable hydrology; these time series were then used as inputs into the BDCP Model. A second aspect of climate change, the anticipated amount of sea level rise, is incorporated into the BDCP CalSim II model by modifying flow-salinity relationships that estimate salinity within the Delta based on sea level and flows within Delta channels.

This Report does not evaluate the analytical processes by which reservoir inflows and runoff were developed, nor does it evaluate the modified flow-salinity relationships that are assumed due to sea level rise; those items could be the focus of another independent review. This Report is limited to evaluating how the modified flows were incorporated into the BDCP Model and whether the operation of the CVP and SWP water system in response to the modified flows and the modified flow-salinity relationship is reasonable for the ELT and LLT conditions. This work reviews the assumed underlying hydrology and simulated operation of the CVP/SWP, assumed regulatory requirements, and the resultant water delivery reliability.

Assessment of Climate Change Assumptions and Implementation

To assess climate change, the three Without Project (or "baseline" or "no action") modeling scenarios were reviewed: No Action Alternative (NAA)³, No Action Alternative at the Early Long Term (NAA – ELT), and No Action Alternative at the Late Long Term (NAA –LLT). Assumptions for NAA, NAA-ELT, and NAA-LLT are provided in the Draft BDCP EIR/EIS Appendix 5A, Section B, Table B-8. The only difference between these scenarios is the climate-related changes made for the ELT and LLT conditions (Table 1).

² BDCP EIR/EIS Appendix 5A, Section A and BDCP HCP/NCCP Appendix 5.A.2

³ NAA is also called the Existing Biological Conditions number 2 (EBC-2) in the Draft Plan.

Table 1. Scenarios used to evaluate climate change

Scenario	Climate Change Assumptions	
	Hydrology	Sea Level Rise
No Action Alternative (NAA)	None	None
No Action Alternative at Early Long Term (NAA-ELT)	Modified reservoir inflows and runoff for expected conditions at 2025	15 cm
No Action Alternative at Early Long Term (NAA-LLT)	Modified reservoir inflows and runoff for expected conditions at 2060	45 cm

The differences between the NAA and NAA-ELT reveal the effects of the climate change assumptions under ELT conditions; similarly, the differences between the NAA and NAA-LLT reveal the effects of the climate change assumptions under LLT conditions. Numerous comparisons between NAA, NAA-ELT, and NAA-LLT are discussed in the Technical Appendix of this report; issues that shaped our conclusions are discussed below.

Climate change implementation is incorrect, yielding non-sensible results.

Climate change hydrology in the Upper San Joaquin River basin (above Friant Dam) was incorporated incorrectly into the BDCP Model, resulting in non-sensible results. Because overall CVP operations and the San Joaquin River are interconnected, this error causes problems throughout the CVP system. With the coordinated operations of the CVP and SWP, this error can affect the SWP system.

Specifically, under climate change, inflow to Millerton Lake is expected to decrease (BDCP DEIR/S, Appendix 29B). However, when climate change was implemented into the BDCP Model, it was done incorrectly such that: (1) the inflow into Millerton Lake *was not adjusted* for climate change and is thus overestimated, and yet (2) the flood control operations and water allocation decisions for Millerton Lake *were adjusted* for climate change as if the inflow was reduced. The net effect is that storage in Millerton Lake is overestimated; in fact, the BDCP model indicates that the amount of water stored in Millerton Lake will actually be increased as a result of climate change even though the inflow to the lake is projected to be reduced (i.e., non-sensible). This error results in the overestimation of Millerton Lake storage causing an overestimation of reservoir releases for flood control purposes and available water downstream at the Mendota Pool; these unreasonably high flood releases are then diverted by CVP exchange contractors in lieu of taking CVP Delta water, which means that either CVP Delta exports are reduced or the water is backed up into San Luis Reservoir (SLR), overestimating SLR storage. Furthermore, any excess water from the Millerton Lake that is not diverted at Mendota Pool would continue downstream and ultimately increase Vernalis flow, which subsequently affects Delta exports. Ultimately, changes in exports have the potential to affect upstream reservoir releases (i.e., from Lake Shasta) as well.

This is a situation where one seemingly minor error cascades through the entire system. This error exists in all BDCP Model scenarios (baselines and project alternatives) that have climate change incorporated at either ELT or LLT conditions. In other words, all model results reported in the BDCP and associated Draft EIR/S contain this error, with the only exception of the Existing Biological Conditions baselines numbers 1 and 2 (EBC1 and EBC2), which are evaluated in the BDCP.

Effects of climate change create unrealistic operations.

Review of the BDCP Model output for the Without Project condition with climate change assumptions for the ELT or LLT (NAA-ELT and NAA-LLT, respectively) reveal that the model is operated beyond its usable range. The purpose of CalSim II is to simulate how the CVP and SWP systems would be operated in order to meet regulatory requirements and water delivery objectives based on a certain amount of precipitation and runoff. When the precipitation patterns and resultant runoff were changed in the BDCP Model for climate change, the logic

regarding how the system is operated to meet the regulatory and water delivery objectives was not changed. The net effect is that neither the regulatory criteria nor the delivery objectives are met.

With rising temperatures and shifting precipitation patterns with less snow, temperature criteria on the Sacramento River will become increasingly more difficult to meet. For instance, the BDCP Model includes an assumption that equilibrium temperatures in the Sacramento River between Shasta and Gerber will increase on an average annual basis by 1.6°F by 2025 (ELT) by 3.3°F by 2060 (LLT). NMFS 2009 Biological Opinion specifies temperature targets of 56°F in the Sacramento River between Balls Ferry and Bend Bridge for the protection of salmon. Because of lower storage conditions in Shasta Lake and the magnitude of temperature increase in the assumptions is so large, the BDCP Model shows that the probability of exceeding the mortality threshold in the Sacramento River at Bend Bridge in August and September increases from approximately 80% in the No Action Alternative to 90% to 95% by 2025 (under ELT conditions) and to 95% to 100% by 2060 (under LLT conditions). This significant difference shows the overwhelming influence that the climate change assumptions have on the BDCP Model results.

Reservoir Storage: Under the climate change scenarios, reservoir storage (particularly in the CVP system) is operated very aggressively so that the reservoirs are drawn down to an extremely low level (termed “dead pool”) in approximately 1 of every 10 years, even without the BDCP. At dead pool level, little or no water can be released from the reservoir – not for fish, not for drinking water, not for agriculture. For example, since Folsom Reservoir became operational in 1955, the storage has never been drawn down to reach dead pool (which is approximately 100,000 acre-feet); the lowest storage level on record was 147,000 acre-feet at the end of September 1977. However, the BDCP Model predicts that, under climate change, the reservoir will be about 100,000 acre-feet or about 30% lower than its historical low in 10% of years. Some municipalities, such as the city of Folsom, are entirely dependent on reservoir releases for drinking water. Reaching dead pool would cut municipal deliveries below the level required to maintain public health and safety. In reality, and to avoid such dire circumstances, the CVP and SWP would likely request that regulatory agencies modify standards to conserve storage and would likely mandate conservation (or rationing) by water users. Similar steps were taken in early in 2014 to reduce water diversions and reservoir releases for fishery needs and Delta requirements. Emergency measures such as these are not simulated in the model, so the BDCP Model does not reflect reasonable future operations with climate change.

With the predicted changes in precipitation and temperature implemented in the BDCP Model, there is simply not enough water available to meet all regulatory objectives and water user demands. Yet the BDCP Model continues its normal routine and thus fails to meet its objectives. In this aspect, the BDCP Model simply does not simulate reality. For instance, if the ELT and LLT conditions actually occur, the CVP and SWP would likely adapt to protect water supplies and the environment. Examples of reactions to climate change would likely include: (1) updating operational rules regarding water releases for flood protection; (2) during severe droughts, emergency drought declarations could call for mandatory conservation and changes in some regulatory criteria similar to what has been experienced in the current and previous droughts ; and (3) if droughts become more frequent, the CVP and SWP would likely revisit the rules by which they allocate water during shortages and operate more conservatively in wetter years. The likelihood of an appropriate operational response to climate change is supported by the many modifications to CVP and SWP operations made during the winter and spring of 2014 to respond to the current drought. The BDCP Model is, however, useful in that it reveals that difficult decisions must be made.

Conclusions Regarding Climate Change Assumptions and Implementation

Water Code section 85320, subdivision (b)(2)(C) requires consideration of, among other things, the “potential effects of climate change, possible sea level rise up to 55 inches, and possible changes in total precipitation and runoff patterns on the conveyance alternatives and habitat restoration activities considered in the environmental

impact report". In examining the possible effects of climate change, it is not appropriate to assume that current project operations will remain static and not respond to climate change. The BDCP's simplistic approach of assuming a linear operation of the CVP and SWP produces results that are not useful for dealing with the complex problem of climate change because it does not reflect the way in which the CVP and the SWP would actually operate whether or not the BDCP is implemented. The Reviewers recommend a sensitivity analysis be conducted to develop a better understanding of the range of possible responses to climate change by the CVP and SWP, and the regulatory structures that dictate certain project operations.

Including climate change, without adaptation measures, results in insufficient water needed to meet all regulatory objectives and user demands. For example, the BDCP Model results that include climate change indicate that during droughts, water in reservoirs is reduced to the minimum capacity possible. Reservoirs have not been operated like this in the past during extreme droughts and the current drought also provides evidence that adaptation measures are called for long in advanced to avoid draining the reservoirs. In this aspect, the BDCP Model simply does not reflect a real future condition. Foreseeable adaptations that the CVP and SWP could make in response to climate change include: (1) updating operational rules regarding water releases for flood protection; (2) during severe droughts, emergency drought declarations could call for mandatory conservation; and (3) if droughts become more frequent, the CVP and SWP would likely revisit the rules by which they allocate water during shortages and operate more conservatively in wetter years. The modifications to CVP and SWP operations made during the winter and spring of 2014 in response to the drought supports the likelihood of future adaptations. The BDCP Model is, however, useful in that it reveals that difficult decisions must be made in response to climate change. But, in the absence of making those decisions, the BDCP Model results themselves are not informative, particularly during drought conditions. With future conditions projected to be so dire without the BDCP, the effects of the BDCP appear positive simply because it appears that conditions cannot get any worse (i.e., storage cannot be reduced below its minimum level). However, in reality, the future condition will not be as depicted in the BDCP Model. The Reviewers recommend that Reclamation and DWR develop more realistic operating rules for the hydrologic conditions expected over the next half-century and incorporate those operating rules into the any CalSim II Model that includes climate change.

3.2 General Assumptions and Operations

BDCP CalSim II Assumptions

The assumptions for these runs are defined in the December 2013 Draft BDCP⁴ and associated Draft EIR/S.

Each of the no action alternatives assumes the same regulatory requirements, generally representing the existing regulatory environment at the time of study formulation (February 2009), including Stanislaus ROP the National Marine Fisheries Services (NMFS) Biological Opinion (BO) (June 2009) Actions III.1.2 and III.1.3, Trinity Preferred EIS Alternative, NMFS 2004 Winter-run BO, NMFS BO (June 2009) Action I.2.1, SWRCB WR90-5, CVPIA (b)(2) flows, NMFS BO (June 2009) Action I.2.2, ARFM NMFS BO (June 2009) Action II.1, no SJRRP flow modeled, Vernalis SWRCB D1641 Vernalis flow and WQ and NMFS BO (June 2009) Action IV.2.1, Delta D1641 and NMFS Delta Actions including Fall X2 Fish & Wildlife Service (FWS) BO (December 2008) Action 4, Export restrictions including NMFS BO (June 2009) Action IV.11.2v Phase II, OMR FWS BO (December 2008) Actions 1-3 and NMFS BO (June 2009) Action IV.2.3v.

The modeling protocols for the recent USFWS BO (2008) and NMFS BO (2009) have been cited as being cooperatively developed by Reclamation, NMFS, U.S. Fish and Wildlife Service (USF&WS), California Department of Fish and Wildlife (CDF&W), and DWR.

⁴ BDCP EIR/EIS Appendix 5A

Each of the BDCP no action alternatives (NAA, NAA-ELT, and NAA-LLT) uses the same New Melones Reservoir and other San Joaquin River operations. At the time of these studies' formulation, the NMFS BO (June 2009) had been recently released. Also, the San Joaquin River Agreement (SJRA), including the Vernalis Adaptive Management Program (VAMP) and its incorporation into D1641 for Vernalis flow requirements were either still in force or being discussed for extension. As a component of study assumptions, the protocols of the SJRA and an implementation of the NMFS BO for San Joaquin River operations (including New Melones Reservoir operations) are included in the studies. These protocols, in particular the inclusion of VAMP which has now expired, are not appropriate as an assumption within either the No Action or Alternative Scenarios within a full disclosure of BDCP impacts. Although appropriate within the identification of actions, programs and protocols present at the time of the NOI/NOP, they are not representative of current or reasonably foreseeable operations. Also, the BDCP Model assumes no San Joaquin River Restoration Program releases in the future operation of the Friant Division of the CVP. While assuming no difference in the current and future operation of the Friant Division avoids another difference in existing and projected future hydrology of the San Joaquin River, the assumption does not recognize the existence of the San Joaquin River Restoration Program. Results of CVP and SWP operations, in particular as affected by export constraints dependent on San Joaquin River flows and their effect on OMR, E/I and I/E diversion constraints, would be different with a different set of assumptions for San Joaquin River operations, in a manner similar to the cascading effect described above in connection with climate change.

Finally, the habitat restoration requirements in the 2008 FWS BO and the 2009 NMFS BO are not included in the NAA baselines. Although the restoration is required to be completed either with or without completion of the BDCP, the restoration was only analyzed as part of the with project scenarios.

Conclusions Regarding General Assumptions and Operations

The benchmark study upon which the BDCP Model was built contains inaccuracies that affect the analysis.

CalSim II is continuously being improved and refined. As the regulatory environment changes and operational and modeling staff work together to improve the model's capability to simulate actual operations, the model is continually updated. The BDCP Model relied upon a version of CalSim II that dates back to 2009, immediately after the new biological opinions (BiOps) from the NMFS and the United States Fish and Wildlife Service (USFWS) significantly altered the operational criteria of the CVP and SWP. In the last 4 to 5 years, DWR, Reclamation, and outside modeling experts have worked together to improve the model. Changes include better (more realistic) implementation of the new BiOps and numerous fixes to the code. Since CalSim II is undergoing continual improvements, there will always be "vintage" issues in that by the time a project report is released, the model is likely slightly out of date. However, in this case - with the major operational changes that have occurred in the new regulatory environment - many issues have been identified and fixed in the last 4 to 5 years that have a significant effect on model results. CalSim II modeling for the DWR 2013 Delivery Reliability Report contains numerous modeling updates and fixes that significantly alter results of the BDCP Model. A key modeling revision in the 2013 DWR modeling was fixing an error regarding artificial minimum instream flow requirements in the Sacramento River at Hood. An "artificial" minimum instream flow requirement had been specified; the requirement is artificial in that it does not represent a regulatory requirement, but rather is a modeling technique to force upstream releases to satisfy Delta needs.

3.3 Assumptions and Operational Criteria for inclusion of proposed BDCP facilities

To evaluate the assumptions and operations of the proposed BDCP facilities, the Reviewers analyzed the output from the BDCP Model and examined the internal workings of the models. This approach allows for evaluation of not only the possible effects of the BDCP, also but whether the assumptions and operational criteria are implemented appropriately to reflect the project description and reasonably foreseeable actions.

Assessment of Assumptions and Operations in coordination with new BDCP facilities

BDCP's Alternative 4 has four possible sets of operational criteria, termed the Decision Tree, that differ based on the "X2" standards⁵ that they contemplate:

- Low Outflow Scenario (LOS), otherwise known as operational scenario H1, assumes existing spring X2 standard and the removal of the existing Fall X2 standard;
- High Outflow Scenario (HOS), otherwise known as H4, contemplates the existing Fall X2 standard and providing additional outflow during the spring;
- Evaluated Starting Operations (ESO), otherwise known as H3, assumes continuation of the existing X2 spring and fall standards;
- Enhanced spring outflow only (not evaluated in the December 2013 Draft BDCP), scenario H2, assumes additional spring outflow and no Fall X2 standards.

While it is not entirely clear how the Decision Tree would work in practice, the general concept is that prior to operation of the new facility, implementing authorities would select the appropriate Scenario (from amongst the four choices) based on their evaluation of targeted research and studies to be conducted during planning and construction of the facility.

For this analysis, the Reviewers analyzed the HOS (or H4) scenario because the BDCP⁶ indicates that the initial permit will include HOS operations that may be later modified at the conclusion of the targeted research studies. The HOS includes the existing Fall X2 requirements but adds additional outflow requirements in the spring. The model code was reviewed and discussed with DWR and Reclamation, who acknowledged that although the SWP was bearing the majority of the responsibility for meeting the additional spring outflow in the modeling, the responsibility would need to be shared with the CVP⁷. In subsequent discussions, DWR and Reclamation have suggested that the additional water may be purchased from other water users. However, the actual source of water for the additional outflow has not been defined. While not how the projects would actually be operated, since the BDCP Model assumes that the SWP bears the majority of the responsibility for meeting the additional outflow, the Reviewers' analysis of the BDCP Model results for HOS is limited to the evaluation of how the SWP reservoir releases on the Feather River translate into changes in Delta outflow and exports.

Our remaining analysis examines the ESO (or H3) scenario (labeled Alt 4-ELT or Alt 4-LLT in this section) because it employs the same X2 standards as are implemented in NAA-ELT and NAA-LLT. This allowed the Reviewers to focus the analysis on the effects of the BDCP operations independent of the possible change in the X2 standard.

The differences between the without project scenario (NAA-ELT) and the corresponding with project scenario (Alt4 H3-ELT) should reveal the effects of the project under ELT conditions. However, as discussed above, implementation of climate change assumptions and the occurrence of unrealistic operations likely obfuscates the effects of the BDCP. Although the modeling approach may provide a relative comparison between equal foundational operations, the Reviewers are hesitant to place any confidence in the computed differences shown between the NAA-ELT and Alt4-ELT Scenarios. Numerous comparisons between NAA-ELT and Alt4 H3-ELT are discussed in the technical appendix of this report; issues that shaped our conclusions are discussed below.

⁵ X2 is a salinity standard that requires outflows sufficient to attain a certain level of salinity at designated locations in the Delta at certain times of year.

⁶ Draft BDCP, Chapter 3, Section 3.4.1.4.4

⁷ August 7, 2013 meeting with DWR, Reclamation, and CH2M HILL

Assumptions for the “High Outflow Scenario” are unrealistic.

The HOS is one branch of the BDCP Decision Tree, also identified as Alternative 4, operational scenario H4 in the DEIR/EIS. The HOS requires additional water (Delta outflow) during certain periods in the spring, in excess of the current regulatory requirements. The BDCP Model assumes that if the required additional Delta outflow cannot be met by reducing exports, this increased Delta outflow will be met by releases made by the SWP’s Oroville Reservoir. The assumptions regarding how much water to release from Oroville to attempt to meet the proposed regulations and how much and when to refill Oroville are unrealistic.

According to the Draft EIR/EIS⁸, the HOS will reduce SWP south of Delta water deliveries for municipal and industrial (M&I) water users 7% below the level that they would receive without the BDCP (on average). During dry and critical years, SWP south of Delta water deliveries for M&I and agricultural water users will drop 17% below the level that they would receive without the BDCP. In other words, according to the BDCP Model results SWP Contractors would get less water than they would otherwise get without BDCP.

CVP and SWP obligations for providing flow to satisfy Delta outflow requirements is described in the Coordinated Operations Agreement (COA). Because the CVP and SWP share responsibility for meeting required Delta outflow based on specific sharing in the agreement, it is not reasonable to conclude that CVP water supplies would increase an average of 70 TAF while SWP water supplies decrease on average of 100 TAF under the HOS. The manner in which this alternative is modeled is inconsistent with existing agreements and operating criteria. If the increases in outflow were met based on COA, there would likely be reductions in Shasta and Folsom storage that would likely cause adverse environmental impacts, which have not been modeled or analyzed in the BDCP EIR/S.

Furthermore, there is no apparent source of water to satisfy the increased outflow requirements and pay back the COA debt. It appears, through recent public discussions regarding the HOS that BDCP anticipates additional water to satisfy the increased Delta outflow requirement and to prevent the depletion of cold water pools will be acquired through water transfers from upstream water sources. However, this approach is unrealistic. During most of the spring, when BDCP proposes that Delta outflow be increased, agricultural water users are not irrigating. This means that there is not sufficient transfer water available to meet the increased Delta outflow requirements without releasing stored water from the reservoirs.

San Luis Reservoir operational assumptions produce results that are inconsistent with real world operations.

San Luis Reservoir (SLR) is an off-stream reservoir located south of the Delta and jointly owned and operated by CVP and SWP. The reservoir is used to store water that is exported from the Delta when available and used to deliver water to CVP and SWP Contractors when water demands exceed the amount of water that can be pumped from the Delta. The decision of when to move water that is stored in upstream reservoirs, such as Shasta, Folsom, or Oroville, through the Delta for export to fill SLR is based on the experience and expert judgment of the CVP and SWP operators.

CalSim II attempts to simulate the expert judgment of the operators by imposing artificial operating criteria; the criteria are artificial in the sense that they are not imposed by regulatory or operational constraints but rather imposed as a tool to simulate expert judgment. One such artificial operating criteria is the SLR target storage level: CalSim II attempts to balance upstream Sacramento Basin CVP and SWP reservoirs with storage in SLR by setting artificial target storage levels in SLR, such that the CVP and SWP will release water from upstream reservoirs to meet target levels in SLR. The artificial target storage will be met as long as there is ability to convey

⁸ Draft EIR/EIS, Appendix 5A-C, Table C-13-20-2

water (under all regulatory and physical capacity limits) and as long as water is available in upstream reservoirs. SLR target storage criteria are also sometimes described in section 4.2 as the “San Luis rule-curve”.

In the BDCP Model, CVP and SWP reservoir operating criteria for Alternative 4 H3 ELT differ from the corresponding without project scenario (e.g. NAA-ELT). The difference in criteria and result is primarily driven by changes to the artificial constraint used to determine when to fill SLR: the SLR target storage. In Alternative 4 H3 ELT, SLR target storage is set very high in the spring and early summer months, and then reduced in August and set to SLR dead pool from September through December. This change in SLR target storage relative to the no action alternative causes upstream reservoirs to be drawn down from June through August and then recuperate storage by cutting releases in September. This change to the artificial operating criteria SLR target storage causes changes in upstream cold water pool management and affects several resource areas.

In addition to changes in upstream storage conditions, changes in SLR target storage cause SLR storage to drop below a water supply concern level (300,000 acre-feet) in almost 6 out of every 10 years under ELT conditions and more than 7 out of every 10 years under LLT conditions for Alternative 4 H3. When storage in SLR drops below this 300,000 acre-foot level, algal blooms in the reservoir often cause water quality concerns for drinking water at Santa Clara Valley Water District. The change in SLR target storage also causes SLR levels to continue to drop and reach dead pool level for the SWP in 4 out of every 10 years and also dead pool level for the CVP in 1 out of every 10 years under the ELT conditions.

Reaching dead pool level in SLR creates shortages to water users south of the Delta. Although some delivery shortages are due to California Aqueduct capacity constraints, the largest annual delivery shortages are a result of inappropriately low SLR target storage. Average annual Table A shortages due to artificially low SLR storage levels increased from 3 TAF in the NAA-ELT scenario to 35 TAF in the Alt4-ELT scenario. Such shortages occurred in 2% of simulated years in the NAA-ELT scenario and 23% of years in the Alt4-ELT scenario. In addition to the inability to satisfy Table A allocations, low storage levels cause loss of SWP Contractors’ Article 56 water stored in SLR. Average annual Article 56 shortages were 43 TAF in the Alt4-ELT scenario because of low San Luis storage and 5 TAF in the NAA-ELT scenario. Low San Luis storage causes Article 56 shortages in 27% of simulated years in the Alt4-ELT scenario as compared to 5% of simulated years in the NAA-ELT. Another consequence of low storage levels in SLR is a shift in water supply benefits from Article 21 to Table A.

In summary, the operational assumptions for SLR are unrealistic in Alternative 4 because they create problems in upstream storage reservoirs and create shortages for south of Delta water users that would not occur in the real world. In reaching this conclusion, the Reviewers met with operators from CVP and SWP to review the BDCP Model results and discussed real-time operations. The operators provided guidance in selection of superior assumptions, which results in more realistic operations in the independent model (see Section 4).

Delta Cross Channel operational assumptions overestimate October outflow

When south Delta exports are low due to regulatory limits, and upstream reservoirs are making releases to meet the instream flow objectives at Rio Vista, operators have the ability to close the Delta Cross Channel (DCC) in order to reduce the required reservoir releases (by closing the DCC a greater portion of water released from the reservoirs stays in the Sacramento River to meet the Rio Vista requirements). As long as the Delta salinity standards are met, operators have indicated that they would indeed close the DCC in this manner (as was done in October and November 2013). In the BDCP Model, the DCC is not closed in this manner. The net result is that the BDCP Model overestimates outflow under such circumstances typically occurring in October.

The overestimated outflow leads to incorrect conclusions regarding the effects of BDCP. For instance, an actual increase in fall outflow could be beneficial for the endangered fish species delta smelt (USFWS, 2008). Therefore, by overestimating outflow in October, the BDCP studies likely overestimate the benefit to delta smelt (Mount

et al, 2013). Similarly, an actual increase in fall outflow would reduce salinity in the western Delta, which could be beneficial for in-Delta diverters; therefore, overestimating outflow in October artificially reduces salinity, incorrectly reducing the net impacts on in-Delta diverters.

Conclusions Regarding Assumptions and Operations in coordination with new BDCP facilities

BDCP's "High Outflow Scenario" is not sufficiently defined for analysis.

The HOS requires additional water (Delta outflow) during certain periods in the spring. The BDCP Model places most of the responsibility for meeting this new additional outflow requirement on the SWP. However, the SWP may not actually be responsible for meeting this new additional outflow requirement. This is because the COA, as it is currently being implemented, would require a water allocation adjustment that would keep the SWP whole. Where one project (CVP or SWP) releases water to meet a regulatory requirement, the COA requires a water balancing to ensure the burden does not fall inappropriately among the projects. The BDCP Model is misleading because it fails to adjust project operations, as required by the COA, to "pay back" the water "debt" to the SWP due to these additional Delta outflow requirements. Unless there is a significant revision to COA, the BDCP Model overstates the impacts of increased Delta outflow on the SWP and understates the effects on the CVP.

Furthermore, after consulting with DWR and Reclamation project operators and managers, the Reviewers conclude that there is no apparent source of CVP or SWP water to satisfy both the increased Delta outflow requirements and pay back the COA "debt" to the SWP without substantially depleting upstream water storage. It appears, through recent public discussions regarding the HOS, that BDCP anticipates additional water to satisfy the increased Delta outflow requirement and to prevent the depletion of cold water pools will be acquired through water transfers from upstream water users. However, this approach is unrealistic because during most of the spring, when BDCP proposes that Delta outflow be increased, agricultural water users are not typically irrigating. This means that there is not sufficient transfer water available to meet the increased Delta outflow requirements without releasing stored water from the reservoirs. Releasing stored water to meet the increased Delta outflow requirements could potentially impact salmonids on the Sacramento and American River systems.

Simulated operation of BDCP's dual conveyance, coordinating proposed North Delta diversion facilities with existing south Delta diversion facilities, is inconsistent with the project description.

The Draft BDCP and associated Draft EIR/EIS specify criteria for how much flow can be diverted by the new NDD facilities and specify when to preferentially use either the NDD facilities or the existing SDD facilities. However, the BDCP Model contains an artificial constraint that prevents the NDD facilities from taking water as described in the BDCP project description. In addition to affecting diversions from the NDD, this artificial constraint contains errors that affect the NAA operation. This error has been fixed by DWR and Reclamation in more recent versions of the model; however, the error remains in the BDCP Model. Additionally, the BDCP Model does not reflect the Summer operations of the SDD that are described in the Draft EIR/EIS as a feature of the BDCP project intended to prevent water quality degradation in the south Delta. The net effect of these two errors is that the BDCP Model significantly underestimates the amount of water diverted from the NDD facilities and overestimates the amount of water diverted from the SDD.

BDCP Model contains numerous coding and data issues that skew the analysis and conflict with actual real-time operational objectives and constraints

Operational logic is coded into the CalSim II model to simulate how DWR and Reclamation would operate the system under circumstances for which there are no regulatory or other definitive rules. This attempt to specify (i.e., code) the logic sequence and relative weighting so that a computer can simulate "expert judgment" of the

human operators is a critical element to the CalSim II model. In the BDCP Model, some of the operational criteria for water supply allocations and existing facilities such as the Delta Cross Channel and SLR are inconsistent with real-world conditions.

4 INDEPENDENT MODELING

The Independent Modeling effort originally stemmed from reviews of BDCP Model during which the Reviewers discovered that the BDCP Model did not provide adequate information to determine the effects of the BDCP. There are three basic reasons why the Reviewers cannot assess how the BDCP will affect water operations: 1) NAAs do not depict reasonable operations under the described climate change assumptions, 2) operating criteria used in the BDCP Alternative 4 result in unrealistic operations, and 3) updates to CalSim II since the BDCP modeling was performed almost 4 years ago will likely alter model results to a sufficient degree that conclusions based on the BDCP modeling will likely be different than those disclosed in the Draft EIR/EIS. Given that it is not possible to determine how BDCP may affect CVP and SWP operations or water system flows and conditions with the BDCP model, Independent Modeling was performed to assess potential effects due to the BDCP.

To revise the models, the Reviewers consulted with operators at DWR and Reclamation to improve the representation of operational assumptions. Additionally, the Reviewers consulted with modelers at DWR and Reclamation to share findings, to strategize on the proper way to incorporate the guidance received from the operators, and to present revised models to DWR and Reclamation for their review. This collaborative and iterative process differed considerably from a standard consulting contract where the work product is not shared beyond the client-consultant until a final version is complete. To the contrary, consultations with agency experts were conducted early and repeatedly to ensure the revisions would reflect reasonable operations and to provide an independent review.

The first phase of this Independent Modeling effort (described in Section 4.1) was development of an updated without project baseline (similar to the NAA but with current, improved assumptions). The Independent Modeling does not incorporate climate change because the climate change hydrological assumptions developed by BDCP cause unrealistic operation of the system absent commensurate changes to operating criteria.

After the baseline was complete and reviewed, the second phase of this effort (described in Section 4.2) incorporated the facilities and operations for the BDCP described as Alternative 4 H3 in the Draft EIR/EIS, and otherwise known as the Evaluated Starting Operations (ESO) scenarios in the BDCP. During this phase, the issues that were identified during the Reviewers' initial review were corrected (see Section 3.3) along with corrections made to resolve additional issues that were revealed as improvements were incorporated. Finally, results of the Independent Modeling and potential effects of the BDCP on water supply and instream flows are discussed in Section 4.3.

4.1 Improvements to CalSim II Assumptions

For this effort, the most up to date modeling tools were provided by DWR and Reclamation and further improvements were added to the CalSim II assumptions in coordination with DWR and Reclamation staff. Many of the improvements have since been incorporated into DWR and Reclamation's model and others are under review.

Revisions incorporated by DWR and Reclamation for the 2013 baseline

DWR and Reclamation provided CalSim II models used for the 2013 SWP Delivery Reliability Report (DRR) for use in this Independent Modeling effort. The 2013 SWP DRR, Technical Addendum, and associated models are now available on DWR's website⁹. Assumptions used for this Independent Modeling effort are consistent with the 2013 SWP DRR and are listed in Table 4 of the Technical Addendum.

⁹ <http://baydeltaoffice.water.ca.gov/swpreliability/>

CalSim II is continuously being improved to better represent CVP and SWP operations and fix known problems. The Technical Addendum to the 2013 SWP DRR contains a list of updates and fixes that have occurred since the last SWP DRR was released in 2011. Among these changes and fixes are key items that directly affect operation of facilities proposed in the BDCP Alternative 4; these items are listed on pages 4-6 of the 2013 SWP DRR Technical Addendum.

A key component of this package of modeling revisions was fixing an error regarding artificial minimum instream flow requirements in the Sacramento River at Hood. An “artificial” minimum instream flow requirement had been specified; the requirement is artificial in that it does not represent a regulatory requirement, but rather is a modeling technique.

Additional Revisions to CalSim II Assumptions

As part of the Independent Modeling effort, a number of changes were made to the 2013 SWP DRR version of CalSim II to better represent the existing facilities, regulatory requirements, and water user demands. These revisions are described in the Technical Appendix and summarized here:

- San Joaquin River Restoration Program (SJRRP) was not incorporated. This modification was made to be consistent with the BDCP assumptions, but also allows the identification of the separate effect of the BDCP void of the combined effect with SJRRP flows. Although inclusion of the SJRRP is necessary in the documentation of BDCP, the Independent Modeling did not include it.
- VAMP operations were not incorporated because the VAMP program has expired and is no longer being implemented.
- Tuolumne River basin was updated.
- Folsom Reservoir operations for flood control were updated.
- Additional water demands on the Feather River were incorporated to represent existing agricultural diversions used for rice decomposition.
- Diversions by East Bay Municipal Utility District (EBMUD) from the Sacramento River at Freeport were modified to better represent the EBMUD CVP water service contract.
- Minimum flow requirements for Wilkins Slough and Red Bluff were corrected for September 1933.
- CVP M&I demands are updated to reflect current assumptions used by Reclamation.
- Modifications were made to more accurately reflect refilling of New Bullards Bar Reservoir in coordination with transfers made under the Yuba Accord.
- Los Vaqueros Reservoir capacity was updated to reflect a recent expansion of the reservoir that was completed in 2012.

4.2 Improvements to BDCP Operations

After the baseline was completed and reviewed (as summarized above in Section 4.1), the facilities and operations associated with BDCP Alternative 4 H3 in the Draft EIR/EIS, otherwise known as the Evaluated Starting Operations (ESO) scenarios in the Draft Plan, were incorporated into the model. During this phase, the issues that were identified during the Reviewers’ initial review (see Section 3.3) were corrected along with correcting additional issues that were revealed as improvements were incorporated. These revisions are described in the Technical Appendix and summarized here:

- San Luis Reservoir operation
- Delta Cross Channel gate operation in October
- Delivery allocation adjustment for CVP SOD contractors

- Folsom/Shasta balance
- North Delta Diversion bypass criteria
- Wilkins Slough minimum flow requirement

In the Independent Modeling, San Luis rule-curve logic was refined for both SWP and CVP operations. San Luis rule-curve is used to maintain an appropriate balance between San Luis Reservoir (SLR) storage and North of Delta reservoirs. The key considerations in formulating rule-curve are 1) ensuring that sufficient water is available in SLR to meet contract allocations when exports alone are insufficient due to various operational constraints and 2) minimize SLR carryover storage to low point criteria (both CVP and SWP) and Article 56 carryover (only SWP). The basic premise is to maintain SLR storage no higher than necessary to satisfy south of Delta obligations to avoid excessive drawdown of upstream storage.

In the BDCP NAA and the Independent Modeling FNA, the model has a priority to release excess stored water that will likely be released for flood control purposes from Shasta and Folsom storage for export at Jones Pumping Plant to storage in SLR in the late summer and early fall months. The purpose was to get a head start on filling SLR for the coming water year if there is a high likelihood of Shasta or Folsom spilling. This was an assumed CVP/SWP adaptation to the export reductions in the winter and spring months due to the salmon and smelt biological opinions. However, with the NDD facility in Alt 4, winter and spring export restrictions impact CVP exports much less and there is no longer a reason to impose this risk on upstream storage. As such, the weights, or prioritizations, of storage in Shasta and Folsom were raised so that excess water would not be released specifically to increase CVP San Luis storage Reservoir above rule-curve. This was changed in Alt 4 and not the FNA to better reflect how the system may operate under these different conditions.

The BDCP Alt 4 results in significantly more October surplus Delta outflow as compared to the baseline. The cause of this Delta surplus at a time when the Delta is frequently in balance is a combination of proposed through-Delta export constraints (Old and Middle River (OMR) flow criteria and no through-Delta exports during the San Joaquin River October pulse period), Rio Vista flow requirements, and DCC gate operations. In DWR's BDCP studies, it was assumed that the DCC gates would be open for the entire month of October thereby requiring much higher Sacramento River flows at Hood in order to meet the Rio Vista flow requirement than if the DCC gates were closed. Whereas in the Independent Modeling of the BDCP it was assumed that the DCC gates were closed for a number of days during the month such that the 7,000 cfs NDD bypass criteria would be sufficient to meet the weekly average Rio Vista flow requirements. The intent was to minimize surplus Delta outflow while meeting Delta salinity standards and maintaining enough bypass flow to use the NDD facility for SDD. This is an approximation of what is likely to occur in real-time operations under similar circumstances. Further gate closures may be possible as salinity standards allow if operators decide to preserve upstream storage at the expense of NDD diversions. This type of operation would require additional model refinements.

CVP SOD Ag service and M&I allocations are limited by both system wide water supply (storage plus inflow forecasts) and Delta export constraints; whereas similar CVP NOD allocations are dependent solely on water supply. This frequently results in SOD water service contractors receiving a lower contract year allocation than NOD water service contractors, especially under the Biological Opinion export restrictions. However, with the NDD facility operations as proposed under Alt 4 H3, the CVP can largely bypass these Delta export restrictions and the export capacity constraint on CVP SOD allocations was determined to be overly conservative. Therefore, the export capacity component of CVP SOD allocations was removed in the BDCP Alternative and both SOD and NOD CVP allocations are equal and based only on water supply.

For the Independent Modeling, CVP operations were refined in the BDCP Alternative to provide maximum water supply benefits to CVP contractors while protecting Trinity, Shasta, and Folsom carryover storage in the drier years. As a whole, this was accomplished with refinements to allocation logic and San Luis rule-curve. However, in the initial study runs, an imbalance between Folsom and Shasta was created; while there was a total positive

impact to upstream storage in dry years, there was a negative impact to Folsom storage. This was resolved by inserting Folsom protections in the Shasta-Folsom balancing logic. With these protections, the positive carryover impacts were distributed to Trinity, Shasta, and Folsom.

The daily disaggregation method for implementing NDD bypass criteria as implemented in DWR's BDCP model was left mostly intact for the Independent Modeling. However, to properly fit the bypass criteria implementation within the latest CalSim operations formulation certain modifications were made. Modifications are as follows:

1. No NDD operations occur in cycles 6 through 9 so that Delta operations and constraints can be fully assessed without NDD interference.
2. Cycles 10 and 11 (Daily 1 and Daily 2 respectively) were added to determine NDD operations given various operational constraints including the NDD bypass criteria.
3. From July to October, bypass criteria are based on monthly average operations (no daily disaggregation). Given the controlled reservoir releases at this time and the constant bypass criteria (5,000 cfs from July to September and 7,000 cfs in October), this was determined to be a reasonable assumption. This also simplified coordination of DCC gate operations with NDD in October which will be discussed later.
4. When warranted by conditions in cycle Daily 1 (cycle 10), the bypass criteria in May and June were allowed to be modeled on a monthly average basis in cycle Daily 2 (cycle 11). This allowed a reduction in the number of cycles necessary to determine the fully allowed diversion under the bypass criteria when the Delta was in balance and additional upstream releases were made to support diversions from the North Delta.

Currently in CalSim II, relaxation of the Wilkins Slough minimum flow requirement is tied to CVP NOD Ag Service Contractor allocations. This does not reflect actual operations criteria where relaxation of the flow requirement is dependent solely on storage conditions at Shasta. From the comparative analysis perspective of our CalSim planning studies, this introduces a potential problem: changes in CVP NOD Ag Service allocations can result in unrealistic changes in required flow at Wilkins Slough, and such changes in Wilkins Slough required flow can result in unrealistic impacts to Shasta storage. To bypass this problem, we assumed that the required flow at Wilkins Slough in the alternative was equal to the baseline.

4.3 Independent Modeling output and analysis of BDCP Effects

Analysis for this effort was focused on BDCP Alt 4 with existing spring and Fall X2 requirements, which corresponds to "Alternative 4 H3" in the Decisions Tree. This modeling is performed without climate change, and includes refined operating criteria for the NDD, CVP and SWP reservoirs, DCC gate closures, and water supply allocations. This modeling includes all Project features that are included in Alt 4 in the BDCP Model. The key Project features incorporated into BDCP are displayed in Figure 1 and summarized as:

- North Delta Diversion capacity of 9,000 cfs
- NDD bypass flow requirements
- 25,000 acres of additional tidal habitat
- Notched Fremont Weir to allow more flow into Yolo Bypass
- Additional positive Old and Middle River flow requirements
- Removal of the San Joaquin River I/E ratio (NMFS 2009)
- Changed location for Emmaton water quality standard in SWRCB D-1641
- Additional Sacramento River flow requirement at Rio Vista

Sacramento San Joaquin Delta




Figure 1. Map of Delta with location of key BDCP facilities and regulatory changes

Annual maximum and minimum storage in San Luis for the (a) CVP and (b) SWP under ELT conditions for the no action alternative (NAA_ELT) and BDCP Alternative 4 H3 (Alt4_ELT).

For the purpose of describing results of the Independent Modeling, the revised baseline scenario without climate change, originally termed No Action Alternative (NAA) in the BDCP Draft EIR/EIS, is referred to as the Future No Action (FNA) in this discussion. Additionally, in the Independent Modeling, Alternative 4 operational scenario H3 without climate change is simply referred to as "Alt 4". The results for the Independent Modeling are illustrated in the Technical Attachment. Key results are presented below.

The change in conditions between FNA and Alt 4 is indicative of the effects of the BDCP on water supply and Delta flows. An effect of the BDCP is an anticipated increase in Delta export and corresponding decrease in Delta Outflow. Table 2 illustrates the estimated change in Delta Outflow by year type, amounting to an average annual 0.76 MAF. Table 3 illustrates the corresponding change in exports by year type, and also illustrates the estimated change in geographical source of export water. With the BDCP it is anticipated that exports from the South Delta (via through Delta conveyance) will decrease by 2.53 MAF. Exports derived from the North Delta (via the tunnels) will amount to 3.28 MAF.

Table 2. Change in Delta outflow due to the BDCP (Alt 4 minus FNA) (Million Acre-Feet)

Reduction in the quantity of water that leaves the Delta by flowing west into San Francisco Bay by water year type.

Water Year Type	FNA Delta Outflow	Change in Delta Outflow
Wet	28.6	-1.2
Above Normal	17.1	-1.0
Below Normal	9.9	-0.68
Dry	7.3	-0.39
Critical	5.1	-0.13
Average	15.6	-0.76

Table 3. Change in quantity of water exported due to the BDCP (Alt 4 minus FNA) (Million Acre-Feet)

Reduction in the quantity of water exported from the existing South Delta export facilities and corresponding increase in the quantity exported from the proposed facilities in the North Delta, by water year type.

Water year Type	FNA Total Delta Export	Change in South Delta Exports (through Delta)	Change in North Delta Exports (through tunnels)	Change in Total Exports
Wet	6.0	-3.8	5.0	1.2
Above Normal	5.2	-2.9	4.4	1.5
Below Normal	5.1	-2.4	3.2	0.8
Dry	4.2	-1.8	1.8	0.07
Critical	2.8	-0.7	0.7	0.02
Average	4.9	-2.53	3.28	0.75

Table 4. Change in quantity of CVP water exported by SWP facilities (Alt 4 minus FNA) (Thousand Acre-Feet)

Quantity of water exported at Banks Pumping Plant for later use by CVP contractors is increased in all water year types except the driest years (critical designation).

Water Year Type	FNA CVP water exported by SWP	Change in CVP water exported by SWP
Wet	58	229
Above Normal	44	208
Below Normal	66	117
Dry	86	7
Critical	38	-9
Average	60	123

The Independent Modeling shows that implementation of the BDCP could shift a portion of the SWP exports from summer to winter and spring because the proposed NDD facilities can export water at times when the existing SDD facilities are constrained due to fishery concerns. As a result of this shift in timing, capacity is available at the SWP facilities during the summer months. The BDCP Model assumes that CVP could utilize the SWP facilities (Table 4) at any time when the CVP facilities are fully utilized; this sharing of diversion facilities is termed "joint point of diversion" or JPOD. Additional criteria to meet specific water quality and water level objectives are defined in response plans required by the State Water Board's water right decision D-1641. BDCP Model assumes that these additional criteria are met; the Independent Modeling continues this assumption without making any judgment as to whether the criteria would be met. An evaluation of this would require additional hydrodynamic modeling.

The Independent Modeling shows higher average annual CVP carryover (end of September) storage than the NAA by about 28 TAF. During dryer years when upstream storage is lower there is an increase in carryover and during wetter years when storage is higher there are storage decreases (Table 5). Upstream SWP storage, Table 6, behaves in a similar manner as CVP storage, there are decreases in wetter years and increased in dryer years.

CVP San Luis Reservoir fills in about 40% of years in Alt 4 compared to about 20% in the FNA. CVP San Luis reaches dead pool in about 25% of years in both the FNA and Alt 4. SWP San Luis Reservoir fills in about 43% of years in Alt 4 compared to about 18% in the FNA. SWP San Luis reaches dead pool in about 25% of years in Alt 4 and about 30% of years in the FNA.

Table 5. Change in CVP upstream carryover storage (Alt 4 minus FNA) (Thousand Acre-Feet)

CVP carryover (end of September) storage decreases in wetter years when FNA storage is highest and increases in dryer years when FNA storage is lowest

Water Year Type	FNA CVP Upstream Storage	Change in CVP Upstream Storage
Wet	5578	-8
Above Normal	5200	-150
Below Normal	4717	-1
Dry	4049	66
Critical	2285	258
Average	4558	28

Table 6. Change in SWP upstream carryover storage (Alt 4 minus FNA) (Thousand Acre-Feet)

SWP carryover (end of September) storage decreases in wetter years when FNA storage is highest and increases in dryer years when FNA storage is lowest

Water Year Type	FNA SWP Upstream Storage	Change in SWP Upstream Storage
Wet	2407	33
Above Normal	1934	-150
Below Normal	1517	14
Dry	1194	157
Critical	968	127
Average	1709	44

5 COMPARING INDEPENDENT MODELING AND BDCP MODEL

The Independent Modeling effort originally stemmed from reviews of DWR's BDCP Model where the Reviewers through their independent analysis found that BDCP Model does not provide adequate information to determine how BDCP may affect the system. Based on the premise that the Independent Modeling portrays a more accurate characterization of how the CVP/SWP system may operate under Alt 4, this comparison is meant to demonstrate the differences between results of a more accurate and realistic analysis and the BDCP Model. Differences in results between these modeling efforts are believed to provide insight regarding how effects that BDCP will have on the actual CVP/SWP system differ from modeling used to support the Draft EIR/S.

Although thorough comparisons of modeling were performed, only key differences are illustrated for the purpose of this comparison.

Conclusions regarding BDCP effects

Based on the Independent Modeling, the amount of water exported (diverted from the Delta) may be approximately 200 thousand acre-feet (TAF) per year higher than the amount disclosed in the Draft EIR/S. This total represents

- approximately 40 TAF/yr more water diverted and delivered to the SWP south of Delta contractors, and
- approximately 160 TAF/yr more water diverted and delivered to the CVP south of Delta contractors.

The BDCP Model estimates that, under the NAA ELT (without the BDCP), total average annual exports for CVP and SWP combined are estimated to be 4.73 million acre feet (MAF) and in the Independent Modeling FNA combined exports are 5.61 MAF. The BDCP Model indicates an increase in exports of approximately 540 TAF and the Independent Modeling shows an increase of approximately 750 TAF in Alt 4.

The Independent Modeling suggests that Delta outflow would decrease by approximately 200 TAF/yr compared to the amount indicated in the Draft EIR/S.

- This lesser amount of Delta outflow has the potential to cause greater water quality and supply impacts for in-Delta beneficial uses and additional adverse effects on species. To determine the potential effects of the reduced amount of outflow, additional modeling is needed using tools such as DSM2.

The BDCP Model does not accurately reflect the location of the diversions that the SWP and CVP will make from the Delta.

- When the errors in the model are corrected, it reveals that the North Delta intakes could divert approximately 680 TAF/yr more than what was disclosed in the BDCP Draft EIR/S, and
- the amount of water diverted at the existing South Delta facilities would be approximately 460 TAF/yr less than what is projected in the BDCP Draft EIR/S.

Hydrologic modeling of BDCP alternatives using CalSim II has not been refined enough to understand how BDCP may affect CVP and SWP operations and changes in Delta flow dynamics. Better defined operating criteria for project alternatives is needed along with adequate modeling rules to analyze how BDCP may affect water operations. Without a clear understanding of how BDCP may change operations, affects analysis based on this modeling may not produce reliable results and should be revised as improved modeling is developed.

6 GLOSSARY

acre-foot The volume of water (about 325,900 gallons) that would cover an area of 1 acre to a depth of 1 foot. This is enough water to meet the annual needs of one to two households.

agricultural water supplier As defined by the California Water Code, a public or private supplier that provides water to 2,000 or more irrigated acres per year for agricultural purposes or serves 2,000 or more acres of agricultural land. This can be a water district that directly supplies water to farmers or a contractor that sells water to the water district.

annual Delta exports The total amount of water transferred (“exported”) to areas south of the Delta through the Harvey O. Banks Pumping Plant (SWP) and the C. W. “Bill” Jones Pumping Plant (CVP) in 1 year.

appropriative water rights Rights allowing a user to divert surface water for beneficial use. The user must first have obtained a permit from the State Water Resources Control Board, unless the appropriative water right predates 1914.

Article 21 water Water that a contractor can receive in addition to its allocated Table A water. This water is only available if several conditions are met: (1) excess water is flowing through the Delta; (2) the contractor can use the surplus water or store it in the contractor’s own system; and (3) delivering this water will not interfere with Table A allocations, other SWP deliveries, or SWP operations.

biological opinion A determination by the U.S. Fish and Wildlife Service or National Marine Fisheries Service on whether a proposed federal action is likely to jeopardize the continued existence of a threatened or endangered species or result in the destruction or adverse modification of designated “critical habitat.” If jeopardy is determined, certain actions are required to be taken to protect the species of concern.

CalSim-II A computer model, jointly developed by DWR and the U.S. Bureau of Reclamation, that simulates existing and future operations of the SWP and CVP. The hydrology used by this model was developed by adjusting the historical flow record (1922–2003) to account for the influence of changes in land uses and regulation of upstream flows.

Central Valley Project (CVP) Operated by the U.S. Bureau of Reclamation, the CVP is a water storage and delivery system consisting of 20 dams and reservoirs (including Shasta, Folsom, and New Melones Reservoirs), 11 power plants, and 500 miles of major canals. CVP facilities reach some 400 miles from Redding to Bakersfield and deliver about 7 million acre-feet of water for agricultural, urban, and wildlife use.

cubic feet per second (cfs) A measure of the rate at which a river or stream is flowing. The flow is 1 cfs if a cubic foot (about 7.48 gallons) of water passes a specific point in 1 second. A flow of 1 cubic foot per second for a day is approximately 2 acre-feet.

Delta exports Water transferred (“exported”) to areas south of the Delta through the Harvey O. Banks Pumping Plant (SWP) and the C. W. “Bill” Jones Pumping Plant (CVP).

Delta inflow The combined total of water flowing into the Delta from the Sacramento River, San Joaquin River, and other rivers and waterways.

exceedence plot For the SWP, a curve showing SWP delivery probability (especially for Table A water)—specifically, the likelihood that SWP Contractors will receive a certain volume of water under current or future conditions.

incidental take permit A permit issued by the U.S. Fish and Wildlife Service or National Marine Fisheries Service, under Section 10 of the federal Endangered Species Act, to private nonfederal entities undertaking otherwise lawful projects that might result in the “take” of an endangered or threatened species. In California, an additional permit is required and take may be authorized under Section 2081 of the California Fish and Game Code through issuance of either an incidental take permit or a consistency determination. The California Department of Fish and Wildlife is authorized to accept a federal biological opinion as the take authorization for a State-listed species when a species is listed under both the federal and California Endangered Species Acts.

riparian water rights Water rights that apply to lands traversed by or adjacent to a natural watercourse. No permit is required to use this water, which must be used on riparian land and cannot be stored for later use. Riparian rights attach only to the “natural” flow in the water course and do not apply to abandoned flows or stored water releases.

State Water Project (SWP) Operated by DWR, a water storage and delivery system of 33 storage facilities, about 700 miles of open canals and pipelines, four pumping-generating plants, five hydroelectric power plants, and 20 pumping plants that extends for more than 600 miles in California. Its main purpose is to store and distribute water to 29 urban and agricultural water suppliers in Northern California, the San Francisco Bay Area, the San Joaquin Valley, the Central Coast, and Southern California. The SWP provides supplemental water to 25 million Californians (almost two-thirds of California’s population) and about 750,000 acres of irrigated farmland. Water deliveries have ranged from 1.4 million acre-feet in a dry year to more than 4.0 million acre-feet in a wet year.

SWP Contractors Twenty-nine entities that receive water for agricultural or municipal and industrial uses through the SWP. Each contractor has executed a long-term water supply contract with DWR. Also sometimes referred to as “State Water Contractors.”

Table A water (Table A amounts) The maximum amount of SWP water that the State agreed to make available to an SWP Contractor for delivery during the year. Table A amounts determine the maximum water a contractor may request each year from DWR. The State and SWP Contractors also use Table A amounts to serve as a basis for allocation of some SWP costs among the contractors.

urban water supplier As defined by the California Water Code, a public or private supplier that provides water for municipal use directly or indirectly to more than 3,000 customers or supplies more than 3,000 acre-feet of water in a year. This can be a water district that provides the water to local residents for use at home or work, or a contractor that distributes or sells water to that water district.

Water Rights Decision 1641 (D-1641) A regulatory decision issued by the State Water Resources Control Board in 1999 (updated in 2000) to implement the 1995 Water Quality Control Plan for the San Francisco Bay/Sacramento–San Joaquin Delta. D-1641 assigned primary responsibility for meeting many of the Delta’s water quality objectives to the SWP and CVP, thus placing certain limits on SWP and CVP operations.

water year In reports on surface water supply, the period extending from October 1 through September 30 of the following calendar year. The water year refers to the September year. For example, October 1, 2010, through September 30, 2011 is the 2011 water year.

Review of Bay Delta Conservation Program Modeling

by MBK Engineers and Daniel B. Steiner, Consulting Engineer

Technical Appendix

Contents

1	Introduction	5
2	Review of BDCP CalSim II Modeling.....	6
2.1	Climate Change	6
	Implementation of Climate Change.....	6
	CalSim II Assumptions.....	6
	Regulatory requirements	7
	Model Results	7
	Inflow and Reservoir Storage in the Sacramento River Basin.....	7
	Carryover Storage in the Sacramento River Basin	9
	Inflow and Carryover Storage in the San Joaquin River Basin	11
	SWP Water Supply	13
	CVP/SWP Exports	17
	Joint Point of Diversion	18
	San Luis Reservoir Operations.....	19
	Sacramento River Temperature	19
	Conclusions regarding Climate Change Assumptions and Implementation.....	21
2.2	BDCP Operation.....	22
	Description of the BDCP Project	22
	High Outflow Scenario (HOS or H4) Results	23
	Evaluated Starting Operations (ESO or H3) Results.....	26
	North Delta Diversion Intakes	26
	CVP/SWP Exports	26
	Delta Outflow	30
	CVP/SWP Reservoir Carryover Storage	31
	San Luis Reservoir Operations.....	31
	CVP Water Supply	35
	SWP Water Supply	38
	Freemont Weir Modifications and Yolo Bypass Inundation	40
	Sacramento River Temperature	42
	Conclusions regarding CalSim II modeling of BDCP Alternative 4	43
	BDCP’s “High Outflow Scenario” is not sufficiently defined for analysis.....	43
	Simulated operation of BDCP’s dual conveyance, coordinating proposed North Delta diversion facilities with existing south Delta diversion facilities, is inconsistent with the project description.	43
	BDCP modeling contains numerous coding and data issues that skew the analysis and conflict with actual real-time operational objectives and constraints	43
3	INDEPENDENT MODELING.....	44

3.1 Changes to CalSim II Assumptions 44

 Revisions approved by DWR and Reclamation for the 2013 baseline..... 44

 Additional Revisions to CalSim II Assumptions..... 45

 San Joaquin River Basin..... 45

 Folsom Lake Flood Control Diagram 46

 Feather River Rice Decomposition Demand 46

 Dynamic EBMUD Diversion at Freeport 46

 Wilkins Slough Minimum Flow Requirement..... 46

 CVP M&I Demands 47

 Yuba Accord Water Transfer 47

 Los Vaqueros Reservoir..... 47

3.2 Changes to BDCP Operations 47

 San Luis Reservoir Rule-Curve Logic Change..... 47

 Upstream Storage Release to Fill San Luis Reservoir Above Needed Supply..... 48

 Delivery allocation adjustment for CVP SOD Ag service and M&I contractors..... 48

 Folsom/Shasta Balance 48

 North Delta Diversion Bypass Criteria..... 48

 Delta Cross Channel Gate Reoperation in October..... 49

 Wilkins Slough minimum flow requirement 49

3.3 Alternative 4 Modeling results 50

 CVP/SWP Delta Exports..... 51

 Delta Outflow 55

 Carryover Storage 55

 San Luis Reservoir Operations..... 58

 CVP Water Supply 58

 SWP Water Supply 61

4 Comparing Independent Modeling and BDCP Modeling 63

 Delta Exports..... 63

 Delta Outflow..... 64

 Reservoir Storage..... 65

 North Delta Diversions..... 66

 Delta flows below the NDD facility 67

 Sacramento River water entering the Central Delta 69

 Conclusions regarding BDCP effects..... 72

Figures

Figure 1. Projected Inflow to Trinity, Shasta, Oroville, and Folsom Reservoirs – NAA, NAA-ELT and NAA-LLT9

Figure 2. Projected Shasta Reservoir Carryover Storage, NAA, NAA-ELT and NAA-LLT10

Figure 3. Projected Inflow to Millerton Lake –NAA, NAA-ELT and NAA-LLT11

Figure 4. Millerton Reservoir Carryover Storage, NAA, NAA-ELT and NAA-LLT Scenarios.....12

Figure 5. CVP Water Service Contractor Delivery Summary14

Figure 6. CVP Contractor Delivery Summary for Contractors with Shasta Criteria Allocations.....15

Figure 7. SWP Delta Delivery Summary16

Figure 8. CVP Exports at Jones PP, NAA, NAA-ELT and NAA-LLT.....17

Figure 9. Total CVP/SWP Exports, NAA, NAA-ELT and NAA-LLT.....18

Figure 10. Cross Valley Canal Wheeling at Banks19

Figure 11. San Luis Reservoir Storage – NAA, NAA-ELT and NAA-LLT19

Figure 12. Temperature Exceedance Sacramento River at Bend Bridge Existing, No Action Alternative, ELT20

Figure 13. Temperature Exceedance Sacramento River at Bend Bridge Existing, No Action Alternative, LLT21

Figure 14. Changes in Feather River Flow, Alt 4 H4 ELT minus NAA-ELT24

Figure 15. Changes in Oroville Storage, Alt 4 H4 ELT minus NAA-ELT24

Figure 16. Changes in Delta Outflow, Alt 4 H4 ELT minus NAA-ELT.....25

Figure 17. Changes in Delta Export, Alt 4 H4 ELT minus NAA-ELT25

Figure 18. Changes in CVP and SWP Deliveries, Alt 4 H4 ELT minus NAA-ELT25

Figure 19. NDD, Bypass Requirement, Bypass Flow, and Excess Sacramento R. flow for Alt 4-ELT26

Figure 20. Change in CVP (Jones) and SWP (Banks) Exports (Alt 4-ELT minus NAA-ELT).....27

Figure 21. Change in Conveyance Source of Exports (Alt 4-ELT minus NAA-ELT)28

Figure 22. Alt 4-ELT North Delta Diversion Versus South Delta Diversion for July, August, and September29

Figure 23. South Delta Diversion at Banks30

Figure 24. Delta Outflow Change (Alt 4-ELT minus NAA-ELT)31

Figure 25. Trinity Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type33

Figure 26. Shasta Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type33

Figure 27. Oroville Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type34

Figure 28. Folsom Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type34

Figure 29. Federal Share of San Luis Reservoir (Alt 4-ELT and NAA-ELT).....35

Figure 30. State Share of San Luis Reservoir (Alt 4-ELT and NAA-ELT).....35

Figure 31. CVP Service Contract Deliveries (Alt 4-ELT and NAA-ELT).....37

Figure 32. SWP Contract Deliveries (Alt 4-ELT and NAA-ELT)39

Figure 33. Fremont Weir vs. Sacramento River NAA-ELT.....40

Figure 34. Fremont Weir vs. Sacramento River Alt 4-ELT41

Figure 35. Average Fremont Weir Flow to Bypass by Water Year Type NAA-ELT.....41

Figure 36. Average Fremont Weir Flow to Bypass by Water Year Alt 4 ELT minus NAA-ELT.....41

Figure 37. Annual Change in Fremont Weir Flow to Bypass Alt 4-ELT minus NAA-ELT42

Figure 38. Sacramento River Temperature at Bend Bridge NAA-ELT and Alt 4-ELT42

Figure 39. Alt 4 Features50

Figure 40. Change in Delta Exports at Jones Alt 4 minus FNA51

Figure 41. Change in Delta Exports at Banks Alt 4 minus FNA52

Figure 42. Change in CVP Delta Exports at Banks Alt 4 minus FNA52

Figure 43. Change in Conveyance Source of Exports (Alt 4 minus FNA)53

Figure 44. Alt 4 North Delta Diversion Versus South Delta Diversion for July, August, and September54

Figure 45. Changes in Delta Outflow (Alt 4 minus FNA).....55

Figure 46. Trinity Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type56

Figure 47. Shasta Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type56

Figure 48. Oroville Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type57

Figure 49. Folsom Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type57

Figure 50. SWP San Luis	58
Figure 51. CVP San Luis	58
Figure 52. CVP Water Supply Delivery and Allocation	60
Figure 53. SWP Delivery for Alt 4 and FNA.....	62
Figure 54. Result Difference: Delta Exports	63
Figure 55. Result Difference: South Delta Diversion	64
Figure 56. Result Difference: North Delta Diversion	64
Figure 57. Result Difference: Net Delta Outflow.....	65
Figure 58. Result Difference: Shasta Storage	65
Figure 59. Result Difference: Folsom Storage.....	66
Figure 60. NDD, and Sacramento River Flow	66
Figure 61. Sacramento River below Hood.....	68
Figure 62. Flow through Delta Cross Channel and Georgiana Slough versus Sacramento River Flow at Hood	69
Figure 63. Cross Channel Flow	70
Figure 64. Flow through Delta Cross Channel and Georgiana Slough.....	71

Tables

Table 1. Scenarios used to evaluate climate change	6
Table 2. CVP Water Service Contractor Allocation Summary	12
Table 3. CVP Delivery Summary (Alt 4-ELT and NAA-ELT).....	36
Table 4. SWP Delivery Summary (Alt 4-ELT and NAA-ELT).....	38
Table 5. CVP Delivery Summary	59
Table 6. SWP Delivery Summary	61

1 INTRODUCTION

Since December 2012, MBK Engineers and Dan Steiner (collectively “Reviewers”) have assisted various parties in evaluating the operations modeling that was performed for the Bay Delta Conservation Plan (BDCP). To assist in understanding BDCP and the potential implications, stakeholders¹ requested that the Reviewers review the CalSim II modeling studies performed as part of the BDCP (hereafter “BDCP Studies” or “BDCP Model”).

An initial review led the Reviewers to conclude that the BDCP Model, which serves as the basis for the environmental analysis contained in the BDCP Environmental Impact Report/Statement (EIR/S), provides very limited useful information to understand the effects of the BDCP. The BDCP Model contains erroneous assumptions, errors, and outdated tools, which result in impractical or unrealistic Central Valley Project (CVP) and State Water Project (SWP) operations. The unrealistic operations, in turn, do not accurately depict the effects of the BDCP.

The Reviewers revised the BDCP Model to depict a more accurate, consistent version of current and future benchmark hydrology so that the effects of the BDCP could be ascertained. The BDCP Model was also revised to depict more realistic CVP and SWP operations upon which to contrast the various BDCP alternatives. The Reviewers made significant efforts to coordinate with and inform the U.S. Bureau of Reclamation (Reclamation) and the California Department of Water Resources (DWR) managers and modelers, and CVP and SWP operators of the Reviewers’ modifications, assumptions, and findings. Where appropriate, the Reviewers also used Reclamation and DWR’s guidance and direction to refine the Reviewers’ analysis.

This technical appendix summarizes: (1) the independent review of the CalSim II modeling publicly released for the BDCP’s Draft Environmental Impact Report/Statement (EIRS), (2) the corrections and revisions made to the assumptions in the CalSim II model, and (3) comparisons between the BDCP and independent modeling results. The detailed information in this appendix is summarized in our main report.

¹ The entities who funded this report are Contra Costa Water District, East Bay Municipal Utility District, Friant Water Authority, Northern California Water Association, North Delta Water Agency, San Joaquin River Exchange Contractors Water Authority, San Joaquin Tributaries Authority, and Tehama Colusa Canal Authority.

2 REVIEW OF BDCP CALSIM II MODELING

2.1 Climate Change

Implementation of Climate Change

The analysis presented in the BDCP Documents attempts to incorporate the effects of climate change at two future climate periods: the early long term (ELT) at approximately the year 2025; and the late long term (LLT) at approximately 2060. As described in the BDCP documents², other analytical tools were used to determine anticipated changes to precipitation and air temperature that is expected to occur under ELT and LLT conditions. Projected precipitation and temperature was then used to determine how much water is expected to flow into the upstream reservoirs and downstream accretions/depletions over an 82-year period of variable hydrology; these time series were then used as inputs into the CalSim II operations model. A second aspect of climate change, the anticipated amount of sea level rise, is incorporated into the CalSim II model by modifying a subroutine that determines salinity within the Delta based on flows within Delta channels. The effects of sea level rise will manifest as a need for additional outflow when water quality is controlling operations to prevent seawater intrusion.

This report does not review the analytical processes by which reservoir inflows and runoff were developed, nor does it evaluate the modified flow-salinity relationships that are assumed due to sea level rise; those items could be the focus of another independent review. This review is limited to evaluating how the modified flows were incorporated into CalSim II and whether the operation of the CVP and SWP water system in response to the modified flows and the modified flow-salinity relationship is reasonable for the ELT and LLT conditions. This work reviews the assumed underlying hydrology and simulated operation of the CVP/SWP, assumed regulatory requirements, and the resultant water delivery reliability.

CalSim II Assumptions

To assess climate change, the three without Project (or “baseline” or “no action”) modeling scenarios were reviewed: No Action Alternative (NAA)³, No Action Alternative at the Early Long Term (NAA – ELT), and No Action Alternative at the Late Long Term (NAA –LLT). Assumptions for NAA, NAA-ELT, and NAA-LLT are provided in the Draft EIR⁴. The only difference between these scenarios is the climate-related changes made for the ELT and LLT conditions (Table 1).

Table 1. Scenarios used to evaluate climate change

Scenario	Climate Change Assumptions	
	Hydrology	Sea Level Rise
No Action Alternative (NAA)	None	None
No Action Alternative at Early Long Term (NAA-ELT)	Modified reservoir inflows and runoff for expected conditions at 2025	15 cm
No Action Alternative at Early Long Term (NAA-LLT)	Modified reservoir inflows and runoff for expected conditions at 2060	45 cm

² BDCP EIR/EIS Appendix 5A, Section A and BDCP HCP/NCCP Appendix 5.A.2

³ NAA is also called the Existing Biological Conditions number 2 (EBC-2) in the Draft Plan.

⁴ BDCP EIR/EIS Appendix 5A, Section B, Table B-8

The differences between the NAA and NAA-ELT reveal the effects of the climate change assumptions under ELT conditions; similarly, the differences between the NAA and NAA-LLT reveal the effects of the climate change assumptions under LLT conditions.

Regulatory requirements

Each of the no action alternatives assumes the same regulatory requirements, generally representing the existing regulatory environment at the time of study formulation (February 2009), including Stanislaus ROP NMFS BO (June 2009) Actions III.1.2 and III.1.3, Trinity Preferred EIS Alternative, NMFS 2004 Winter-run BO, NMFS BO (June 2009) Action I.2.1, SWRCB WR90-5, CVPIA (b)(2) flows, NMFS BO (June 2009) Action I.2.2, ARFM NMFS BO (June 2009) Action II.1, no SJRRP flow modeled, Vernalis SWRCB D1641 Vernalis flow and WQ and NMFS BO (June 2009) Action IV.2.1, Delta D1641 and NMFS Delta Actions including Fall X2 FWS BO (December 2008) Action 4, Export restrictions including NMFS BO (June 2009) Action IV.11.2v Phase II, OMR FWS BO (December 2008) Actions 1-3 and NMFS BO (June 2009) Action IV.2.3v.

The modeling protocols for the recent USFWS BO (2008) and NMFS BO (2009) have been cited as being cooperatively developed by Reclamation, NMFS, U.S. Fish and Wildlife Service (USF&WS), California Department of Fish and Wildlife (CDF&W), and DWR.

Each of the BDCP no action alternatives (NAA, NAA-ELT, and NAA-LLT) uses the same New Melones Reservoir and other San Joaquin River operations. At the time of these studies' formulation, the National Marine Fisheries Services (NMFS) Biological Opinion (BO) (June 2009) had been recently released. Also, the San Joaquin River Agreement (SJRA, including the Vernalis Adaptive Management Program [VAMP]) and its incorporation into D1641 for Vernalis flow requirements were either still in force or being discussed for extension. As a component of study assumptions, the protocols of the SJRA and an implementation of the NMFS BO for San Joaquin River operations (including New Melones Reservoir operations) is included in the studies. These protocols, in particular the inclusion of VAMP which has now expired, is not appropriate as an assumption within either the No Action or Alternative Scenarios. Although appropriate within the identification of actions, programs and protocols present at the time of the NOI/NOP, they are not representative of current or reasonably foreseeable operations. Also, modeling of the future operation of the Friant Division of the CVP assumes no San Joaquin River Restoration Program releases. While assuming no difference in the current and future operation of the Friant Division avoids another difference in existing and projected future hydrology of the San Joaquin River, the assumption does not recognize the existence of the San Joaquin River Restoration Program. Results of CVP and SWP operations, in particular as affected by export constraints dependent on San Joaquin River flows and their effect on OMR, E/I and I/E diversion constraints, would be different with a different set of assumptions for San Joaquin River operations.

Finally, the habitat restoration requirements in the 2008 FWS BO and the 2009 NMFS BO are not included in the No Action Alternative baselines. Although the restoration is required to be completed either with or without completion of the BDCP, the restoration was only analyzed as part of the with project scenarios.

Model Results

Inflow and Reservoir Storage in the Sacramento River Basin


The significance of changed hydrology between the three without project baselines is illustrated in Figure 1 below. The figure illustrates the projected combined inflow of Trinity, Shasta, Oroville, and Folsom Reservoirs under the three NAA baselines. Numerous modeling projections for climate change have been developed, and in this BDCP group of Scenarios Trinity, Shasta, and Oroville inflow are projected to increase overall, but with a

significant shift from spring runoff to winter runoff and increases in wetter years with decreases in dryer years. Folsom Reservoir inflow is projected to remain about the same at the time of the NAA-ELT Scenario but decreases by the time of the NAA-LLT Scenario. The spring to winter shift in runoff is also projected for Folsom Reservoir inflow.

If climate change resulted in such drastic inflow changes, there is argument that certain underlying operating criteria such as instream flow requirements and flood control diagrams would require change in recognition of the changed hydrology. Regarding current environmental flow requirements carried into the NAA Scenarios, we question an assumed operation that continues to attempt to meet temperature targets when flow releases are unlikely to meet the target and thus a sustainable operation plan is not possible. For example, the CVP and SWP are unlikely to draw reservoirs to dead pool as often as the models depict. The NAA-ELT and NAA-LLT model Scenarios show project reservoirs going to dead pool in 10% of years; such operation would result in cutting upstream urban area deliveries below what is needed for public health and safety in 10% of years and would lead to water temperature conditions that would likely not achieve the assumed objectives. Again in short, the Scenarios that include climate change do not provide a reasonable underlying CVP/SWP operation with a changed hydrology from which to impose a Project upon to understand how BDCP Alternatives will affect the water system and water users.

In our opinion, the CalSim II depicted operations that incorporate climate change are not reasonably foreseeable and do not represent a likely future operation of the CVP/SWP. Although an argument is typically made that these study baselines will be used in a comparison analysis with Project Alternatives tiering from these baselines, we believe that the depicted operations do not represent credible CVP/SWP operations and we have no confidence in the results and they are inappropriate as the foundation of a Project Alternative. As such, although the modeling approach may provide a relative comparison between equal foundational operations, we are apprehensive to place much confidence in the computed differences shown between the NAA and Project Alternative Scenarios.

Figure 1. Projected Inflow to Trinity, Shasta, Oroville, and Folsom Reservoirs – NAA, NAA-ELT and NAA-LLT




Carryover Storage in the Sacramento River Basin

For upstream CVP and SWP reservoirs the assumed shift of inflows due to climate change (Figure 1) along with a continuing need to satisfy exports demands significantly affects carryover storage. The CVP and SWP simply cannot satisfy water demands and regulatory criteria imposed on them in the NAA-ELT and NAA-LLT modeling scenarios.

Figure 2 illustrates the typical change in carryover storage as shown for Trinity, Shasta, Oroville, and Folsom Reservoirs. The relatively high frequency (approximately 10% of time) of minimum storage occurring at CVP reservoirs illustrates our questioning of credible operations in the studies.


Figure 2. Projected Shasta Reservoir Carryover Storage, NAA, NAA-ELT and NAA-LLT



Inflow and Carryover Storage in the San Joaquin River Basin

San Joaquin Valley reservoirs are depicted with an overall decrease in annual runoff with some shifting of runoff from spring to winter, but mostly just decreases in spring runoff due to a decline in snowmelt runoff during late spring⁵. Figure 3 illustrates the assumed effects of climate change upon inflow to Millerton Lake.

Figure 3. Projected Inflow to Millerton Lake –NAA, NAA-ELT and NAA-LLT




The hydrology differences imposed in the NAA Scenarios of the Friant Division are described above, and its appropriateness may be subject to additional debate and Alternative assumptions. However, our review found that implementation of Millerton Reservoir inflow as affected by climate change was improperly performed.

⁵ BDCP Appendix 5A.2

Inflow to Millerton Reservoir in this version of CalSim is input in three separate time series for purposes of depicting the hydrology of potential upper basin reservoirs. Climate change hydrology was inconsistently incorporated at Millerton Reservoir and misapplied to the water supply and flood control operations. The result is an unrealistic operation for river releases and canal diversions. Figure 3 illustrates the projected ELT and LLT changes in Millerton Reservoir inflow incorporated in these studies. On face value of the input data, regardless of Friant Dam river release assumptions the effect of climate change at Millerton Lake will affect water deliveries.

Evidence of the inconsistent inflow problem is shown in the result for the comparison of carryover storage of Millerton Reservoir under the NAA, NAA-ELT, and NAA-LLT Scenarios (Figure 4). Carryover storage is higher in the ELT and LLT Scenarios due to climate change effects to inflow incorporated in reservoir operations but not in the computation of water supply deliveries. Thus, water deliveries are suppressed and the reservoir ends the year with greater storage.

Figure 4. Millerton Reservoir Carryover Storage, NAA, NAA-ELT and NAA-LLT Scenarios



CVP Water Service Contractor’s water allocations are based on available CVP supplies, Figure 5 contains exceedance probability plots of deliveries and allocation percentages to these contractors. Table 2 contains average annual allocation to these CVP Water Service Contractors. Water supplies to these contractors decrease in the ELT and LLT relative to NAA Conditions.

Table 2. CVP Water Service Contractor Allocation Summary

	NAA	NAA-ELT	NAA-LLT
North of Delta Agricultural Service Contractors	61%	53%	46%
South of Delta Agricultural Service Contractors	48%	44%	39%
North of Delta M&I Contractors	85%	81%	77%
South of Delta M&I Contractors	79%	77%	74%

CVP Sacramento River Settlement, San Joaquin River Exchange, and Refuge deliveries are based on Shasta Criteria and are 100% in most years and 75% in “Shasta critical” years⁶. Figure 6 contains exceedance probability charts for annual water deliveries to CVP contractors whose allocations are based on Shasta Criteria. In the NAA-ELT and NAA-LLT modeling scenarios, the Sacramento River Settlement and Refuge deliveries are reduced due to water shortages that occur more often under the climate change assumptions.

SWP Water Supply

Corresponding with the CVP operation is the projected operation of the SWP under No Action Conditions. These illustrations are shown to provide a comparison to SWP storage and exports, particularly during drought. A comparison of SWP exports to CVP SOD deliveries shows that each project exports about the same amount of water during drought.

Average annual SWP Table A water supply allocations are 62% for NAA, 61% for NAA-ELT, and 57% for NAA-LLT. Figure 7 contains an exceedance probability plot summary of SWP deliveries. SWP North of Delta deliveries to the Feather River Service Area in both the ELT and LLT are less than NAA during about 10% of the time.

⁶ A “Shasta critical” year is determined when the forecasted full natural inflow into Shasta Lake is equal to or less than 3.2 million acre-feet.

Figure 5. CVP Water Service Contractor Delivery Summary






Figure 6. CVP Contractor Delivery Summary for Contractors with Shasta Criteria Allocations


Sacramento River Settlement Contractor Delivery



Sacramento Valley Refuge Delivery



San Joaquin River Exchange Contractor Delivery



South of Delta Refuge Delivery









Figure 7. SWP Delta Delivery Summary



CVP/SWP Exports

Exports of the CVP and SWP have been projected to change due to a combination of climate change effects on water availability (primary effect), flow requirements for salinity control (sea level rise), additional in-basin water demands, and to a small extent greater export potential (DMC-CA intertie). Figure 8 illustrates the simulation of CVP exports and combined CVP/SWP exports under NAA, NAA-ELT, and NAA-LLT Scenarios. Under NAA average annual CVP exports are about 2.24 MAF (2.18 at Jones PP) and are about 100 TAF less in the NAA-ELT Scenario and 230 TAF less in the NAA-LLT. Annual average SWP exports are about 2.61 MAF in the NAA and are 68 TAF less in the NAA-ELT and 212 TAF less in the NAA-LLT. Annual average combined CVP/SWP exports are about 4.9 MAF in the NAA modeling (Figure 9) and about 170 TAF and 460 TAF less in the NAA-ELT and NAA-LLT respectively.

Figure 8. CVP Exports at Jones PP, NAA, NAA-ELT and NAA-LLT






Figure 9. Total CVP/SWP Exports, NAA, NAA-ELT and NAA-LLT



Joint Point of Diversion

The NAA Alternatives do not make use of Joint Point of Diversion (JPOD), however CVP water is pumped at Banks to satisfy the Cross Valley Canal (CVC) contracts. Figure 10 shows annual Banks wheeling for CVC for the NAA, NAA-ELT and NAA-LLT.


Figure 10. Cross Valley Canal Wheeling at Banks



San Luis Reservoir Operations

Modeling protocols will use San Luis Reservoir to store water when available and provide supply as exports are constrained by hydrology or regulatory constraints. Figure 11 illustrates the projected operation of San Luis Reservoir under the NAA, NAA-ELT, and NAA-LLT Scenarios. The annual maximum storage shows that the ability to fill San Luis Reservoir is somewhat similar for NAA and NAA-ELT but with less ability to fill in the NAA-LLT. The frequency of a low annual low point of San Luis Reservoir is exacerbated in the NAA-LLT Scenario. In all the Scenarios, San Luis Reservoir is heavily exercised. As currently projected, San Luis Reservoir will only fill as the result of very favorable hydrologic conditions including the availability of spill water from Friant or the Kings River system that offsets DMC water demands at the Mendota Pool.

Figure 11. San Luis Reservoir Storage – NAA, NAA-ELT and NAA-LLT



Sacramento River Temperature

CalSim II results, along with meteorological data, are used in temperature models that simulate reservoir temperature and river temperature. The BDCP modeling provided by DWR for review included the Sacramento

River temperature model and results for the No Action and Alternatives. Each BDCP Alternative used temperature target criteria for the upper Sacramento River as is used for the Existing Conditions modeling scenario. Equilibrium temperatures, a calculated model input that approximately depicts the effective air temperature for interaction with water temperature in the model, between Shasta and Gerber are increased by an annual average of 1.6°F for the ELT Scenarios and by 3.3°F for LLT Scenarios. Figure 12 contains monthly exceedance probability charts of temperature at Bend Bridge in the Sacramento River for April through October for the Existing Conditions and NAA-ELT Scenarios. There is about a 1 degree increase in average monthly temperature for the April through October period. Figure 13 contains similar information as Figure 12, but compares modeling results for the NAA-LLT and Existing Conditions Scenarios, there is often a 2°F increase in the NAA-LLT relative to Existing Conditions.

The increase in equilibrium temperatures combined with decreases in storage would lead to water temperature conditions that would likely not achieve the assumed objectives. Figure 12 and Figure 13 illustrate an increase in the probability that a water temperature target of 56°F would be exceeded at Bend Bridge under both the NAA-ELT and NAA-LLT Scenarios. The probability of exceedance increases approximately 5% to 20% depending on the month for the NAA-ELT Scenario and approximately 10% to 40% for the NAA-LLT Scenario.

Figure 12. Temperature Exceedance Sacramento River at Bend Bridge Existing, No Action Alternative, ELT





Figure 13. Temperature Exceedance Sacramento River at Bend Bridge Existing, No Action Alternative, LLT



Conclusions regarding Climate Change Assumptions and Implementation

In examining the possible effects of climate change, it is not appropriate to assume that current project operations will remain static and not respond to climate change. The BDCP's simplistic approach of assuming a linear operation of the CVP and SWP produces results that are not useful for dealing with the complex problem of climate change because it does not reflect the way in which the CVP and the SWP would actually operate whether or not the BDCP is implemented. Reviewers recommend a sensitivity analysis be conducted to develop a better understanding of the range of possible responses to climate change by the CVP and SWP, and the regulatory structures that dictate certain project operations.

Including climate change, without adaptation measures, results in insufficient water needed to meet all regulatory objectives and user demands. For example, the BDCP Model results that include climate change indicate that during droughts, water in reservoirs is reduced to the minimum capacity possible. Reservoirs have not been operated like this in the past during extreme droughts and the current drought also provides evidence that adaptation measures are called for long in advanced to avoid draining the reservoirs. In this aspect, the BDCP Model simply does not reflect a real future condition. Foreseeable adaptations that the CVP and SWP could make in response to climate change include: (1) updating operational rules regarding water releases for flood protection; (2) during severe droughts, emergency drought declarations could call for mandatory conservation; and (3) if droughts become more frequent, the CVP and SWP would likely revisit the rules by which they allocate water during shortages and operate more conservatively in wetter years. The modifications to CVP and SWP operations made during the winter and spring of 2014 in response to the drought supports the likelihood of future adaptations. The BDCP Model is, however, useful in that it reveals that difficult decisions must be made in response to climate change. But, in the absence of making those decisions, the BDCP Model results themselves are not informative, particularly during drought conditions. With future conditions projected to be so dire without the BDCP, the effects of the BDCP appear positive simply because it appears that conditions cannot get any worse (i.e., storage cannot be reduced below its minimum level). However, in reality, the future condition will

not be as depicted in the BDCP Model. The Reviewers recommend that Reclamation and DWR develop more realistic operating rules for the hydrologic conditions expected over the next half-century and incorporate those operating rules into the any CalSim II Model that includes climate change.

2.2 BDCP Operation

The next step of our analysis centered on reviewing BDCP modeling of the with project scenarios as described in the December 2013 Draft BDCP and described as Alternative 4 in the Draft EISR.

Description of the BDCP Project

At the time of review, this Alternative was coined Alt 4 and represented a dual conveyance facility. The two DWR analyses reviewed were identified as:

- Alt 4 (dual conveyance) – ELT
The same system demands and facilities as described in the NAA-ELT with the following primary changes: three proposed North Delta Diversion (NDD) intakes of 3,000 cfs each; NDD bypass flow requirements; additional positive OMR flow requirements and elimination of the San Joaquin River I/E ratio and the export restrictions during VAMP; modification to the Freemont Weir to allow additional seasonal inundation and fish passage; modified Delta outflow requirements in the spring and/or fall (defined in the Decision Tree discussed below); movement of the Emmaton salinity standard; redefinition of the EI ratio; and removal of current permit limitations for the south Delta export facilities. Set within the ELT environment.
- Alt 4 (dual conveyance) – LLT
The same as the previous Scenario except established in the LLT environment.

The BDCP contemplates a dual conveyance system that would move water through the Delta's interior or around the Delta through an isolated conveyance facility. The BDCP CalSim II files contained a set of studies evaluating the projected operation of a specific version of such a facility. The Alternative was imposed on two baselines: the NAA-ELT scenario and the NAA-LLT scenario.

The changes (benefits or impacts) of the operation due to Alt 4 are highly dependent upon the assumed operation of not only the BDCP facilities and the changed regulatory requirements associated with those facilities, but also by the assumed integrated operation of the CVP and SWP facilities. The modeling of the NAA Scenarios introduced a significant change in operating protocols suggested primarily for reaction to climate change. We consider the extent of the reaction not necessarily representing a likely outcome, and thus have little confidence that the NAA baselines are a "best" (or even valid) representation of a baseline from which to compare an action Alternative. However, a comparison review of the Alternative to the NAA baselines illuminates operational issues in the BDCP modeling and provides insight as to where benefits or impacts may occur as additional studies are provided.

Since the effects of climate changes are more severe in the LLT than in the ELT, this review focuses on the ELT modeling because the results are less skewed by the climate change assumptions and problems.

BDCP's Alternative 4 has four possible sets of operational criteria, termed the Decision Tree, that differ based on the "X2" standards⁷ that they contemplate:

- Low Outflow Scenario (LOS), otherwise known as operational scenario H1, assumes existing spring X2 standard and the removal of the existing fall X2 standard;

⁷ X2 is a salinity standard that requires outflows sufficient to attain a certain level of salinity at designated locations in the Delta at certain times of year.

- High Outflow Scenario (HOS), otherwise known as H4, contemplates the existing fall X2 standard and providing additional outflow during the spring;
- Evaluated Starting Operations (ESO), otherwise known as H3, assumes continuation of the existing X2 spring and fall standards;
- Enhanced spring outflow only (not evaluated in the December 2013 Draft BDCP), scenario H2, assumes additional spring outflow and no fall X2 standards.

While it is not entirely clear how the Decision Tree would work in practice, the general concept is that the prior to operation of the new facility, implementing authorities would select the appropriate Scenario (from amongst the four choices) based on their evaluation of targeted research and studies to be conducted during planning and construction of the facility.

For our analysis, we reviewed the HOS (or H4) scenario because the BDCP⁸ indicates that the initial permit will include HOS operations that may be later modified at the conclusion of the targeted research studies. The HOS includes the existing fall X2 requirements but adds additional outflow requirements in the spring. We reviewed the model code and discussed the operations with DWR and Reclamation, who acknowledged that although the SWP was bearing the majority of the responsibility for meeting the additional spring outflow in the modeling, the responsibility would need to be shared with the CVP⁹. In subsequent discussions, DWR and Reclamation have suggested that the additional water may be purchased from other water users. However, the actual source of water for the additional outflow has not been defined. Since the BDCP modeling assumes that SWP bears the majority of the responsibility for meeting the additional outflow, yet this is not how the project will be operated in reality, our review of the BDCP modeling results for HOS is limited to the evaluation of how the SWP reservoir releases on the Feather River translate into changes in Delta outflow and exports.

Our remaining analysis examines the ESO (or H3) scenario (labeled Alt 4-ELT or Alt 4-LLT in this section) because it employs the same X2 standards as are implemented in the No Action Alternatives NAA-ELT and NAA-LLT. This allows us to focus our analysis on the effects of the BDCP operations independent of the possible change in the X2 standard.

High Outflow Scenario (HOS or H4) Results

In Alt 4-ELT H4 Feather River flows during wetter years are increased more than 3,000 cfs in April and May and then decreased in most year types during July and August, while September flow is only decreased in wetter years. Figure 14 shows average monthly change in Feather River flow by water year type. Accompanying the changes in Feather River flow are changes in Oroville Reservoir storage levels, Figure 15 contains average monthly changes in Oroville storage. Alt4-ELT H4 end of June storage in Oroville during wetter years is about 480 TAF lower than the NAA-ELT while critical year storage is about 400 TAF higher. Counter to the reduction in Oroville storage, CVP average upstream carryover storage increases about 80 TAF and critical year increases by 380 TAF. Figure 16 contains average monthly changes in Delta outflow, increases in Feather River spring time flows are generally not used to increase Delta outflow, but are allowed to support increases in Delta exports.

Figure 17 displays changes in average monthly Delta exports, there are increases when diverting higher upstream spring releases in wetter years, while there are decreases during summer months in most years. Figure 18

⁸ Draft BDCP, Chapter 3, Section 3.4.1.4.4

⁹ August 7, 2013 meeting with DWR, Reclamation, and CH2M HILL

contains an average annual summary of project deliveries, total CVP deliveries increase by about 70 TAF while SWP deliveries decrease by about 100 TAF. Drier year SWP deliveries decrease by 250 to 400 TAF, while wet year deliveries increase by 200 TAF. Total CVP deliveries increase in wetter years by exporting increased releases from Oroville.

The overall effect of the HOS appears to be increases in Oroville releases that support both CVP and SWP exports in wetter years, with modest increases in Delta outflow. There is also a decrease in SWP reliability through large delivery reductions in dryer years accompanied by Oroville storage increases. In addition to increases in dry and critical year storage in Oroville, total CVP dry and critical year carryover increases by 100 TAF and 380 TAF respectively with negligible reductions in wetter years types.

CVP and SWP obligation for providing flow to satisfy Delta outflow requirements is described in the Coordinated Operations Agreement (COA). Because the CVP and SWP share responsibility for meeting required Delta outflow based on specific sharing agreement, it doesn't seem reasonable that CVP water supplies would increase while SWP water supplies decrease under this Alternative. The manner in which this alternative is modeled is inconsistent with existing agreements and operating criteria. If the increases in outflow were met based on COA, there would likely be reductions in Shasta and Folsom storage that may cause adverse environmental impacts.

Figure 14. Changes in Feather River Flow, Alt 4 H4 ELT minus NAA-ELT




Figure 15. Changes in Oroville Storage, Alt 4 H4 ELT minus NAA-ELT




Figure 16. Changes in Delta Outflow, Alt 4 H4 ELT minus NAA-ELT




Figure 17. Changes in Delta Export, Alt 4 H4 ELT minus NAA-ELT





Figure 18. Changes in CVP and SWP Deliveries, Alt 4 H4 ELT minus NAA-ELT




Evaluated Starting Operations (ESO or H3) Results

North Delta Diversion Intakes

Sacramento River flow below the North Delta Diversion (NDD) must be maintained above the specified bypass flow requirement, therefore the NDD rates are limited to the Sacramento River flow above the bypass requirement. Due to an error in CalSim II that specifies an unintended additional bypass requirement, modeling performed for the BDCP EIRS often bypasses more Sacramento River flow than is specified in the BDCP project description. This error has been fixed in the most recent public releases of CalSim II, but BDCP modeling has not been updated to reflect these fixes. Figure 19 contains exceedance probability plots showing the Sacramento River required bypass, Sacramento River bypass flow, NDD, and excess Sacramento River flow to the Delta as modeling for BDCP. As can be seen in Figure 19, the bypass flow is always above the bypass requirement in July and August. The BDCP version of CalSim sets a requirement for Sacramento River inflow to the Delta needed to satisfy all Delta flow, quality, and export requirements, this requirement should be removed when modeling the NDD.


Figure 19. NDD, Bypass Requirement, Bypass Flow, and Excess Sacramento R. flow for Alt 4-ELT



CVP/SWP Exports

Overall the Alt 4 will increase exports compared to the NAA-ELT, with the majority of the increased exports realized by the SWP. Figure 20 illustrates a comparison between the NAA-ELT and Alt 4-ELT of CVP and SWP exports. On average, total combined exports under Alt 4-ELT are projected to increase by 537 TAF from 4.73 MAF to 5.26 MAF compared to the NAA-ELT.

Figure 20. Change in CVP (Jones) and SWP (Banks) Exports (Alt 4-ELT minus NAA-ELT)



With the addition of the North Delta Diversion facility, the water exported dramatically shifts from South Delta diversions to North Delta diversions. Figure 21 illustrates the change in routing of South of Delta exports under Alt 4 compared to the NAA-ELT. On average, export through the South Delta facility are projected to decrease by 2.1 MAF and the North Delta diversions will export 2.6 MAF which includes the 2.1 MAF shifted from the South Delta facility plus the additional 537 TAF of increased exports.

Figure 21. Change in Conveyance Source of Exports (Alt 4-ELT minus NAA-ELT)






Figure 22 contains figures for July, August, and September for Alt 4-ELT that plot NDD against SDD. In the months of July to September SDD are occasionally very high, exceeding 14,000 cfs in July, with minimal NDD. This occurs due to outdated model code that imposes an instream flow requirement in Sacramento River flow below Hood in excess of the bypass criteria prescribed in the BDCP. There are numerous occurrences when bypass flows prescribed in the BDCP are exceeded and SDD are higher than expected. On the other hand, there are also many times when NDD are above minimum pumping levels and SDD are below the BDCP prescribed 3,000 cfs threshold indicated by the green line in Figure 22. For unknown reasons, the model code requiring SDD to be greater than 3,000 cfs before NDDs occur from July through September is deactivated in the BDCP modeling of this Alternative.

Figure 22. Alt 4-ELT North Delta Diversion Versus South Delta Diversion for July, August, and September



South Delta Diversion at Banks is not limited to existing permit capacity of 6,680 cfs and pumping may reach full capacity of 10,300 cfs in July, August, and September. Figure 23 contains exceedance probability charts of South Delta Diversion at Banks for July, August, and September. The chart for July shows SDD at Banks exceeding existing permit capacity 20% of years, in August this occurs in about 7% of years. There are South Delta diversions at Banks 25% of the time in September while diversions from the Sacramento River may range from 2,500 cfs to 7,500 cfs.

Figure 23. South Delta Diversion at Banks




Generally exports increase during winter and spring months due to the ability to avoid fishery concerns by diverting at the North Delta rather than South Delta.

Delta Outflow

Figure 24 illustrates a comparison of Delta outflow between the NAA-ELT and Alt 4-ELT. Decreases in Delta outflow are the result of the CVP and SWP ability to increase Delta exports in Alt 4-ELT. The apparent increase in Delta outflow in October is partially due to additional export restrictions though Old and Middle River flow requirements. However, the increase in October Delta outflow is also due to an unrealistic operation of the Delta Cross Channel. The additional export restrictions cause the flow standards imposed at Rio Vista to be the controlling point in CVP and SWP operations; the water quality standards are all being met and do not require

flows above the amount needed to satisfy the Rio Vista standard. Meeting the Rio Vista flow standards without closing the Delta Cross Channel gate results in releasing more water from upstream reservoirs than would otherwise be necessary. This occurs because a certain amount of the water released to meet the Rio Vista flow standards would flow into the Central Delta at location of the Delta Cross Channel gate. This water would not make it to Rio Vista and therefore would not be counted towards meeting the Rio Vista flow standards. However, due to the BDCP model’s assumed restrictions on exports at this time, this water could not be pumped from the South Delta facilities and thus ends up as “extra” Delta outflow. By closing the Delta Cross Channel gate, the operators would assure that all of the water released to meet the Rio Vista flow standards would be counted towards those standards. The BDCP model’s assumptions that the Delta Cross Channel gate would not be closed are not practical or a sensible operation as the operators confirmed they would close the gate during these conditions to avoid the unnecessary loss of water supplies (as was done in October and November 2013). The assumption in the BDCP model to maintain the gate in the open position causes it to overstate the amount of Delta outflow.

Figure 24. Delta Outflow Change (Alt 4-ELT minus NAA-ELT)



CVP/SWP Reservoir Carryover Storage

CVP/SWP reservoir operating criteria in the Alt4-ELT scenario differs from the NAA-ELT scenario. This difference is primarily driven by changes in both CVP and SWP San Luis Reservoir target storage. CalSim II balances upstream Sacramento Basin CVP and SWP reservoirs with storage in San Luis Reservoir by setting target storage levels in San Luis Reservoir. CalSim II will release water from upstream reservoirs to meet target levels in San Luis Reservoir and the target storage will be met as long as there is capacity to convey water and water is available in upstream reservoirs. In Alt 4 the San Luis Reservoir target storage is set very high in the spring and early summer months, and then reduced in August and set to San Luis Reservoir dead pool from September through December. This change in San Luis target storage relative to the NAA causes upstream reservoirs to be drawn down from June through August and then recuperate storage relative to the NAA by cutting releases in September; Alt 4 upstream storage then remains close to the NAA during fall months. These operational criteria cause changes in upstream cold water pool management and affect several resource areas. Figure 25, Figure 26, Figure 27, and Figure 28 contain exceedance charts for carryover storage and average monthly changes in storage by Sacramento Valley Water Year Type for North of Delta CVP and SWP reservoirs.

San Luis Reservoir Operations

In addition to changes in upstream storage conditions, changes in San Luis Reservoir target storage cause San Luis Reservoir storage to reach dead pool in many years with subsequent SOD delivery shortages. Although some

delivery shortages are due to California Aqueduct capacity constraints, the largest annual delivery shortages are a result of inappropriately low target storage levels. Average annual Table A shortages due to artificially low San Luis reservoir storage levels increased from 3 TAF in the NAA-ELT scenario to 35 TAF in the Alt4-ELT scenario. (Shortages due only to a lack of South of Delta conveyance capacity were not included in these averages.) Such shortages occurred in 2% of simulated years in the NAA-ELT scenario and 23% of years in the Alt4-ELT scenario. In addition to the inability to satisfy Table A allocations, low storage levels cause loss of SWP contractors' Article 56 water stored in San Luis Reservoir. Average annual Article 56 shortages were 43 TAF in the Alt4-ELT scenario because of low San Luis storage and 5 TAF in the NAA-ELT scenario. Low San Luis storage causes Article 56 shortages in 27% of simulated years in the Alt4-ELT scenario as compared to 5% of simulated years in the NAA-ELT. Another consequence of low storage levels in San Luis Reservoir is a shift in water supply benefits from Article 21 to Table A. As seen in Figure 29 and Figure 30 San Luis Reservoir storage fills more regularly in the Alt 4-ELT scenario, but is exercised to a lower point more often.

Figure 25. Trinity Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type





Figure 26. Shasta Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type





Figure 27. Oroville Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type




Figure 28. Folsom Reservoir Carryover Storage and Average Monthly Changes (Alt 4-ELT minus NAA-ELT) in Storage by Water Year Type




Figure 29. Federal Share of San Luis Reservoir (Alt 4-ELT and NAA-ELT)





Figure 30. State Share of San Luis Reservoir (Alt 4-ELT and NAA-ELT)



CVP Water Supply

The changes in water supply to CVP customers, based on customer type and water year type is shown in Table 3. Alt 4-ELT shows an average increase of approximately 109,000 AF of delivery accruing to CVP customers with CVP SOD agricultural contractors receiving most of the benefit. Changes in Sacramento River Settlement contract deliveries are not an anticipated benefit of the BDCP, increases in these deliveries in Alt 4-ELT relative to the NAA-ELT are due to the shortages in the NAA-ELT from climate change that are reduced in Alt 4-ELT. Although the BDCP modeling demonstrates minor benefits to NOD CVP service contractors, this increase is not an anticipated benefit of the BDCP.

Consistent with modeling for the NAA-ELT Scenario, San Joaquin River Exchange Contractors receive full deliveries in accordance with contract provisions. Figure 31 compares CVP Service Contract delivery of Alt 4-ELT to the NAA-ELT Scenario. Increases in delivery generally occur in below and above normal years.

Table 3. CVP Delivery Summary (Alt 4-ELT and NAA-ELT)



NAA-ELT (1,000 AF)

	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmnt	CVP NOD Total	CVP SOD Total
All Years	187	796	852	201	112	86	271	1846	2321	2215
W	309	1364	875	236	134	90	281	1856	2491	2837
AN	246	908	802	214	110	83	257	1716	2258	2246
BN	146	596	875	198	108	92	281	1899	2335	2044
D	95	440	864	175	100	90	277	1890	2250	1864
C	29	152	741	140	79	64	223	1674	1908	1376

Difference: Alt4-ELT minus NAA-ELT (1,000 AF)

	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmnt	CVP NOD Total	CVP SOD Total
All Years	8	90	0	4	4	1	0	3	15	94
W	1	68	0	1	3	2	1	-2	1	72
AN	14	199	0	3	12	1	0	-1	17	211
BN	17	153	0	5	4	0	0	0	22	158
D	10	48	0	5	2	1	-1	-1	15	49
C	3	6	0	5	2	-1	2	26	33	12

Figure 31. CVP Service Contract Deliveries (Alt 4-ELT and NAA-ELT)



SWP Water Supply


Similar in nature, but larger in magnitude are changes in SWP deliveries. Figure 32 and Table 4 illustrate the benefits of Alt 4-ELT in comparison to the NAA-ELT Scenario. These studies show an increase in average annual SWP SOD deliveries of approximately 408,000 AF, but a reduction in critical year deliveries of approximately 177,000 AF. There is an overall reduction in Article 56 deliveries. Typically in modeling and in actual SWP operations, increases in Table A correspond with increases in Article 56. The reason that Article 56 deliveries decrease overall is that insufficient quantities of water are carried over in San Luis and Article 56 contractors are subsequently shorted. SWP delivery increase is slightly less than increases in Banks export because there is increased wheeling for the Cross Valley Canal contractors with BDCP.

Table 4. SWP Delivery Summary (Alt 4-ELT and NAA-ELT)

NAA-ELT (1,000 AF)				
	Table A	Art. 21	Art. 56	Total
All Years	2425	52	90	2567
W	3112	79	112	3303
AN	2467	34	57	2559
BN	2515	48	109	2673
D	2033	43	88	2165
C	1172	28	47	1246

Difference: Alt4-ELT minus NAA ELT (1,000 AF)				
	Table A	Art. 21	Art. 56	Total
All Years	339	75	-6	408
W	587	159	5	751
AN	728	99	-24	803
BN	525	44	2	571
D	-120	19	-10	-111
C	-146	-19	-12	-177

Figure 32. SWP Contract Deliveries (Alt 4-ELT and NAA-ELT)



Freemont Weir Modifications and Yolo Bypass Inundation

A component of the BDCP Alternative 4 is a modification to the Freemont Weir to allow water to flow into the Yolo Bypass when the Sacramento River is at lower flow than is currently needed. Currently, the Sacramento River does not flow over the Freemont Weir until flow reaches about 56,000 cfs. With the proposed modification Sacramento River flow may enter the Yolo Bypass at much lower flow levels. Figure 33 and Figure 34 contains charts that compare Freemont Weir flow into the Yolo Bypass to Sacramento River flow at the weir, Figure 33 show this relationship for the NAA-ELT and Figure 34 shows this same relationship for Alt 4-ELT.

Although CalSim II is a monthly time-step model, it contains an algorithm that estimates daily flow. Therefore, average monthly flows displayed in Figure 33 shows Sacramento River entering the Yolo Bypass at flow levels less than 56,000 cfs, when this occurs water is flowing over the Freemont Weir for a portion of the month. There is a 100 cfs minimum flow diversion from the Sacramento River diversion to the Yolo Bypass from September through June in Alt 4-ELT.

Figure 35 and Figure 36 contains average monthly flow from the Sacramento River over the Freemont Weir to the Yolo Bypass for the NAA-ELT (Figure 35), average monthly difference between Alt 4-ELT and NAA-ELT (Figure 36), and the annual average difference between Alt 4-ELT and NAA-ELT (Figure 37). In the NAA-ELT scenario flow over the Freemont Weir generally occurs in wet years, this flow is extended to all year types and all months except July and August in Alt 4-ELT. The average annual increase in flow is about 430 TAF.

Figure 33. Freemont Weir vs. Sacramento River NAA-ELT




Figure 34. Fremont Weir vs. Sacramento River Alt 4-ELT




Figure 35. Average Fremont Weir Flow to Bypass by Water Year Type NAA-ELT




Figure 36. Average Fremont Weir Flow to Bypass by Water Year Alt 4 ELT minus NAA-ELT






Figure 37. Annual Change in Fremont Weir Flow to Bypass Alt 4-ELT minus NAA-ELT



Sacramento River Temperature

Figure 38 contains exceedance probability plots of Sacramento River temperature at Bend Bridge for the NAA-ELT and Alt 4-ELT. For the months of April through July modeling shows few changes in upper Sacramento River water temperature. The Alt 4-ELT scenario shows temperature increases in August relative to the NAA-ELT. In about 75% of years modeling shows about 0.5°F increase in Alt 4-ELT relative to the NAA-ELT. The temperature models will meet inputted target temperatures until Shasta Lake cold water is depleted, this typically occurs in September. This is the likely reason temperature increases in modeling tend to occur in September.

Figure 38. Sacramento River Temperature at Bend Bridge NAA-ELT and Alt 4-ELT



Conclusions regarding CalSim II modeling of BDCP Alternative 4

BDCP's "High Outflow Scenario" is not sufficiently defined for analysis.

The High Outflow Scenario (HOS) requires additional water (Delta outflow) during certain periods in the spring. The BDCP Model places most of the responsibility for meeting this new additional outflow requirement on the SWP. However, the SWP may not actually be responsible for meeting this new additional outflow requirement. This is because the COA, as it is currently being implemented, would require a water allocation adjustment that would keep the SWP whole. Where one project (CVP or SWP) releases water to meet a regulatory requirement, the COA requires a water balancing to ensure the burden does not fall inappropriately among the projects. The BDCP Model is misleading because it fails to adjust project operations, as required by the COA, to "pay back" the water "debt" to the SWP due to these additional Delta outflow requirements. Unless there is a significant revision to COA, the BDCP Model overstates the impacts of increased Delta outflow on the SWP and understates the effects on the CVP.

Furthermore, after consulting with DWR and Reclamation project operators and managers, the Reviewers conclude that there is no apparent source of CVP or SWP water to satisfy both the increased Delta outflow requirements and pay back the COA "debt" to the SWP without substantially depleting upstream water storage. It appears, through recent public discussions regarding the HOS, that BDCP anticipates additional water to satisfy the increased Delta outflow requirement and to prevent the depletion of cold water pools will be acquired through water transfers from upstream water users. However, this approach is unrealistic because during most of the spring, when BDCP proposes that Delta outflow be increased, agricultural water users are not typically irrigating. This means that there is not sufficient transfer water available to meet the increased Delta outflow requirements without releasing stored water from the reservoirs. Releasing stored water to meet the increased Delta outflow requirements could potentially impact salmonids on the Sacramento and American River systems

Simulated operation of BDCP's dual conveyance, coordinating proposed North Delta diversion facilities with existing south Delta diversion facilities, is inconsistent with the project description.

The Draft BDCP and associated Draft EIR/EIS specify criteria for how much flow can be diverted by the new North Delta Diversion (NDD) facilities and specify when to preferentially use either the NDD facilities or the existing South Delta Diversion (SDD) facilities. However, the BDCP Model contains an artificial constraint that prevents the NDD facilities from taking water as described in the BDCP project description. In addition to affecting diversions from the NDD, this artificial constraint contains errors that affect the NAA operation. This error has been fixed by DWR and Reclamation in more recent versions of the model; however, the error remains in the BDCP Model. Additionally, the BDCP Model does not reflect the Summer operations of the SDD that are described in the Draft EIR/EIS as a feature of the BDCP project intended to prevent water quality degradation in the south Delta. The net effect of these two errors is that the BDCP Model significantly underestimates the amount of water diverted from the NDD facilities and overestimates the amount of water diverted from the SDD.

BDCP modeling contains numerous coding and data issues that skew the analysis and conflict with actual real-time operational objectives and constraints

logic is coded into the CalSim II model to simulate how DWR and Reclamation would operate the system under circumstances for which there are no regulatory or other definitive rules. This attempt to specify (i.e., code) the logic sequence and relative weighting so that a computer can simulate "expert judgment" of the human operators is a critical element to the CalSim II model. In the BDCP Model, some of the operational criteria for water supply allocations and existing facilities such as the Delta Cross Channel and San Luis Reservoir are inconsistent with real-world conditions.

3 INDEPENDENT MODELING

The Independent Modeling effort originally stemmed from reviews of BDCP Model during which the Reviewers discovered that the BDCP Model did not provide adequate information to determine the effects of the BDCP. There are three basic reasons why the Reviewers cannot assess how the BDCP will affect water operations: 1) NAAs do not depict reasonable operations under the described climate change assumptions, 2) operating criteria used in the BDCP Alternative 4 result in unrealistic operations, and 3) updates to CalSim II since the BDCP modeling was performed almost 4 years ago will likely alter model results to a sufficient degree that conclusions based on the BDCP modeling will likely be different than those disclosed in the Draft EIR/EIS. Given that it is not possible to determine how BDCP may affect CVP and SWP operations or water system flows and conditions with the BDCP model, Independent Modeling was performed to assess potential effects due to the BDCP.

To revise the models, the Reviewers consulted with operators at DWR and Reclamation to improve the representation of operational assumptions. Additionally, the Reviewers consulted with modelers at DWR and Reclamation to share findings, to strategize on the proper way to incorporate the guidance received from the operators, and to present revised models to DWR and Reclamation for their review. This collaborative and iterative process differed considerably from a standard consulting contract where the work product is not shared beyond the client-consultant until a final version is complete. To the contrary, consultations with agency experts were conducted early and repeatedly to ensure the revisions would reflect reasonable operations and to provide an independent review.

The first phase of this Independent Modeling effort was development of an updated without project baseline (similar to the NAA but with current, improved assumptions). The Independent Modeling does not incorporate climate change because the climate change hydrological assumptions developed by BDCP cause unrealistic operation of the system absent commensurate changes to operating criteria.

After the baseline was complete and reviewed, the second phase of this effort incorporated the facilities and operations for the BDCP described as Alternative 4 H3 in the Draft EIR/EIS, and otherwise known as the Evaluated Starting Operations (ESO) scenarios in the BDCP. During this phase, the issues that were identified during the Reviewers' initial review were corrected along with corrections made to resolve additional issues that were revealed as improvements were incorporated. Finally, results of the Independent Modeling and potential effects of the BDCP on water supply and instream flows are discussed.

3.1 Changes to CalSim II Assumptions

Revisions approved by DWR and Reclamation for the 2013 baseline

DWR and Reclamation provided CalSim II models used for the 2013 SWP Delivery Reliability Report (DRR) for use in this independent modeling effort. Changes to these models were made for this effort and provided to DWR and Reclamation, many of these changes have since been incorporated into DWR and Reclamation's model and others are under review.

The CalSim II model used for the 2013 SWP DRR is located on DWR's web site at:

<http://baydeltaoffice.water.ca.gov/modeling/hydrology/CalSim/Downloads/CalSimDownloads/CalSim-IIStudies/SWPReliability2013/index.cfm>. Documentation for this model is described in the report titled: "Draft Technical Addendum to the State Water Project Delivery Reliability Report 2013", also located on DWR's web site at: <http://baydeltaoffice.water.ca.gov/swpreliability/>. Key modeling assumptions used for this effort are consistent with the 2013 SWP DRR and are listed in Table 4 of the Technical Addendum.

CalSim II is continuously being worked on and improved to better represent CVP and SWP operations and fix known problems. The Technical Addendum to the 2013 SWP DRR contains a description of updates and fixes that have occurred since modeling was performed for the BDCP Draft EIRS. Among these changes and fixes are key items that directly affect operation of facilities proposed in BDCP Alternative 4, these items are described on page 4 of 2013 SWP DRR Technical Addendum. Key among these fixes is the correction of the Sacramento River flow requirement for Delta inflow that causes NDD bypass to exceed requirements.

A key component of this independent modeling effort is the development of an acceptable CalSim II Future No-Action (FNA) model scenario. The purpose for developing the FNA Scenario is to produce an operational scenario that is realistic enough to understand how changes proposed in the BDCP will affect operations. The process of developing the FNA involved research and development of CalSim II model updates and several meetings with Reclamation and DWR modeling and operations staff. In addition to changes in the FNA Scenario, CalSim II was updated to better reflect operation of the NDD, CVP and SWP reservoir balancing, DCC gate operations, and CVP/SWP water supply allocations.

Additional Revisions to CalSim II Assumptions

The following changes were made to the 2013 SWP DRR version of CalSim II for this effort:

- San Joaquin River Basin
 - Turned off San Joaquin River Restoration Program (SJRRP) The SJRRP will cause a change to San Joaquin River inflow to the Delta not associated with the BDCP. To avoid adding complications to the identification of BDCP export benefits the SJRRP was not incorporated into the analysis.
 - Tuolumne: updated time-series, lookup tables, and wresl code
 - Turned off SJRA (VAMP) releases
- Updated Folsom flood diagram
- Rice decomposition demand diversions from Feather River
- Dynamic EBMUD diversion at Freeport
- SEP1933 correction to daily disaggregated minimum flow requirements at Wilkins Slough and Red Bluff
- CVP M&I demands are updated to reflect assumptions used by Reclamation
- Yuba Accord Transfer
- Los Vaqueros Reservoir capacity

San Joaquin River Basin

BDCP modeling depicted San Joaquin River Basin operations generally consistent with the actions, programs and protocols in place at the time of NOI/NOP issuance. Some of those conditions are now not representative of current development or operations. With the exception of the assumption for the SJRRP, the independent modeling has revised San Joaquin River Basin operations to reflect more contemporary LOD assumptions. In future level analyses the independent modeling similarly assumes no SJRRP, but only for analysis simplicity concerning BDCP export benefits. Additional analyses may be useful in understanding effects of collectively implementing the BDCP and SJRRP.

The San Joaquin River Basin (SJR) is depicted for current conditions, primarily affected by the operations of the Stanislaus, Tuolumne, Merced, and upper San Joaquin River tributaries. The upper San Joaquin River is currently modeled in a "pre-" SJRRP condition, consistent with the 2005 CalSim version. The FNA Scenario also models the upper San Joaquin River without the SJRRP. The SJR depicts near-term operations including SWRCB D-1641 flow and water quality requirements at Vernalis met when hydrologically possible with New Melones operations. The Vernalis flow objective is set by SWRCB D-1641 February-June base flow requirements. There are no pulse flow requirements during April and May, and there is no acquired flow such as VAMP or Merced water. D1641 Vernalis water quality requirements are set at 950/650 EC to provide an operational buffer for the requirement. New

Melones is operated to provide RPA Appendix 2E flows as fishery releases and maintains the DO objective in the Stanislaus River through a flow surrogate. Stanislaus River water right holders (OID/SSJID) are provided deliveries up to land use requirements as occasionally limited due to operation agreement (formula). CVP Stanislaus River contractors are provided allocations up to 155 TAF per year in accordance with proposed 3-level plan based on the New Melones Index (NMI). For modeling purposes during the worst drought sequence periods, CVP Stanislaus River contractors and OID/SSJID diversions are additionally cut to maintain New Melones Reservoir storage no lower than 80 TAF. Merced River is operated for Federal Energy Regulatory Commission (FERC) and Davis-Grunsky requirements, and provides October flows as a condition of Merced ID's water rights. The Tuolumne River is operated to its current FERC requirements and current water use needs and has been updated to recent conditions.

Folsom Lake Flood Control Diagram

During wetter years, inflow to Folsom Lake is sufficient to keep the reservoir full while satisfying all demands downstream. When this condition occurs in actual operations, operators increase releases during summer months to maintain higher instream flows and prevent large releases in the fall to evacuate Folsom to satisfy flood control storage requirements. To prevent the model from keeping the reservoir full going into the fall months and then making large releases to comply with flood control storage requirements, the maximum allowable storage during summer months is ramped from full storage in June to flood control levels in the fall. Although this is a common modeling tool, Folsom storage level for the end of September was set too low in the SWP DRR model causing unnecessary releases and resulting in Folsom storage being lower than desired. An adjustment was made to achieve a more realistic summer drawdown for Folsom.

Feather River Rice Decomposition Demand

Demand for rice straw decomposition (decomp) water from Thermalito Afterbay was added to the model and updated to reflect historical diversion from Thermalito in the October through January period. There are approximately 110,000 acres of rice in the Feather River Service Area irrigated primarily with water diverted from Thermalito Afterbay. Although decomp water demand for the Sacramento River has been included in CalSim II since about 2006, this demand has been absent for the Feather River. Inclusion of decomp demand in the version of CalSim II used for this effort results in an increase in Feather River diversion in fall months of about 160,000 AF.

Dynamic EBMUD Diversion at Freeport

Previously the EBMUD operation was pre-determined and input to CalSim II as a time-series. The below criteria was implemented in CalSim II model code to achieve a dynamic representation of EBMUD diversion from the Sacramento River at Freeport.

The EBMUD water service contract is unique. EBMUD's total system storage must be forecast to be below 500 TAF on October 1 for CVP water to be available under the EBMUD contract. In years when this occurs, we assume EBMUD will take the minimum of 65 TAF of CVP water or their CVP allocation (133 TAF * CVP M&I allocations) in the first and second years of any multi-year period when CVP water is available under their contract. In the third year, EBMUD would be limited to 35 TAF of CVP water (assuming diversion of 65 TAF in years one and two) because their contract limits cumulative CVP water over three consecutive years to 165 TAF. The 65, 65, 35 TAF annual diversion pattern then repeats if water is available for four or more consecutive years under the EBMUD contract.

Wilkins Slough Minimum Flow Requirement

Wilkins Slough minimum flow requirements, C129_MIF, includes an adjustment for daily operations based on work with the Sacramento River Daily Operations Model (SRDOM). The flow adjustment for daily flows for September 1933 in the state variable input file appeared unreasonable in the previous model. The flow

adjustment in this month was approximately 1,860 cfs and was requiring release of approximately 100 TAF out of Shasta. Review of the entire time-series of daily adjustments showed the adjustment in this month was an order of magnitude greater than in any other September in the simulation period. The year 1933 is a critically dry year, and the third of four consecutive Shasta Critical years. Historical precipitation records from the consumptive use models for the Sacramento Valley, which serves as the basis of much of the CalSim hydrology, were reviewed to ensure there was no unusual precipitation in this month that may create variations in daily flows. It was determined that this daily adjustment is in error. The daily adjustment for this time-step was set to 10 cfs, the value for August 1933.

CVP M&I Demands

Reclamation M&I contractor demands upstream from the Delta have not been adequately represented in CalSim II until Reclamation updated the model in 2012. A more accurate representation of CVP M&I demands, developed in 2012, was incorporated into the model for this effort.

Yuba Accord Water Transfer

In CalSim, Yuba Accord Water Transfers are limited to releases from New Bullards Bar Reservoir. The release is picked up at Banks Pumping Plant or stored in Oroville and Shasta for later release. The additional release from New Bullards Bar is represented in CalSim through an inflow arc. The subsequent refill of New Bullards Bar is represented in CalSim through a diversion arc. In CalSim II, refill is assumed to always occur in the winter following the transfer. However, in the SWP DRR model, there were a few years in which no transfers took place but refill still occurred in the following winter. This was fixed in the updated baseline by capping refill to the previous summer's total transfer.

Los Vaqueros Reservoir

Expansion of Los Vaqueros Reservoir was completed in 2012. Storage capacity was increased from 103 TAF to 160 TAF. In DWR's BDCP studies, Los Vaqueros capacity was set to 103 TAF. The independent modeling increases Los Vaqueros capacity to 160 TAF.

3.2 Changes to BDCP Operations

San Luis Reservoir Rule-Curve Logic Change

In the independent modeling, San Luis rule-curve logic was refined for both SWP and CVP operations. San Luis rule-curve is used to maintain an appropriate balance between San Luis Reservoir storage and North of Delta reservoirs. The key considerations in formulating rule-curve are as follows:

- Ensure that sufficient water is available in San Luis Reservoir to meet contract allocations when exports alone are insufficient due to various operational constraints.
- Minimize San Luis Reservoir carryover storage to low point criteria (both CVP and SWP) and Article 56 carryover (only SWP). The basic premise is to maintain Reservoir San Luis storage no higher than necessary to satisfy south of Delta obligations to avoid excessive drawdown of upstream storage.

In DWR's BDCP studies, there were significant shortages in Table A and Article 56 deliveries because of an improper balance between upstream and San Luis Reservoir storage. The updated SWP rule-curve logic reduces these shortages but does not eliminate them. Also, the updated CVP rule-curve logic allows for higher CVP allocations without increasing risk of shorting SOD contractors.

Upstream Storage Release to Fill San Luis Reservoir Above Needed Supply

In the BDCP NAA and the independent modeling FNA, the model has a priority to release excess stored water that will likely be released for flood control purposes from Shasta and Folsom storage for export at Jones Pumping Plant to storage in San Luis Reservoir in the late summer and early fall months. The purpose was to get a head start on filling San Luis Reservoir for the coming water year if there is a high likelihood of Shasta or Folsom spilling. This was an assumed CVP/SWP adaptation to the export reductions in the winter and spring months due to the salmon and smelt biological opinions. However, with the NDD facility in Alt 4, winter and spring export restrictions impact CVP exports much less and there is no longer a reason to impose this risk on upstream storage. As such, the weights, or prioritizations, of storage in Shasta and Folsom were raised so that excess water would not be released specifically to increase CVP San Luis storage Reservoir above rule-curve. This was changed in Alt 4 and not the FNA to better reflect how the system may operate under these different conditions.

Delivery allocation adjustment for CVP SOD Ag service and M&I contractors

CVP SOD Ag service and M&I allocations are limited by both systemwide water supply (storage plus inflow forecasts) and Delta export constraints; whereas similar CVP NOD allocations are dependent solely on water supply. This frequently results in SOD water service contractors receiving a lower contract year allocation than NOD water service contractors, especially under the Biological Opinion export restrictions. However, with the NDD facility operations as proposed under Alt 4 H3, the CVP can largely bypass these Delta export restrictions, and the export capacity constraint on CVP SOD allocations was determined to be overly conservative. Therefore, the export capacity component of CVP SOD allocations was removed in the BDCP Alternative and both SOD and NOD CVP allocations are equal and based only on water supply.

Folsom/Shasta Balance

CVP operations were refined in the BDCP Alternative to provide maximum water supply benefits to CVP contractors while protecting Trinity, Shasta, and Folsom carryover storage in the drier years. As a whole, this was accomplished with refinements to allocation logic and San Luis rule-curve. However, in initial study runs, an imbalance between Folsom and Shasta was created; while there was a total positive impact to upstream storage in dry years, there was a negative impact to Folsom storage. This was resolved by inserting Folsom protections in the Shasta-Folsom balancing logic. With these protections, the positive carryover impacts were distributed to Trinity, Shasta, and Folsom.

North Delta Diversion Bypass Criteria

The daily disaggregation method for implementing NDD bypass criteria as implemented in DWR's BDCP model was left mostly intact for the updated BDCP studies. However, there were modifications to properly fit the bypass criteria implementation within the latest CalSim operations formulation. Modifications are as follows:

1. No NDD operations occur in cycles 6 through 9 so that Delta operations and constraints can be fully assessed without NDD interference.
2. Cycles 10 and 11 (Daily 1 and Daily 2 respectively) were added to determine NDD operations given various operational constraints including the NDD bypass criteria.
3. From July to October, bypass criteria are based on monthly average operations (no daily disaggregation). Given the controlled reservoir releases at this time and the constant bypass criteria (5,000 cfs from July to September and 7,000 cfs in October), this was determined to be a reasonable assumption. This also simplified coordination of DCC gate operations with NDD in October which will be discussed later.
4. When warranted by conditions in cycle Daily 1 (cycle 10), the bypass criteria in May and June were allowed to be modeled on a monthly average basis in cycle Daily 2 (cycle 11). This allowed a reduction in the number of cycles necessary to determine the fully allowed diversion under the bypass criteria when

the Delta was in balance and additional upstream releases were made to support diversions from the North Delta.

Delta Cross Channel Gate Reoperation in October

The BDCP Alt 4 results in significantly more October surplus Delta outflow as compared to the baseline. The cause of this Delta surplus at a time when the Delta is frequently in balance is a combination of proposed through-Delta export constraints (OMR flow criteria and no through-Delta exports during the San Joaquin River October pulse period), Rio Vista flow requirements, and DCC gate operations. In DWR's BDCP studies, it was assumed that the DCC gates would be open for the entire month of October thereby requiring much higher Sacramento River flows at Hood in order to meet the Rio Vista flow requirement than if the DCC gates were closed. Whereas in the independent BDCP modeling it was assumed that the DCC gates were closed for a number of days during the month such that the 7,000 cfs NDD bypass criteria would be sufficient to meet the weekly average Rio Vista flow requirements. The intent was to minimize surplus Delta outflow while meeting Delta salinity standards and maintaining enough bypass flow to use the NDD facility for SOD exports. This is an approximation of what is likely to occur in real-time operations under similar circumstances. Further gate closures may be possible as salinity standards allow if operators decide to preserve upstream storage at the expense of NDD diversions. This type of operation would require additional model refinements.

Wilkins Slough minimum flow requirement


Currently in CalSim II, relaxation of the Wilkins Slough minimum flow requirement is tied to CVP NOD Ag Service Contractor allocations. This does not reflect actual operations criteria where relaxation of the flow requirement is dependent solely on storage conditions at Shasta. From the comparative analysis perspective of our CalSim planning studies, this introduces a potential problem: changes in CVP NOD Ag Service allocations can result in unrealistic changes in required flow at Wilkins Slough, and such changes in Wilkins Slough required flow can result in unrealistic impacts to Shasta storage. To bypass this problem, we assumed that the required flow at Wilkins Slough in the alternative was equal to the baseline.

3.3 Alternative 4 Modeling results

Analysis for this effort was focused on BDCP Alt 4 with existing spring and fall X2 requirements, which corresponds to "Alternative 4 H3" in the Decisions Tree. This modeling is performed without climate change, and includes refined operating criteria for the NDD, CVP and SWP reservoirs, DCC gate closures, and water supply allocations. This modeling includes all Project features that are included in Alt 4 in the BDCP modeling. The Project features are displayed in Figure 39 and summarized as:

- NDD capacity of 9,000 cfs
- Bypass flow requirements for operation of the NDD
- Additional positive OMR flow requirements
- No San Joaquin River I/E ratio
- Changed location for Emmatton water quality standard in SWRCB D-1641
- Additional Sacramento River flow requirement at Rio Vista
- 25,000 acres of additional tidal habitat
- Notched Fremont Weir

Figure 39. Alt 4 Features




For the purpose of describing results of the independent modeling, the revised Future No Action model scenario is labeled “FNA” and the revised BDCP Alt 4 scenario is labeled “Alt 4”.

CVP/SWP Delta Exports

Average annual exports at Jones pumping plant are about 170 TAF higher in the Alt 4 Scenario compared to the FNA scenario, as seen in Figure 40. Increases generally occur from January through June when Old & Middle River (OMR) criteria limit use of Jones PP in the FNA Scenario. Decreases occur in July in drier year types because the increased ability to convey water in spring months reduces the need to convey water stored in upstream reservoirs in July. Reductions in Jones export in October are partially a function of increases in OMR flow requirements.

Figure 40. Change in Delta Exports at Jones Alt 4 minus FNA



Similar to export at Jones, Banks exports are generally higher from January through June because use of NDD allows pumping that is not possible in the FNA Scenario, as seen in Figure 41. Banks exports are increased during summer months of wetter year types. This is due to earlier wheeling for CVP Cross Valley Canal contractors (without NDD Banks capacity isn’t typically available until Fall in wet years) and wheeling of CVP water through Joint Point of Diversion (JPOD). CVP export at Banks is displayed in Figure 42. In wetter years, upstream CVP reservoirs hold more water than can be exported at Jones pumping plant, this water is typically spilled in the FNA scenario. CVP water stored in upstream reservoirs can be released in July, August, and September to support south of Delta beneficial use of water through use of JPOD in Alt 4.

Figure 41. Change in Delta Exports at Banks Alt 4 minus FNA





Figure 42. Change in CVP Delta Exports at Banks Alt 4 minus FNA



Changes in total, South Delta, and North Delta exports are displayed in Figure 43. Average annual increase in total Delta exports is about 750 TAF, the increases primarily occur in wetter year types with lesser increases in dryer years. South Delta export decreases about 2.53 MAF in Alt 4 relative to the FNA. Export through the NDD is 3.28 MAF in Alt 4, about 58% of total exports are diverted from the North Delta.

Figure 43. Change in Conveyance Source of Exports (Alt 4 minus FNA)







Figure 44 contains modeling results from Alt 4 for July, August, and September that plot NDD against SDD (Through Delta Export). There are many occasions when SDD are 3,000 cfs, which is due to criteria specifying that SDD during this time period need to be at least 3,000 cfs prior to diverting at the NDD facility. Although there are about six occurrences in July and three in August where the model did not satisfy this criterion, this issue has not yet been addressed for this modeling effort.


Figure 44. Alt 4 North Delta Diversion Versus South Delta Diversion for July, August, and September



Delta Outflow

Figure 45 contains annual and monthly average changes in Delta outflow by water year type, average annual Delta outflow decreases about 760 TAF in the Alt 4 Scenario relative to the FNA Scenario. The decrease is primarily due to increases in Delta exports, which are about 750 TAF on average. Larger decreases generally occur in January through May when exports are constrained in the FNA Scenario and in the Alt 4 Scenario the NDD can be used to export water. Delta outflow increases in October due to the combination of additional OMR flow requirements that restrict exports and Sacramento River flow requirements at Rio Vista. The additional surplus Delta outflow in Alt 4 was minimized through coordination of the Delta Cross Channel Gate operations with the Rio Vista flow requirements and North Delta Diversion bypass requirements.

Figure 45. Changes in Delta Outflow (Alt 4 minus FNA)



Carryover Storage

Figure 46, Figure 47, Figure 48, and Figure 49 contain exceedance charts for carryover storage and average monthly changes in storage by Sacramento Valley Water Year Type for CVP and SWP upstream reservoirs. CVP/SWP reservoirs tend to be higher in the Alt 4 Scenario relative to the FNA on an average basis. Generally, CVP/SWP reservoirs are higher in storage in dryer year types and can be lower in wetter year types.

Ability to convey stored water from upstream CVP/SWP reservoirs to south of Delta water users is increased in Alt 4 relative to the FNA. Therefore, when upstream reservoirs are at higher storage levels more water is released to satisfy south of Delta water demands. This is the primary reason Shasta, Oroville, and Folsom tend to be lower during summer months of wetter years.

Currently, and in the FNA Scenario, the CVP and SWP ability to export natural flow, or unstored water, is constrained due to SWRCB D-1641 and requirements in the salmon and smelt biological opinions. With the greater ability to export unstored water during winter and spring months in the Alt 4 Scenario, compared to FNA, there is generally a reduced reliance on stored water to satisfy south of Delta demands. The increased ability to export unstored water allows the CVP and SWP to maintain higher storage levels in upstream reservoirs during dryer year types while still maintaining south of Delta deliveries. Carryover storage in the Alt 4 Scenario tends to be higher than the FNA Scenario at lower storage levels, and Alt 4 storage is lower in wetter years when storage levels are higher. In the wettest of years there is enough water in the system that both scenarios have similar carryover storage conditions.

Figure 46. Trinity Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type




Figure 47. Shasta Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type




Figure 48. Oroville Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type







Figure 49. Folsom Reservoir Carryover Storage and Average Monthly Changes in Storage by Water Year Type



San Luis Reservoir Operations

As seen in Figure 50 and Figure 51 below, both CVP and SWP portions of San Luis Reservoir storage fills more regularly in the Alt 4 Scenario. As described earlier in this document, low point in both CVP and SWP San Luis Reservoir is managed to satisfy water supply obligations the model makes during the spring of each year. This is a complex balance involving available upstream storage, available conveyance capacity, delivery allocations, and south of Delta demand patterns. Considering this myriad of variables, there are times when low point in San Luis Reservoir is higher in the Alt 4 Scenario than the FNA Scenario and times when the opposite is true.

Figure 50. SWP San Luis





Figure 51. CVP San Luis



CVP Water Supply

As can be seen in Table 5, the independent modeling analysis shows an average increase of approximately 262 TAF of delivery accruing to CVP customers in the Alt 4 Scenario relative to the FNA Scenario, mostly occurring to CVP SOD agricultural customers. Delivery increases are greater in wetter year types with lower increases in dryer years. Figure 52 contains exceedance probability plots for CVP water service contractor deliveries and allocations. Changes in Sacramento River Settlement and San Joaquin River Exchange Contractor deliveries do not occur in the modeling analysis and are not an anticipated benefit of the BDCP. Although modeling demonstrates minor changes to NOD CVP service contractors, this increase is not an anticipated benefit of the BDCP.

Table 5. CVP Delivery Summary


Average Annual CVP deliveries by Water Year Type FNA (1,000 AF)

	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmt	CVP NOD Total	CVP SOD Total
All Years	220	882	852	214	116	87	273	1860	2380	2306
W	327	1408	875	241	135	90	280	1856	2515	2881
AN	284	999	802	221	113	83	258	1716	2304	2341
BN	206	725	875	217	111	90	281	1900	2413	2176
D	138	569	864	195	106	88	277	1896	2317	2000
C	43	202	741	157	87	71	234	1754	2025	1447

Difference: Alt 4 minus FNA (1,000 AF)

	AG NOD	AG SOD	Exchange	M&I NOD	M&I SOD	Refuge NOD	Refuge SOD	Sac. Setlmt	CVP NOD Total	CVP SOD Total
All Years	2	251	0	0	9	0	0	0	2	260
W	0	305	0	0	10	0	1	0	0	316
AN	10	492	0	1	14	1	0	-2	10	504
BN	12	354	0	5	16	0	-2	1	19	366
D	-10	67	0	-4	4	1	0	-1	-15	72
C	2	27	0	2	2	1	0	-1	4	29

Figure 52. CVP Water Supply Delivery and Allocation



SWP Water Supply


The independent analysis shows an increase in average annual SWP SOD deliveries of approximately 450 TAF, but a reduction in critical year deliveries of approximately 116 TAF. Annual average Article 21 deliveries increase by about 100 TAF and Article 56 increases by about 18 TAF. Figure 53 contains exceedance probability plots for SWP SOD deliveries for the FNA and Alt 4 Scenarios, each of these plots show increases in higher delivery years. Although Table A deliveries increase in 65% of years, there are decreases in 35% of the dryer years (see Table 6).

Table 6. SWP Delivery Summary

FNA				
	Table A	Art. 21	Art. 56	Total
All Years	2426	64	90	2580
W	3221	98	121	3440
AN	2628	86	81	2794
BN	2527	82	95	2703
D	1809	14	70	1893
C	1105	17	48	1170

Difference Alt4 minus FNA				
	Table A	Art. 21	Art. 56	Total
All Years	328	102	18	448
W	525	220	14	759
AN	636	98	-1	733
BN	565	50	31	647
D	-63	41	27	6
C	-124	-8	16	-116

Figure 53. SWP Delivery for Alt 4 and FNA



4 COMPARING INDEPENDENT MODELING AND BDCP MODELING


The independent modeling effort originally stemmed from reviews of DWR’s BDCP modeling where we found that BDCP modeling does not provide adequate information to determine how BDCP may affect the system. Based on the premise that the independent modeling portrays a more accurate characterization of how the CVP/SWP system may operate under Alt 4, this comparison is meant to demonstrate the differences between results of a more accurate analysis and BDCP modeling. Differences in results between these modeling efforts are believed to provide insight regarding how effects that BDCP will have on the actual CVP/SWP system differ from modeling used to support the Draft EIRS.

Although thorough comparisons of modeling were performed, only key differences are illustrated for the purpose of this comparison.

Delta Exports


Figure 54 displays changes in the Delta exports for the BDCP modeling (Alt 4-ELT minus NAA-ELT) and for the independent modeling (Alt 4 minus FNA). Independent modeling analysis shows about 200 TAF greater increases in exports than the BDCP modeling. A large component of this difference is due to fixes of known modeling issues, as described in the 2013 SWP DRR. This difference is also attributable to more realistic reservoir operations, more efficient DCC gate operations, changes in water supply allocation logic, and more efficient operation of the NDD.

Figure 54. Result Difference: Delta Exports




Average annual SDD are decreased by about 460 TAF in the independent analysis compared to the BDCP modeling. A large component of this difference is due to fixes of known modeling issues, as described in the 2013 SWP DRR. These fixes prevent “artificial” bypass criteria from limiting use of the NDD beyond what is intended in the BDCP project description. This difference is also attributable to more efficient DCC gate operations and more efficient operation of the NDD. Figure 55 demonstrates the difference between the BDCP and independent analysis, where SDD decrease by 2.07 MAF in the BDCP analysis and by 2.53 MAF in the independent analysis.

Figure 55. Result Difference: South Delta Diversion



Use of the NDD is 680 TAF greater in the independent analysis relative to the BDCP analysis. A large component of this difference is due to fixes of known modeling issues, as described in the 2013 SWP DRR. These fixes prevent “artificial” bypass criteria from limiting use of the NDD beyond what is described in the BDCP project description. Figure 56 compares average annual NDD in the BDCP to the independent analysis.


Figure 56. Result Difference: North Delta Diversion



Delta Outflow

Total Delta exports in the independent analysis are about 200 TAF greater than the BDCP modeling analysis with a corresponding decrease in Delta outflow in the independent analysis of about 200 TAF. Figure 57 compares average annual changes in Delta outflow between the independent analysis and BDCP modeling, BDCP modeling shows a decrease of about 567 TAF and the independent analysis shows a decrease of about 759 TAF.

Figure 57. Result Difference: Net Delta Outflow



Reservoir Storage

Reservoir operating rules for Alt4 in the BDCP EIRS modeling are changed relative to the NAA. In the BDCP EIRS modeling of Alt 4 rules are set to releases more water from upstream reservoirs to San Luis Reservoir from late winter through July, reduce releases in August, and then minimize releases to drive San Luis Reservoir to dead pool from September through December. This operation is inconsistent with actual operations and causes reductions in upstream storage from May through August. Figure 58 and Figure 59 contain exceedance probability plots of carryover storage and average monthly changes in storage by water year type for Shasta and Folsom for the BDCP and independent modeling. Although carryover storage for Alt 4 and the NAA is similar in the BDCP EIRS modeling, there is drawdown from June through August that may cause impacts to cold water pool management. In the independent modeling upstream reservoirs are drawn down more in years when storage is available while dryer year storage is maintained at higher levels, this is illustrated in the carryover plots for Shasta and Folsom in Figure 58 and Figure 59.

Figure 58. Result Difference: Shasta Storage






Figure 59. Result Difference: Folsom Storage



North Delta Diversions

Independent modeling shows greater NDD during July and other months because the BDCP EIRS modeling includes artificially high Sacramento River bypass flow requirements. Figure 60 contains exceedance probability plots of Sacramento River required bypass, Sacramento River bypass flow, NDD, and excess Sacramento River flow to the Delta. As can be seen in Figure 60, bypass flow is always above the bypass requirement. The BDCP version of CalSim sets a requirement for Sacramento River inflow to the Delta that the independent modeling does not need in order to satisfy Delta requirements, therefore the NDD is higher in the independent modeling.

Figure 60. NDD, and Sacramento River Flow



Delta flows below the NDD facility


Figure 61 contains monthly exceedance probability plots for Sacramento River below the NDD for the following scenarios: 1) BDCP NAA-ELT, 2) BDCP Alt 4-ELT, 3) independent modeling FNA, and 4) independent modeling Alt 4. The most significant differences in flow changes occur in October, July, August, and September. Changes in Sacramento River flow entering the Delta are a key indicator of changes in interior Delta flows, water levels, and water quality.

For the month of October the independent modeling shows flow below the NDD to be about 2,000 cfs lower than the BDCP modeling. The difference in this month is largely due to reoperation (closure) of the cross channel gate to lessen the amount of Sacramento River flow at Hood necessary to maintain Rio Vista flow requirements downstream of the cross channel gates.

The most substantial difference between the BDCP and independent modeling occurs in July and August. The differences in these two months are primarily attributable to model fixes that have occurred since the BDCP modeling was performed. In the independent modeling, July flows are reduced on average about 7,500 cfs while BDCP shows a reduction of about 3,300 cfs. In the independent modeling August flows are reduced on average about 5,900 cfs while BDCP shows a reduction of about 3,900 cfs.

In the independent modeling September flows are reduced by about 6,100 cfs while BDCP modeling shows a reduction of about 5,300 cfs. The independent modeling shows Sacramento River flow entering the Delta to be about 7,000 cfs 50% of the time, BDCP modeling show Sacramento River flow is about 8,000 cfs 50% of the time.


Figure 61. Sacramento River below Hood



Sacramento River water entering the Central Delta

In CalSim, flow through the DCC gate and Georgianna Slough from the Sacramento River into the Central Delta is assumed to be linearly dependent on flow at Hood. There are two linear relationships; one is used when the DCC gates are closed, and the other is used when the DCC gates are open. The 2013 SWP Delivery Reliability Report CalSim II modeling, and therefore our independent modeling, used different linear flow relationships than BDCP. The BDCP and 2013 DRR (and independent) flow relationships for both the open and closed gate conditions are compared in Figure 62. When Sacramento River flow at Hood is in the range from 5,000 cfs to 10,000 cfs the balance between Hood flow, required flow at Rio Vista, and DCC gate operation can affect upstream reservoir operations, SOD exports, and Delta outflow. As shown in Figure 62, given the same flow at Hood and DCC gates closed, the independent analysis will show slightly higher flow into the Central Delta (12% to 17% difference for the Hood flows in the 5,000 cfs to 10,000 cfs range). With DCC gates open the same flow at Hood, the independent analysis will show lower flow into the Central Delta (-15% to -25% difference for the Hood 5,000 cfs to 10,000 cfs range). Figure 63 and Figure 64 show the differences through the DCC and combined flow through the DCC and Georgianna Slough.

Figure 62. Flow through Delta Cross Channel and Georgianna Slough versus Sacramento River Flow at Hood



In addition to the differences in flow equations for portion of Sacramento River entering the interior Delta through the DCC and Georgianna Slough, the DCC gate operations were modified for the month of October. In the independent modeling, the DCC gate is operated to balance the amount of Sacramento River flow needed to meet flow standards at Rio Vista on the Sacramento River and flow needed to meet western Delta water quality. This changed operation often results in DCC gate closures for about 15 days during the month of October. The reduction in flow through the DCC during October can be seen in Figure 64.

Figure 63. Cross Channel Flow





Figure 64. Flow through Delta Cross Channel and Georgiana Slough



Conclusions regarding BDCP effects

Based on the Independent Modeling, the amount of water exported (diverted from the Delta) may be approximately 200 thousand acre-feet (TAF) per year higher than the amount disclosed in the Draft EIR/S. This total represents

- approximately 40 TAF/yr more water diverted and delivered to the SWP south of Delta contractors, and
- approximately 160 TAF/yr more water diverted and delivered to the CVP south of Delta contractors.

The BDCP Model estimates that, under the NAA ELT (without the BDCP), total average annual exports for CVP and SWP combined are estimated to be 4.73 million acre feet (MAF) and in the Independent Modeling FNA combined exports are 5.61 MAF. The BDCP Model indicates an increase in exports of approximately 540 TAF and the Independent Modeling shows an increase of approximately 750 TAF in Alt 4.

The Independent Modeling suggests that Delta outflow would decrease by approximately 200 TAF/yr compared to the amount indicated in the Draft EIR/S.

- This lesser amount of Delta outflow has the potential to cause greater water quality and supply impacts for in-Delta beneficial uses and additional adverse effects on species. To determine the potential effects of the reduced amount of outflow, additional modeling is needed using tools such as DSM2.

The BDCP Model does not accurately reflect the location of the diversions that the SWP and CVP will make from the Delta.

- When the errors in the model are corrected, it reveals that the North Delta intakes could divert approximately 680 TAF/yr more than what was disclosed in the BDCP Draft EIR/S, and
- the amount of water diverted at the existing South Delta facilities would be approximately 460 TAF/yr less than what is projected in the BDCP Draft EIR/S.

Hydrologic modeling of BDCP alternatives using CalSim II has not been refined enough to understand how BDCP may affect CVP and SWP operations and changes in Delta flow dynamics. Better defined operating criteria for project alternatives is needed along with adequate modeling rules to analyze how BDCP may affect water operations. Without a clear understanding of how BDCP may change operations, affects analysis based on this modeling may not produce reliable results and should be revised as improved modeling is developed.