

Exhibit CAW-030JJ

July 13, 2004

Victoria Whitney, Division Chief
Division of Water Rights
State Water Resources Control Board
1001 I Street
Sacramento, CA 95812

Re: SWRCB Order No. WR 95-10, as amended 3rd Quarterly Report for Water Year
October 1, 2003 through September 30, 2004

Dear Sir:

Pursuant to Condition 13 of the subject order as amended, this letter is California American's *third quarterly* report for the water year October 1, 2003 through September 30, 2004.

Condition 13, as amended, requires:

13. Starting with the first full month following adoption of this Order, California American shall file quarterly with the Chief, Division of Water Rights:
- (a) Reports of the monthly total amounts being: (1) pumped from wells; and (2) diverted from the Carmel River. Reports of the total monthly amount being pumped from wells shall show the amount being pumped from each well and shall show the location of each well.
 - (b) Reports of the progress being made in complying with the schedule submitted to comply with Condition 11,
 - (c) Reports of the progress being made in complying with Conditions 4, 5, 6, 7, 8, and 9, and
 - (d) California American shall submit a quarterly water budget thirty days after approval by the District."

RESPONSES

- I. Condition 13(a). The total amounts being: (1) pumped from wells and (2) diverted from the Carmel River by month for each well location for the third Quarter of the Water Year, October 1' 2003 through June 30, 2004 is shown on Attachment 1. Attachment 2 shows the monthly production data through June 2004 from specific sub-units in the Carmel Valley via Carmel Valley wells. Carmel Valley Filter Plant produced 0.0AF from San Clemente Reservoir, with

191.7 AF from Aquifers No. 1 and No. 2; Water West 40.7AF; Aquifer No. 3 – 2291.5 AF; Aquifer No. 4 – 727.9 AF. Total production through the month of March 2004 was 8384.9AF. Net production, which includes ASR diversions, was 8215.3 AF. See Table. Los Padres releases are shown on Attachment 4

II. Condition 13(b). Condition No. 11 has been satisfied because The Monterey Peninsula Water Management District has continued to implement the Mitigation Program for the District's Water Allocation Program Environmental Impact Report.

III. Condition 13(c). Progress being made in complying with Conditions 4, 5, 6, 7, 8, and 9 is as follows:

- CONDITION NO. 4

California American shall maximize production from the Seaside aquifer for the purpose of serving existing connections, honoring existing commitments (allocations), and to reduce diversions from the Carmel River to the greatest practicable extent during periods of low flow. California American shall minimize diversions from the Seaside aquifer whenever flow in the Carmel River exceeds 40 cfs at the Highway 1 Bridge from November 1 to April 30. The long-term yield of the basin shall be maintained by using the practical rate of withdrawal method.

Response No. 4:

Attachment 3 shows Net System Production Water Year to Date.

- CONDITION NO. 5

To the maximum extent feasible without inducing seawater intrusion or unreasonably affecting the operation of other wells, California American shall satisfy the water demands of its customers by extracting water from its most downstream wells.

Response No. 5:

In July 2003, US Fish & Wildlife Service and California American executed the Second Amended Agreement for protection of the California Red-legged frog for California American's Carmel Valley operations (Agreement with USFWS). The Agreement states that, provided that California American complies with its terms and the Biological Opinion, incidental take of California Red-legged frog shall be exempt from the take prohibitions of Section 9 of the Endangered Species Act. One of the requirements of the Agreement with USFWS is to pump from downstream wells to the extent practicable, which is consistent with Condition No. 5.

On March 21, 2002, the State Board adopted WRO 2002-0002, which modified California American's operation of the upper Carmel Valley wells in a manner that is consistent with Condition No. 5.

• CONDITION NO. 6

California American shall conduct a study of the feasibility benefits and estimated costs of supplying water to the areas now served by the Carmel Valley Filter Plant from its more nearby wells downstream of the plant and shall also conduct a similar study of utilizing the existing or expanded Begonia Treatment Plant or other facilities located further downstream in lieu of the Carmel Valley Filter Plant. This latter study shall be completed within one year of the date of entry of this Order. Petitioner shall have an opportunity to comment on the scope of the study. The study shall be under the direction of the Division of Water Rights, and will be conducted by a consultant approved by the Division. If the Chief, Division of Water Rights, finds that the measures identified in the studies are feasible, California American must implement supplying water from the facilities identified by the Division according to a schedule approved by Division of Water Rights. The objective of supplying water from the wells is to maintain surface flow in the stream as far downstream as possible by releasing water from San Clemente Dam for maintenance of fish habitat. The results of the study and recommendations shall be provided to the District and DF&G for comment.

Response No. 6:

In accordance with the terms of Order Nos. 95-10 and 98-04, two studies were done. The first was completed and submitted to the State Board in September 1996. The Reconnaissance-Level Feasibility Study of the Operational Reconfiguration of Lower Carmel Valley Wells was completed and was submitted to the State Board on June 21, 1999. In April 2001, the State Board issued Order 2001-04 in which it found these studies adequate. The order was protested and after a hearing, the State Board adopted WRO 2002-0002 on March 21, 2002 and confirmed the studies were adequate.

In past years, operation of the upper Carmel Valley wells has been limited during the months of May through December. WRO 2002-0002 changed the trigger for reducing operation of upper Carmel Valley Wells from specific months to "low flow periods", defined as times when stream flow in the Carmel River at the Don Juan Bridge (RM 10.8) gage is less than 20 cfs for five consecutive days. WRO 2002-0002 also required installation of certain facilities to facilitate usage of the more downstream aquifers and to determine whether the Carmel Valley Village Zone water supply needs can be supplied from the Begonia Zone.

In compliance with WRO 2002-0002, California American installed a pump that delivers water from the Begonia zone to the Carmel Valley Village in March 2002. During low flow periods, California American has ceased diversions from San Clemente Reservoir, is

pumping from Russell Wells 2 and 4, and has limited its pumping of the other upper Carmel Valley Wells to a schedule of maintenance pumping, which is set forth below. The maintenance-pumping schedule and the complete cessation of diversions from San Clemente Reservoir are being monitored and evaluated by NMFS and California American and are subject to adjustment in order to satisfy the needs of California American's customers and the needs of the steelhead. Since the pump has been installed, production from the Russell Wells has been limited to 0.5 cfs during low flow periods and the majority of Carmel Valley Village demand has been met by pumping water from the Begonia zone, which includes water well production facilities in AQ 3, AQ 4 and the Seaside Groundwater Basin. This mode of operation is being evaluated to address the adequacy of California American's distribution system and the new pump to accommodate the water supply needs of the Carmel Valley Village from the Begonia Zone.

Status of wells during April through June 2004:

Lower Carmel Valley Wells

Rancho Canada – On-line
San Carlos – Emergency Stand-by only (under influence of surface water)
Cypress – On Line
Pearce – On Line
Schulte – On Line
Manor – On line
Begonia #2 – On Line
Berwick #7 – Out of Service until further notice.
Berwick #8 – On Line

Upper Carmel Valley Wells

Panetta 2 – Off Line (run 8hrs/day for 1 to 2 days per month for maintenance)
Panetta 4 – Off Line (run 8hrs/day for 1 to 2 days per month for maintenance)
Garzas 3 – Off Line (run 8hrs/day for 1 to 2 days per month for maintenance)
Garzas 4 – Off Line (run 8hrs/day for 1 to 2 days per month for maintenance)
Los Laureles 5 – Off Line (run 1 to 2 hours once a week for maintenance)
Los Laureles 6 – Off Line (run 1 to 2 hours once a week for maintenance)
Scarlett 8 – Off Line (run 1 to 2 hours once a week for maintenance)
Robles – Off Line (run 1 to 2 hours once a week for maintenance)
Russell 2 – On Line
Russell 4 – On Line

As of June 6, 2004, the low flow period as defined by the Conservation Agreement and Order 2002-02 ended. The upper valley wells remain off line until the end of the low flow period.

- CONDITION NO. 7

California American shall evaluate the feasibility of bypassing early storm runoff at Los Padres and San Clemente Dams to recharge the subterranean stream below San Clemente Dam in order to restore surface water flows in the river at an earlier date. The results of the study and recommendations shall be provided to the District and CDF&G for comment.

- CONDITION NO. 8

California American shall conduct a study of the feasibility, benefits, and costs of modifying critical stream reaches to facilitate the passage of fish. The study shall be designed and carried out in consultation with DF&G and the District. The results of the study and recommendations shall be provided to the district and DF&G for comment.

Response Nos. 7 & 8:

See prior quarterly reports.

California American has proposed an alternate water supply project to meet the Order 95-10 as modified by subsequent orders. After diligent review of the options for technical, political and environmental merit, California American amended its application for a new reservoir on the Carmel River to include the desalination/ASR project originally developed by the CPUC, entitled *Plan B*. Additionally, California American requested that the CPUC be the lead agency for the Company's project, which has been named the Coastal Water Project. The CPUC has agreed to be the lead agency for the environmental work. The Proponents Environmental Assessment (PEA) consultants have selected and have initiated work. California American has signed a letter of intent with the County of Monterey aimed at developing a partnership to build and operate a new desalination facility. California American and the Monterey County Water Resources Agency have kicked off a series of presentations of their approach to the development of a new water supply to replace the Carmel basin diversions. To date, the project team has presented its plan and project status to four city councils. The project team will continue to conduct public meetings for the duration of the PEA/EIR process.

Other items:

In early May 2004 California American identified an excessive use pattern by customers in the Monterey system served from the Carmel Valley. The excess use, driven by low winter rains and a warm spring, took Carmel River Basin diversions from 100 acre feet below budget to nearly a hundred acre feet ahead of plan during May. California American took immediate action to ask the customers to watch their water use through a direct phone call and several direct mailings to over 30,000 customers. California American and their attorneys met with the Chair of the SWRCB and staff to outline the problem and to describe the company's efforts to curb the excess use. California

American also met several times with the CPUC staff and members to explore methods to control the excess use. California American proposed new rate blocks for golf course and public authority irrigation uses and per the CPUC staff direction a moratorium on new connections and expanded uses of water in the Monterey area. The CPUC acted on July 8, 2004 to enact the temporary rate increase. California American will follow with an application for a moratorium following a public meeting. The General Manager of the Monterey Peninsula Water Management District declared a Stage 3 Water Conservation and Rationing Plan for the service area at the end of June.


As of the writing of this report the supply deficit had recovered to 22 acre feet due to cool weather and improved conservation in early July.

The Department of Safety of Dams has directed California American to permanently lower San Clemente Reservoir at all times possible. California American has reduced the elevation of the San Clemente reservoir to the level acceptable to DSOD and has installed a pipeline and floating weir and a pipeline to the existing fish ladder to allow steelhead to migrate down river even though the reservoir is not spilling. California American and DSOD are in discussions to finish the environmental review process on strengthening of the dam. The process will include CEQA and NEPA level evaluations.

Based on preliminary studies on the safe yields on the Seaside Ground Water Basin California American filed a lawsuit against the other pumpers in the aqueduct seeking adjudication of the ground water supplies. The suit has been assigned to a judge and is currently in mediation.

Should your staff have any questions please call me at (831) 646-3214.

Sincerely,



Steven Leonard
Vice-President / Manager
Coastal Division
California American Water

Victoria Whitney, Division Chief
July 13, 2004 Page 7



Enclosures

cc: K. Urquardt
J. Driscoll, Esq.
P. Lyman, Esq.
P. Townsley
D. Stephenson
D. Laredo, Esq.
D. Armanasco
S. Somach, Esq.
D. Berger

CALIFORNIA AMERICAN WATER
 Monterey Division
 UPPER CV WELLS - PRODUCTION
 Water Year 2003-2004

	Russell #2	Russell #4	Robles	Panetta #1	Panetta #2	Garzas #3	Garzas #4	LL #5	LL #6	Total
Oct CF	0	1,094,038	0	0	0	0	0	0	0	1,094,038
1000 G	0	8,184	0	0	0	0	0	0	0	8,184
AF	0.0	25.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.1
Nov CF	0	624,005	0	0	0	0	0	0	0	624,005
1000 G	0	4,688	0	0	0	0	0	0	0	4,688
AF	0.0	14.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	14.3
Dec CF	0	1,135,722	0	0	0	0	0	0	0	1,135,722
1000 G	0	8,496	0	0	0	0	0	0	0	8,496
AF	0.0	26.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	26.1
Jan CF	10,620	1118082	-	0	0	-	-	0	0	1,128,702
1000 G	79	8364	-	-	-	-	-	0	0	8,443
AF	0.2	25.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	25.9
Feb CF	-	1,056,647	-	0	0	-	-	0	0	1,056,647
1000 G	-	7904	-	0	0	-	-	0	0	7,904
AF	0.0	24.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	24.3
Mar CF	2,396,703	6,560	1,533,514	0	0	365,711	576,510	0	0	4,898,998
1000 G	17,929	49	11,471	-	-	2885	4313	0	0	36,647
AF	55.0	0.2	35.2	0.0	0.0	8.9	13.2	0.0	0.0	112.5
Apr CF	1,000,000	1,000,000	1,000,000	0	0	729,338	1,000,000	0	0	7,890,860
1000 G	1,000,000	1,000,000	1,000,000	0	0	5,411	7,850	0	0	59,036
AF	600.0	600.0	600.0	0.0	0.0	16.6	24.1	0.0	0.0	181.1
May CF	1,000,000	1,000,000	1,000,000	0	0	0	0	0	0	1,268,003
1000 G	1,000,000	1,000,000	1,000,000	0	0	0	0	0	0	9,465
AF	600.0	600.0	600.0	0.0	0.0	0.0	0.0	0.0	0.0	26.1
Jun CF	1,000,000	1,000,000	1,000,000	0	0	0	0	0	0	852,618
1000 G	1,000,000	1,000,000	1,000,000	0	0	0	0	0	0	7,201
AF	600.0	600.0	600.0	0.0	0.0	0.0	0.0	0.0	0.0	22.1
Jul CF	0	-	0	0	0	0	0	0	0	-
1000 G	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
AF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Aug CF	0	-	0	0	0	0	0	0	0	-
1000 G	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
AF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sep CF	0	-	0	0	0	0	0	0	0	-
1000 G	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
AF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL CF	7,290,435	5,035,054	4,986,895	-	-	1,109,049	1,625,960	-	-	20,059,393
1000 G	54,536	37,665	37,394	-	-	8,296	12,163	-	-	150,055
AF	167.4	115.6	114.8	0.0	0.0	25.5	37.3	0.0	0.0	460.5

CALIFORNIA AMERICAN WATER
 Monterey Division
 LOWER CV WELLS - PRODUCTION
 Water Year 2003-2004

	Berwick #7	Berwick #8	Begonia	Manor	Schulte	Peano	Cypress	San Carlos	R. Canada	BRP Backwash (c)	L. CV Wells Inru BRP	Scalest #6	Total
Oct CF	0	256,100	2,327,500	273,800	6,519,300	8,637,300	7,071,200	0	12,382,400	(13,860)	37,481,260	0	37,481,260
1000 G	0	1,916	17,411	2,047	48,768	64,611	52,896	0	92,627	(104)	280,379	0	280,379
AF	0.0	5.9	53.4	6.3	149.7	198.3	162.3	0.0	284.3	-0.3	860.5	0.0	860.5
Nov CF	0	38,000	1,234,600	1,300	2,263,100	7,427,400	6,247,100	0	9,008,800	79,538	26,140,762	0	26,140,762
1000 G	0	284	9,235	10	16,929	55,581	46,732	0	67,381	196,141	195,546	0	195,546
AF	0.0	0.9	28.3	0.0	52.0	170.5	143.4	0.0	206.8	601.9	600.1	0.0	600.1
Dec CF	0	20,000	1,062,200	2,900	3,857,300	8,814,500	3,322,800	0	10,852,000	18,936	27,912,764	0	27,912,764
1000 G	0	150	7,946	22	28,855	65,937	24,858	0	81,179	142	208,802	0	208,802
AF	0.0	0.5	24.4	0.1	88.6	202.4	76.3	0.0	249.1	0.4	640.8	0.0	640.8
Jan CF	0	34,500	2,157,700	1,200	6,096,200	9,933,000	7,402,500	0	11,428,600	67,244	36,986,456	-	36,986,456
1000 G	0	258	16,141	9	45,603	74,304	55,375	0	85,482	503	276,678	-	276,678
AF	0.0	0.8	49.5	0.0	138.9	228.0	169.9	0.0	262.4	1.5	849.1	0.0	849.1
Feb CF	0	1,614,900	4,730,400	415,400	6,894,100	8,788,300	6,845,300	-	10,483,300	(6,060)	39,577,760	-	39,577,760
1000 G	0	12,080	35,386	3,107	51,571	65,741	49,710	-	78,421	(45)	296,062	-	296,062
AF	0.0	37.1	108.8	9.5	158.3	201.8	152.6	0.0	240.7	(0.1)	908.6	0.0	908.6
Mar CF	0	2,396,100	5,125,400	639,900	8,504,200	6,025,500	7,188,400	0	11,560,400	72,431	41,367,469	3,970,400	45,337,869
1000 G	0	17,924	38,341	4,787	63,616	45,074	53,773	0	86,478	542	309,450	29,701	339,151
AF	0.0	55.0	117.7	14.7	195.2	138.3	165.0	0.0	265.4	1.7	949.7	91.1	1,040.8
Apr CF	0	634,800	1,818,300	247,800	8,095,300	6,662,400	6,665,300	0	10,529,300	30,739	33,990,861	6,692,200	40,683,061
1000 G	0	4,781	13,113	1,833	61,853	52,280	54,981	0	75,783	290	209,192	50,069	259,261
AF	0.0	13.5	37.0	5.1	165.3	122.1	152.3	0.0	213.3	0.7	853.1	15.5	1,071.7
May CF	0	1,329,300	3,520,900	2,200	14,748,400	13,015,500	10,820,000	0	10,820,000	77,149	42,638,751	12,215,300	54,854,051
1000 G	0	9,716	26,238	2,200	107,840	93,015	86,977	0	87,000	577	319,407	8,076	328,483
AF	0.0	27.6	81.5	0.6	280.3	260.3	237.7	0.0	243.5	1.6	960.2	23.6	1,003.8
Jun CF	0	1,000,000	2,811,000	1,000	8,321,000	6,921,000	6,921,000	0	10,655,000	94,489	30,900,000	10,735,701	41,635,701
1000 G	0	7,500	21,100	7,500	62,500	53,500	53,500	0	77,500	707	264,709	5	304,709
AF	0.0	21.4	61.5	2.1	173.7	154.7	154.7	0.0	107.5	2.2	935.1	6.9	935.1
Jul CF	0	-	-	-	-	-	-	0	-	-	-	-	-
1000 G	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
AF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Aug CF	0	-	-	-	-	-	-	0	-	-	-	-	-
1000 G	0	-	-	-	-	-	-	0	-	-	-	-	-
AF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sep CF	0	-	-	-	-	-	-	0	-	-	-	-	-
1000 G	0	-	-	-	-	-	-	0	-	-	-	-	-
AF	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL CF	-	8,518,700	29,061,300	1,960,900	59,043,100	79,260,500	58,038,500	-	97,426,100	420,616	332,889,484	11,875,900	344,765,384
1000 G	0	63,732	217,394	14,669	441,673	592,910	434,158	0	728,798	3,146	2,490,186	88,838	2,579,024
AF	0.0	195.6	667.2	45.0	1,355.4	1,819.6	1,332.4	0.0	2,236.6	9.7	7,642.1	272.6	7,914.7

CALIFORNIA AMERICAN WATER
Monterey Division
CVFP Daily Production Report
Water Year 2003-2004

Date	Gravity CF	Low Flow CF	Russell #2 CF	Russell #4 CF	To Carmel River	Wells 2 & 4	Diversion (Less Russell)		Backwash		NET DIVERSION TO SYSTEM		CFS	To the River CFS
							CF	AF	CF	AF	CF	AF		
10/03	0	1,180,780	0	1,094,038	0	1,094,038	86,722	2.0	86,722	2.0	0	0.00	0.00	
11/03	0	875,890	0	824,005	0	824,005	51,875	1.2	51,875	1.2	0	0.00	0.00	
12/03	0	1,227,810	0	1,135,722	0	1,135,722	92,098	2.1	92,098	2.1	0	0.00	0.00	
01/04	0	1,238,810	10,620	1,118,082	0	1,128,702	110,108	2.5	110,108	2.5	0	0.00	0.00	
02/04	0	1,145,300	0	1,056,847	0	1,056,847	88,653	2.0	88,653	2.0	0	0.00	0.00	
03/04	0	2,495,620	2,396,703	6,580	0	2,403,283	92,357	2.1	92,357	2.1	0	0.00	0.00	
04/04	0	2,724,490	2,652,492	6,580	0	2,659,072	68,889	1.6	68,889	1.6	0	0.00	0.00	
05/04	0	1,571,800	1,568,025	3,580	0	1,571,605	46,897	1.1	46,897	1.1	0	0.00	0.00	
06/04	0	1,618,030	1,614,812	3,220	0	1,618,032	55,412	1.3	55,412	1.3	0	0.00	0.00	
Total	0	13,017,840	7,230,435	5,035,054	0	12,325,435	682,451	15.9	682,451	15.9	0	0.00	0.00	

CALIFORNIA AMERICAN WATER
 Monterey Division
 S.C. DAM & CARMEL VALLEY WELLS
 Production Water Year (AF)
 2003-04

Date	CVFP San Clemente Dam	Aquifer 1 Russell 2 & 4	Aquifer 2 Robles Los Laureles 5 & 6	Water West Panetta 1 & 2 Garzas 3 & 4	Aquifer 3 Scarlett & Berwick 7 & 8 Begonia/Manor/Schulte Pearce/Cypress/San Carlos	Aquifer 4 Rancho Canada	Total Production	BIRP BW & Seaside Test Inject. (ASR)	Net Production
Oct 2003	0.0	25.1	0.0	0.0	575.8	284.3	885.2	0.3	885.5
Oct 2002	0.0	23.0	0.0	0.0	619.2	200.3	842.5	-1.9	840.6
Nov 2003	0.0	14.3	0.0	0.0	395.1	206.8	616.2	-1.8	614.4
Nov 2002	0.0	22.3	0.0	0.0	489.3	203.6	715.2	-1.9	713.3
Dec 2003	0.0	26.1	0.0	0.0	392.1	249.1	667.3	-0.6	666.7
Dec 2002	0.0	22.8	0.0	0.0	455.9	206.7	685.4	-0.3	685.1
Jan 2004	0.0	25.9	0.0	0.0	538.2	262.4	876.5	-1.5	875.0
Jan 2003	44.3	11.2	11.4	15.2	612.4	210.6	905.1	0.2	905.3
Feb 2004	0.0	24.3	0.0	0.0	667.0	240.7	932.8	-81.0	851.8
Feb 2003	46.1	0.0	82.9	2.3	619.9	116.1	867.4	-28.3	839.1
Mar 2004	0.0	55.2	35.2	22.4	577.1	265.2	1,155.0	-30.4	1,074.6
Mar 2003	55.8	0.0	93.2	0.0	861.4	4.3	1,014.7	-28.5	986.1
Apr 2004	0.0	60.9	79.6	40.7	830.7	241.7	1,253.5	-0.7	1,252.8
Apr 2003	52.7	4.9	88.0	0.0	623.4	292.3	1,061.3	-67.6	993.7
May 2004	0.0	29.1	0.0	0.0	761.8	248.5	1,039.0	-1.8	1,037.2
May 2003	41.7	25.9	88.7	0.0	665.8	306.2	1,128.3	-50.7	1,077.7
Jun 2004	0.0	22.1	0.0	0.0	699.5	237.7	959.4	-2.2	957.2
Jun 2003	0.0	61.9	0.0	0.0	601.6	316.2	979.7	-1.2	978.5
Jul 2004							0.0		0.0
Jul 2003	0.3	25.7	0.0	0.0	743.8	308.1	1,077.9	-2.3	1,075.6
Aug 2004							0.0		0.0
Aug 2003	0.0	26.0	0.0	0.0	794.5	254.0	1,074.5	-0.4	1,074.1
Sep 2004							0.0		0.0
Sep 2003	0.0	23.8	0.0	0.0	664.9	275.8	964.5	-1.6	962.9
Total	0.0	283.0	114.8	62.8	5,687.7	2,236.7	8,384.9	-169.6	8,215.3

California American Water
 Monterey Division
 Net System Production
 Year to Date 2004

Month	San Clemente Dam Surface Water	U. Carmel Valley Wells	L. Carmel Valley Wells	Seaside Wells	Ryan Ranch Wells	Hidden Hills Wells	Bishop Wells	Amber Wells	Chubar Wells	Ralph Lane Wells	ASR (C) Test Well	NET SYSTEM (All Facilities)
01/04 1000 G CF AF	0 0 0.00	1,128,702 8,443 25.91	36,986,456 276,678 849.09	434,600 3,251 9.98	131,919 987 3.03	418,301 3,129 9.60	285,078 2,133 6.54	456,745 3,417 10.49	351,400 2,629 8.07	44,195 331 1.01	0 0 0.00	40,237,396 300,997 923.72
Y-T-D 1000 G CF AF	0 0 0.00	1,128,702 8,443 25.91	36,986,456 276,678 849.09	434,600 3,251 9.98	131,919 987 3.03	418,301 3,129 9.60	285,078 2,133 6.54	456,745 3,417 10.49	351,400 2,629 8.07	44,195 331 1.01	0 0 0.00	40,237,396 300,997 923.72
02/04 1000 G CF AF	0 0 0.00	1,056,647 7,904 24.26	39,577,760 296,062 908.58	0 0 0.00	154,714 1,157 3.55	385,889 2,887 8.86	260,629 1,950 5.96	456,208 3,413 10.47	379,100 2,836 8.70	36,862 276 0.85	3,533,177 26,430 81.11	38,774,762 290,055 890.15
Y-T-D 1000 G CF AF	0 0 0.00	2,185,349 16,348 50.17	76,564,216 572,740 1,757.67	434,600 3,251 9.98	286,633 2,144 6.58	804,300 6,017 18.46	545,707 4,082 12.53	912,953 6,829 20.96	379,100 2,836 8.70	36,862 276 0.85	3,533,177 26,430 81.11	79,012,158 591,052 1,813.87
03/04 1000 G CF AF	0 0 0.00	4,898,968 36,647 112.47	45,337,868 339,151 1,040.81	0 0 0.00	212,210 1,587 4.87	608,101 4,549 13.98	598,508 4,028 12.36	766,753 5,736 17.60	488,900 3,657 11.22	37,310 279 0.86	3,427,034 25,636 78.67	49,461,613 369,969 1,135.48
Y-T-D 1000 G CF AF	0 0 0.00	7,084,347 52,965 162.63	121,902,095 911,891 2,798.49	434,600 3,251 9.98	498,843 3,732 11.45	1,412,401 10,565 32.42	1,084,213 8,110 24.88	1,679,706 12,565 38.56	488,900 3,657 11.22	37,310 279 0.86	6,960,211 52,066 159.78	128,473,771 961,051 2,949.35
04/04 1000 G CF AF	0 0 0.00	1,241,176 8,241 25.59	16,852,766 124,176 380.02	0 0 0.00	706,559 5,354 16.16	2,212,636 16,852 50.8	1,674,642 14,629 43.0	2,961,970 22,934 68.4	586,600 4,409 12.8	42,081 324 0.95	0 0 0.00	61,521,816 460,149 1,412.12
Y-T-D 1000 G CF AF	0 0 0.00	8,325,523 62,206 188.22	183,355,062 1,241,176 3,800.2	434,600 3,251 9.98	706,559 5,354 16.16	2,212,636 16,852 50.8	1,674,642 14,629 43.0	2,961,970 22,934 68.4	586,600 4,409 12.8	42,081 324 0.95	6,960,211 52,066 159.78	188,385,966 1,473,182 4,333.5
05/04 1000 G CF AF	0 0 0.00	1,367,019 9,465 28.59	45,691,759 339,186 1,030.08	0 0 0.00	469,660 3,515 10.78	1,620,695 7,631 22.87	360,605 7,166 21.05	1,566,359 14,823 43.66	734,300 5,493 16.86	60,861 465 1.40	0 0 0.00	74,775,801 539,322 1,716.62
Y-T-D 1000 G CF AF	0 0 0.00	8,692,542 61,671 186.81	129,046,821 1,580,362 4,830.28	434,600 3,251 9.98	1,266,219 9,473 28.07	3,232,699 24,162 74.21	2,835,247 21,209 61.09	4,535,204 33,926 104.11	734,300 5,493 16.86	60,861 465 1.40	6,960,211 52,066 159.78	264,761,467 1,960,654 6,076.69
06/04 1000 G CF AF	0 0 0.00	1,622,616 7,201 22.30	40,793,707 304,709 935.12	0 0 0.00	401,404 3,603 8.21	949,603 7,104 21.94	855,686 7,149 21.94	1,446,390 10,823 33.21	698,800 5,227 16.04	56,205 465 1.34	0 0 0.00	70,925,725 530,561 1,628.23
Y-T-D 1000 G CF AF	0 0 0.00	17,205,628 128,707 384.68	253,230,506 1,984,297 5,813.37	59,666,635 396,968 1,218.24	1,667,618 12,478 38.28	4,162,302 31,286 96.01	3,790,933 28,368 87.03	5,982,654 44,749 137.33	698,800 5,227 16.04	58,205 435 1.34	6,960,211 52,066 159.78	335,687,212 2,511,115 7,706.32

CALIFORNIA AMERICAN WATER
Monterey Division
Los Padres Daily Release (CFS)
Water Year 2003-2004

Date	Oct 03	Nov 03	Dec 03	Jan 04	Feb 04	Mar 04	Apr 04	May 04	Jun 04	Jul 04	Aug 04	Sep 04
1	10.0	7.6	8.2	207.0	22.0	258.0	38.0	20.0	14.0			
2	10.0	7.4	8.1	260.0	47.0	224.0	36.0	19.0	14.0			
3	9.5	7.9	8.1	160.0	92.0	193.0	35.0	19.0	12.0			
4	8.5	7.5	8.1	115.0	95.0	169.0	34.0	18.0	11.0			
5	8.1	7.4	8.0	92.0	84.0	151.0	33.0	17.0	11.0			
6	8.3	7.4	7.9	78.0	73.0	136.0	33.0	17.0	11.0			
7	8.3	7.5	8.1	66.0	64.0	123.0	33.0	17.0	11.0			
8	8.5	7.5	8.1	57.0	58.0	112.0	32.0	17.0	12.0			
9	8.2	7.5	8.3	51.0	54.0	103.0	31.0	17.0	12.0			
10	8.0	7.1	8.4	48.0	50.0	95.0	29.0	17.0	12.0			
11	7.3	7.5	8.5	44.0	47.0	88.0	28.0	18.0	11.0			
12	7.2	7.7	8.6	41.0	44.0	82.0	28.0	18.0	11.0			
13	7.2	7.8	8.6	38.0	42.0	77.0	27.0	17.0	11.0			
14	7.3	7.7	8.7	36.0	40.0	72.0	27.0	16.0	11.0			
15	7.3	7.9	8.7	35.0	38.0	68.0	27.0	16.0	11.0			
16	7.4	8.2	8.8	36.0	43.0	65.0	28.0	15.0	10.0			
17	7.9	7.9	9.0	31.0	48.0	61.0	28.0	15.0	10.0			
18	8.5	7.8	9.1	29.0	267.0	58.0	28.0	15.0	10.0			
19	8.5	7.9	9.2	28.0	185.0	55.0	28.0	16.0	10.0			
20	8.5	8.0	9.0	28.0	146.0	53.0	27.0	16.0	10.0			
21	8.3	8.3	9.0	27.0	125.0	51.0	27.0	16.0	10.0			
22	7.9	8.5	9.1	26.0	115.0	49.0	26.0	16.0	9.8			
23	7.5	8.5	9.0	25.0	102.0	48.0	25.0	16.0	9.3			
24	7.3	8.0	9.1	26.0	95.0	46.0	24.0	15.0	10.0			
25	7.4	7.5	9.4	25.0	653.0	47.0	23.0	15.0	10.0			
26	7.6	7.8	9.4	24.0	797.0	52.0	22.0	14.0	8.4			
27	7.5	8.1	9.6	24.0	549.0	46.0	21.0	14.0	8.4			
28	7.5	8.1	9.6	25.0	381.0	44.0	21.0	14.0	8.5			
29	7.3	8.0	9.2	24.0	304.0	41.0	21.0	14.0	8.6			
30	7.4	8.0	490.0	23.0		40.0	20.0	15.0	8.7			
31	7.5		168.0	23.0		40.0		15.0				
Total	247.7	234.0	993.7	1,752.0	4,660.0	2,747.0	840.0	504.0	316.7	0.0	0.0	0.0