

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL COAST REGION  
895 Aerovista Place, Suite 101  
San Luis Obispo, California**

**DRAFT RESOLUTION NO. R3-2005-0029  
MODIFICATION OF DISCHARGE LIMITS**

**For**

**ORDER No. R3-2004-0153  
WASTE DISCHARGE AND WATER RECYCLING REQUIREMENTS**

**For**

**SAN BENITO COUNTY SERVICES AREA NO. 45  
RANCHO LARIOS  
San Benito County**

The California Regional Water Quality Control Board, Central Coast Region (hereinafter Regional Board) finds that:

The settleable solids effluent limitation presented to the Board in Order No R3-2004-0153 was incorrectly listed at 0.05 mg/L rather than 0.5 ml/L. The draft Order distributed for public comment on September 17, 2004, contained the correct limitation of 0.5 ml/L, but the limitation was incorrectly stated in the Staff Report, reproduced in the proposed Order, and ultimately adopted by the Board on December 3, 2004. Since this limit was unintended, is unnecessarily stringent for this type of discharge (spray disposal), and would be impossible to comply with at this facility, staff recommends that it be changed back to 0.5 ml/L with the adoption of this resolution.

**THEREFORE BE IT RESOLVED:**

1. The settleable solids limit under Specification B.1 of Order No. R3-2004-0153 is 0.5 mL/L, monthly average.
2. Any person affected by this action of the Regional Board may petition the State Water Resources Control Board (State Board) to review the action in accordance with section 13320 of the California Water Code and Title 23, California Code of Regulations, Section 2050. The State Board must receive the petition within 30 days of the date of this Resolution. Copies of the law and regulations applicable to filing petitions will be provided upon request.

I, Roger W. Briggs, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of a Resolution adopted by the California Regional Water Quality Control Board, Central Coast Region, on February 11, 2005.

---

Roger W. Briggs, Executive Officer