

MONITORING AND REPORTING PROGRAM NO. 90-89
 FOR
 WESTSIDE TRANSPORT, INC.
 GILROY, SANTA CLARA COUNTY

Effluent Monitoring

A sampling station shall be established at the treated washwater storage tank where representative effluent samples can be obtained. Samples shall be collected and analyzed according to the following schedule:

<u>Constituent</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Minimum Frequency of Analysis</u>
Average Daily Flow of treated washwater for dust control and landscape irrigation	gallons/day		Daily when there is a discharge
pH	units	Grab	First working day of each month
Total Dissolved Solids (TDS)	mg/l	Grab	" "
Oil and Grease	mg/l	Grab	" "

Water supply Monitoring

Within 30 days after the adoption of this order, the Discharger shall sample and analyze its water supply for TDS and pH. Thereafter, the water supply shall be sampled and analyzed for TDS and pH during the first working day of January of each year.

Implementation

The Discharger shall implement this monitoring program beginning July 14, 1990.

Reporting

In addition to the constituents above which must be monitored and reported, the following must also be reported:


1. The quantity of sludge removed, method of disposal, and the date of cleaning the oil/water separator.
2. The volume of used oil recovered from the oil/water separator, the name of the used oil hauler, and the hauling date of the used oil.

If no sludge or used oil is taken from the facility during the reporting quarter, a statement to that effect must be included in the monitoring report.

Monitoring reports containing information collected during the specified monitoring period shall be submitted in accordance with the following schedule:

<u>Monitoring Period</u>	<u>Report Due</u>
January 1 - March 31	April 30
April 1 - September 30	October 30
October 1 - December 31	January 30

ORDERED BY



Executive Officer

July 13, 1990

Date

AJM/10:90-89.MRP