

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
California Dept. of Corrections	Soledad Correctional Facility WWTP	718412	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	13-Jan-08	Blockage caused an 1800 gallon sewage spill from manhole at Mt. View Road on prison grounds to land. No waterbody was affected.	Contained, cleared blockage, cleaned up.	No further action recommended at this time.		Monterey
CA Dept of Corrections Mens Colony	California Mens Colony CS	727653	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	27-Jan-08	Power failure and generator failure at CA Men's Colony caused 20,000 gallon sewage (sewage diluted with rain water) spill from a manhole to storm drain that feeds Chorro Creek.		Priority because greater than 5,000 gallons. ACL Complaint 08-0026 issued 3/21/08; hearing pending.	ACL	San Luis Obispo
CA State Parks	Big Basin CS	720659	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	27-Jan-08	Tree fell and broke sewer pipe causing a 8400 gallon sewage spill (most of the water coming from the pipe was groundwater from infiltration) at Hihn Hammond Bridge from gravity sewer to E. Waddel Creek.	As of 2/6/2008, crews worked to effect repairs and restore service under emergency contract. BOD samples of discharge were very low.	Facility not in use (3 campers present). No wastewater in discharge. Rainfall and infiltration diluted to low level.	VER	Santa Cruz

Abbreviations:

- Collection System - CS
- Notice of Violation - NOV
- Verbal Action - VER
- Administrative Civil Liability - ACL
- Cleanup and Abatement Order - CAO
- Staff Enforcement Letter - SEL
- Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Carmel Area WWD	Carmel Area Wastewater Dist CS	711204	Water Quality > Sanitary Sewer Overflow/Spill	WDR	5-Jan-08	Flooding and heavy rains at pump station at Monte Verde / 16th caused a 1000 gallon sewage and stormwater spill to Carmel Lagoon.	Wet well was actively pumped via pump truck and transported to gravity portion of collection system. The release was from dry vault pumping which contained an approx 10:1 ratio of storm water to sewage.	Water Board staff contacted County Health and Discharger.	VER	Monterey
Carpinteria SD	Carpinteria SD CS	724610	Water Quality > Sanitary Sewer Overflow/Spill	WDR	26-Jan-08	Rags covering inlet structure to CSD Plant caused 150 gallon sewage spill at 6th Street, manhole 7G-310 to the ground. No waterbody was affected.	Discharger cleared the line and cleaned the area.	No further action recommended at this time.		Santa Barbara
Cuyama Community Services District	Cuyama CSD WWTP	738198	Water Quality > Effluent -> CAT1	NPDES	1-Jan-08	Violation of monthly average and daily maximum bromodichloromethane and dibromochloromethane limits.			NOV	Santa Barbara

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program Date	Description	Corrective Action	Comments	Action	County
Gilroy, City of	Gilroy CS	721769	Water Quality > Sanitary Sewer Overflow/Spill	31-Jan-08	Grease deposition caused a 20 gallon sewage spill at 6900 Church Street from a manhole to asphalt and partial gutter. No waterbody was affected.	None			Santa Clara
Guadalupe, City of	Guadalupe WWTP	730080	Water Quality > Effluent -> CAT1	30-Jan-08	TSS Violation: Average monthly limit is 60 mg/L and the reported value is 64.2 mg/L	No actions taken by discharger.	CAO issued 3/17/08.	CAO	Santa Barbara
Hollister, City of	Hollister Domestic WWTP	736321	Water Quality > Unauthorized Discharge	31-Jan-08	Unauthorized Discharge Violation: diversion of influent to Industrial plant. Bypass of treatment facility is prohibited. Diversion occurred January 1 and 2 and the 22 through 31. Reported value of 17.75MG (0.57 MGD) diverted flow.	None at this time.	continued past sunset date October 15, 2005 given the domestic plant is at capacity. Ongoing diversions of domestic wastewater to the industrial plant will be required until implementation of the L TWMP provides		San Benito

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Mission Hills CSD	Mission Hills La Purisima	730074	Water Quality - > Effluent -> CAT1	WDR	10-Jan-08	Total Nitrogen violation: limit is 15.0 mg/L and reported value is 18.7 mg/L	The discharger has been extending detention time and increased aeration.	No further action recommended at this time.		Santa Barbara
Monterey, City of	Collection WDR - Monterey	719533	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	14-Jan-08	Dirt and debris blockage caused <50 gallon sewage spill near Laurel Yard, (Veteran's Drive at Yard Driveway) from the manhole to storm drain catch basin. No waterbody was affected.	No further action recommended at this time.	Spill contained and cleaned.		Monterey
Monterey, City of	Collection WDR - Monterey	720021	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	11-Jan-08	Fifty gallon sewage leakage at 60 Fisherman's Wharf from Isabella's Restaurant into Monterey Bay.	Monterey County Health Department shut down restaurant until leak fixed.	Leak originated from dishwasher drain.	VER	Monterey
Morro Bay, City of	City of Morro Bay CS	727611	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	15-Jan-08	Lift station failed due to power outage causing unknown amount of sewage spill to culvert leading to Morro Creek.	Discharger contained and cleaned the spill area in accordance with their SSMP. No waterbody was affected.	No further action recommended at this time.		San Luis Obispo

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Morro Bay, City of	City of Morro Bay CS	713976	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	12-Jan-08	Root intrusion caused 30-gallon sewage spill from a clean-out/ backflow valve at 595 North Estero Street into the back yard. No waterbody was affected.	Discharger contained and cleaned the spill area in accordance with their SSMP.	No further action recommended at this time.		San Luis Obispo
Salinas, City of	Collection WDR - Salinas	719539	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	17-Jan-08	Blockage in the City Sanitary Sewer caused a 50 gallon sewage spill at the intersection of E. Laurel Drive and Cooper Avenue from manhole to the nearby curb and gutter. No waterbody was affected.	Crew began cleanup at 9:15pm and ended at 10pm. Crew washed down all affected street surfaces and recovered spilled effluent and wash water with hydro-vacuum truck.	No further action recommended at this time.		Monterey

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
San Juan Bautista, City of	San Juan Bautista CS	727613	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	31-Jan-08	Blockage in main sewer line caused 300 gallon sewage spill at Via Juan Pablo Sr and Via Avenia Perdo through a manhole to a storm drain. An unknown quantity entered catch basin which feeds an unknown creek.	Contained with sandbags and vacuumed up. No waterbody affected.	No further action recommended at this time.		San Benito
San Luis Obispo, City of	San Luis Obispo CS	729716	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	24-Jan-08	Root intrusion blockage caused a 35 gallon sewage spill at 1327 Foothill Blvd. from clean out in planter box. No waterbody affected.	The discharger contained and cleaned the spill.	No further action recommended at this time.		San Luis Obispo
San Luis Obispo, City of	San Luis Obispo CS	718453	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	7-Jan-08	Blockage caused a 200 gallon sewage spill from a manhole at 1048 Roe Avenue to a storm drain into a dry ditch. No waterbody was affected.	The Discharger contained and cleaned the spill area in accordance with their SSMP.	No further action recommended at this time.		San Luis Obispo

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
San Luis Obispo, City of	San Luis Obispo CS	718422	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	13-Jan-08	Release of 1000 gallons of sewage by a private lateral at 1121 Orchid to a dry creek bed to an unknown tributary to an unknown river.	The Discharger contained and cleaned the spill area in accordance with their SSMP.	No further action recommended at this time.		San Luis Obispo
San Luis Obispo, City of	San Luis Obispo CS	718413	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	15-Jan-08	Blocked sewer lateral caused a 1200 gallon sewage spill at 1121 Orcutt/Oceanaire Mobile Home Park to Acacia Creek.	The Discharger contained and cleaned the spill area in accordance with their SSMP.	No further action recommended at this time.	VER	San Luis Obispo
Santa Barbara City PWD	Ei Estero NPDES CS	713102	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	8-Jan-08	Debris blockage caused 100 gallon sewage spill from private sewer lateral cleanup at 1220 Olive St. to the storm drain and Pacific Ocean.	City crew shut off water until property owner could clear the line. City is pursuing enforcement action.	No further action recommended at this time.		Santa Barbara

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Santa Barbara City PWD	El Estero NPDES CS	716324	Water Quality - > Sanitary Sewer	WDR	18-Jan-08	Root intrusion blockage caused a 1500 gallon sewage spill at 909 De La Vina Street from private cleanout to the ground. Approximately 50 gallons saturated into the soil in unlined creek channel to Mission Creek.	Cleared blockage, restored flow, contained spilled material and cleaned up spill area.	No further action needed.		Santa Barbara
Santa Barbara City PWD	El Estero NPDES CS	717160	Water Quality - > Sanitary Sewer	WDR	16-Jan-08	Grease deposition blockage caused a 250 gallon sewage spill from a manhole at 1964 Las Canoas Rd. St. Mary's Seminary to the ground. Approximately 25 gallons spilled to Mission Creek.	Line cleared and spill area cleaned up, increased preventative maintenance in area.	No further action needed.		Santa Barbara

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Santa Barbara City PWD	El Estero NPDES CS	717887	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	23-Jan-08	High rainfall resulted in a 3000 gallon sewage spill from a manhole at Montecito St. at Nopal St. intersection to East Beach and into the Pacific Ocean.	Posted area to warn public, cleaned up spill, and restored flow in sewer line.	No further action needed.	VER	Santa Barbara
Santa Barbara City PWD	El Estero NPDES CS	713103	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	5-Jan-08	Root intrusion of public sewer system at City Parks Property 2200 Blk. Laguna St. caused a 300 gallon sewage spill to the ground. No waterbody was affected.	Discharger cleaned area, inspection line, and restored flow. No waterbody was affected.	No further action recommended at this time.		Santa Barbara
Santa Cruz County	Santa Cruz County CS	720023	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	15-Jan-08	Stoppage caused a 25 gallon sewage spill at Hilton Drive Boulder Creek No. 4 Station - manhole to the ground. No waterbody was affected.	No waterbody affected.	No further action recommended at this time.		Santa Cruz

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Santa Lucia Community Services District	Santa Lucia Csd CS	711995	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	4-Jan-08	Power failure at Arroyo Sequoia Wastewater liftstation caused a 5000 gallon sewage spill with estimated dilution factor of 200:1 to San Clemente Creek.		Priority because 5,000 gallon spill. Enforcement action pending.		Monterey
Scotts Valley, City of	Scotts Valley CS	720093	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	9-Jan-08	Debris blockage caused a 15 gallon sewage spill at 560 Bethany Drive at entrance of Bethany Bible College manhole to the ground. No waterbody was affected.	No waterbody affected.	No further action recommended at this time.		Santa Cruz
Scotts Valley, City of	Scotts Valley CS	727615	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	30-Jan-08	Back up in sewer line caused a 200 gallon sewage spill at 3103 Scotts Valley Drive to a storm drain that feeds to Carbonera Creek that is tributary to the San Lorenzo River.	City sent NOV requiring 30-day response, repair pipe, repair pipe (cause of spill), and post-repair video. Owner responded adequately.	No further action recommended at this time.		Santa Cruz

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VEA
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Scotts Valley, City of	Scotts Valley CS	712742	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	9-Jan-08	Debris blockage at 560 Bethany caused a 15 gallon sewage spill to the ground. No waterbody was affected.	No waterbody affected.	No further action recommended at this time.		Santa Cruz
Seaside County SD	Seaside Co SDCS	731598	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	17-Jan-08	Unknown cause resulted in 200 gallon sewage spill at 600 Olympia Avenue from manhole to the ground. No waterbody was affected.	Spill cleaned up.	No further action recommended at this time.		Monterey
Solvang, City of	Solvang WWTP	730068	Water Quality - > Effluent -> CAT1	WDR	31-Jan-08	Chloride violation: Monthly limit is 150 mg/L. The reported values is 178 mg/L.	No action at this time.	Discharger is developing a salts management plan to address salts issue.		Santa Barbara
South County Regional WW Authority	SCRWA CS	711675	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	4-Jan-08	Rain event flooded streets and sewer manholes causing excessive system inflow at 13865 Monterey Road causing a 31,000 gallon sewage spill into the field. No waterbody was affected.	Great storm caused spill. No waterbody affected.	No further action recommended at this time.		Santa Clara

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
South County Regional WW Authority	SCRWA CS	722482	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	16-Jan-08	Root intrusion caused a 500 gallon sewage spill at Circle Lane @ Oak View Drive from manhole to the ground. No waterbody was affected.	No waterbody affected.	No further action recommended at this time.		Santa Clara
Spawn Mate, Inc.	Arroyo Grande Mushroom Farm	726244	Reporting -> Deficient Report	WDR	25-Jan-08	Failed to submit quarterly report.		Staff enforcement letter sent 01/25/2007.	SEL	San Luis Obispo
Spawn Mate, Inc.	Arroyo Grande Mushroom Farm	726244	Reporting -> Deficient Report	WDR	25-Jan-08	Failed to submit quarterly report.		Staff enforcement letter sent 01/25/2007.	SEL	San Luis Obispo
UC Santa Cruz	UC Santa Cruz CS	729320	Water Quality > Sanitary Sewer Overflow/Spill/	WDR	14-Jan-08	Root intrusion caused a 15 gallon sewage spill at 1156 High Street at Theater Arts Center cleanout to ground. No waterbody was affected.	No water body affected.	No further action recommended at this time.		Santa Cruz

Abbreviations:
 Collection System - CS
 Notice of Violation - NOV
 Verbal Action - VER
 Administrative Civil Liability - ACL
 Cleanup and Abatement Order - CAO
 Staff Enforcement Letter - SEL
 Waste Discharge Requirements - WDR

Enforcement Report 5-9-08

Agency	Facility	ID	Type	Program	Date	Description	Corrective Action	Comments	Action	County
Watsonville City of	Watsonville CS	721095	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	30-Jan-08	Rag blockage caused 100 gallon sewage spill from manhole at Via Serra and La Joya Streets to storm drain system through drain inlet at intersection. No waterbody was affected.	No waterbody affected.	No further action recommended at this time.		Santa Cruz
Watsonville City of	Watsonville CS	718065	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	24-Jan-08	Root intrusion caused a 200 gallon sewage spill at 29 Nona Avenue from both a city sewer manhole and a private lateral safety relief valve to a drainage ditch that flows into the Siruve Slough.	Little adverse effect due to substantial stormwater flow.	No further action recommended at this time.		Santa Cruz
Watsonville City of	Watsonville CS	711956	Water Quality - > Sanitary Sewer Overflow/Spill/	WDR	5-Jan-08	A very large storm combined with high tide and storm surge caused a 500 gallon sewage spill at Sewer Pump Station #1 Pajaro Dunes to the Watsonville Slough.	No adverse effect due to stormwater flow.	No further action recommended at this time.		Santa Cruz

Abbreviations:

- Collection System - CS
- Notice of Violation - NOV
- Verbal Action - VER
- Administrative Civil Liability - ACL
- Cleanup and Abatement Order - CAO
- Staff Enforcement Letter - SEL
- Waste Discharge Requirements - WDR