

**From:** "Silva, Nicole E. x4584" <SilvaNE@co.monterey.ca.us>  
**To:** "Sorrel Marks" <Smarks@waterboards.ca.gov>  
**Date:** 4/10/2008 10:17:59 AM  
**Subject:** RE: Central Coast Basin Plan Revisions

Hello Sorrel,

I was asked to notify you of a concern with the Basin Plan Revisions, Chapter 4, VIII.D.2.a 14) Onsite wastewater systems shall not be located in areas subject to inundation from a 25-year flood.

Data is limited on 25-year flood plains. Monterey County requests that the prohibition refer to the 50-year flood plain, which FEMA maps have identified. The concern is the lack of existing data will require site specific flood analysis for most projects. Please contact me if you have questions or would like further comment.

Thank You,

Nicole Silva

Senior EHS

(831) 755-4584

silvane@co.monterey.ca.us

Physical Address:

855 East Laurel Drive, Building H

Salinas, CA 93906

Mailing Address:

1270 Natividad Road, Rm B301

Salinas, CA 93906

-----Original Message-----

From: Sorrel Marks [mailto:Smarks@waterboards.ca.gov]

Sent: Tuesday, March 18, 2008 4:04 PM