

Central Valley Regional Water Quality Control Board

30 September 2016

Fred Kenney
Roseville Golfland, Ltd
1893 Taylor Road
Roseville, CA 95661

CERTIFIED MAIL
91 7199 9991 7035 8421 0864

NOTICE OF APPLICABILITY

**WATER QUALITY ORDER 2003-0003-DWQ
STATEWIDE WASTE DISCHARGE REQUIREMENTS FOR DISCHARGES TO LAND WITH
A LOW THREAT TO WATER QUALITY
ROSEVILLE GOLFLAND LTD,
GOLFLAND SUNSPASH
PLACER COUNTY**

On 20 September 2016, Roseville Golfland Ltd. submitted a Notice of Intent (NOI) to obtain coverage under Water Quality Order 2003-0003-DWQ, *Statewide General Waste Discharge Requirements for Discharges to Land with a Low Threat to Water Quality* (hereafter General Order) for discharges of wastewater to land at the above-referenced site. The submittal contains all the information required to evaluate applicability of the General Order; therefore, the NOI is considered complete. The facility has not been previously regulated. Based on the information provided in the NOI, the discharge meets the conditions of the General Order. The discharge is hereby covered under State Water Resources Control Board General Order 2003-0003-DWQ-0154. Please include this number on all correspondence related to this discharge.

PROJECT LOCATION

Golfland Sunsplash is a water slide and miniature golf park located at 1893 Taylor Road in Placer County, just east of Interstate 80. Antelope Creek is approximately 300 feet west of the facility, across Highway 80, and Secret Ravine is approximately 500 feet east, across Taylor Road.

The Water Quality Control Plan for the Sacramento River and San Joaquin River Basins, Fourth Edition, revised October 2011 (hereafter Basin Plan), designates beneficial uses, establishes water quality objectives, contains implementation plans and policies for protecting waters of the basin, and incorporates by reference plans and policies adopted by the State Water Resources Control Board. Pursuant to §13263(a) of the California Water Code (CWC), waste discharge requirements must implement the Basin Plan.

PROJECT DESCRIPTION

The miniature golf portion of the facility is open year around, while the water slides are open seasonally for approximately 100 days per year, generally from mid-May to mid-September. The facility discharges a mixture of approximately 3,600 gallons per day of chlorinated public pool water and potable water (used to wash down the decks) intermittently during the operating

season. The water flows into drains located throughout the facility, is captured in a sump, and then pumped to three discharge areas. During construction of the facility, three small areas on site were left unpaved, filled with gravel and sand, and are now used for wastewater infiltration into shallow soils. Wastewater is contained in the three infiltration areas, does not leave the facility, and does not pose a threat to the two nearby creeks located west and east of the facility.

According to GeoTracker, groundwater is approximately 10 to 20 feet below ground surface. The discharge from the facility is likely reaching groundwater; however, due to the level of chlorination in the wastewater, the discharge is not expected to significantly degrade groundwater quality.

FACILITY-SPECIFIC REQUIREMENTS

The General Order and this Notice of Applicability regulates the discharge of water to land from Golfland Sunsplash located in Placer County.

1. Discharge at a location or in a manner different from that described in the Notice of Intent or this Notice of Applicability is prohibited.
2. The Discharger shall submit the required annual fee (as specified in the annual billing issued by the State Water Resources Control Board) until the Notice of Applicability is officially terminated.
3. Failure to abide by the conditions of the General Order and this letter authorizing applicability could result in enforcement actions, as authorized by provisions of the California Water Code.

DOCUMENT SUBMITTALS

Based on Table 2 in the Monitoring and Reporting Program for the General Order, wastewater monitoring is not required for facilities discharging wastewater from commercial and public swimming pools. Therefore, because the discharge from Golfland Sunsplash consists of chlorinated pool water and potable water, there are no monitoring requirements for the discharge.

Now that the NOA has been issued, the Board's Compliance and Enforcement section will take over management of your case. Guy Childs is your new point of contact for any questions about the Order. In addition, all monitoring and technical reports should be submitted to him. The enclosed transmittal sheet shall be included with each monitoring report. If you find it necessary to make a change to your permitted operations, Guy will direct you to the appropriate Permitting staff. You may contact Guy at (916) 464-4648 or at gchilds@waterboards.ca.gov


PAMELA C. CREEDON For
Executive Officer

Enclosures: Water Quality Order No. 2003-0003-DWQ

cc: Ralph Echols, Placer County Department of Environmental Health, Auburn