



---

**Central Valley Regional Water Quality Control Board**

20 July 2018

Alan Maio  
Cemex Construction Materials Pacific, LLC.  
2365 Iron Point Road, Suite 120  
Folsom, CA 95630

CERTIFIED MAIL  
91 7199 9991 7035 8364 7432

**NOTICE OF APPLICABILITY (NOA) AMENDMENT; GENERAL WASTE DISCHARGE REQUIREMENTS ORDER R5-2016-0076 FOR LIMITED THREAT DISCHARGES TO SURFACE WATER; CEMEX CONSTRUCTION MATERIALS PACIFIC, LLC., PATTERSON SAND AND GRAVEL FACILITY DEWATERING PROJECT, PLACER COUNTY**

The Cemex Construction Materials Pacific, LLC. (Discharger), Patterson Sand and Gravel Facility Dewatering Project was issued a Notice of Applicability (NOA) on 2 July 2018 for coverage under the General Order for Limited Threat Discharges to Surface Water (Limited Threat General Order), and was assigned Limited Threat General Order number R5-2016-0076-045. On 6 July 2018 the Discharger requested an amendment of the NOA. The requested amendment is hereby approved and NOA R5-2016-0076-045 is amended as described below. Please attach this document to the original NOA.

**AMENDMENT:**

The NOA for coverage under the Limited Threat General Order specified an effluent flow limitation of 1.5 million gallons per day on page 2. Upon receiving the Notice of Applicability, the Discharger notified the San Joaquin Delta Permitting Unit of the Central Valley Regional Water Quality Control Board that the flow limit in the NOA was based on the projected average daily discharge flow rather than the projected maximum daily discharge flow provided in the Discharger's Notice of Intent. The Discharger requested the effluent flow limit be revised based on the projected maximum daily discharge flow.

Effective immediately, the NOA is amended as shown in underline/strikeout format below to change the effluent flow limitation on page 2 of the NOA from 1.5 million gallons per day to 2.9 million gallons per day.

**EFFLUENT LIMITATIONS**

Effluent limitations are specified in Section V. Effluent Limitations and Discharge Specifications of the Limited Threat General Order. Based on the information provided in the NOI, effluent limitations are only required for flow and pH identified, below:

1. **Flow.** The total flow discharged shall not exceed ~~1.5~~2.9 million gallons per day.

Any person aggrieved by this action of the Central Valley Water Board may petition the State Water Board to review the action in accordance with California Water Code section 13320 and California Code of Regulations, title 23, sections 2050 and following. The State Water Board must receive the petition by 5:00 p.m., 30 days after the date of this NOA amendment, except that if the thirtieth day following the date of this Order falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board by 5:00 p.m. on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the internet at:  
[http://www.waterboards.ca.gov/public\\_notices/petitions/water\\_quality](http://www.waterboards.ca.gov/public_notices/petitions/water_quality) or will be provided upon request.

***ORIGINAL SIGNED BY ADAM LAPUTZ FOR***

Patrick Pulupa  
Executive Officer

cc: David Smith, U.S. EPA, Region IX, San Francisco (email only)  
Afrooz Farsimadan, Division of Water Quality, State Water Board, Sacramento (email only)