

ITEM: 34

SUBJECT: Uncontested Waste Discharge Requirements Waiver

REPORT: Following are the proposed waste discharge requirements that prohibit discharge to surface waters. All agencies and the dischargers concur or have offered no comments. Items indicated as updates on the summary agenda make the requirements consistent with current plans and policies of the Board.

The City of Clovis operates a treatment plant to treat surface water for potable use. The treatment consists of clarification, filtration, chlorination, and pH adjustment. The settled solids are dried in lined drying beds, and then the dried material is transported to a landfill for disposal. This waiver resolution waives waste discharge requirements for discharge of the sludge to the lined drying beds.

RECOMMENDATION: Adopt the proposed waste discharge requirements.

21/22 June 2007

Mgmt. Review \_\_\_\_\_

Legal Review \_\_\_\_\_

Central Valley Regional Water Quality Control Board  
11020 Sun Center Drive, #200  
Rancho Cordova, CA 95670