

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

CENTRAL VALLEY REGION

11020 Sun Center Drive #200, Rancho Cordova, California 95670-6114
 Phone (916) 464-3291 • FAX (916) 464-4645
 http://www.waterboards.ca.gov/centralvalley

ORDER NO. R5-2008-XXXX
NPDES NO. CA0079588

Deleted: CA0078018

**WASTE DISCHARGE REQUIREMENTS FOR THE
 CITY OF RIO VISTA
 BEACH WASTEWATER TREATMENT FACILITY
 SOLANO COUNTY**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

| | |
|---|---|
| Discharger | City of Rio Vista |
| Name of Facility | City of Rio Vista Beach Wastewater Treatment Facility |
| Facility Address | 1000 Beach Drive |
| | Rio Vista, CA 94571 |
| | Solano County |
| The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a minor discharge. | |

The discharge by the City of Rio Vista from the discharge point identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location

| Discharge Point | Effluent Description | Discharge Point Latitude | Discharge Point Longitude | Receiving Water |
|------------------------|--|---------------------------------|----------------------------------|------------------------|
| 001 | Secondary treated municipal wastewater | 38° 08' 31" N | 121° 41' 34" W | Sacramento River |

Table 3. Administrative Information

| | |
|---|--|
| This Order was adopted by the Regional Water Quality Control Board on: | <Adoption Date> |
| This Order shall become effective on: | <Effective Date> |
| This Order shall expire on: | <Expiration Date> |
| The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than: | 180 days prior to the Order expiration date |

I, PAMELA C. CREEDON, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on <Adoption Date>.

 PAMELA C. CREEDON, Executive Officer

Table of Contents

| | | |
|------|--|----|
| I. | Facility Information | 4 |
| II. | Findings | 4 |
| III. | Discharge Prohibitions..... | 10 |
| IV. | Effluent Limitations and Discharge Specifications | 11 |
| | A. Effluent Limitations – Discharge Point No. 001 | 11 |
| | 1. Final Effluent Limitations – Discharge Point No. 001 | 11 |
| | 2. Interim Effluent Limitations | 12 |
| | B. Land Discharge Specifications..... | 12 |
| | C. Reclamation Specifications..... | 13 |
| V. | Receiving Water Limitations | 13 |
| | A. Surface Water Limitations..... | 13 |
| | B. Groundwater Limitations | 15 |
| VI. | Provisions | 15 |
| | A. Standard Provisions..... | 15 |
| | B. Monitoring and Reporting Program (MRP) Requirements | 20 |
| | C. Special Provisions..... | 20 |
| | 1. Reopener Provisions | 20 |
| | 2. Special Studies, Technical Reports and Additional Monitoring Requirements | 21 |
| | 3. Best Management Practices and Pollution Prevention | 23 |
| | 4. Construction, Operation and Maintenance Specifications | 23 |
| | 5. Special Provisions for Municipal Facilities (POTWs Only)..... | 23 |
| | 6. Other Special Provisions | 25 |
| | 7. Compliance Schedules – Not Applicable..... | 26 |
| VII. | Compliance Determination | 26 |

List of Tables

| | | |
|----------|----------------------------------|-------|
| Table 1. | Discharger Information | Cover |
| Table 2. | Discharge Location | Cover |
| Table 3. | Administrative Information | Cover |
| Table 4. | Facility Information..... | 4 |
| Table 5. | Basin Plan Beneficial Uses | 6 |
| Table 6. | Effluent Limitations | 11 |

List of Attachments

| | |
|---|-----|
| Attachment A – Definitions | A-1 |
| Attachment B – Map | B-1 |
| Attachment C – Flow Schematic..... | C-1 |
| Attachment D – Standard Provisions | D-1 |
| Attachment E – Monitoring and Reporting Program (MRP)..... | E-1 |
| Attachment F – Fact Sheet | F-1 |
| Attachment G – Summary of Reasonable Potential Analysis | G-1 |
| Attachment H – Constituents to be Monitored | H-1 |

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

| | |
|---|--|
| Discharger | City of Rio Vista |
| Name of Facility | City of Rio Vista Beach Wastewater Treatment Facility |
| Facility Address | 1000 Beach Drive |
| | Rio Vista, CA 94571 |
| | Solano County |
| Facility Contact, Title, and Phone | Project Manager, 707-374- 2633 |
| Mailing Address | One Main Street, Rio Vista, CA 94571 |
| Type of Facility | Publicly Owned Treatment Works (POTW) |
| Facility Design Flow | Average daily discharge flow of 0.65 million gallons per day (mgd) |

Deleted: Doug Little, Associate

Deleted: 2930

II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Regional Water Board), finds:

A. Background. The City of Rio Vista (hereinafter Discharger) is currently discharging pursuant to Order No. 5-01-178 and National Pollutant Discharge Elimination System (NPDES) Permit No. ~~CA0079588~~. The Discharger submitted a Report of Waste Discharge, dated 13 March 2006, and applied for a NPDES permit renewal to discharge an average daily discharge flow up to 0.65 million gallons per day (mgd) of secondary level treated wastewater from the City of Rio Vista Beach Wastewater Treatment Facility, hereinafter Facility. The application was deemed complete.

Deleted: CA0078018

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

B. Facility Description. Veolia Water Company is the operator of the City of Rio Vista Beach Wastewater Treatment Facility, which is owned by the City of Rio Vista. The U.S. Army Corps of Engineers owns the property at 1000 Beach Drive and has granted the City of Rio Vista a right of way in order to operate and maintain its sewage treatment and pumping facility on this property. The treatment system consists of bar screening and grit removal, two primary clarifiers, two activated sludge reactors, two secondary clarifiers, and chlorination/dechlorination. Sludge is dewatered on drying beds (lined and unlined) and disposed offsite at a local landfill. Wastewater is discharged through an outfall at Discharge Point No. 001, 77 feet offshore (see table on cover page) in the Sacramento River, a water of the United States, within Sacramento-San Joaquin Delta.

Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.

- C. Legal Authorities.** This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).
- D. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E and G are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100-21177.
- F. Technology-based Effluent Limitations.** Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations (CFR)¹ require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at Part 133 and Best Professional Judgment (BPJ) in accordance with Part 125, section 125.3. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet (Attachment F).
- G. Water Quality-based Effluent Limitations.** Section 301(b) of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed State criterion or policy interpreting the State's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

H. Water Quality Control Plans. The Regional Water Board adopted a *Water Quality Control Plan, Fourth Edition (Revised February 2007), for the Sacramento and San Joaquin River Basins* (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. The beneficial uses of the Sacramento River within the Sacramento-San Joaquin Delta downstream of the discharge are municipal and domestic supply, agricultural irrigation, agricultural stock watering, industrial process supply, industrial service supply, water contact recreation, other non-contact water recreation, warm freshwater habitat, cold freshwater habitat, migration of aquatic organisms (warm and cold), warm spawning habitat, wildlife habitat, and navigation.

Thus, as discussed in detail in the Fact Sheet, beneficial uses applicable to the Sacramento River within the Sacramento-San Joaquin Delta are as follows:

Table 5. Basin Plan Beneficial Uses

| Discharge Point | Receiving Water Name | Beneficial Use(s) |
|-----------------|--|---|
| 001 | Sacramento River within the Sacramento-San Joaquin Delta | Municipal and domestic supply, agricultural irrigation, agricultural stock watering, industrial process supply, industrial service supply, water contact recreation, other non-contact water recreation, warm freshwater habitat, cold freshwater habitat, migration of aquatic organisms (warm and cold), warm spawning habitat, wildlife habitat, and navigation. |

The Basin Plan includes a list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to WQLSs. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." The listing for the Delta Waterways (western portion) is listed as a WQLS for chlorpyrifos, DDT, diazinon, electrical conductivity, exotic species, group A pesticides, mercury, and unknown toxicity in the 303(d) list of impaired water bodies.

The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on 18 May 1972, and amended this plan on 18 September 1975. This plan contains temperature objectives for surface waters. Requirements of this Order implement the Thermal Plan.

Requirements of this Order specifically implement the applicable Water Quality Control Plans.

- I. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on 22 December 1992, and later amended it on 4 May 1995 and 9 November 1999. About forty criteria in the NTR applied in California. On 18 May 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on 13 February 2001. These rules contain water quality criteria for priority pollutants.
- J. State Implementation Policy.** On 2 March 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on 28 April 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on 18 May 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on 24 February 2005 that became effective on 13 July 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Compliance Schedules and Interim Requirements.** In general, an NPDES permit must include final effluent limitations that are consistent with Clean Water Act section 301 and with 40 CFR 122.44(d). There are exceptions to this general rule. The State Water Board has concluded that where the Regional Water Board's Basin Plan allows for schedules of compliance and the Regional Water Board is newly interpreting a narrative standard, it may include schedules of compliance in the permit to meet effluent limits that implement a narrative standard. See *In the Matter of Waste Discharge Requirements for Avon Refinery* (State Board Order WQ 2001-06 at pp. 53-55). See also *Communities for a Better Environment et al. v. State Water Resources Control Board*, 34 Cal.Rptr.3d 396, 410 (2005). The Basin Plan for the Sacramento and San Joaquin Rivers includes a provision that authorizes the use of compliance schedules in NPDES permits for water quality objectives that are adopted after the date of adoption of the Basin Plan, which was 25 September 1995 (See Basin Plan at page IV-16). Consistent with the State Water Board's Order in the CBE matter, the Regional Water Board has the discretion to include compliance schedules in NPDES permits when it is including an effluent limitation that is a "new interpretation" of a narrative water quality objective. This conclusion is also consistent with the United States Environmental Protection Agency policies and administrative decisions (see for example *Whole Effluent Toxicity (WET) Control Policy*). The Regional Water Board, however, is not required to include a schedule of compliance, but may issue a Time Schedule Order pursuant to Water Code section 13300 or a Cease and Desist Order pursuant to Water Code section 13301 where it finds that the discharger is violating or threatening to violate the permit. The Regional Water Board will consider the merits of each case in

determining whether it is appropriate to include a compliance schedule in a permit, and, consistent with the Basin Plan, should consider feasibility of achieving compliance, and must impose a schedule that is as short as practicable to achieve compliance with the objectives, criteria, or effluent limit based on the objective or criteria.

For CTR constituents, Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or 18 May 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation that exceeds 1 year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order includes compliance schedules and interim effluent limitations. A detailed discussion of the basis for the compliance schedules and interim effluent limitations is included in the Fact Sheet.

L. Alaska Rule. On 30 March 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. (40 CFR 131.21; 65 Fed. Reg. 24641 (27 April 2000).) Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after 30 May 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by 30 May 2000 may be used for CWA purposes, whether or not approved by USEPA.

M. Stringency of Requirements for Individual Pollutants. This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on biochemical oxygen demand (BOD) (5-day @ 20° C), total suspended solids (TSS), pH and settleable solids. Water quality-based effluent limitations consist of restrictions on aluminum, ammonia, arsenic, chlorine residual, copper, dibromochloromethane, dichlorobromomethane, iron, lead, manganese, nitrate, nitrite, pH, pathogens, and temperature. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations are based on the CTR-SIP, which was

approved by USEPA on 1 May 2001. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to 30 May 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to 30 May 2000, but not approved by USEPA before that date, are nonetheless “*applicable water quality standards for purposes of the [Clean Water] Act*” pursuant to 40 CFR 131.21(c)(1). Collectively, this Order’s restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.

- N. Antidegradation Policy.** Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California’s antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 is consistent with the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board’s Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet the permitted discharge is consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.
- O. Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.
- P. Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The discharger is responsible for meeting all requirements of the applicable Endangered Species Act.
- Q. Monitoring and Reporting.** Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- R. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in

Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.

- S. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections VI.A.2.v and V.B of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- T. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- U. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

IT IS HEREBY ORDERED, that Order No. 5-01-178 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

III. DISCHARGE PROHIBITIONS

- A. Discharge of wastewater at a location or in a manner different from that described in the Findings is prohibited.
- B. The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Federal Standard Provisions I.G. and I.H. (Attachment D).
- C. Neither the discharge nor its treatment shall create a nuisance as defined in Section 13050 of the California Water Code.
- D. The Discharger shall not allow pollutant-free wastewater to be discharged into the collection, treatment, and disposal system in amounts that significantly diminish the system's capability to comply with this Order. Pollutant-free wastewater means rainfall, groundwater, cooling waters, and condensates that are essentially free of pollutants.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point No. 001

1. Final Effluent Limitations – Discharge Point No. 001

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001 as described in the attached MRP (Attachment E):

- a. The Discharger shall maintain compliance with the effluent limitations specified in Table 6:

Table 6. Effluent Limitations

| Parameter | Units | Effluent Limitations | | | | |
|---|----------------------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Aluminum, Total Recoverable | µg/L | 411 | -- | 750 | -- | -- |
| Ammonia, Total (as N) | mg/L | 35 | -- | 91 | -- | -- |
| | lbs/day ¹ | 190 | -- | 493 | -- | -- |
| | lbs/day ² | 671 | -- | 1746 | -- | -- |
| Arsenic, Total Recoverable | µg/L | -- | -- | 16 | -- | -- |
| Biochemical Oxygen Demand, 5-day @ 20°C (BOD ₅) | mg/L | 30 | 45 | 60 | -- | -- |
| | lbs/day ¹ | 163 | 244 | 326 | -- | -- |
| | lbs/day ² | 575 | 863 | 1151 | -- | -- |
| Copper, Total Recoverable | µg/L | 58 | -- | 116 | -- | -- |
| Dibromochloromethane | µg/L | -- | -- | 2.8 | -- | -- |
| Dichlorobromomethane | µg/L | -- | -- | 5.6 | -- | -- |
| Iron, Total Recoverable | µg/L | -- | -- | 300 | -- | -- |
| Lead, Total Recoverable | µg/L | -- | -- | 7.2 | -- | -- |
| Manganese, Total Recoverable | µg/L | -- | -- | 467 | -- | -- |
| Nitrate, Total (as N) | mg/L | -- | -- | 65 | -- | -- |
| Nitrite, Total (as N) | mg/L | -- | -- | 3.1 | -- | -- |
| pH | Standard Units | -- | -- | -- | 6.5 | 8.1 |
| Settleable Solids | ml/L | 0.1 | -- | 0.2 | -- | -- |
| Total Suspended Solids (TSS) | mg/L | 30 | 45 | 60 | -- | -- |
| | lbs/day ¹ | 163 | 244 | 326 | -- | -- |
| | lbs/day ² | 575 | 863 | 1151 | -- | -- |

Deleted: m

¹ Based on a design average dry weather flow capacity of 0.65 mgd (applicable May-Oct).

² Based on a design peak wet weather flow capacity of 2.3 mgd (applicable Nov-Apr).

- b. **Percent Removal:** The average monthly percent removal of BOD 5-day 20°C and total suspended solids shall not be less than 85 percent.
- c. **Acute Whole Effluent Toxicity.** Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:
 - i. 70%, minimum for any one bioassay; and
 - ii. 90%, median for any three consecutive bioassays.
- d. **Total Residual Chlorine.** Effluent total residual chlorine shall not exceed:
 - i. 0.011 mg/L, as a 4-day average; and
 - ii. 0.019 mg/L, as a 1-hour average.
- e. **Total Coliform Organisms.** Effluent total coliform organisms shall not exceed:
 - i. 23 MPN/100 mL as a 7-day median; and
 - ii. 240 MPN/100 mL more than once in any 30 day period.
- f. **Discharge Flow (May-October).** The Average Daily Discharge Flow (May-October) shall not exceed 0.65 mgd.
- g. **Discharge Flow (November-April).** The Average Daily Discharge Flow (November-April) shall not exceed 2.3 mgd.
- h. **Temperature.** The maximum temperature shall not exceed the natural receiving water temperature by more than 20°F.
- i. **Aluminum.** The annual average effluent total aluminum concentration shall not exceed 200 µg/L.
- j. **Electrical Conductivity @ 25°C.** For a calendar year, the annual average electrical conductivity of the effluent shall not exceed 1,300 µmhos/cm.

2. Interim Effluent Limitations

Effective immediately, the Discharger shall maintain compliance with the following effluent limitations at Discharge Point No. 001, with compliance measured at Monitoring Location **EFF-001** as described in the attached MRP.

- a. **Mercury, Total Recoverable.** The monthly total mercury mass loading shall not exceed 0.0071 lbs.

B. Land Discharge Specifications

[Not applicable]

C. Reclamation Specifications

[Not applicable]

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in the Sacramento River:

1. **Bacteria.** The fecal coliform concentration, based on a minimum of not less than five samples for any 30-day period, to exceed a geometric mean of 200 MPN/100 mL, nor more than 10 percent of the total number of fecal coliform samples taken during any 30-day period to exceed 400 MPN/100 mL.
2. **Biostimulatory Substances.** Water to contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.
3. **Chemical Constituents.** Chemical constituents to be present in concentrations that adversely affect beneficial uses.
4. **Color.** Discoloration that causes nuisance or adversely affects beneficial uses.
5. **Dissolved Oxygen.** The dissolved oxygen concentration to be reduced below 5.0 mg/L at any time.
6. **Floating Material.** Floating material to be present in amounts that cause nuisance or adversely affect beneficial uses.
7. **Oil and Grease.** Oils, greases, waxes, or other materials to be present in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.
8. **pH.** The pH to be depressed below 6.5 or raised above 8.5. The change in pH to be more than 0.5 units, as an annual average.
9. **Pesticides:**
 - a. Pesticides to be present, individually or in combination, in concentrations that adversely affect beneficial uses;
 - b. Pesticides to be present in bottom sediments or aquatic life in concentrations that adversely affect beneficial uses;
 - c. Total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical

methods approved by USEPA or the Executive Officer/prescribed in *Standard Methods for the Examination of Water and Wastewater, 18th Edition*, or other equivalent methods approved by the Executive Officer.

- d. Pesticide concentrations to exceed those allowable by applicable antidegradation policies (see State Water Board Resolution No. 68-16 and 40 CFR 131.12.).
- e. Pesticide concentrations to exceed the lowest levels technically and economically achievable.
- f. Pesticides to be present in concentration in excess of the maximum contaminant levels set forth in California Code of Regulations, Title 22, Division 4, Chapter 15/specified in Table 64444-A (Organic Chemicals) of Section 64444 of Title 22 of the California Code of Regulations.
- g. Thiobencarb to be present in excess of 1.0 µg/L.

10. Radioactivity:

- a. Radionuclides to be present in concentrations that are harmful/deleterious to human, plant, animal, or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life.
- b. Radionuclides to be present in excess of the maximum contaminant levels specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations.

11. Suspended Sediments. The suspended sediment load and suspended sediment discharge rate of surface waters to be altered in such a manner as to cause nuisance or adversely affect beneficial uses.

12. Settleable Substances. Substances to be present in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.

13. Suspended Material. Suspended material to be present in concentrations that cause nuisance or adversely affect beneficial uses.

14. Taste and Odors. Taste- or odor-producing substances to be present in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses/or to domestic or municipal water supplies.

15. Temperature.

- a. Elevated temperature waste discharges either individually or combined with other discharges shall not create a zone, defined by water temperatures of more than 1°F above natural receiving water temperature, which exceeds 25 percent of the cross-sectional area of a main river channel at any point.
- b. No discharge shall cause a surface water temperature rise greater than 4°F above the natural temperature of the receiving waters at any time or place.

16. **Toxicity.** Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.

17. **Turbidity.** The turbidity to increase as follows:

- a. More than 1 Nephelometric Turbidity Unit (NTU) where natural turbidity is between 0 and 5 NTUs.
- b. More than 20 percent where natural turbidity is between 5 and 50 NTUs.
- c. More than 10 NTU where natural turbidity is between 50 and 100 NTUs.
- d. More than 10 percent where natural turbidity is greater than 100 NTUs.

B. Groundwater Limitations

1. The discharge shall not cause the groundwater to exceed water quality objectives, unreasonably affect beneficial uses, or cause a condition of pollution or nuisance.
2. Release of waste constituents from any storage, treatment, or disposal component associated with the Facility shall not, in combination with other sources of the waste constituents, cause groundwater within influence of the Facility to contain waste constituents in concentrations in excess of natural background quality or that listed below, whichever is greater:
 - a. Total coliform organisms median of 2.2 MPN/100 mL over any 7-day period.

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. The Discharger shall comply with the following provisions:
 - a. If the Discharger's wastewater treatment plant is publicly owned or subject to regulation by California Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to Title 23, CCR, Division 3, Chapter 26.
 - b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i. violation of any term or condition contained in this Order;
 - ii. obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;

- iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
- iv. a material change in the character, location, or volume of discharge.

The causes for modification include:

- *New regulations.* New regulations have been promulgated under Section 405(d) of the Clean Water Act, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.
- *Land application plans.* When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
- *Change in sludge use or disposal practice.* Under 40 Code of Federal Regulations (CFR) 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Regional Water Board may review and revise this Order at any time upon application of any affected person or the Regional Water Board's own motion.

- c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Regional Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - i. contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
 - ii. controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.
- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by USEPA under Section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. The discharge of any radiological, chemical or biological warfare agent or high-level, radiological waste is prohibited.
- i. A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- j. Safeguard to electric power failure:
 - i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, or failure of electric power, the discharge shall comply with the terms and conditions of this Order.
 - ii. Upon written request by the Regional Water Board the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures experienced over the past five years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Regional Water Board.
 - iii. Should the treatment works not include safeguards against reduction, loss, or failure of electric power, or should the Regional Water Board not approve the existing safeguards, the Discharger shall, within ninety days of having been advised in writing by the Regional Water Board that the existing safeguards are inadequate, provide to the Regional Water Board and USEPA a schedule of compliance for providing safeguards such that in the event of reduction, loss, or failure of electric power, the Discharger shall comply with the terms and conditions of this Order. The schedule of compliance shall, upon approval of the Regional Water Board, become a condition of this Order.
- k. The Discharger, upon written request of the Regional Water Board, shall file with the Board a technical report on its preventive (failsafe) and contingency (cleanup)

plans for controlling accidental discharges, and for minimizing the effect of such events. This report may be combined with that required under Regional Water Board Standard Provision VI.A.2.m.

The technical report shall:

- i. Identify the possible sources of spills, leaks, untreated waste by-pass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.
- ii. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- iii. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

The Regional Water Board, after review of the technical report, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions shall be incorporated as part of this Order, upon notice to the Discharger.

- i. A publicly owned treatment works (POTW) whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment and disposal facilities. The projections shall be made in January, based on the last three years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in four years, the Discharger shall notify the Regional Water Board by 31 January. A copy of the notification shall be sent to appropriate local elected officials, local permitting agencies and the press. Within 120 days of the notification, the Discharger shall submit a technical report showing how it will prevent flow volumes from exceeding capacity or how it will increase capacity to handle the larger flows. The Regional Water Board may extend the time for submitting the report.
- m. The Discharger shall submit technical reports as directed by the Executive Officer. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code, sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in

a manner such that all work can be clearly attributed to the professional responsible for the work.

- n. Laboratories that perform sample analyses must be identified in all monitoring reports submitted to the Regional Water Board and USEPA.
- o. The Discharger shall conduct analysis on any sample provided by USEPA as part of the Discharge Monitoring Quality Assurance (DMQA) program. The results of any such analysis shall be submitted to USEPA's DMQA manager.
- p. Effluent samples shall be taken downstream of the last addition of wastes to the treatment or discharge works where a representative sample may be obtained prior to mixing with the receiving waters. Samples shall be collected at such a point and in such a manner to ensure a representative sample of the discharge.
- q. All monitoring and analysis instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary, at least yearly, to ensure their continued accuracy.
- r. The Discharger shall file with the Regional Water Board technical reports on self-monitoring performed according to the detailed specifications contained in the Monitoring and Reporting Program attached to this Order.
- s. The results of all monitoring required by this Order shall be reported to the Regional Water Board, and shall be submitted in such a format as to allow direct comparison with the limitations and requirements of this Order. Unless otherwise specified, discharge flows shall be reported in terms of the monthly average and the daily maximum discharge flows.
- t. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, sections 13385, 13386, and 13387.
- u. For POTWs, prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse, the Discharger must file a petition with the State Water Board, Division of Water Rights, and receive approval for such a change. (CWC section 1211).
- v. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, maximum daily effluent limitation, 1-hour average effluent limitation, or receiving water limitation contained in this Order, the Discharger shall notify the Regional Water Board by telephone (916) 464-3291 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Regional Water Board waives confirmation. The written notification shall include the information required by Attachment D, Section V.E.1 [40 CFR 122.41(l)(6)(i)].

B. Monitoring and Reporting Program (MRP) Requirements

1. The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

- a. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.

Conditions that necessitate a major modification of a permit are described in 40 CFR 122.62, including:

- i. If new or amended applicable water quality standards are promulgated or approved pursuant to Section 303 of the CWA, or amendments thereto, this permit may be reopened and modified in accordance with the new or amended standards.
 - ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
- b. **Mercury.** If mercury is found to be causing toxicity based on acute or chronic toxicity test results, or if a TMDL program is adopted, this Order shall be reopened and the interim mass effluent limitation modified (higher or lower) or an effluent concentration limitation imposed. If the Regional Water Board determines that a mercury offset program is feasible for Dischargers subject to a NPDES permit, then this Order may be reopened to re-evaluate the interim mercury mass loading limitation(s) and the need for a mercury offset program for the Discharger.
 - c. **Whole Effluent Toxicity.** As a result of a Toxicity Reduction Evaluation (TRE), this Order may be reopened to include a chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if the State Water Board revises the SIP's toxicity control provisions that would require the establishment of numeric chronic toxicity effluent limitations, this Order may be reopened to include a numeric chronic toxicity effluent limitation based on the new provisions.
 - d. **Water Effects Ratios (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating CTR criteria for applicable priority pollutant inorganic constituents. In addition, default dissolved-to-total metal

translators have been used to convert water quality objectives from dissolved to total recoverable when developing effluent limitations for inorganic constituents. If the Discharger performs studies to determine site-specific WERs and/or site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity.** For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct chronic whole effluent toxicity testing, as specified in the Monitoring and Reporting Program (Attachment E, Section V). Furthermore, this Provision requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity. If the discharge exceeds the toxicity numeric monitoring trigger established in this Provision, the Discharger is required to initiate a Toxicity Reduction Evaluation (TRE), in accordance with an approved TRE Work Plan, and take actions to mitigate the impact of the discharge and prevent reoccurrence of toxicity. A TRE is a site-specific study conducted in a stepwise process to identify the source(s) of toxicity and the effective control measures for effluent toxicity. TREs are designed to identify the causative agents and sources of whole effluent toxicity, evaluate the effectiveness of the toxicity control options, and confirm the reduction in effluent toxicity. This Provision includes requirements for the Discharger to develop and submit a TRE Work Plan.
 - i. **Initial Investigative Toxicity Reduction Evaluation (TRE) Work Plan.** Within 90 days of the effective date of this Order, the Discharger shall submit to the Regional Water Board an Initial Investigative TRE Work Plan for approval by the Executive Officer. This should be a one to two page document including, at minimum:
 - a) A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of effluent toxicity, effluent variability, and treatment system efficiency;
 - b) A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in operation of the facility; and
 - c) A discussion of who will conduct the Toxicity Identification Evaluation, if necessary (i.e. an in-house expert or outside contractor).
 - ii. **Accelerated Monitoring and TRE Initiation.** When the numeric toxicity monitoring trigger is exceeded during regular chronic toxicity monitoring, and the testing meets all test acceptability criteria, the Discharger shall initiate accelerated monitoring as required in the Accelerated Monitoring Specifications. WET testing results exceeding the monitoring trigger during

accelerated monitoring demonstrates a pattern of toxicity and requires the Discharger to initiate a TRE to address the effluent toxicity.

- iii. **Numeric Monitoring Trigger.** The numeric toxicity monitoring trigger is $> 16 \text{ TUc}$ (where $\text{TUc} = 100/\text{NOEC}$). The monitoring trigger is not an effluent limitation; it is the toxicity threshold at which the Discharger is required to begin accelerated monitoring and initiate a TRE.
- iv. **Accelerated Monitoring Specifications.** If the monitoring trigger is exceeded during regular chronic toxicity testing, within 14 days of notification by the laboratory of the test results, the Discharger shall initiate accelerated monitoring. Accelerated monitoring shall consist of four (4) chronic toxicity tests in a 6-week period (i.e. one test every 2 weeks) using the species that exhibited toxicity. The following protocol shall be used for accelerated monitoring and TRE initiation:
 - a) If the results of four (4) consecutive accelerated monitoring tests do not exceed the monitoring trigger, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring. However, notwithstanding the accelerated monitoring results, if there is sufficient evidence of a pattern of effluent toxicity, the Executive Officer may require that the Discharger initiate a TRE.
 - b) If the source(s) of the toxicity is easily identified (i.e. temporary plant upset), the Discharger shall make necessary corrections to the facility and shall continue accelerated monitoring until four (4) consecutive accelerated tests do not exceed the monitoring trigger. Upon confirmation that the effluent toxicity has been removed, the Discharger may cease accelerated monitoring and resume regular chronic toxicity monitoring.
 - c) If the result of any accelerated toxicity test exceeds the monitoring trigger, the Discharger shall cease accelerated monitoring and initiate a TRE to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. Within thirty (30) days of notification by the laboratory of the test results exceeding the monitoring trigger during accelerated monitoring, the Discharger shall submit a TRE Action Plan to the Regional Water Board including, at minimum:
 - 1) Specific actions the Discharger will take to investigate and identify the cause(s) of toxicity, including TRE WET monitoring schedule;
 - 2) Specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 - 3) A schedule for these actions.

Within sixty (60) days of notification by the laboratory of the test results, the Discharger shall submit to the Regional Water Board a TRE Work Plan for approval by the Executive Officer. The TRE Work Plan shall outline

the procedures for identifying the source(s) of, and reducing or eliminating effluent toxicity. The TRE Work Plan must be developed in accordance with EPA guidance².

- b. **Effluent and Receiving Water Characterization Study.** An effluent and receiving water monitoring study is required to ensure adequate information is available for the next permit renewal. During the third year of the permit term, the Discharger shall conduct quarterly monitoring³ of the effluent at EFF-001 and of the receiving water at RSW-001. The Discharger shall monitor for all priority pollutants and other constituents of concern as described in Attachment H. The report shall be completed in conformance with the following schedule.

| <u>Task</u> | <u>Compliance Date</u> |
|-----------------------------------|---|
| Submit Workplan and Time Schedule | No later than 2 years 6 months from adoption of the permit |
| Conduct quarterly monitoring | During third year of permit term |
| Submit Final Report | 6 months following completion of final quarterly monitoring event |

3. Best Management Practices and Pollution Prevention

- a. **Salinity Evaluation and Minimization Plan.** The Discharger shall prepare a salinity evaluation and minimization plan to address sources of salinity from the Facility. The plan shall be completed and submitted to the Regional Water Board within 9 months of the adoption date of this Order for the approval by the Executive Officer.

4. Construction, Operation and Maintenance Specifications

[Not applicable]

5. Special Provisions for Municipal Facilities (POTWs Only)

a. Sludge/Biosolids Discharge Specifications

- i. Collected screenings, residual sludge, biosolids, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer, and consistent with *Consolidated Regulations for Treatment, Storage, Processing, or Disposal of Solid Waste*, as set forth in Title 27, CCR, Division 2, Subdivision 1, section 20005, et seq. Removal for further treatment, disposal, or reuse at sites (i.e., landfill, composting sites, soil amendment sites) that are operated in accordance with valid waste discharge requirements issued by a regional water quality control board will satisfy these specifications.

² See Attachment F (Fact Sheet) Section VII.B.2.a. for a list of EPA guidance documents that must be considered in development of the TRE Workplan.

³ Dioxin and furan sampling shall be conducted only twice in accordance with Attachment H.

- ii. Sludge and solid waste shall be removed from screens, sumps, ponds, clarifiers, etc. as needed to ensure optimal plant performance.
- iii. The treatment of sludge generated at the Facility shall be confined to the Facility property and conducted in a manner that precludes infiltration of waste constituents into soils in a mass or concentration that will violate Groundwater Limitations V.B. In addition, the storage of residual sludge, solid waste, and biosolids on Facility property shall be temporary and controlled, and contained in a manner that minimizes leachate formation and precludes infiltration of waste constituents into soils in a mass or concentration that will violate Groundwater Limitations V.B.
- iv. The use and disposal of biosolids shall comply with existing Federal and State laws and regulations, including permitting requirements and technical standards included in 40 CFR Part 503. If the State Water Board and the Regional Water Board are given the authority to implement regulations contained in 40 CFR Part 503, this Order may be reopened to incorporate appropriate time schedules and technical standards. The Discharger must comply with the standards and time schedules contained in 40 CFR Part 503 whether or not they have been incorporated into this Order.

b. Biosolids Disposal Requirements

- i. The Discharger shall comply with the Monitoring and Reporting Program for biosolids disposal contained in Attachment E.
- ii. Any proposed change in biosolids use or disposal practice from a previously approved practice shall be reported to the Executive Officer and USEPA Regional Administrator at least **90 days** in advance of the change.
- iii. The Discharger is encouraged to comply with the "Manual of Good Practice for Agricultural Land Application of Biosolids" developed by the California Water Environment Association.

c. Biosolids Storage Requirements

- i. Facilities for the storage of Class B biosolids shall be located, designed and maintained to restrict public access to biosolids.
- ii. Biosolids storage facilities shall be designed and maintained to prevent washout or inundation from a storm or flood with a return frequency of 100 years.
- iii. Biosolids storage facilities, which contain biosolids, shall be designed and maintained to contain all storm water falling on the biosolids storage area during a rainfall year with a return frequency of 100 years.

iv. Biosolids storage facilities shall be designed, maintained and operated to minimize the generation of leachate.

- d. **Collection System.** On 2 May 2006, the State Water Board adopted State Water Board Order 2006-0003, a Statewide General WDR for Sanitary Sewer Systems. The Discharger shall be subject to the requirements of Order 2006-0003 and any future revisions thereto. Order 2006-0003 requires that all public agencies that currently own or operate sanitary sewer systems apply for coverage under the General WDR. By 2 November 2006, the Discharger is required by that Order, not incorporated by reference herein, to apply for coverage under State Water Board Order 2006-0003 for operation of its wastewater collection system.

Regardless of the coverage obtained under Order 2006-0003, the Discharger's collection system is part of the treatment system that is subject to this Order. As such, pursuant to federal regulations, the Discharger must properly operate and maintain its collection system [40 CFR 122.41(e)], report any non-compliance [40 CFR 122.41(l)(6) and (7)], and mitigate any discharge from the collection system in violation of this Order [40 CFR 122.41(d)].

6. Other Special Provisions

- a. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to the Regional Water Board.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Regional Water Board and a statement. The statement shall comply with the signatory and certification requirements in the Federal Standard Provisions (Attachment D, Section V.B.) and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved in writing by the Executive Officer.

- b. This permit, and the Monitoring and Reporting Program which is a part of this permit, requires that certain parameters be monitored on a continuous basis. The wastewater treatment plant is not staffed on a full time basis. Permit violations or system upsets can go undetected during this period. The Discharger is required to establish an electronic system for operator notification for continuous recording device alarms. For existing continuous monitoring systems, the electronic notification system shall be installed **within 6 months of adoption** of this permit. For systems installed following permit adoption, the notification system shall be installed simultaneously.

7. Compliance Schedules – Not Applicable

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

- A. **BOD and TSS Effluent Limitations.** Compliance with the final effluent limitations for BOD and TSS shall be ascertained by 24-hour composite samples. Compliance with effluent limitations for percent removal shall be calculated using the arithmetic mean of 20°C BOD (5-day) and total suspended solids in effluent samples collected over a monthly period as a percentage of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.
- B. **Aluminum Effluent Limitations.** Compliance with the final effluent limitations for aluminum can be demonstrated using either total or acid-soluble (inductively coupled plasma/atomic emission spectrometry or inductively coupled plasma/mass spectrometry) analysis methods, as supported by USEPA's Ambient Water Quality Criteria for Aluminum document (EPA 440/5-86-008), or other standard methods that exclude aluminum silicate particles as approved by the Executive Officer.
- C. **Total Coliform Organisms Effluent Limitations.** For each day that an effluent sample is collected and analyzed for total coliform organisms, the 7-day median shall be determined by calculating the median concentration of total coliform bacteria in the effluent utilizing the bacteriological results of the last seven days for which analyses have been completed. If the 7-day median of total coliform organisms exceeds a most probable number (MPN) of 23 per 100 milliliters, the Discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period.
- D. **Total Residual Chlorine Effluent Limitations.** Continuous monitoring analyzers for chlorine residual or for dechlorination agent residual in the effluent are appropriate methods for compliance determination. A positive residual dechlorination agent in the effluent indicates that chlorine is not present in the discharge, which demonstrates compliance with the effluent limitations. This type of monitoring can also be used to prove that some chlorine residual exceedances are false positives. Continuous monitoring data showing either a positive dechlorination agent residual or a chlorine residual at or below the prescribed limit are sufficient to show compliance with the total residual chlorine effluent limitations, as long as the instruments are maintained and calibrated in accordance with the manufacturer's recommendations.

Any excursion above the 1-hour average or 4-day average total residual chlorine effluent limitations is a violation. If the Discharger conducts continuous monitoring and the Discharger can demonstrate, through data collected from a back-up monitoring system, that a chlorine spike recorded by the continuous monitor was not actually due to chlorine, then any excursion resulting from the recorded spike will not be considered an exceedance, but rather reported as a false positive.

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ), also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n \quad \text{where: } \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best Practicable Treatment or Control (BPTC): BPTC is a requirement of State Water Resources Control Board Resolution 68-16 – “Statement of Policy with Respect to Maintaining High Quality of Waters in California” (referred to as the “Antidegradation Policy”). BPTC is the treatment or control of a discharge necessary to assure that, *“(a) a pollution or nuisance will not occur and (b) the highest water quality consistent with maximum benefit to the people of the State will be maintained.”* Pollution is defined in CWC Section 13050(l). In general, an exceedance of a water quality objective in the Basin Plan constitutes “pollution”.

Bioaccumulative pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV) is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the

arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ) are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA) is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in U.S. EPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Estimated Chemical Concentration is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters are all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL) is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND) are those sample results less than the laboratory's MDL.

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP) means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product

reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL) is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System is the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ) is a measure of variability that is calculated as follows:


$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

- x is the observed value;
- μ is the arithmetic mean of the observed values; and
- n is the number of samples.

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)


ATTACHMENT B – MAP



| | | |
|--|---|--|
| | <p>SITE LOCATION MAP</p> <p>CITY OF RIO VISTA WASTEWATER TREATMENT FACILITY SOLANO COUNTY</p> | |
|--|---|--|

ATTACHMENT C – FLOW SCHEMATIC

— Liquid Stream
- - - Solids Stream



ATTACHMENT D –STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application (40 CFR 122.41(a)).
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement (40 CFR 122.41(a)(1)).

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order (40 CFR 122.41(c)).

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment (40 CFR 122.41(d)).

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order (40 CFR 122.41(e)).

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges (40 CFR 122.41(g)).

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations (40 CFR 122.5(c)).

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR 122.41(i); Wat. Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location (40 CFR 122.41(i)(4)).

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility (40 CFR 122.41(m)(1)(i)).
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production (40 CFR 122.41(m)(1)(ii)).
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below (40 CFR 122.41(m)(2)).

3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 CFR 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below (40 CFR 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above (40 CFR 122.41(m)(4)(ii)).
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass (40 CFR 122.41(m)(3)(i)).
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice) (40 CFR 122.41(m)(3)(ii)).

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation (40 CFR 122.41(n)(1)).

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was

caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review (40 CFR 122.41(n)(2)).

2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above (40 CFR 122.41(n)(3)(iv)).
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof (40 CFR 122.41(n)(4)).

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition (40 CFR 122.41(f)).

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit (40 CFR 122.41(b)).

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code (40 CFR 122.41(l)(3); 122.61).

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity (40 CFR 122.41(j)(1)).
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order (40 CFR 122.41(j)(4); 122.44(i)(1)(iv)).

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time (40 CFR 122.41(j)(2)).

B. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements (40 CFR § 122.41(j)(3)(i));
2. The individual(s) who performed the sampling or measurements (40 CFR § 122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 CFR 122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 CFR 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 CFR 122.41(j)(3)(v)); and
6. The results of such analyses (40 CFR 122.41(j)(3)(vi)).

C. Claims of confidentiality for the following information will be denied (40 CFR § 122.7(b)):

1. The name and address of any permit applicant or Discharger (40 CFR 122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data (40 CFR 122.7(b)(2)).

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order (40 CFR 122.41(h); Wat. Code, Section 13267).

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below (40 CFR 122.41(k)).
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA) (40 CFR 122.22(a)(3)).
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board (40 CFR 122.22(b)(3)).

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative (40 CFR 122.22(c)).
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order (40 CFR 122.22(l)(4)).
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices (40 CFR 122.41(l)(4)(i)).
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board (40 CFR § 122.41(l)(4)(ii)).
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order (40 CFR 122.41(l)(4)(iii)) .

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date (40 CFR 122.41(l)(5)).

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance (40 CFR 122.41(l)(6)(i)).
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order (40 CFR 122.41(l)(6)(ii)(A)).
 - b. Any upset that exceeds any effluent limitation in this Order (40 CFR 122.41(l)(6)(ii)(B)).
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours (40 CFR 122.41(l)(6)(iii)).

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 CFR 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1) (40 CFR 122.41(l)(1)(ii)).
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements (40 CFR 122.41(l)(2)).

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above (40 CFR 122.41(l)(7)).

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information (40 CFR 122.41(l)(8)).

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 CFR 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order (40 CFR 122.42(b)(2)).
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW (40 CFR 122.42(b)(3)).

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

| | |
|--|----|
| Attachment E – Monitoring and Reporting Program (MRP)..... | 1 |
| I. General Monitoring Provisions..... | 1 |
| II. Monitoring Locations | 2 |
| III. Influent Monitoring Requirements..... | 2 |
| A. Monitoring Location INF-001..... | 2 |
| IV. Effluent Monitoring Requirements | 3 |
| A. Monitoring Location EFF-001..... | 3 |
| V. Whole Effluent Toxicity Testing Requirements | 4 |
| VI. Land Discharge Monitoring Requirements | 7 |
| VII. Reclamation Monitoring Requirements..... | 7 |
| VIII. Receiving Water Monitoring Requirements – Surface Water..... | 7 |
| A. Monitoring Locations RSW-001 and RSW-002..... | 7 |
| IX. Other Monitoring Requirements..... | 8 |
| A. Biosolids | 8 |
| B. Municipal Water Supply | 8 |
| X. Reporting Requirements..... | 9 |
| A. General Monitoring and Reporting Requirements..... | 9 |
| B. Self Monitoring Reports (SMRs) | 10 |
| C. Discharge Monitoring Reports (DMRs)..... | 12 |
| D. Other Reports | 12 |

List of Tables

| | |
|---|----|
| Table E-1. Monitoring Station Locations..... | 2 |
| Table E-2. Influent Monitoring..... | 2 |
| Table E-3. Effluent Monitoring | 3 |
| Table E-4. Chronic Toxicity Testing Dilution Series..... | 6 |
| Table E-5. Receiving Water Monitoring Requirements ² | 7 |
| Table E-6. Municipal Water Supply Monitoring Requirements..... | 9 |
| Table E-7. Monitoring Periods and Reporting Schedule..... | 12 |

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

The Code of Federal Regulations section 122.48 requires that all NPDES permits specify monitoring and reporting requirements. Water Code Sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and state regulations.

I. GENERAL MONITORING PROVISIONS

- A. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and the approval of this Regional Water Board.
- B. Chemical, bacteriological, and bioassay analyses shall be conducted at a laboratory certified for such analyses by the State Department of Health Services. In the event a certified laboratory is not available to the Discharger, analyses performed by a noncertified laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program must be kept in the laboratory and shall be available for inspection by Regional Water Board staff. The Quality Assurance-Quality Control Program must conform to USEPA guidelines or to procedures approved by the Regional Water Board.
- C. All analyses shall be performed in a laboratory certified to perform such analyses by the California Department of Health Services. Laboratories that perform sample analyses shall be identified in all monitoring reports.
- D. Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy. All flow measurement devices shall be calibrated at least once per year to ensure continued accuracy of the devices.
- E. Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this Monitoring and Reporting Program.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

| Discharge Point Name | Monitoring Location Name | Monitoring Location Description (include Latitude and Longitude when available) |
|----------------------|--------------------------|--|
| -- | INF-001 | A location where a representative sample of the influent into the Facility can be collected prior to any plant return flows or treatment processes. |
| 001 | EFF-001 | A location where a representative sample of the effluent from the Facility can be collected after all treatment processes and prior to commingling with other waste streams or being discharged into the Sacramento River. [Latitude: 38° 08' 31" N; Longitude: 121° 41' 34" W] |
| -- | BIO-001 | A location where a representative sample of biosolids can be collected. |
| | RSW-001 | Approximately 1 mile upstream of Discharge Point No. 001. |
| -- | RSW-002 | Approximately 250 feet upstream of Discharge Point No. 001. |
| -- | RSW-003 | Approximately 250 feet downstream of Discharge Point No. 001. |
| -- | SPL-001 | A location where a representative sample location for the municipal water supply can be collected. If the water supply is from more than one source, a weighted average should be calculated. |

Deleted: 1
 Deleted: 500
 Deleted: 2
 Deleted: 500

III. INFLUENT MONITORING REQUIREMENTS

A. Monitoring Location INF-001

1. The Discharger shall monitor influent to the facility at INF-001 as follows:

Table E-2. Influent Monitoring

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|--|-----------------|------------------------------|----------------------------|---------------------------------|
| Flow | mgd | Meter | Continuous | 1 |
| Biochemical Oxygen Demand (5-day @ 20°C) | mg/L lbs/day | 24-hr Composite ² | 1/week | 1 |
| Total Suspended Solids | mg/L lbs/day | 24-hr Composite ² | 1/week | 1 |
| pH | Standard Units | Grab | 1/week | 1 |
| Electrical Conductivity @ 25°C | µmhos/cm | Grab | 1/month | 1 |

¹ As required by 40 CFR Part 136.
² 24-hour flow proportional composite.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001

1. The Discharger shall monitor secondary treated effluent at EFF-001 as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

Table E-3. Effluent Monitoring

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|---|-----------------|------------------------------|----------------------------|---------------------------------|
| Aluminum, Total Recoverable | µg/L | Grab | 1/month | 1 |
| Ammonia Nitrogen, Total (as N) ^{2,3} | mg/L | Grab | 1/week | 1 |
| Arsenic, Total Recoverable ⁶ | µg/L | Grab | 1/month | 1 |
| Bis (2-chloroethyl) ether ⁶ | µg/L | Grab | 1/quarter | 1 |
| Biochemical Oxygen Demand, 5-day @ 20°C (BOD ₅) | mg/L lbs/day | 24-hr Composite ⁵ | 1/week | 1 |
| Boron, Total Recoverable | µg/L | Grab | 1/quarter | 1 |
| Chlorine, Total Residual | mg/L | Meter | continuous ⁴ | 1 |
| Coliform, Total | MPN/100 mL | Grab | 1/week | 1 |
| Copper, Total Recoverable ⁶ | µg/L | Grab | 1/month | 1 |
| Diazinon | µg/L | Grab | 1/quarter | 1 |
| Dibromochloromethane ⁶ | µg/L | Grab | 1/month | 1 |
| Dichlorobromomethane ⁶ | µg/L | Grab | 1/month | 1 |
| Dissolved Oxygen | mg/L | Grab | 1/week | 1 |
| Electrical Conductivity @ 25°C | µmhos/cm | Grab | 1/month | 1 |
| Flow | mgd | Meter | continuous | 1 |
| Iron, Total Recoverable | µg/L | Grab | 1/month | 1 |
| Lead, Total Recoverable ⁶ | µg/L | Grab | 1/month | 1 |
| Manganese, Total Recoverable | µg/L | Grab | 1/month | 1 |
| Mercury, Total Recoverable | µg/L | Grab | 1/quarter | 1 |
| Mercury, methyl | µg/L | Grab | 1/quarter | 1 |
| Nitrate (as N) | mg/L | Grab | 1/month | 1 |
| Nitrite (as N) | mg/L | Grab | 1/month | 1 |
| Oil and Grease | mg/L | Grab | 1/month | 1 |
| pH | Standard Units | Grab | 5 days/week | 1 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|------------------------|-----------------|---------------------------------|----------------------------|---------------------------------|
| Settleable Solids | mL/L | Grab | 1/month | 1 |
| Temperature | °F | Grab | 5 days/week | 1 |
| Total Dissolved Solids | mg/L | Grab | 1/month | 1 |
| Total Suspended Solids | mg/L lbs/day | 24-hr Composite ⁵ | 1/week | 1 |

¹ As required by 40 CFR Part 136.

² Concurrent with whole effluent toxicity monitoring.

³ Report as total.

⁴ Continuous monitoring required **within 6 months of the effective date of this Order**. In the interim, grab samples with a minimum sampling frequency of 5/week is required. Total residual chlorine must be monitored with a method sensitive to and accurate at the permitted level of 0.01 mg/L.

⁵ 24-hour flow proportioned composite.

⁶ For priority pollutant constituents with effluent limitations, detection limits shall be below the effluent limitations. If the lowest minimum level (ML) published in Appendix 4 of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Plan or SIP) is not below the effluent limitation, the detection limit shall be the lowest ML. For priority pollutant constituents without effluent limitations, the detection limits shall be equal to or less than the lowest ML published in Appendix 4 of the SIP.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

- A. **Acute Toxicity Testing.** The Discharger shall conduct acute toxicity testing to determine whether the effluent is contributing acute toxicity to the receiving water. The Discharger shall meet the following acute toxicity testing requirements:
- Monitoring Frequency – The Discharger shall perform quarterly acute toxicity testing, concurrent with effluent ammonia sampling.
 - Sample Types – For static non-renewal and static renewal testing, the samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location EFF-001.
 - Test Species – Test species shall be fathead minnows (*Pimephales promelas*).
 - Methods – The acute toxicity testing samples shall be analyzed using EPA-821-R-02-012, Fifth Edition. Temperature, total residual chlorine, and pH shall be recorded at the time of sample collection. No pH adjustment may be made unless approved by the Executive Officer.
 - Test Failure – If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.

B. **Chronic Toxicity Testing.** The Discharger shall conduct three species chronic toxicity testing to determine whether the effluent is contributing chronic toxicity to the receiving water. The Discharger shall meet the following chronic toxicity testing requirements:

1. Monitoring Frequency – The Discharger shall perform annual three species chronic toxicity testing.
2. Sample Types – Effluent samples shall be 24-hour composite samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at the effluent monitoring location specified in the Monitoring and Reporting Program. The receiving water control shall be a grab sample obtained from the RSW-001 sampling location, as identified in the Monitoring and Reporting Program.
3. Sample Volumes – Adequate sample volumes shall be collected to provide renewal water to complete the test in the event that the discharge is intermittent.
4. Test Species – Chronic toxicity testing measures sublethal (e.g. reduced growth, reproduction) and/or lethal effects to test organisms exposed to an effluent compared to that of the control organisms. The Discharger shall conduct chronic toxicity tests with:
 - The cladoceran, water flea, *Ceriodaphnia dubia* (survival and reproduction test);
 - The fathead minnow, *Pimephales promelas* (larval survival and growth test); and
 - The green alga, *Selenastrum capricornutum* (growth test).
5. Methods – The presence of chronic toxicity shall be estimated as specified in *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821-R-02-013, October 2002.*
6. Reference Toxicant – As required by the SIP, all chronic toxicity tests shall be conducted with concurrent testing with a reference toxicant and shall be reported with the chronic toxicity test results.
7. Dilutions – The chronic toxicity testing shall be performed using the dilution series identified in Table E-4, below. The receiving water control shall be used as the diluent (unless the receiving water is toxic).
8. Test Failure – The Discharger must re-sample and re-test as soon as possible, but no later than fourteen (14) days after receiving notification of a test failure. A test failure is defined as follows:
 - a. The reference toxicant test or the effluent test does not meet all test acceptability criteria as specified in the *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition,*

EPA/821-R-02-013, October 2002 (Method Manual), and its subsequent amendments or revisions; or

- b. The percent minimum significant difference (PMSD) measured for the test exceeds the upper PMSD bound variability criterion in Table 6 on page 52 of the Method Manual. (A retest is only required in this case if the test results do not exceed the monitoring trigger specified in Special Provisions VI.C.2.a.iii.)

Table E-4. Chronic Toxicity Testing Dilution Series

| Sample | Dilutions (%) | | | | | Controls | |
|--------------------|---------------|----|------|-------|--------|-----------------|------------------|
| | 50 | 25 | 12.5 | 6.25 | 3.125 | Receiving Water | Laboratory Water |
| % Effluent | 50 | 25 | 12.5 | 6.25 | 3.125 | 0 | 0 |
| % Receiving Water | 50 | 75 | 87.5 | 93.75 | 96.875 | 100 | 0 |
| % Laboratory Water | 0 | 0 | 0 | 0 | 0 | 0 | 100 |

C. **WET Testing Notification Requirements.** The Discharger shall notify the Regional Water Board within 24-hrs after the receipt of test results exceeding the monitoring trigger during regular or accelerated monitoring, or an exceedance of the acute toxicity effluent limitation.

D. **WET Testing Reporting Requirements.** All toxicity test reports shall include the contracting laboratory's complete report provided to the Discharger and shall be in accordance with the appropriate "Report Preparation and Test Review" sections of the method manuals. At a minimum, whole effluent toxicity monitoring shall be reported as follows:

1. **Chronic WET Reporting.** Regular chronic toxicity monitoring results shall be reported to the Regional Water Board within 30 days following completion of the test, and shall contain, at minimum:
 - a. The results expressed in TUC, measured as 100/NOEC, and also measured as 100/LC₅₀, 100/EC₂₅, 100/IC₂₅, and 100/IC₅₀, as appropriate;
 - b. The statistical methods used to calculate endpoints;
 - c. The statistical output page, which includes the calculation of the PMSD;
 - d. The dates of sample collection and initiation of each toxicity test; and
 - e. The results compared to the numeric toxicity monitoring trigger.

Additionally, the monthly discharger self-monitoring reports shall contain an updated chronology of chronic toxicity test results expressed in TUC, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency, i.e., either quarterly, monthly, accelerated, or TRE.

2. **Acute WET Reporting.** Acute toxicity test results shall be submitted with the monthly discharger self-monitoring reports and reported as percent survival.
3. **TRE Reporting.** Reports for Toxicity Reduction Evaluations shall be submitted in accordance with the schedule contained in the Discharger's approved TRE Work Plan.
4. **Quality Assurance (QA).** The Discharger must provide the following information for QA purposes:
 - a. Results of the applicable reference toxicant data with the statistical output page giving the species, NOEC, LOEC, type of toxicant, dilution water used, concentrations used, PMSD, and dates tested.
 - b. The reference toxicant control charts for each endpoint, which include summaries of reference toxicant tests performed by the contracting laboratory.
 - c. Any information on deviations or problems encountered and how they were dealt with.

VI. LAND DISCHARGE MONITORING REQUIREMENTS

[Not applicable]

VII. RECLAMATION MONITORING REQUIREMENTS

[Not applicable]

VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER

A. Monitoring Locations RSW-001 and RSW-002

1. The Discharger shall monitor the Sacramento River at RSW-001 and RSW-002 as follows:

Table E-5. Receiving Water Monitoring Requirements²

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|--------------------------------|----------------|-------------|----------------------------|---------------------------------|
| Dissolved Oxygen | mg/L | Grab | 1/quarter | 1 |
| Temperature | °F | Grab | 1/quarter | 1 |
| Turbidity | NTU | Grab | 1/quarter | 1 |
| Electrical Conductivity @ 25°C | µmhos/cm | Grab | 1/quarter | 1 |
| pH | Standard Units | Grab | 1/quarter | 1 |
| Total Dissolved Solids | mg/L | Grab | 1/quarter | 1 |

¹ As required by 40 CFR Part 136.

² Shall report Sacramento River flow (cfs) and the flow direction at the time of sampling.

IX. OTHER MONITORING REQUIREMENTS

A. Biosolids

1. Monitoring Location BIO-001

1. A composite sample of sludge shall be collected annually at Monitoring Location BIO-001 in accordance with USEPA's *POTW Sludge Sampling and Analysis Guidance Document*, August 1989, and tested for priority pollutants listed in 40 CFR Part 122 Appendix D, Tables II and III (excluding total phenols).
2. A composite sample of sludge shall be collected in accordance with USEPA's *POTW Sludge Sampling and Analysis Guidance Document*, August 1989, and tested for the metals listed in Title 22.
3. Sampling records shall be retained for a minimum of **5 years**. A log shall be kept of sludge quantities generated and of handling and disposal activities. The frequency of entries is discretionary; however, the log should be complete enough to serve as a basis for part of the annual report.
4. Upon removal of sludge, the Discharger shall submit characterization of sludge quality, including sludge percent solids and quantitative results of chemical analysis for the priority pollutants listed in 40 CFR Part 122 Appendix D, Tables II and III (excluding total phenols). Suggested methods for analysis of sludge are provided in USEPA publications titled "Test Methods for Evaluating Solid Waste: Physical/Chemical Methods" and "Test Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater". Recommended analytical holding times for sludge samples should reflect those specified in 40 CFR 136.6.3(e). Other guidance is available in USEPA's *POTW Sludge Sampling and Analysis Guidance Document*, August 1989.

B. Municipal Water Supply

1. Monitoring Location SPL-001

The Discharger shall monitor the Municipal Water Supply at SPL-001 as follows. A sampling station shall be established where a representative sample of the municipal water supply can be obtained. Municipal water supply samples shall be collected at approximately the same time as effluent samples.

Table E-6. Municipal Water Supply Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|---|----------|-------------|----------------------------|---------------------------------|
| Total Dissolved Solids | mg/L | Grab | 1/quarter | 2 |
| Electrical Conductivity @ 25°C ¹ | µmhos/cm | Grab | 1/quarter | 2 |

¹ If the water supply is from more than one source, the EC shall be reported as a weighted average and include copies of supporting calculations.

² As required by 40 CFR Part 136.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. Upon written request of the Regional Water Board, the Discharger shall submit a summary monitoring report. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year(s).
3. **Compliance Time Schedules.** For compliance time schedules included in the Order, the Discharger shall submit to the Regional Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Regional Water Board by letter when it returns to compliance with the compliance time schedule.
4. The Discharger shall report to the Regional Water Board any toxic chemical release data it reports to the State Emergency Response Commission within 15 days of reporting the data to the Commission pursuant to section 313 of the "Emergency Planning and Community Right to Know Act of 1986".
5. **Reporting Protocols.** The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
 - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
6. **Multiple Sample Data.** When determining compliance with an AMEL , AWEL, or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
- a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

B. Self Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. Monitoring results shall be submitted to the Regional Water Board by the **first day** of the second month following sample collection. Quarterly and annual monitoring

results shall be submitted by the **first day of the second month following each calendar quarter, semi-annual period, and year**, respectively.

3. In reporting the monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner to illustrate clearly whether the discharge complies with waste discharge requirements. The highest daily maximum for the month, monthly and weekly averages, and medians, and removal efficiencies (%) for BOD and Total Suspended Solids, shall be determined and recorded as needed to demonstrate compliance.
4. With the exception of flow, all constituents monitored on a continuous basis (metered), shall be reported as daily maximums, daily minimums, and daily averages; flow shall be reported as the total volume discharged per day for each day of discharge.
5. If the Discharger monitors any pollutant at the locations designated herein more frequently than is required by this Order, the results of such monitoring shall be included in the calculation and reporting of the values required in the discharge monitoring report form. Such increased frequency shall be indicated on the discharge monitoring report form.
6. A letter transmitting the self-monitoring reports shall accompany each report. Such a letter shall include a discussion of requirement violations found during the reporting period, and actions taken or planned for correcting noted violations, such as operation or facility modifications. If the Discharger has previously submitted a report describing corrective actions and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory. The transmittal letter shall contain the penalty of perjury statement by the Discharger, or the Discharger's authorized agent, as described in the Standard Provisions.
7. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

Regional Water Quality Control Board
Central Valley Region
11020 Sun Center Dr., Suite #200
Rancho Cordova, CA 95670-6114

8. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-7. Monitoring Periods and Reporting Schedule

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period | SMR Due Date |
|--------------------|---|---|---|
| Continuous | First day of calendar month following permit effective date | All | Submit with monthly SMR |
| 5 days/week | Monday following first day of calendar month following permit effective date | Monday through Friday | Submit with monthly SMR |
| 1/week | Sunday following first day of calendar month following permit effective date | Sunday through Saturday | Submit with monthly SMR |
| 1/month | First day of calendar month following permit effective date | First day of calendar month through last day of calendar month | Submit with monthly SMR |
| 1/quarter | Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date | January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31 | 1 May 1 August 1 November 1 February |
| 1/year | January 1 following (or on) permit effective date | January 1 through December 31 | 1 February following the year of sampling |

C. Discharge Monitoring Reports (DMRs)

[Not applicable]

D. Other Reports

- 1. Progress Reports.** As specified in the compliance time schedules required in Special Provisions VI, progress reports shall be submitted in accordance with the following reporting requirements. At minimum, the progress reports shall include a discussion of the status of final compliance, whether the Discharger is on schedule to meet the final compliance date, and the remaining tasks to meet the final compliance date.
- 2. Within 60 days** of permit adoption, the Discharger shall submit a report outlining minimum levels, method detection limits, and analytical methods for approval, with a goal to achieve detection levels below applicable water quality criteria. At a minimum, the Discharger shall comply with the monitoring requirements for CTR constituents as outlined in Section 2.3 and 2.4 of the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*, adopted 2 March 2000 by the State Water Resources Control Board. All peaks identified by analytical methods shall be reported.
- 3. The Discharger's sanitary sewer system** collects wastewater using sewers, pipes, pumps, and/or other conveyance systems and directs the raw sewage to the wastewater treatment plant. A "sanitary sewer overflow" is defined as a discharge to ground or surface water from the sanitary sewer system at any point upstream of the wastewater treatment plant. Sanitary sewer overflows are prohibited by this Order. All violations must be reported as required in Standard Provisions. Facilities (such as wet wells, regulated impoundments, tanks, highlines, etc.) may be part of a

sanitary sewer system and discharges to these facilities are not considered sanitary sewer overflows, provided that the waste is fully contained within these temporary storage facilities.

4. **Annual Operations Report.** By **30 January** of each year, the Discharger shall submit a written report to the Executive Officer containing the following:
 - a. The names, certificate grades, and general responsibilities of all persons employed at the Facility.
 - b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
 - c. A statement certifying when the flow meter(s) and other monitoring instruments and devices were last calibrated, including identification of who performed the calibration.
 - d. A statement certifying whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last revised and last reviewed for adequacy.
 - e. The Discharger may also be requested to submit an annual report to the Regional Water Board with both tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the compliance record. If violations have occurred, the report shall also discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

ATTACHMENT F – FACT SHEET

Table of Contents

| | | |
|---|----|-------------|
| Attachment F – Fact Sheet | 1 | |
| I. Permit Information | 1 | |
| II. Facility Description | 2 | |
| A. Description of Wastewater and Biosolids Treatment or Controls | 2 | |
| B. Discharge Points and Receiving Waters | 2 | |
| C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data | 3 | |
| D. Compliance Summary | 4 | |
| E. Planned Changes | 5 | |
| III. Applicable Plans, Policies, and Regulations | 5 | |
| A. Legal Authority | 5 | |
| B. California Environmental Quality Act (CEQA) | 5 | |
| C. State and Federal Regulations, Policies, and Plans | 5 | |
| D. Impaired Water Bodies on CWA 303(d) List | 8 | |
| E. Other Plans, Policies and Regulations | 8 | |
| IV. Rationale For Effluent Limitations and Discharge Specifications | 9 | |
| A. Discharge Prohibitions | 10 | |
| B. Technology-Based Effluent Limitations | 10 | |
| 1. Scope and Authority | 10 | |
| 2. Applicable Technology-Based Effluent Limitations | 11 | |
| C. Water Quality-Based Effluent Limitations (WQBELs) | 12 | |
| 1. Scope and Authority | 12 | |
| 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives | 12 | Deleted: 16 |
| 3. Determining the Need for WQBELs | 18 | Deleted: 33 |
| 4. WQBEL Calculations | 35 | Deleted: 38 |
| 5. Whole Effluent Toxicity (WET) | 40 | Deleted: 39 |
| D. Final Effluent Limitations | 41 | Deleted: 39 |
| 1. Mass-based Effluent Limitations | 41 | Deleted: 40 |
| 2. Averaging Periods for Effluent Limitations | 42 | Deleted: 40 |
| 3. Satisfaction of Anti-Backsliding Requirements | 42 | Deleted: 41 |
| 4. Satisfaction of Antidegradation Policy | 43 | Deleted: 43 |
| E. Interim Effluent Limitations | 45 | Deleted: 43 |
| F. Land Discharge Specifications | 46 | Deleted: 44 |
| G. Reclamation Specifications | 46 | Deleted: 44 |
| V. Rationale for Receiving Water Limitations | 46 | Deleted: 44 |
| A. Surface Water | 47 | Deleted: 45 |
| B. Groundwater | 50 | Deleted: 48 |
| VI. Rationale for Monitoring and Reporting Requirements | 50 | Deleted: 48 |
| A. Influent Monitoring | 50 | Deleted: 48 |
| B. Effluent Monitoring | 51 | Deleted: 49 |
| C. Whole Effluent Toxicity Testing Requirements | 51 | Deleted: 49 |
| D. Receiving Water Monitoring | 51 | Deleted: 49 |
| 1. Surface Water | 51 | Deleted: 49 |
| 2. Groundwater | 52 | Deleted: 50 |
| E. Other Monitoring Requirements | 52 | Deleted: 50 |

Deleted: CA0078018

FACILITY NAME
 PERMITS
 NPDES
 RPD
 CA0079588

| | | |
|---|----|-------------|
| VII. Rationale for Provisions..... | 52 | Deleted: 50 |
| A. Standard Provisions..... | 52 | Deleted: 50 |
| B. Special Provisions..... | 53 | Deleted: 51 |
| 1. Reopener Provisions..... | 53 | Deleted: 51 |
| 2. Special Studies and Additional Monitoring Requirements..... | 54 | Deleted: 52 |
| 3. Best Management Practices and Pollution Prevention..... | 57 | Deleted: 55 |
| 4. Construction, Operation, and Maintenance Specifications..... | 57 | Deleted: 55 |
| 5. Special Provisions for Municipal Facilities..... | 57 | Deleted: 55 |
| 6. Other Special Provisions..... | 58 | Deleted: 56 |
| 7. Compliance Schedules..... | 58 | Deleted: 56 |
| VIII. Public Participation..... | 58 | Deleted: 56 |
| A. Notification of Interested Parties..... | 58 | Deleted: 56 |
| B. Written Comments..... | 59 | Deleted: 56 |
| C. Public Hearing..... | 59 | Deleted: 57 |
| D. Waste Discharge Requirements Petitions..... | 59 | Deleted: 57 |
| E. Information and Copying..... | 60 | Deleted: 57 |
| F. Register of Interested Persons..... | 60 | Deleted: 58 |
| G. Additional Information..... | 60 | Deleted: 58 |

List of Tables

| | | |
|--|----|-------------|
| Table F-1. Facility Information..... | 1 | |
| Table F-2. Historic Effluent Limitations and Monitoring Data..... | 3 | |
| Table F-3. Historic Interim Effluent Limitations and Monitoring Data..... | 4 | |
| Table F-4. Summary of Technology-based Effluent Limitations..... | 11 | |
| Table F-5. Salinity Water Quality Criteria/Objectives & Plant Effluent Data..... | 31 | Deleted: 29 |
| Table F-6. Basin Plan Water Quality Objectives for EC..... | 32 | Deleted: 30 |
| Table F-7. Historical Compliance with EC objectives at Emmaton..... | 32 | Deleted: 30 |
| Table F-8. WQBEL Calculations for Aluminium..... | 37 | Deleted: 35 |
| Table F-9. WQBEL Calculations for Ammonia..... | 37 | Deleted: 35 |
| Table F-10. WQBEL Calculations for Copper..... | 38 | Deleted: 36 |
| Table F-11. WQBEL Calculations for Dibromochloromethane..... | 38 | Deleted: 36 |
| Table F-12. WQBEL Calculations for Dichlorobromomethane..... | 38 | Deleted: 36 |
| Table F-13. WQBEL Calculations for Lead..... | 39 | Deleted: 36 |
| Table F-14. Summary of Water Quality-based Effluent Limitations..... | 39 | Deleted: 37 |
| Table F-15. Chronic Toxicity Exceedances..... | 41 | Deleted: 37 |
| Table F-16. Summary of Final Effluent Limitations..... | 44 | Deleted: 39 |
| Table F-17. Performance-based Effluent Limitation Calculation Summary..... | 46 | Deleted: 42 |
| | | Deleted: 44 |

ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

| | |
|---|--|
| WDID | |
| Discharger | City of Rio Vista |
| Name of Facility | City of Rio Vista Beach Wastewater Treatment Facility |
| Facility Address | 1000 Beach Drive |
| | Rio Vista, CA 94571 |
| | Solano County |
| Facility Contact, Title and Phone | Project Manager, 707-374-2633 |
| Authorized Person to Sign and Submit Reports | Public Works Director, 707-374-6451 |
| Mailing Address | One Main Street, Rio Vista, CA 94571 |
| Billing Address | Same as Mailing Address |
| Type of Facility | POTW |
| Major or Minor Facility | Minor |
| Threat to Water Quality | 2 |
| Complexity | B |
| Pretreatment Program | N |
| Reclamation Requirements | NA |
| Facility Permitted Flow | Average daily discharge flow of 0.65 million gallons per day (mgd) |
| Facility Design Flow | Average daily discharge flow of 0.65 mgd |
| Watershed | Sacramento River |
| Receiving Water | Sacramento River |
| Receiving Water Type | Sacramento-San Joaquin Delta |

Deleted: Doug Little, Associate

Deleted: 2930

Deleted: Brent Salmi,

A. Veolia Water Company is the operator of the City of Rio Vista Beach Wastewater Treatment Facility (hereinafter referred to as Facility), which is owned by the City of Rio Vista. The U.S. Army Corps of Engineers owns the property at 1000 Beach Drive and

has granted the City of Rio Vista a right of way in order to operate and maintain its sewage treatment and pumping facility on this property.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B. The Facility discharges secondary level treated wastewater to the Sacramento River within the Sacramento-San Joaquin Delta, a water of the United States, and is currently regulated by Order No. 5-01-178 which was adopted on 14 June 2001 and expired on 1 June 2006. The terms and conditions of the current Order have been automatically continued and remain in effect until new Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit are adopted pursuant to this Order.
- C. The Discharger filed a report of waste discharge and submitted an application for renewal of its WDRs and NPDES permit on 13 March 2006.

II. FACILITY DESCRIPTION

The City of Rio Vista Beach Wastewater Treatment Facility provides sewerage service for the City of Rio Vista community and serves a population of approximately 4,500 people. The Facility design average daily discharge flow capacity is 0.65 million gallons per day (mgd).

A. Description of Wastewater and Biosolids Treatment or Controls

The treatment system at the Facility consists of bar screening and grit removal, two primary clarifiers, two activated sludge reactors, two secondary clarifiers, and chlorination/dechlorination. Sludge is dewatered using a dry-vac treatment process (plate and frame press using chemical treatment and heat to produce a Class “A” biosolids) and has the ability to also use lined drying beds. The dried biosolids are disposed offsite at local agricultural sites or to a local landfill. The Facility average daily discharge treatment capacity is 0.65 mgd and the peak wet weather design flow (PWWF) is 2.3 mgd. Effluent flow monitoring data during the previous permit term recorded the highest wet weather daily flow of 1.42 mgd.

Deleted: Sludge is dewatered on drying beds (lined and unlined) and disposed offsite at a local landfill.

B. Discharge Points and Receiving Waters

1. The Facility is located in Section 31, T4N, R3E, MDB&M, as shown in Attachment B, a part of this Order.
2. Treated municipal wastewater is discharged 77 feet offshore at Discharge Point No. 001 to the Sacramento River, a water of the United States, at a point latitude 38° 08' 31" N and longitude 121° 41' 34" W.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the existing Order for discharges from Discharge Point No. 001 (Monitoring Location EFF-001) from the term of the previous Order are summarized below:

1. The effluent could not exceed the following final effluent limits:

Table F-2. Historic Effluent Limitations and Monitoring Data

| Parameter | Units | Effluent Limitation | | | Effluent Monitoring Data (August 2001- August 2006) | | |
|---|----------------------|----------------------|----------------|-----------------|---|----------------------------------|-------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Highest Average Monthly Discharge | Highest Average Weekly Discharge | Highest Daily Discharge |
| Biochemical Oxygen Demand, 5-day @20°C (BOD ₅) ¹ | mg/L | 30 | 45 | 60 | 34 | 97 | 97 |
| | lbs/day ² | 163 | 244 | 326 | 128 | 421 | 421 |
| | lbs/day ³ | 575 | 863 | 1,151 | 129 | 319 | 319 |
| | % removal | 85 | -- | -- | 84 | -- | -- |
| Total Suspended Solids (TSS) ¹ | mg/L | 30 | 45 | 60 | 84 | 159 | 300 |
| | lbs/day ² | 163 | 244 | 326 | 343 | 644 | 1,213 |
| | lbs/day ³ | 575 | 863 | 1,151 | 100 | 193 | 193 |
| | % removal | 85 | -- | -- | 33 | -- | -- |
| Total Coliform | MPN/100 mL | Monthly Median of 23 | | 500 | Maximum Monthly Median of 1260 | | 1,600 |
| Settleable Solids | ml/L | 0.1 | -- | 0.2 | 1.48 | -- | 45 |
| Chlorine Residual | mg/L | 0.01 | -- | 0.02 | 6.4 | -- | 10 |
| | lbs/day ² | 0.054 | -- | 0.109 | NA | -- | NA |
| | lbs/day ³ | 0.192 | -- | 0.384 | NA | -- | NA |
| Oil and Grease | mg/L | 10 | -- | 15 | 1.1 | -- | 1.1 |
| | lbs/day ² | 55 | -- | 82 | ND | -- | ND |
| | lbs/day ³ | 192 | -- | 288 | 5.4 | -- | 5.4 |
| Arsenic | mg/L | 6.36 | -- | 12.8 | 20 | -- | 20 |
| | lbs/day ² | 34.5 | -- | 69.4 | 63 | -- | 63 |
| | lbs/day ³ | 122 | -- | 246 | 69 | -- | 69 |
| pH | SU | 6.5-8.5 | | | 5.9-8.5 | | |
| Flow ⁶ | mgd | 0.65 | -- | -- | 0.63 | -- | -- |
| Acute Toxicity | % survival | 7 | | | Minimum of 75 | | |
| Persistent Chlorinated Hydrocarbon Pesticides ⁵ | µg/L | -- | -- | ND ⁴ | -- | -- | ND ⁴ |
| | lbs/day ² | -- | -- | ND | -- | -- | ND |

NA= Not available.

ND= Reported as non-detect.

- ¹ To be ascertained by a 24-hour composite.
- ² Based upon a design treatment capacity of 0.65 mgd (applicable May-October).
- ³ Based upon a design peak wet weather flow capacity of 2.3 mgd (applicable November-April).
- ⁴ Each persistent chlorinated hydrocarbon pesticide shall be ND (non-detectable). The Discharger shall use USEPA standard analytical techniques that have the lowest practical level for the persistent chlorinated hydrocarbon pesticides with a minimum acceptable reporting level as indicated in Appendix 4 of the SIP. Persistent chlorinated hydrocarbon pesticides include alpha BHC, aldrin, alpha endosulfan, beta endosulfan, beta BHC, gamma BHC (lindane), delta BHC, 4,4'-DDD, 4,4'-DDE, 4,4'-DDT, chlordane, dieldrin, endrin, endrin aldehyde, endosulfan sulfate, heptachlor, heptachlor epoxide, and toxaphene.
- ⁵ Full compliance with this limitation is not required until 1 June 2006.
- ⁶ The average dry weather (May through October) flow.
- ⁷ Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:
 - Minimum for any one bioassay-----70%
 - Median for any three or more consecutive bioassays-----90%.

2. The following effluent limitations were in effect as interim limitations until a dilution/mixing zone study was completed and final limits established.

Table F-3. Historic Interim Effluent Limitations and Monitoring Data

| Parameter | Units | Effluent Limitation | | | Monitoring Data August 2001 – August 2006 | | |
|--------------|----------------------|---------------------|----------------|---------------|--|----------------------------------|-------------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Highest Average Monthly Discharge | Highest Average Weekly Discharge | Highest Daily Discharge |
| Aluminum | µg/L | -- | -- | 1,053 | -- | -- | 100 |
| | lbs/day ¹ | -- | -- | 5.7 | -- | -- | 2.4 |
| | lbs/day ² | -- | -- | 20.2 | -- | -- | 7.8 |
| Ammonia as N | mg N/L | -- | -- | 89.3 | -- | -- | 30 |
| | lbs/day ¹ | -- | -- | 484 | -- | -- | 69 |
| | lbs/day ² | -- | -- | 1,713 | -- | -- | 168 |

¹ Based upon a design treatment capacity of 0.65 mgd (applicable May-October).
² Based upon a design peak wet weather flow capacity of 2.3 mgd (applicable November-April).

D. Compliance Summary

The following compliance summary applies to the Facility during the term of Order No. 5-01-178 (NPDES Permit No. CA0079588).

1. Administrative Civil Liability (ACL) Order No. R5-01-185 assessed mandatory penalties for violations of Waste Discharge Requirements Order No. 5-01-178 in the amount of \$30,000. The ACL Order allowed the City to complete a project to achieve full compliance with the permit by 14 December 2006 in lieu of paying the penalty.

Further review indicated that the plant expansion was designed to correct the violations which resulted in mandatory penalties, and that the expansion was completed in August 2001.

On 12 December 2001, a site visit was conducted to review plant operations after completion of the expansion, and to evaluate compliance with the current Waste

Discharge Requirements. At the time of the inspection the Facility was found to be operating improperly. As a result a Notice of Violation was issued on 3 January 2002. In response to the Notice of Violation, the Facility submitted a Summary Report on 1 February 2002 detailing corrective measures taken.

2. Based on data contained in self-monitoring reports from July 2001 through September 2006, the Facility exceeded total coliform effluent limitations numerous times. The highest recorded exceedance for total coliform monthly median was 1260 MPN/100 mL (the monthly median limitation was 23 MPN/100 mL), and several times the highest recorded daily maximum for total coliform was reported as >1600 MPN/100 mL (the daily maximum limitation was 500 MPN/100 mL).

E. Planned Changes

According to a letter to the Regional Water Board from Mr. Brent Salmi of the City of Rio Vista on 13 March 2006 regarding Rio Vista Main WWTF NPDES Permit Renewal Forms, the City is considering whether it can implement either of the following two long-term plans:

1. Redirect the Facility influent flow to the new Northwest Wastewater Treatment Facility (WWTF) site and discharge effluent to the Sacramento River at that location.
2. Add effluent filters to the existing Facility, and begin the process of attempting to stabilize the Facility site to reduce the risk of site liquefaction in the event of a major earthquake.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the applicable plans, policies, and regulations identified in section II of the Limitations and Discharge Requirements (Findings). This section provides supplemental information, where appropriate, for the plans, policies, and regulations relevant to the discharge.

A. Legal Authority

See Limitations and Discharge Requirements - Findings, Section II.C.

B. California Environmental Quality Act (CEQA)

See Limitations and Discharge Requirements - Findings, Section II.E.

C. State and Federal Regulations, Policies, and Plans

1. **Water Quality Control Plans.** The Regional Water Board adopted a *Water Quality Control Plan, Fourth Edition (Revised February 2007), for the Sacramento and San Joaquin River Basins Lake Basin* (Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, State Water Board Resolution No. 88-63 requires that, with certain

exceptions, the Regional Water Board assign the municipal and domestic supply use to water bodies that do not have beneficial uses listed in the Basin Plan. The beneficial uses of the Sacramento River within the Sacramento-San Joaquin Delta downstream of the discharge are municipal and domestic supply, agricultural irrigation, agricultural stock watering, industrial process supply, industrial service supply, water contact recreation, other non-contact water recreation, warm freshwater habitat, cold freshwater habitat, migration of aquatic organisms (cold and warm), warm spawning habitat, wildlife habitat, and navigation.

The Basin Plan on page II-1.00 states: "*Protection and enhancement of existing and potential beneficial uses are primary goals of water quality planning...*" and with respect to disposal of wastewaters states that "*...disposal of wastewaters is [not] a prohibited use of waters of the State; it is merely a use which cannot be satisfied to the detriment of beneficial uses.*"

The federal CWA section 101(a)(2), states: "*it is the national goal that wherever attainable, an interim goal of water quality which provides for the protection and propagation of fish, shellfish, and wildlife, and for recreation in and on the water be achieved by July 1, 1983.*" Federal Regulations, developed to implement the requirements of the CWA, create a rebuttable presumption that all waters be designated as fishable and swimmable. Federal Regulations, 40 CFR 131.2 and 131.10, require that all waters of the State regulated to protect the beneficial uses of public water supply, protection and propagation of fish, shell fish and wildlife, recreation in and on the water, agricultural, industrial and other purposes including navigation. Section 131.3(e), 40 CFR, defines existing beneficial uses as those uses actually attained after November 28, 1975, whether or not they are included in the water quality standards. Federal Regulation, 40 CFR 131.10 requires that uses be obtained by implementing effluent limitations, requires that all downstream uses be protected and states that in no case shall a state adopt waste transport or waste assimilation as a beneficial use for any waters of the United States.

2. **Thermal Plan.** The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on 18 May 1972, and amended this plan on 18 September 1975. This plan contains temperature objectives for surface waters. Since the Facility discharges to the Sacramento-San Joaquin Delta, the Thermal Plan is applicable to the discharge. Requirements of this Order implement the Thermal Plan.
3. **Bay-Delta Plan.** The *Water Quality Control Plan for the San Francisco Bay/Sacramento-San Joaquin Delta Estuary* (Bay-Delta Plan) was adopted in May 1995 by the State Water Board superseding the 1991 Bay-Delta Plan. The Bay-Delta Plan identifies the beneficial uses of the estuary and includes objectives for flow, salinity, and endangered species protection.

The Bay-Delta Plan attempts to create a management plan that is acceptable to the stakeholders while at the same time is protective of beneficial uses of the

Sacramento-San Joaquin Delta. The State Water Board adopted Decision 1641 (D-1641) on 29 December 1999. D-1641 implements flow objectives for the Bay-Delta Estuary, approves a petition to change points of diversion of the Central Valley Project and the State Water Project in the Southern Delta, and approves a petition to change places of use and purposes of use of the Central Valley Project. The water quality objectives of the Bay-Delta Plan are implemented as part of this Order.

4. **Antidegradation Policy.** Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. As discussed in detail in the Fact Sheet (Attachment F, Section IV.D.4.) the discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution 68-16.
5. **Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. Compliance with the anti-backsliding requirements is discussed in Section IV.D.3.
6. **Emergency Planning and Community Right to Know Act.** Section 13263.6(a), California Water Code, requires that *"the Regional Water Board shall prescribe effluent limitations as part of the waste discharge requirements of a POTW for all substances that the most recent toxic chemical release data reported to the state emergency response commission pursuant to Section 313 of the Emergency Planning and Community Right to Know Act of 1986 (42 U.S.C. Sec. 11023) (EPCRA) indicate as discharged into the POTW, for which the State Water Board or the Regional Water Board has established numeric water quality objectives, and has determined that the discharge is or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to, an excursion above any numeric water quality objective"*.

The most recent toxic chemical data report does not indicate any reportable off-site releases or discharges to the collection system for this Facility. Therefore, a reasonable potential analysis based on information from Emergency Planning and Community Right to Know Act (EPCRA) cannot be conducted. Based on information from EPCRA, there is no reasonable potential to cause or contribute to an excursion above any numeric water quality objectives included within the Basin Plan or in any State Water Board plan, so no effluent limitations are included in this permit pursuant to CWC section 13263.6(a).

However, as detailed elsewhere in this Order, available effluent data indicate that there are constituents present in the effluent that have a reasonable potential to cause or contribute to exceedances of water quality standards and require inclusion of effluent limitations based on federal and state laws and regulations.

7. **Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act.

D. Impaired Water Bodies on CWA 303(d) List

1. Under Section 303(d) of the 1972 Clean Water Act, states, territories and authorized tribes are required to develop lists of water quality limited segments. The waters on these lists do not meet water quality standards, even after point sources of pollution have installed the minimum required levels of pollution control technology. On 30 November 2006 USEPA gave final approval to California's 2006 Section 303(d) List of Water Quality Limited Segments. The Basin Plan references this list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 CFR 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to [WQLSs]. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." The listing for Delta Waterways (western portion) includes: chlorpyrifos, DDT, diazinon, electrical conductivity, exotic species, group A pesticides, mercury, and unknown toxicity.
2. **Total Maximum Daily Loads.** The USEPA requires the Regional Water Board to develop total maximum daily loads (TMDLs) for each 303(d) listed pollutant and water body combination. TMDLs for the Sacramento – San Joaquin Delta are currently being developed for diazinon, chlorpyrifos, and mercury. This Order may be reopened to apply applicable water quality-based effluent limitations upon the completion of these TMDLs.

E. Other Plans, Policies and Regulations

1. The discharge authorized herein and the treatment and storage facilities associated with the discharge of treated municipal wastewater, except for discharges of residual sludge and solid waste, are exempt from the requirements of Title 27, California Code of Regulations (CCR), section 20005 et seq. (hereafter Title 27). The

exemption, pursuant to Title 27 CCR section 20090(a), is based on the following:

- a. The waste consists primarily of domestic sewage and treated effluent;
- b. The waste discharge requirements are consistent with water quality objectives;
and
- c. The treatment and storage facilities described herein are associated with a municipal wastewater treatment plant.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

Effluent limitations and toxic and pretreatment effluent standards established pursuant to Sections 301 (Effluent Limitations), 302 (Water Quality Related Effluent Limitations), 304 (Information and Guidelines), and 307 (Toxic and Pretreatment Effluent Standards) of the Clean Water Act (CWA) and amendments thereto are applicable to the discharge.

The Federal CWA mandates the implementation of effluent limitations that are as stringent as necessary to meet water quality standards established pursuant to state or federal law [33 U.S.C., § 1311(b)(1)(C); 40 CFR 122.44(d)(1)]. NPDES permits must incorporate discharge limits necessary to ensure that water quality standards are met. This requirement applies to narrative criteria as well as to criteria specifying maximum amounts of particular pollutants. Pursuant to Federal Regulations, 40 CFR 122.44(d)(1)(i), NPDES permits must contain limits that control all pollutants that *“are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard, including state narrative criteria for water quality.”* Federal Regulations, 40 CFR 122.44(d)(1)(vi), further provide that *“[w]here a state has not established a water quality criterion for a specific chemical pollutant that is present in an effluent at a concentration that causes, has the reasonable potential to cause, or contributes to an excursion above a narrative criterion within an applicable State water quality standard, the permitting authority must establish effluent limits.”*

The CWA requires point source discharges to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations: 40 CFR 122.44(a) requires that permits include applicable technology-based limitations and standards, and 40 CFR 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water where numeric water quality objectives have not been established. The Regional Water Board’s Basin Plan, page IV-17.00, contains an implementation policy (“Policy for Application of Water Quality Objectives”) that specifies that the Regional Water Board *“will, on a case-by-case basis, adopt numerical limitations in orders which will implement the narrative objectives.”* This Policy complies with 40 CFR 122.44(d)(1). With respect to narrative objectives, the Regional Water Board must establish effluent limitations using one or more of three specified sources, including (1) USEPA’s published water quality criteria, (2) a proposed state

criterion (*i.e.*, water quality objective) or an explicit state policy interpreting its narrative water quality criteria (*i.e.*, the Regional Water Board's "Policy for Application of Water Quality Objectives")(40 CFR 122.44(d)(1) (vi) (A), (B) or (C)), or (3) an indicator parameter. The Basin Plan contains a narrative objective requiring that: "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life*" (narrative toxicity objective). The Basin Plan requires the application of the most stringent objective necessary to ensure that surface water and groundwater do not contain chemical constituents, discoloration, toxic substances, radionuclides, or taste and odor producing substances that adversely affect beneficial uses. The Basin Plan states that material and relevant information, including numeric criteria, and recommendations from other agencies and scientific literature will be utilized in evaluating compliance with the narrative toxicity objective. The Basin Plan also limits chemical constituents in concentrations that adversely affect surface water beneficial uses. For waters designated as municipal, the Basin Plan specifies that, at a minimum, waters shall not contain concentrations of constituents that exceed Maximum Contaminant Levels (MCL) of CCR Title 22. The Basin Plan further states that, to protect all beneficial uses, the Regional Water Board may apply limits more stringent than MCLs.

A. Discharge Prohibitions

1. As stated in section I.G of Attachment D, Standard Provisions, this Order prohibits bypass from any portion of the treatment facility. Federal Regulations, 40 CFR 122.41 (m), define "bypass" as the intentional diversion of waste streams from any portion of a treatment facility. This section of the Federal Regulations, 40 CFR 122.41 (m)(4), prohibits bypass unless it is unavoidable to prevent loss of life, personal injury, or severe property damage. In considering the Regional Water Board's prohibition of bypasses, the State Water Board adopted a precedential decision, Order No. WQO 2002-0015, which cites the Federal Regulations, 40 CFR 122.41(m), as allowing bypass only for essential maintenance to assure efficient operation.

B. Technology-Based Effluent Limitations

1. Scope and Authority

Regulations promulgated in section 125.3(a)(1) require technology-based effluent limitations for municipal dischargers to be placed in NPDES permits based on Secondary Treatment Standards or Equivalent to Secondary Treatment Standards.

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) established the minimum performance requirements for POTWs [defined in section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such treatment works must, as a minimum, meet effluent limitations based on secondary treatment as defined by the USEPA Administrator.

Based on this statutory requirement, USEPA developed secondary treatment regulations, which are specified in Part 133. These technology-based regulations

apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by secondary treatment in terms of biochemical oxygen demand (BOD₅), total suspended solids (TSS), and pH.

2. Applicable Technology-Based Effluent Limitations

a. **BOD₅ and TSS.** Federal Regulations, 40 CFR Part 133, establish the minimum weekly and monthly average level of effluent quality attainable by secondary treatment for BOD₅ and TSS. A daily maximum effluent limitation for BOD₅ and TSS is also included in the Order to ensure that the treatment works are not organically overloaded and operate in accordance with design capabilities. In addition, 40 CFR 133.102, in describing the minimum level of effluent quality attainable by secondary treatment, states that the 30-day average percent removal shall not be less than 85 percent. This Order contains a limitation requiring an average of 85 percent removal of BOD₅ and TSS over each calendar month.

In Order No. 5-01-178 mass loading limitations for BOD₅ and TSS were calculated using an average daily discharge flow of 0.65 mgd (applicable May through October) and a peak wet weather flow (PWWF) of 2.3 mgd (applicable November through April). This Order retains these mass loading limits.

b. **pH.** Federal Regulations, 40 CFR Part 133, also establish technology-based effluent limitations for pH. The secondary treatment standards require the pH of the effluent to be no lower than 6.0 and no greater than 9.0 standard units.

c. **Flow.** The Facility was designed to provide a secondary level of treatment for an average dry weather flow of 0.65 mgd and a peak wet weather flow of 2.3 mgd. Therefore, this Order contains an average daily discharge flow limitation of 0.65 mgd that is applicable May-October and an average daily discharge flow limitation of 2.3 mgd that is applicable November-April.

**Summary of Technology-based Effluent Limitations
 Discharge Point No. 001**

Table F-4. Summary of Technology-based Effluent Limitations

| Parameter | Units | Effluent Limitations | | | | |
|--|----------------------|----------------------|----------------|-------------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Flow | mgd | -- | -- | 0.65 ² | -- | -- |
| Flow | mgd | -- | -- | 2.3 ³ | -- | -- |
| Biochemical Oxygen Demand, 5-day @ 20°C (BOD ₅) ¹ | mg/L | 30 | 45 | 60 | -- | -- |
| | lbs/day ² | 163 | 244 | 326 | -- | -- |
| | lbs/day ³ | 575 | 863 | 1151 | -- | -- |
| Total Suspended Solids (TSS) ¹ | mg/L | 30 | 45 | 60 | -- | -- |
| | lbs/day ² | 163 | 244 | 326 | -- | -- |

| Parameter | Units | Effluent Limitations | | | | |
|-----------|----------------------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| | lbs/day ³ | 575 | 863 | 1151 | -- | -- |
| pH | SU | -- | -- | -- | 6.0 ⁴ | 9.0 ⁴ |

¹ The average monthly percent removal of BOD 5-day 20°C and total suspended solids shall not be less than 85 percent.
² Based on a design average dry weather flow capacity of 0.65 mgd (applicable May-Oct).
³ Based on a design peak wet weather flow capacity of 2.3 mgd (applicable Nov-Apr).
⁴ More stringent water quality-based effluent limitations for pH are applied in this Order.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

As specified in section 122.44(d)(1)(i), permits are required to include WQBELs for pollutants (including toxicity) that are or may be discharged at levels that cause, have reasonable potential to cause, or contribute to an in-stream excursion above any state water quality standard. The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

- a. **Receiving Water.** The Discharger discharges to the Sacramento River within the Sacramento-San Joaquin Delta. The beneficial uses of the Sacramento-San Joaquin Delta are summarized in Section III of this Fact Sheet.
- b. **Hardness.** While no effluent limitation for hardness is necessary in this Order, hardness is critical to the assessment of the need for, and the development of, effluent limitations for certain metals. The *California Toxics Rule* and the *National Toxics Rule* contain water quality criteria for seven metals that vary as a function of hardness, the lower the hardness the lower the water quality criteria. The hardness-dependent metal criteria include cadmium, copper, chromium III, lead, nickel, silver, and zinc. The equation describing the total recoverable regulatory criterion, as established in the CTR, is as follows:

$$\text{CTR Criterion} = e^{m[\ln(H)]+b} \quad (\text{Equation 1})$$

Where:

- H = Hardness
- b = metal- and criterion-specific constant
- m = metal- and criterion-specific constant

The constants “m” and “b” are specific to both the metal under consideration, and the type of total recoverable criterion (i.e. acute or chronic). The metal-specific values for these constants are provided in the CTR at paragraph (b)(2), Table 1.

The relationship between hardness and the resulting criterion in Equation 1 can exhibit either a downward-facing (i.e., concave downward) or an upward-facing (i.e., concave upward) curve depending on the values of the criterion-specific constants. The curve shapes for acute and chronic criteria for the metals are as follows:

Concave Downward: cadmium (chronic), chromium (III), copper, nickel, and zinc

Concave Upward: cadmium (acute), lead, and silver (acute)

Effluent limitations for the discharge must be set to protect the beneficial uses of the receiving water for all discharge conditions. In the absence of the option of including condition-dependent, “floating” effluent limitations that are reflective of actual hardness conditions at the time of discharge, effluent limitations must be set using a reasonable worst-case condition in order to protect beneficial uses for all discharge conditions. Recent studies indicate that using the lowest recorded receiving water hardness for establishing water quality criteria is not protective of the receiving water under various mixing conditions. The Regional Water Board has evaluated these studies and concurs that for some parameters the beneficial uses of the receiving water are best protected using the lowest hardness value of the effluent. For some parameters, the use of the lowest hardness value of the effluent and either lowest or highest hardness value of the receiving water is the most protective.

For those contaminants where the regulatory criteria exhibit a concave downward relationship as a function of hardness, use of the lowest recorded effluent hardness for establishment of water quality objectives is fully protective of all beneficial uses regardless of whether the effluent or receiving water hardness is higher. Use of the lowest recorded effluent hardness is also protective under all possible mixing conditions between the effluent and the receiving water (i.e., from high dilution to no dilution). Therefore, for cadmium (chronic), chromium (III), copper, nickel, and zinc water quality criteria were calculated using Equation 1 and a reported minimum effluent hardness of 78 mg/L as CaCO₃, based on six samples taken between January 2002 and January 2007.

For those metals where the regulatory criteria exhibit a concave upward relationship as a function of hardness, a water quality objective based on either the effluent hardness or the receiving water hardness would not be protective under all mixing scenarios. Instead, a water quality objective that accounts for both the hardness of the receiving water and the effluent is required. The following equations provide fully protective water quality criteria for those metals that exhibit a concave upward relationship.

$$\text{CTR Criterion} = \left[\frac{m}{H_{rw}} \cdot (H_{eff} - H_{rw}) + 1 \right] \cdot e^{m \cdot \ln(H_{rw}) + b} \quad (\text{Equation 2})$$

Where:

H_{eff} = Effluent hardness
H_{rw} = Receiving water hardness
b = metal- and criterion-specific constant
m = metal- and criterion-specific constant

Therefore, for cadmium (acute), lead, and silver (acute) water quality criteria were calculated using Equation 2 with a lowest reported effluent hardness of 78 mg/L as CaCO₃ and a highest reported receiving water hardness of 100 mg/L as CaCO₃, based on four samples taken between January 2002 and December 2002.

- c. **Assimilative Capacity/Mixing Zone.** The CWA directs states to adopt water quality standards to protect the quality of its waters. USEPA's current water quality standards regulation authorizes states to adopt general policies, such as mixing zones, to implement state water quality standards (40 CFR 122.44 and 122.45). The USEPA allows states to have broad flexibility in designing its mixing zone policies. Primary policy and guidance on determining mixing zone and dilution credits is provided by the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays and Estuaries of California* (State Implementation Policy or SIP) and the Basin Plan. If no procedure applies in the SIP or the Basin Plan, then the Regional Water Board may use the USEPA *Technical Support Document for Water Quality-Based Toxics Control* (EPA/505/2-90-001) (TSD).

The allowance of mixing zones by the Regional Water Board is discussed in the Basin Plan, Policy for Application of Water Quality Objectives, which states in part, "*In conjunction with the issuance of NPDES and storm water permits, the Regional Board may designate mixing zones within which water quality objectives will not apply provided the discharger has demonstrated to the satisfaction of the Regional Board that the mixing zone will not adversely impact beneficial uses. If allowed, different mixing zones may be designated for different types of objectives, including, but not limited to, acute aquatic life objectives, chronic aquatic life objectives, human health objectives, and acute and chronic whole effluent toxicity objectives, depending in part on the averaging period over which the objectives apply. In determining the size of such mixing zones, the Regional Board will consider the applicable procedures and guidelines in the EPA's Water Quality Standards Handbook and the [TSD]. Pursuant to EPA guidelines, mixing zones designated for acute aquatic life objectives will generally be limited to a small zone of initial dilution in the immediate vicinity of the discharge.*"

Section 1.4.2 of the SIP states, in part, “...with the exception of effluent limitations derived from TMDLs, in establishing and determining compliance with effluent limitations for applicable human health, acute aquatic life, or chronic aquatic life priority pollutant criteria/objectives or the toxicity objective for aquatic life protection in a basin plan, the Regional Board may grant mixing zones and dilution credits to dischargers ... The applicable priority pollutant criteria and objectives are to be met throughout a water body except within any mixing zone granted by the Regional Board. The allowance of mixing zones is discretionary and shall be determined on a discharge-by-discharge basis. The Regional Board may consider allowing mixing zones and dilution credits only for discharges with a physically identifiable point of discharge that is regulated through an NPDES permit issued by the Regional Board.”

For completely-mixed discharges, the Regional Water Board may grant a mixing zone and apply a dilution credit in accordance with Section 1.4.2.1 of the SIP. For incompletely-mixed discharges, the Discharger must perform a mixing zone study to demonstrate to the Regional Water Board that a dilution credit is appropriate. In granting a mixing zone, the SIP states that a mixing zone shall be as small as practicable, and meet the conditions provided in Section 1.4.2.2 as follows:

“A mixing zone shall be as small as practicable. The following conditions must be met in allowing a mixing zone:

A: A mixing zone shall not:

- (1) compromise the integrity of the entire water body;
- (2) cause acutely toxic conditions to aquatic life passing through the mixing zone;
- (3) restrict the passage of aquatic life;
- (4) adversely impact biologically sensitive or critical habitats, including, but not limited to, habitat of species listed under federal or State endangered species laws;
- (5) produce undesirable or nuisance aquatic life;
- (6) result in floating debris, oil, or scum;
- (7) produce objectionable color, odor, taste, or turbidity;
- (8) cause objectionable bottom deposits;
- (9) cause nuisance;
- (10) dominate the receiving water body or overlap a mixing zone from different outfalls; or
- (11) be allowed at or near any drinking water intake. A mixing zone is not a source of drinking water. To the extent of any conflict between this determination and the Sources of Drinking Water Policy (Resolution No. 88-63), this SIP supersedes the provisions of that policy.”

In Order No. 5-01-178, based on flow data at Rio Vista from the Department of Water Resources Delta Modeling Section, the worst case conditions for dilution were considered at the flow of the Sacramento River of 1,000 cfs. At the

permitted design flow of 0.65 mgd (1.0 cfs), a minimum dilution was considered to be equal to 1,000 to 1. Although the 1,000 to 1 dilution was used to perform the reasonable potential analysis and to derive effluent limitations for several constituents, the previous Order states that "...a dilution study that accurately defines the 30-day average dilution ratio that takes into account the tidal and seasonal dynamics of the area has not been conducted". Therefore, Order No. 5-01-178 required the Discharger to conduct "...a dilution/mixing zone study to address, but not limited to, whether the discharge is completely or incompletely mixed and mixing zone conditions". A Dilution/Mixing Zone Study Workplan was prepared and subsequently approved by the Regional Water Board on 26 February 2002. Effluent mixing was to be evaluated using hydrodynamic computer modeling and dye tracer studies.

The outfall consists of an 18-inch diameter pipe, which discharges 77 feet from shore at an average depth of 18.5 feet. The Sacramento River at the point of discharge is approximately 2,300 feet wide. ECO:LOGIC Engineering conducted a dilution study using CORMIX computer modeling and developed a report titled City of Rio Vista Main Wastewater Treatment Plant Dilution/Mixing Zone Study, Hydrodynamic Model of Wastewater Effluent Plume in the Sacramento River, dated 1 April 2004. The study demonstrated that within a mixing zone 250 feet (upstream and downstream) x 40 feet, the maximum effluent concentration was 4.76% (i.e. > 20:1 dilution). The plume is estimated to never get closer than 57 feet to the shoreline. This area has been established as the acute and chronic mixing zone. This is a small mixing zone as compared to the entire river width of 2,300 feet. To better monitor compliance at the edge of the mixing zone, the location of the upstream and downstream monitoring locations are located 250 feet from the discharge point.

Deleted: there is at all times at least 20:1 dilution and t

The Sacramento River in the vicinity of the discharge is tidally influenced, resulting in flow reversals. With flow reversals, some volume of river water is multiple dosed with the effluent as the river flows downstream past the discharge, reverses moving upstream past the discharge a second time, then again reverses direction and passes the discharge point a third time as it moves down the river. A particular volume of river water may move back and forth, past the discharge point many times due to tidal action, each time receiving an additional load of wastewater. CORMIX was not developed to account for multiple dosing that may occur in tidal zones. Therefore, a very conservative approach was employed by ECO:LOGIC Engineering to account for the multiple dosing affects. The study states the following:

Deleted: CORMIX is not able to account for tidal effects and multiple dosing. However, a conservative approach for evaluating the effects of multiple dosing of the effluent into the receiving water due to tidal action in the area was used in the evaluation. Based on the results of the study, a dilution credit of 20:1 is allowed for compliance with acute and chronic aquatic life criteria. For long-term human health criteria, the dilution credit of 1000:1 allowed in the previous Order has been carried forward and is allowed for compliance with human health criteria.

Formatted: Indent: Left: 1"

"Cormix is intended primarily for the modeling of steady-state operational conditions and one-time flow reversals. However, in the case of the Rio Vista Main WWTP discharge into the Sacramento River, it is estimated that under critical low river flow conditions a parcel of water could pass over the outfall up to about 13 times (over the course of about three days). This is because of the large magnitude of the tidally-induced flows compared to the net downstream river flows under critical low river flow conditions. Therefore,

Formatted: Indent: Left: 1.25"

some accounting for these additional does of effluent beyond the “one-time” flow reversal capabilities of the Cormix model was necessary to allow for proper modeling.

“Because of the timing, turbulence, and traverse of these multiple tidal flows, the earlier does of effluent become dispersed over much of the river width while the last two does at the final flow reversal will have dispersed very little beyond the river’s area (cross-sectional) over the outfall. It is assumed that the 11 earlier doses preceding the final two effluent does will have dispersed to a net/average effect of those earlier doses being uniformly dispersed in roughly one-third of the river cross section that includes the outfall. In other words, 11 does of effluent (at effluent flows commensurate with low river flows) are diluted into on-third of the river flow, and this constitutes a “background percentage” of effluent already in the river water at the time of the most critical two effluent doses occurring at the final tidally induced flow reversal. This “background percentage” of effluent in the river flow from the first 11 doses of effluent is estimated to be 1.3 percent. An effluent concentration of 1.3 percent was, therefore, added to the results obtained from the Cormix model for the outfall.”

Formatted: Indent: Left: 1.25"

This approach to account for multiple dosing is very conservative and likely over estimates the effluent concentrations in the river.

Formatted: Indent: Left: 1"

Based on the results of the study, a dilution credit of 20:1 is allowed for compliance with acute and chronic aquatic life criteria. For long-term human health criteria, the dilution credit of 1000:1 allowed in the previous Order has been carried forward and is allowed for compliance with human health criteria. This is appropriate, because for long-term human health criteria, the environmental effects are expected to occur far downstream of the discharge point where the discharge is completely mixed. The minimum Sacramento River flow during critical conditions is 1000 cfs. Since the effluent flow limit is 0.65 mgd (~1 cfs), a dilution credit of 1000:1 for human health criteria is appropriate.

The mixing zone is as small as practicable, will not compromise the integrity of the entire water body, restrict the passage of aquatic life, dominate the waterbody or overlap existing mixing zones from different outfalls. The mixing zone is very small relative to the large size of the receiving water (less than 2% of the river width, only 40 feet wide by 250 feet in length). The mixing zone is approximately 9 miles from the nearest drinking water intake and does not overlap a mixing zone from a different outfall.

The discharge will not cause acutely toxic conditions to aquatic life passing through the mixing zone, because the proposed Order requires compliance with an acute toxicity effluent limitation and requires acute bioassays using 100% effluent. Compliance with the acute toxicity effluent limitation assures the effluent is not acutely toxic.

The discharge will not adversely impact biologically sensitive or critical habitats, including, but not limited to, habitat of species listed under federal or State endangered species laws, because the mixing zone is very small and acutely toxic conditions will not occur in the mixing zone.

The discharge will not produce undesirable or nuisance aquatic life, result in floating debris, oil, or scum, produce objectionable color, odor, taste, or turbidity, cause objectionable bottom deposits, or cause nuisance, because the proposed Order requires end-of-pipe effluent limitations (e.g. for biochemical oxygen demand, total suspended solids, and settleable solids) and discharge prohibitions to prevent these conditions from occurring.

As suggested by the SIP, in determining the extent of or whether to allow a mixing zone and dilution credit, the Regional Water Board has considered the presence of pollutants in the discharge that are carcinogenic, mutagenic, teratogenic, persistent, bioaccumulative, or attractive to aquatic organisms, and concluded that the allowance of the mixing zone and dilution credit is adequately protective of the beneficial uses of the receiving water.

The mixing zone therefore complies with the SIP. The mixing zone also complies with the Basin Plan, which requires that the mixing zone not adversely impact beneficial uses. Beneficial uses will not be adversely affected for the same reasons discussed above. In determining the size of the mixing zone, the Regional Water Board has considered the procedures and guidelines in the EPA's Water Quality Standards Handbook, 2d Edition (updated July 2007), Section 5.1, and Section 2.2.2 of the Technical Support Document for Water Quality-based Toxics Control (TSD). The SIP incorporates the same guidelines. The mixing zone is limited to a small zone of initial dilution in the immediate vicinity of the discharge. The TSD indicates that this limitation achieves the objectives of preventing lethality to passing organisms and preventing significant human health risks.

3. Determining the Need for WQBELs

- a. CWA section 301 (b)(1) requires NPDES permits to include effluent limitations that achieve technology-based standards and any more stringent limitations necessary to meet water quality standards. Water quality standards include Regional Water Board Basin Plan beneficial uses and narrative and numeric water quality objectives, State Water Board-adopted standards, and federal standards, including the CTR and NTR. The Basin Plan includes numeric site-specific water quality objectives and narrative objectives for toxicity, chemical constituents, and tastes and odors. The narrative toxicity objective states: "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at III-8.00.) With regards to the narrative chemical constituents objective, the Basin Plan states that waters shall not contain chemical constituents in concentrations that adversely affect beneficial uses. At minimum,

“...water designated for use as domestic or municipal supply (MUN) shall not contain concentrations of chemical constituents in excess of the maximum contaminant levels (MCLs)” in Title 22 of CCR. The narrative tastes and odors objective states: “Water shall not contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to domestic or municipal water supplies or to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.”

- b. Federal regulations require effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause, or contribute to an in-stream excursion above a narrative or numerical water quality standard. Based on information submitted as part of the application, in studies, and as directed by monitoring and reporting programs, the Regional Water Board finds that the discharge has a reasonable potential to cause or contribute to an in-stream excursion above a water quality standard for aluminum, ammonia, arsenic, chlorine residual, coliform, copper, dibromochloromethane, dichlorobromomethane, salinity (including chloride, electrical conductivity, and total dissolved solids), iron, lead, manganese, nitrate, nitrite, and pH. Water quality-based effluent limitations (WQBELs) for these constituents are included in this Order. A summary of the reasonable potential analysis (RPA) is provided in Attachment G, and a detailed discussion of the RPA for each constituent is provided below.
- c. The Regional Water Board conducted the RPA in accordance with Section 1.3 of the SIP. Although the SIP applies directly to the control of CTR priority pollutants, the State Water Board has held that the Regional Water Board may use the SIP as guidance for water quality-based toxics control. The SIP states in the introduction “The goal of this Policy is to establish a standardized approach for permitting discharges of toxic pollutants to non-ocean surface waters in a manner that promotes statewide consistency.” Therefore, in this Order the RPA procedures from the SIP were used to evaluate reasonable potential for both CTR and non-CTR constituents.
- d. WQBELs were calculated in accordance with section 1.4 of the SIP, as described in Attachment F, Section IV.C.4. All calculations for the final effluent limitations are detailed in Attachment G.
- e. **Aluminum.** For protection of freshwater aquatic life, the Regional Water Board in the past has used USEPA’s criteria for prevention of acute and chronic toxicity to implement the Basin Plan’s narrative toxicity objective for aluminum. The recommended four-day average (chronic) and one-hour average (acute) criteria for aluminum are 87 µg/L and 750 µg/L, respectively, for waters with a pH of 6.5 to 9.0. The most stringent of these criteria is the chronic criterion of 87 µg/L. This criterion is based on studies conducted on waters with low pH (6.5 to 6.8 pH units) and hardness (<10 mg/L as CaCO₃), conditions not commonly observed in Central Valley receiving waters like the Sacramento River. Thus, the criterion is likely overly protective for this application. For similar reasons, the Utah

Deleted: a
Deleted: a
Deleted: a

Deleted: CA0078018

Department of Environmental Quality (Department) only applies the 87 µg/L chronic criterion for aluminum where the pH is less than 7.0 and the hardness is less than 50 mg/L as CaCO₃ in the receiving water after mixing. For conditions where the pH equals or exceeds 7.0 and the hardness is equal to or exceeds 50 mg/L as CaCO₃, the Department regulates aluminum based on the 750 µg/L acute criterion. Therefore, in the case of the Sacramento River where the pH is greater than 7 standard units and the hardness is greater than 50 mg/L as CaCO₃, it is unlikely that application of the stringent chronic criteria (87µg/L) is necessary to protect aquatic life. Therefore, based on best professional judgment, only the acute criterion (750 µg/L) has been applied in this Order.

Deleted: both
 Deleted: were higher than 7 and
 Formatted: Subscript
 Deleted: , respectively
 Deleted: no chronic effluent limitation is established in the Order

The MEC for aluminum was 98 µg/L, based on 34 samples collected between October 2005 and March 2008, while the maximum observed upstream receiving water aluminum concentration was 800 µg/L, based on three samples collected between January 2002 and September 2002. The receiving water exceeds the recommended one-hour average (acute) NAWQC criteria for aluminum of 750 µg/L, indicating there is no assimilative capacity. Therefore, this Order includes an average monthly effluent limitation (AMEL) and maximum daily effluent limitation (MDEL) for aluminum of 411 µg/L and 750 µg/L, respectively.

The Basin Plan also includes a chemical constituent objective that states: *At a minimum, water designated for use as domestic or municipal supply (MUN) shall not contain concentrations of chemical constituents in excess of the maximum contaminant levels (MCLs) specified in the provisions of Title 22, Table 64449-A of the California Code of Regulations.*

Criteria for aluminum include the following:

| Source | Criteria (ug/L) |
|--------------------------|-----------------|
| California Primary MCL | 1000 |
| California Secondary MCL | 200 |

The Sacramento River has the designated beneficial use of MUN. Based on this, the lack of available dilution information, and the above effluent data, the discharge has the reasonable potential to cause an exceedence of the Basin Plan chemical constituent objective for aluminum of 200 µg/L. This permit, therefore, includes a final average annual effluent limit of 200 µg/L for aluminum based on the MCL.

Based on the sample results in the effluent, it appears that the Discharger can immediately comply with the new effluent limitations.

- f. **Ammonia.** Untreated domestic wastewater contains ammonia. Nitrification is a biological process that converts ammonia to nitrite and nitrite to nitrate. Denitrification is a process that converts nitrate to nitrite or nitric oxide and then to nitrous oxide or nitrogen gas, which is then released to the atmosphere. The

Discharger does not currently use nitrification to remove ammonia from the waste stream. Inadequate or incomplete nitrification may result in the discharge of ammonia to the receiving stream. Ammonia is known to cause toxicity to aquatic organisms in surface waters. Discharges of ammonia would violate the Basin Plan narrative toxicity objective. Applying 40 CFR 122.44(d)(1)(vi)(B), it is appropriate to use USEPA's Ambient National Water Quality Criteria for the Protection of Freshwater Aquatic Life for ammonia, which was developed to be protective of aquatic organisms.

USEPA's *Ambient Water Quality Criteria for the Protection of Freshwater Aquatic Life*, for total ammonia, recommends acute (1-hour average; criteria maximum concentration or CMC) standards based on pH and chronic (30-day average, criteria continuous concentration or CCC) standards based on pH and temperature. It also recommends a maximum 4-day average concentration of 2.5 times the criteria continuous concentration. USEPA found that as pH increased, both the acute and chronic toxicity of ammonia increased. Salmonids were more sensitive to acute toxicity effects than other species. However, while the acute toxicity of ammonia was not influenced by temperature, it was found that invertebrates and young fish experienced increasing chronic toxicity effects with increasing temperature. Because the Sacramento River within the Sacramento-San Joaquin Delta has a beneficial use of cold freshwater habitat and the presence of salmonids and early fish life stages is well-documented, the recommended criteria for waters where salmonids and early life stages are present were used. USEPA's recommended criteria are shown below:

$$CCC_{30\text{-day}} = \left(\frac{0.0577}{1 + 10^{7.688 - pH}} + \frac{2.487}{1 + 10^{pH - 7.688}} \right) \times \text{MIN} \left(2.85, 1.45 \cdot 10^{0.028(25 - T)} \right), \text{ and}$$

$$CMC = \left(\frac{0.275}{1 + 10^{7.204 - pH}} + \frac{39.0}{1 + 10^{pH - 7.204}} \right),$$

where T is in degrees Celsius.

The maximum permitted effluent pH is 8.1. In order to protect against the worst-case short-term exposure of an organism, a pH value of 8.1 was used to derive the acute criterion. The resulting acute criterion is 4.64 mg/L, calculated with salmonids present.

There is not enough representative receiving water monitoring data to determine the chronic criterion based on the receiving water. Therefore, the maximum running 30-day average effluent temperature of 24°C (based on temperature data from January 2003 – August 2006) and the maximum 30-day effluent pH of 7.8 (based on pH data from June 2006 – March 2008) were used to calculate the 30-day CCC. The resulting 30-day CCC is 1.73 mg/L (as N), calculated with fishes early life stages present. The 4-day average concentration is derived in accordance with the USEPA criterion as 2.5 times the 30-day CCC. Based on a

30-day CCC of 1.73 mg/L (as N), the 4-day average concentration, that should not be exceeded, is 4.33 mg/L.

The MEC for ammonia was 30 mg/L, based on 31 samples collected between August 2003 and August 2006, while the maximum observed upstream receiving water ammonia concentration was 0.3 mg/L, based on four samples collected between January 2002 and December 2002. Therefore, ammonia in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above a level necessary to protect aquatic life resulting in a violation of the Basin Plan's narrative toxicity objective.

The Regional Water Board calculates WQBELs in accordance with SIP procedures for non-CTR constituents, and ammonia is a non-CTR constituent. The SIP procedure assumes a 4-day averaging period for calculating the long-term average discharge condition (LTA). However, USEPA recommends modifying the procedure for calculating permit limits for ammonia using a 30-day averaging period for the calculation of the LTA corresponding to the 30-day chronic criteria. Therefore, while the LTAs corresponding to the acute and 4-day chronic criteria were calculated according to SIP procedures, the LTA corresponding to the 30-day chronic criteria was calculated assuming a 30-day averaging period. The lowest LTA representing the acute, 4-day, and 30-day chronic criteria is then selected as the basis for deriving the AMEL and the MDEL. The remainder of the WQBEL calculation for ammonia was performed according to the SIP procedures.

The previous Order included an interim daily maximum effluent limitation (applicable until a dilution/mixing zone study was completed) for ammonia of 89.3 mg N/L, 484 lbs/day (based on a design flow of 0.65 mgd in May through October), and 1,713 lbs/day (based on a design wet weather flow of 2.3 in November through April). Since the maximum ambient background ammonia concentration is less than the applicable criteria, the receiving water has assimilative capacity for ammonia. As discussed in Section IV.C.2.c., above, the Discharger completed a dilution/mixing zone study and a 20:1 dilution credit has been allowed for acute and chronic aquatic life criteria. Therefore, this Order contains a final AMEL and MDEL for ammonia of 35 mg/L and 91 mg/L, respectively, based on USEPA's National Ambient Water Quality Criteria for the Protection of Freshwater Aquatic Life and to assure the treatment process adequately nitrifies the waste stream to protect the aquatic habitat beneficial uses. Since ammonia is an oxygen demanding substances, this Order also contains mass effluent limitations based on the concentration-based effluent limitations.

- g. **Arsenic.** The Basin Plan (Table III-1) contains a water quality objective of 10 µg/L for dissolved arsenic, which is a site-specific numeric objective applicable to the Delta. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. Since there is no dissolved-to-total metal translator available for arsenic, it was assumed that the translator is

equal to 1. The MEC for total arsenic was 14 µg/L, based on 30 samples collected between October 2005 and March 2008, while the maximum observed upstream receiving water arsenic concentration was 3.1 µg/L, based on four samples collected between January 2002 and December 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's site-specific water quality objective for arsenic.

The previous Order contained monthly average effluent limitations of 6.36 mg/L, 34.5 lbs/day (based on a design flow 0.65 mgd), and 122 lbs/day (based on a wet weather flow of 2.3 mgd), and daily maximum effluent limitations of 12.8 mg/L, 69.4 lbs/day (based on a flow of 0.65 mgd), and 246 lbs/day (based on a flow of 2.3 mgd). Previous limits were based on a dilution of 1,000 to 1 in the Sacramento River. Since the maximum ambient background arsenic concentration is less than the applicable criteria, the receiving water has assimilative capacity for arsenic. As discussed in Section IV.C.2.c., above, a dilution credit of 1000:1 has been allowed. Therefore, a MDEL for arsenic of 6,910 µg/L was calculated, based on the Basin Plan's site-specific objective for the Delta. However, the Regional Water Board finds that granting of this dilution credit could allocate an unnecessarily large portion of the receiving water's assimilative capacity for arsenic and could violate the Antidegradation Policy. For this reason, a more stringent performance-based effluent limitation is included in this order that is calculated in the same way that interim limits are calculated (see Section IV.E.1 below). A MDEL for total arsenic of 16 µg/L is included in this Order.

- h. **Bis (2-chloroethyl) ether.** The CTR includes a bis (2-chloroethyl) ether criterion of 0.031 µg/L for the protection of human health and is based on a one-in-a-million cancer risk for waters from which both water and organisms are consumed. Bis (2-chloroethyl) ether was detected, but not quantified (DNQ), in the effluent at an analytical method detection level of 0.12 µg/L, in one of four samples collected between January 2002 and December 2002, while the upstream receiving water bis (2-chloroethyl) ether concentration was not detected based on four samples collected during the same period. Since the effluent data was DNQ, there is insufficient information to determine whether the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for bis (2-chloroethyl) ether. This Order requires the Discharger to monitor the effluent quarterly to gather additional data for the RPA.
- i. **Boron.** The California State Action Level for drinking water for boron is 1,000 µg/L. The MEC for boron was 1,200 µg/L, based on one sample collected on 18 August 2004, while no upstream receiving water boron data was available. Since there was not enough representative monitoring data in order to determine reasonable potential for boron, and limiting electrical conductivity (EC) in the effluent will in part control boron, an effluent limitation will not be established for boron in this Order. However, the Facility will be required to monitor boron in the

effluent and receiving water in order to collect data to determine reasonable potential for boron in the effluent to exceed water quality objectives.

- j. **Chlorine Residual.** The Discharger uses chlorine for disinfection, which is extremely toxic to aquatic organisms. The Discharger dechlorinates the effluent prior to discharge to the Sacramento River. Due to the existing chlorine use and the potential for chlorine to be discharged, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's narrative toxicity objective.

The USEPA *Technical Support Document for Water Quality-Based Toxics Control* (EPA/505/2-90-001) contains statistical methods for converting chronic (4-day) and acute (1-hour) aquatic life criteria to average monthly and maximum daily effluent limitations based on the variability of the existing data and the expected frequency of monitoring. However, because chlorine is an acutely toxic constituent that can and will be monitored continuously, an average 1-hour limitation is considered more appropriate than an average daily limitation. Average 1-hour (0.011 mg/L) and 4-day (0.019 mg/L) limitations for chlorine, based on these criteria, are included in this Order. Based on evaluation of effluent data, the Discharger can immediately comply with these new effluent limitations for chlorine residual.

The chlorine residual limitations required in this Order are protective of aquatic organisms in the undiluted discharge. If compliance is maintained, the Regional Water Board does not anticipate residual chlorine impacts to benthic organisms.

- k. **Copper.** The Basin Plan (Table III-1) contains a water quality objective of 10 µg/L for dissolved copper. The CTR includes hardness-dependent criteria for the protection of freshwater aquatic life for copper. The criteria for copper are presented in dissolved concentrations. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. The USEPA default conversion factors for copper in freshwater are 0.96 for both the acute and the chronic criteria. Using the lowest recorded hardness of the effluent (78 mg/L as CaCO₃) and the USEPA recommended dissolved-to-total translator, the applicable chronic criterion (maximum 4-day average concentration) is 7.5 µg/L and the applicable acute criterion (maximum 1-hour average concentration) is 11.1 µg/L, as total recoverable.

The MEC for total copper was 41 µg/L, based on five samples collected between January 2002 and December 2003, while the maximum observed upstream receiving water total copper concentration was 4.4 µg/L, based on three samples collected between January 2002 and September 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criteria and the Delta Basin Plan objective for copper. Since the maximum ambient background copper concentration is less than the applicable criteria, the receiving water has assimilative capacity for copper. As discussed in Section IV.C.2.c., above, the Discharger completed a dilution/mixing zone study

and a 20:1 dilution credit has been allowed for acute and chronic aquatic life criteria. Therefore, an AMEL and MDEL for total copper of 58 µg/L and 116 µg/L, respectively, were calculated based on CTR criteria for the protection of freshwater aquatic life.

- I. **Diazinon.** The Basin Plan requires the Regional Water Board to consider relevant numerical criteria and guidelines developed by other agencies in determining compliance with the narrative toxicity objective (Basin Plan, IV-17.00). In March 2000, the California Department of Fish and Game (DFG) established acute and chronic criteria for diazinon to protect fresh water aquatic life. The acute (1-hour average) and chronic (4-day average) criteria are 0.08 µg/L and 0.05 µg/L, respectively.

From January 2002 through April 2004, the Discharger submitted the results for 15 analysis performed for diazinon. Thirteen of the 15 were reported as below analytical detection levels; of the remaining samples, one was reported detected at 0.23 µg/L and the other was reported as detected but not quantified (DNQ). The previous Order required the use of the most sensitive analytical methods for diazinon, which is EPA Method 507. The analytical methods used for the two detected values were EPA Methods 8141A and 3520C, with method detection and reporting levels higher than Method 507, and not approved for use in analyzing for diazinon. Therefore, due to the uncertainty regarding the data provided by the Discharger and the analytical methods used, no effluent limitation is being established at this time. However, due to the fact that diazinon is a 303(d) listed pollutant for the Delta waters, quarterly effluent monitoring will be required to determine if diazinon is present in the discharge, and whether controls are required prior to establishment of an applicable TMDL.

- m. **Dibromochloromethane.** The CTR includes a dibromochloromethane criterion of 0.41 µg/L for the protection of human health and is based on a one-in-a-million cancer risk for waters from which both water and organisms are consumed. The MEC for dibromochloromethane was 0.9 µg/L, based on five samples collected between January 2002 and September 2004, while the upstream receiving water dibromochloromethane concentration was not detected based on four samples collected between January 2002 and December 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for dibromochloromethane.

The maximum ambient background dibromochloromethane concentration is less than the applicable criteria, therefore, the receiving water has assimilative capacity for dibromochloromethane. As described in Section IV.C.2.c. of this Fact Sheet, a dilution credit of up to 1000:1 may be allowed for CTR human health criteria, which results in an AMEL and MDEL for dibromochloromethane of 230 µg/L and 463 µg/L, respectively. However, the Regional Water Board finds that granting of this dilution credit could allocate an unnecessarily large portion of the receiving water's assimilative capacity for dibromochloromethane and could violate the Antidegradation Policy. For this reason, a more stringent

performance-based effluent limitation is included in this order that is calculated in the same way that interim limits are calculated (see Section IV.E.1 below). A MDEL for dibromochloromethane of 2.8 µg/L is included in this Order.

- n. **Dichlorobromomethane.** The CTR includes a dichlorobromomethane criterion of 0.56 µg/L for the protection of human health and is based on a one-in-a-million cancer risk for waters from which both water and organisms are consumed. The MEC for dichlorobromomethane was 1.8 µg/L, based on five samples collected between January 2002 and September 2004, while the upstream receiving water dichlorobromomethane concentration was not detected based on four samples collected between January 2002 and December 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criterion for dichlorobromomethane.

The maximum ambient background dichlorobromomethane concentration is less than the applicable criteria, therefore, the receiving water has assimilative capacity for dichlorobromomethane. As described in Section IV.C.2.c. of this Fact Sheet, a dilution credit of up to 1000:1 may be allowed for CTR human health criteria, which results in an AMEL and MDEL for dichlorobromomethane of 360 µg/L and 724 µg/L, respectively. However, the Regional Water Board finds that granting of this dilution credit could allocate an unnecessarily large portion of the receiving water's assimilative capacity for dichlorobromomethane and could violate the Antidegradation Policy. For this reason, a more stringent performance-based effluent limitation is included in this order that is calculated in the same way that interim limits are calculated (see Section IV.E.1 below). A MDEL for dichlorobromomethane of 5.6 µg/L is included in this Order.

o. **Electrical Conductivity (see Subsection for Salinity)**

- p. **Iron.** The Basin Plan (Table III-1) contains a water quality objective of 300 µg/L for dissolved iron as a site-specific objective for the Delta. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. Since there is no dissolved-to-total metal translator available for iron, it was assumed that the translator is equal to 1. The MEC for iron was 1,800 µg/L, based on four samples collected between January 2002 and December 2002, while the maximum observed upstream receiving water iron concentration was 1,600 µg/L, based on four samples collected between January 2002 and December 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's water quality objective for iron. Since no assimilative capacity exists, a MDEL of 300 µg/L for iron is included in this Order based on the Basin Plan's site-specific objective for the Delta.

Based on the sample results for the effluent, the limitations appear to put the Discharger in immediate non-compliance. New or modified control measures may be necessary in order to comply with the effluent limitations, and the new or modified control measures cannot be designed, installed and put into operation within 30 calendar days. Furthermore, the effluent limitations for iron are a new

regulatory requirement within this permit, which becomes applicable to the waste discharge with the adoption of this Order, which was adopted after 1 July 2000. Therefore, a compliance time schedule for compliance with the iron effluent limitations is established in TSO No. R5-2008-_____ in accordance with CWC section 13300, that requires preparation and implementation of a pollution prevention plan in compliance with CWC section 13263.3.

- q. **Lead.** The CTR includes hardness-dependent standards for the protection of freshwater aquatic life for lead. The standards for metals are presented in dissolved concentrations. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. The conversion factors for lead in freshwater are $1.46203 - [0.145712 \times \ln(\text{hardness})]$ for both the acute and the chronic criteria. Using the lowest recorded hardness of the effluent (78 mg/L) and the highest recorded hardness of the receiving water (100 mg/L), the applicable chronic criterion (maximum 4-day average concentration) is 2.3 µg/L and the applicable acute criterion (maximum 1-hour average concentration) is 58.8 µg/L, as total recoverable.

The MEC for total lead was 2.3 µg/L, based on five samples collected between January 2002 and December 2003, while the maximum observed upstream receiving water total lead concentration was 0.52 µg/L, based on three samples collected between January 2002 and September 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the CTR criteria for lead.

Since the maximum ambient background lead concentration is less than the applicable criteria, the receiving water has assimilative capacity for lead. As discussed in Section IV.C.2.c., above, the Discharger completed a dilution/mixing zone study and a 20:1 dilution credit has been allowed for acute and chronic aquatic life criteria. Therefore, an AMEL and MDEL for total lead of 49 µg/L and 98 µg/L, respectively, were calculated based on CTR criteria for the protection of freshwater aquatic life. However, the Regional Water Board finds that granting of this dilution credit could allocate an unnecessarily large portion of the receiving water's assimilative capacity for the CTR aquatic life criteria for lead and could violate the Antidegradation Policy. For this reason, a more stringent performance-based effluent limitation is included in this order that is calculated in the same way that interim limits are calculated (see Section IV.E.1 below). A MDEL for total lead of 7.2 µg/L is included in this Order.

- r. **Manganese.** The Basin Plan (Table III-1) contains a water quality objective of 50 µg/L for dissolved manganese which is a site-specific numeric objective applicable to the Delta. USEPA recommends conversion factors to translate dissolved concentrations to total concentrations. Since there is no dissolved-to-total metal translator available for manganese, it was assumed that the translator is equal to 1. The MEC for manganese was 150 µg/L, based on five samples collected between January 2002 and December 2002, while the maximum observed upstream receiving water manganese concentration was 33 µg/L,

based on three samples collected between January 2002 and September 2002. Therefore, the discharge has a reasonable potential to cause or contribute to an in-stream excursion above the Basin Plan's water quality objective for manganese.

The maximum ambient background manganese concentration is less than the applicable criteria, therefore, the receiving water has assimilative capacity for manganese. As described in Section IV.C.2.c. of this Fact Sheet, a dilution credit of up to 1000:1 may be allowed, which results in a MDEL for manganese of 1,750 µg/L, based on the Basin Plan's Delta site specific water quality objective for manganese. However, the Regional Water Board finds that granting of this dilution credit could allocate an unnecessarily large portion of the receiving water's assimilative capacity for manganese and could violate the Antidegradation Policy. For this reason, a more stringent performance-based effluent limitation is included in this order that is calculated in the same way that interim limits are calculated (see Section IV.E.1 below). A MDEL for total manganese of 467 µg/L is included in this Order.

- s. **Mercury.** The current USEPA Ambient Water Quality Criteria for Protection of Freshwater Aquatic Life, criteria continuous concentration, for mercury is 0.77 µg/L (30-day average, chronic criteria). The CTR contains a human health criterion of 0.050 µg/L for waters from which both water and aquatic organisms are consumed. Both values are controversial and subject to change. In 40 CFR Part 131, USEPA acknowledges that the human health criteria may not be protective of some aquatic or endangered species and that "*...more stringent mercury limits may be determined and implemented through use of the State's narrative criterion.*" In the CTR, USEPA reserved the mercury criteria for freshwater and aquatic life and may adopt new criteria at a later date.

The MEC for mercury was 0.043 µg/L based on 16 samples collected between August 2003 and August 2006, while the maximum observed upstream receiving water concentration was 0.026 µg/L, based on four samples collected between 30 January 2002 and 18 December 2002. Therefore, no reasonable potential exists to exceed the CTR criterion.

The Sacramento River within the Sacramento-San Joaquin Delta Waterways (western portion) has been listed as an impaired water body pursuant to Section 303(d) of the Clean Water Act because of mercury. Mercury bioaccumulates in fish tissue and, therefore, the discharge of mercury to the receiving water is likely to contribute to exceedances of the narrative toxicity objective and impacts on beneficial uses. Because the Facility discharges to an impaired water body for mercury, the discharge must not cause or contribute to increased mercury levels.

Due to the concern with bioaccumulation and the impaired condition of the Delta, the previous Order recommended an interim performance-based loading limit for mercury to keep the discharge at current levels. However, there was insufficient data to calculate the limit. The Discharger has been collecting total mercury effluent data and this Order contains an interim performance-based mass effluent

limitation of 0.0071 lbs/month for mercury. This limitation is based on maintaining the mercury loading at the current level until a total maximum daily load (TMDL) can be established and USEPA develops mercury standards that are protective of human health. The mass limitation was derived using the maximum observed effluent mercury concentration of 0.043 ug/L (0.000043 mg/L) and the average daily discharge flow rate of 0.65 mgd as follows:

$$(0.000043 \text{ mg/L}) \times (0.65 \text{ mgd}) \times (8.34 \text{ lbs/day conversion factor}) \times (365 \text{ days/12 months}) = 0.0071 \text{ pounds/month}$$

If USEPA develops new water quality standards for mercury or a TMDL for the Sacramento-San Joaquin Delta is adopted, this permit may be reopened and the effluent limitations adjusted.

- t. **Nitrite and Nitrate.** Untreated domestic wastewater contains ammonia. Nitrification is a biological process that converts ammonia to nitrite to nitrate. Denitrification is a process that converts nitrate to nitrite or nitric oxide and then to nitrous oxide or nitrogen gas, which is then released to the atmosphere. Nitrate and nitrite are known to cause adverse health effects in humans. The California DHS has adopted Primary MCLs at Title 22 of the California Code of Regulations (CCR), Table 64431-A, for the protection of human health for nitrite and nitrate that are equal to 1 mg/L and 10 mg/L (measured as nitrogen), respectively. Title 22 CCR, Table 64431-A, also includes a primary MCL of 10,000 µg/L for the sum of nitrate and nitrite, measured as nitrogen.

USEPA has developed a primary MCL and an MCL goal of 1,000 µg/L for nitrite (as nitrogen). For nitrate, USEPA has developed Drinking Water Standards (10,000 µg/L as Primary MCL) and Ambient Water Quality Criteria for protection of human health (10,000 µg/L for non-cancer health effects). Recent toxicity studies have indicated a possibility that nitrate is toxic to aquatic organisms.

The MEC for nitrate was 21 mg/L, based on five samples collected between January 2002 and August 2004, while the maximum observed upstream receiving water nitrate concentration was 2.2 mg/l based on four samples collected between January 2002 and December 2002. The MEC for nitrite was 1 mg/L, based on four samples collected between January 2002 and December 2002, while the maximum observed upstream receiving water nitrite concentration was 0.029 mg/L based on four samples collected between January 2002 and December 2002. Therefore, there is a reasonable potential for the discharge to cause or contribute to an in-stream excursion above the Primary MCLs for nitrite and nitrate.

Since the maximum ambient background nitrate and nitrite concentrations are less than the applicable criteria, the receiving water has assimilative capacity for these constituents. As described in Section IV.C.2.c. of this Fact Sheet, a dilution credit of up to 1000:1 may be allowed for long-term human health criteria, which results in an AMEL of 7,810 mg/L for nitrate (as N) and an AMEL of 972 mg/L for nitrite (as N). However, the Regional Water Board finds that granting of

this dilution credit could allocate an unnecessarily large portion of the receiving water's assimilative capacity for the Basin Plan's chemical constituents objective for nitrate plus nitrite and could violate the Antidegradation Policy. For this reason, a more stringent performance-based effluent limitation is included in this order that is calculated in the same way that interim limits are calculated (see Section IV.E.1 below). A MDEL for nitrate (as N) of 65 mg/L, and a MDEL for nitrite (as N) of 3.1 mg/L are included in this Order.

- u. **Oil and Grease.** The previous Order included numeric monthly average and daily maximum effluent limitations of 10 mg/L and 15 mg/L, respectively. The monitoring data collected during the previous Order term indicated that there is no reasonable potential to violate water quality for oil and grease. Therefore, oil and grease effluent limitations will not be included in this Order. However, the Facility will be required to continue to sample in order to monitor oil and grease in the effluent.

- v. **Persistent Chlorinated Hydrocarbon Pesticides.** The Basin Plan requires that no individual pesticides shall be present in concentrations that adversely affect beneficial uses; discharges shall not result in pesticide concentrations in bottom sediments or aquatic life that adversely affect beneficial uses; persistent chlorinated hydrocarbon pesticides shall not be present in the water column at detectable concentrations; and pesticide concentrations shall not exceed those allowable by applicable antidegradation policies. Order No. 5-01-178 contained an effluent limitation of no detectable concentrations for organochlorine pesticides, based on the 303(d) listing in the Delta and due to prior monitoring of these pesticides with detection levels greater than the minimum levels recommended in the SIP. Order No. 5-01-178 required the Discharger to use detection levels no greater than the minimum levels. Effluent monitoring data from February 2003 to September 2006, at detection levels less than or equal to the SIP minimum levels, indicate no detectable concentrations for pesticides. . Therefore, effluent limitations for pesticides are not carried over from the previous Order.

- w. **Pathogens.** Municipal and domestic supply, agricultural irrigation, and body contact water recreation are beneficial uses of the receiving stream and there is at all times at least 20:1 dilution in the receiving water. Coliform limits are imposed to protect the beneficial uses of the receiving water, including public health through contact recreation and drinking water pathways. In a letter to the Regional Water Board dated 8 April 1999, the California Department of Health Services (recently changed to Department of Public Health or DPH) indicated that DPH would consider wastewater discharged to water bodies with identified beneficial uses of irrigation or contact recreation and where the wastewater receives dilution of more than 20:1 to be adequately disinfected if the effluent coliform concentration does not exceed 23 MPN/100 mL as a 7-day median and if the effluent coliform concentration does not exceed 240 MPN/100 mL more than once in any 30 day period. The previous Order contained an effluent total coliform monthly median limitation of 23 MPN/100 mL and a daily maximum

limitation of 500 MPN/100 mL. The effluent limitations for total coliform have been modified in this Order to be consistent with DPH recommendations. This Order includes effluent limitations for total coliform of 23 MPN/100 mL as a 7-day median, and 240 MPN/100 ml, that should not be exceeded more than once in any 30 day period.

- x. **pH.** The Basin Plan includes a water quality objective for surface waters (except for Goose Lake) that the “...pH shall not be depressed below 6.5 nor raised above 8.5. Changes in normal ambient pH levels shall not exceed 0.5 in fresh waters with designated COLD or WARM beneficial uses.” Effluent Limitations for pH are included in this Order based on the Basin Plan objectives for pH. A more stringent instantaneous maximum pH effluent limitation of 8.1 has been applied based on the performance of the Facility. The more stringent instantaneous maximum pH limitation allows less stringent ammonia (as N) effluent limitations that are protective of the WARM and COLD beneficial uses of the receiving water.
- y. **Salinity.** The discharge contains total dissolved solids (TDS), chloride, sulfate, and electrical conductivity (EC). These are water quality parameters that are indicative of the salinity of the water. Their presence in water can be growth limiting to certain agricultural crops and can affect the taste of water for human consumption. There are no USEPA water quality criteria for the protection of aquatic organisms for these constituents. The Basin Plan contains a chemical constituent objective that incorporates State MCLs, contains a narrative objective, and contains numeric water quality objectives for EC, TDS, sulfate, and chloride.

Table F-5. Salinity Water Quality Criteria/Objectives & Plant Effluent Data

| Parameter | Agricultural WQ Goal ¹ | Secondary MCL ² | Basin Plan/ Bay-Delta Plan ⁴ | Effluent | |
|-----------------|-----------------------------------|----------------------------|--|----------|---------|
| | | | | Average | Maximum |
| EC (µmhos/cm) | Varies ³ | 900, 1600, 2200 | 450-2,780 ⁵ | 1,148 | 1,400 |
| TDS (mg/L) | Varies | 500, 1000, 1500 | N/A | 657 | 760 |
| Sulfate (mg/L) | Varies | 250, 500, 600 | N/A | 85 | 120 |
| Chloride (mg/L) | Varies | 250, 500, 600 | N/A | 106 | 135 |

¹ Agricultural water quality goals based on *Water Quality for Agriculture*, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985)

² The secondary MCLs are stated as a recommended level, upper level, and a short-term maximum level.

³ The EC level in irrigation water that harms crop production depends on the crop type, soil type, irrigation methods, rainfall, and other factors. An EC level of 700 µmhos/cm is generally considered to present no risk of salinity impacts to crops. However, many crops are grown successfully with higher salinities.

⁴ The water quality objective applies to the Sacramento River at Emmatton in the Western Delta.

⁵ The water quality objective can vary based on the Sacramento Valley Water Year Hydrologic Classification (see Table F-6).

Table F-6. Basin Plan Water Quality Objectives for EC Sacramento River at Emmaton, Based on Water Year Type (maximum 14- day running average of mean daily EC in µmhos/cm)

| Date | Water Year Type | | | | |
|--------------------|-----------------|--------------|--------------|------|----------|
| | Wet | Above Normal | Below Normal | Dry | Critical |
| 1 April – 14 June | 450 | 450 | 450 | 450 | 2780 |
| 15 June – 19 June | 450 | 450 | 450 | 1670 | 2780 |
| 20 June – 30 June | 450 | 450 | 1140 | 1670 | 2780 |
| 1 July – 15 August | 450 | 630 | 1140 | 1670 | 2780 |

Table F-7. Historical Compliance with EC objectives at Emmaton (Water Years 1999-2007)

| Water Year Type | # of years this type | Number of Years with Exceedances | Year w/ Exceedances (# of Days) | Applicable Objectives (µmhos/cm) |
|-----------------|----------------------|----------------------------------|---------------------------------|----------------------------------|
| Wet | 2 | 0 | NA | 450 |
| Above Normal | 3 | 0 | NA | 450/650 |
| Below Normal | 1 | 1 | 2004 (13) ¹ | 450/1140 |
| Dry | 3 | 0 | NA | 450/1670 |
| Critically Dry | 0 | 0 | NA | 2780 |

¹ Jones Track levee break June 3-June 30; exceedances 6/7 - 6/19

- i. **Chloride.** The secondary MCL for chloride is 250 mg/L, as recommended level, 500 mg/L as an upper level, and 600 mg/L as a short-term maximum. The recommended agricultural water quality goal for chloride, that would apply the narrative chemical constituent objective, is 106 mg/L as a long-term average based on Water Quality for Agriculture, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). The 106 mg/L water quality goal is intended to protect against adverse effects on sensitive crops when irrigated via sprinklers.

Chloride concentrations in the effluent ranged from 96 mg/L to 135 mg/L, with an average of 106 mg/L, for five samples collected by the Discharger from January 2002 through August 2004. Background concentrations in the Sacramento River ranged from 7 mg/L to 20 mg/L, with an average of 12.8 mg/L, for four samples collected by the Discharger from January 2002 through December 2002. The effluent concentration exceeds the agricultural water quality goal of 106 mg/L.

- ii. **Electrical Conductivity (EC).** The secondary MCL for EC is 900 µmhos/cm as a recommended level, 1,600 µmhos/cm as an upper level, and

2,200 $\mu\text{mhos/cm}$ as a short-term maximum. The agricultural water quality goal, that would apply the narrative chemical constituents objective, is 700 $\mu\text{mhos/cm}$ as a long-term average based on Water Quality for Agriculture, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). The 700 $\mu\text{mhos/cm}$ agricultural water quality goal is intended to prevent reduction in crop yield, i.e., a restriction on use of water, for salt-sensitive crops, such as beans, carrots, turnips, and strawberries. These crops are either currently grown in the area or may be grown in the future. Most other crops can tolerate higher EC concentrations without harm, however, as the salinity of the irrigation water increases, more crops are potentially harmed by the EC, or extra measures must be taken by the farmer to minimize or eliminate any harmful impacts. A water quality objective for EC for agricultural beneficial uses (for the Sacramento River at Emmaton in the Western Delta) is included in the *Water Quality Control Plan for the Bay-Delta Plan*. The objective varies accordingly to the water year hydrologic classifications ranging from 450 $\mu\text{mhos/cm}$ to 2,780 $\mu\text{mhos/cm}$ (see Table F-6, above).

A review of the Discharger's monitoring reports from January 2002 through September 2006 shows an average effluent EC of 1148 $\mu\text{mhos/cm}$, with a range from 676 $\mu\text{mhos/cm}$ to 1,400 $\mu\text{mhos/cm}$ for 49 samples. Background concentrations in the Sacramento River ranged from 180 $\mu\text{mhos/cm}$ to 280 $\mu\text{mhos/cm}$ from January 2002 through December 2002. The levels in the effluent have the potential to exceed the applicable objectives.

- iii. **Sulfate.** The secondary MCL for sulfate is 250 mg/L as recommended level, 500 mg/L as an upper level, and 600 mg/L as a short-term maximum. Sulfate concentrations in the effluent ranged from 56 mg/L to 120 mg/L, with an average of 85 mg/L, for five samples collected by the Discharger from 30 January 2002 through 18 August 2004. Background concentrations in the Sacramento River ranged from 7.9 mg/L to 15 mg/L, with an average of 11 mg/L, for four samples collected by the Discharger from 30 January 2002 through 18 December 2002. The effluent does not exceed the secondary MCL recommended level of 250 mg/L.
- iv. **Total Dissolved Solids (TDS).** The secondary MCL for TDS is 500 mg/L as a recommended level, 1,000 mg/L as an upper level, and 1,500 mg/L as a short-term maximum. The recommended agricultural water quality goal for TDS, that would apply the narrative chemical constituent objective, is 450 mg/L as a long-term average based on Water Quality for Agriculture, Food and Agriculture Organization of the United Nations—Irrigation and Drainage Paper No. 29, Rev. 1 (R.S. Ayers and D.W. Westcot, Rome, 1985). Water Quality for Agriculture evaluates the impacts of salinity levels on crop tolerance and yield reduction, and establishes water quality goals that are protective of the agricultural uses. The 450 mg/L water quality goal is intended to prevent reduction in crop yield, i.e. a restriction on use of water,

for salt-sensitive crops. Only the most salt sensitive crops require irrigation water of 450 mg/L or less to prevent loss of yield. Most other crops can tolerate higher TDS concentrations without harm, however, as the salinity of the irrigation water increases, more crops are potentially harmed by the TDS, or extra measures must be taken by the farmer to minimize or eliminate any harmful impacts.

The average TDS effluent concentration was 657 mg/L; concentrations ranged from 360 mg/L to 760 mg/L for seven samples collected by the Discharger from January 2002 through January 2007. These concentrations exceed the applicable water quality objectives. The background receiving water TDS ranged from 130 mg/L to 640 mg/L, with an average of 265 mg/L in four sampling events performed by the Discharger from January 2002 through December 2002. These data indicate that the receiving water exceeds water quality objectives.

- v. **Salinity Effluent Limitations.** The Regional Water Board, with cooperation of the State Water Board, has begun the process to develop a new policy for the regulation of salinity in the Central Valley. In a statement issued at the 16 March 2006, Regional Water Board meeting, board member Dr. Karl Longley recommended that the Board continue to exercise its authority to regulate discharges of salt to minimize salinity increases within the Central Valley. Dr. Longley stated, *“The process of developing new salinity control policies does not, therefore, mean that we should stop regulating salt discharges until a salinity Policy is developed. In the meantime, the Board should consider all possible interim approaches to continue controlling and regulating salts in a reasonable manner, and encourage all stakeholder groups that may be affected by the Regional Board’s policy to actively participate in policy development.”*

Based on daily EC data for the Sacramento River at Emmaton from August 1999 through April 2008, the Basin Plan water quality objectives were only exceeded during the Jones Tract levee break in June 2004. At all other times, the EC of the river was always in compliance with the objectives. Table F-7, above, displays a summary of compliance with the Basin Plan water quality objectives. This demonstrates that there is assimilative capacity for EC in the receiving water. As discussed in Section IV.C.2.c., above, the long-term dilution for the discharge is 1000:1. However, the Regional Water Board finds that granting of this dilution credit could allocate an unnecessarily large portion of the receiving water’s assimilative capacity for salinity and could violate the Antidegradation Policy. For this reason, a more stringent performance-based effluent limitation is included in this order. The performance-based effluent limit was calculated based on monthly effluent EC data from January 2003 – March 2008. A running 12-month average was calculated for each month data was collected and the annual average effluent limit was projected as the 95th percentile of this dataset (i.e. Mean + 1.645 x Standard Deviation [1152 + 1.645 x 94.33]). An annual average effluent

limitation for EC of 1,300 $\mu\text{mhos/cm}$ is included in this Order. Annual average effluent limitations are appropriate, due to fluctuations that can occur in the Discharger's effluent caused by changes in its water supply EC. Consequently, it is impracticable to calculate performance-based effluent limitations for EC on a shorter averaging period (e.g. weekly or monthly).

This Order also requires the Discharger to implement salinity reduction measures to reduce the salinity in its discharge to the Sacramento River. Specifically, Special Provision VI.C.3.a of this Order requires the Discharger to implement a salinity evaluation and minimization plan to ensure adequate measures are developed and implemented by the Discharger to reduce the discharge of salinity to the Sacramento River within the Sacramento-San Joaquin Delta. Special Provision VI.C.3.b requires the Discharger to report on progress in reducing salinity discharges to the Sacramento River. Implementation measures to reduce salt loading may include source control, mineralization reduction, chemical addition reductions, changing to water supplies with lower salinity, and limiting the salt load from domestic and industrial dischargers. Compliance with these requirements will result in a salinity reduction in the effluent discharged to the receiving water.

- z. **Temperature.** Since the Facility is discharging to the Sacramento-San Joaquin Delta, the *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Waters and Enclosed Bays and Estuaries of California* (Thermal Plan) is applicable to the discharge. The Thermal Plan requires that, "*The maximum temperature shall not exceed the natural receiving water temperature by more than 20°F*" nor the "*Shall cause a surface water temperature rise greater than 4°F above the natural temperature of the receiving waters at any time or place.*" Therefore, to ensure compliance with the Thermal Plan temperature effluent limitations are included in this Order based on the thermal plan.
- aa. **Toxicity.** See Section IV.C.5. of the Fact Sheet regarding whole effluent toxicity.

4. WQBEL Calculations

- a. As discussed in Section IV.C.3 above, effluent limitations based on primary MCLs were applied as AMELs for nitrate and nitrite. Effluent limitations based on the Basin Plan were applied as MDELs for arsenic, iron and manganese. Effluent limitations for chlorine residual, persistent chlorinated hydrocarbon pesticides, and pH were based on Basin Plan objectives and applied directly as effluent limitations. Effluent limitations for temperature were based on the Thermal Plan and applied directly as effluent limitations.
- b. Effluent limitations for aluminum, ammonia, copper, dibromochloromethane, dichlorobromomethane, and lead were calculated in accordance with section 1.4 of the SIP. The following paragraphs describe the methodology used for calculating effluent limitations.

c. **Effluent Limitation Calculations.** For each water quality criterion/ objective, calculate the effluent concentration allowance (ECA) using the following steady-state mass balance equation:

$$ECA = C + D(C - B) \quad \text{where } C > B, \text{ and}$$

$$ECA = C \quad \text{where } C \leq B,$$

where:

- ECA = effluent concentration allowance
- D = dilution credit
- C = the priority pollutant criterion/objective
- B = the ambient background concentration. The ambient background concentration shall be the observed maximum with the exception that an ECA calculated from a priority pollutant criterion/objective that is intended to protect human health from carcinogenic effects shall use the ambient background concentration as an arithmetic mean.

Acute and chronic toxicity ECAs were then converted to equivalent long-term averages (LTAs) using statistical multipliers and the lowest is used. Additional statistical multipliers were then used to calculate the maximum daily effluent limitation (MDEL) and the average monthly effluent limitation (AMEL).

Human health ECAs are set equal to the AMEL and a statistical multiplier is used to calculate the MDEL.

$$AMEL = mult_{AMEL} \left[\min \left(\overbrace{M_A ECA_{acute}, M_C ECA_{chronic}}^{LTA_{acute}} \right) \right]$$

$$MDEL = mult_{MDEL} \left[\min \left(\overbrace{M_A ECA_{acute}, M_C ECA_{chronic}}^{LTA_{chronic}} \right) \right]$$

$$MDEL_{HH} = \left(\frac{mult_{MDEL}}{mult_{AMEL}} \right) AMEL_{HH}$$

- where:
- mult_{AMEL} = statistical multiplier converting minimum LTA to AMEL
 - mult_{MDEL} = statistical multiplier converting minimum LTA to MDEL
 - M_A = statistical multiplier converting CMC to LTA
 - M_C = statistical multiplier converting CCC to LTA

Water quality-based effluent limitations were calculated for aluminum, ammonia, copper, dibromochloromethane, dichlorobromomethane, and lead as follows in Tables F-8 through F-13, below.

Table F-8. WQBEL Calculations for Aluminium

| | Acute | Chronic |
|--------------------------------------|-------------|----------------|
| Criteria (µg/L) ⁽¹⁾ | 750 | 750 |
| Dilution Credit | No Dilution | No Dilution |
| ECA | 750 | 750 |
| ECA Multiplier | 0.38 | 0.59 |
| LTA | 285.0 | 441.4 |
| AMEL Multiplier (95 th %) | 1.44 | ⁽²⁾ |
| AMEL (µg/L) | 411 | ⁽²⁾ |
| MDEL Multiplier (99 th %) | 2.63 | ⁽²⁾ |
| MDEL (µg/L) | 750 | ⁽²⁾ |

⁽¹⁾ USEPA Ambient Water Quality Criteria.

⁽²⁾ Limitations based on Acute LTA (Acute LTA < Chronic LTA).

Table F-9. WQBEL Calculations for Ammonia

| | Acute | Chronic (30-day) | Chronic (4-day) |
|--------------------------------------|-----------|---------------------|--------------------|
| pH ⁽¹⁾ | 8.1 | 7.8 | N/A |
| Temperature °C ⁽²⁾ | N/A | 24 | N/A |
| Criteria (mg/L) ⁽³⁾ | 4.64 | 1.73 | 4.33 |
| Dilution Credit | 20:1 | 20:1 | 20:1 |
| ECA | 91.44 | 30.33 | 84.83 |
| ECA Multiplier | 0.19 | 0.65 | 0.35 |
| LTA ⁽⁴⁾ | 17.60 | 19.73 | 30.02 |
| AMEL Multiplier (95 th %) | 2.01 | ⁽⁵⁾ | ⁽⁵⁾ |
| AMEL (mg/L) | 35 | ⁽⁵⁾ | ⁽⁵⁾ |
| MDEL Multiplier (99 th %) | 5.19 | ⁽⁵⁾ | ⁽⁵⁾ |
| MDEL (mg/L) | 91 | ⁽⁵⁾ | ⁽⁵⁾ |

⁽¹⁾ Acute design pH = 8.1 (max. allowed pH); chronic design pH = 7.8 (max. observed 30-day effluent pH).

⁽²⁾ Temperature = the maximum observed running 30-day average effluent temperature.

⁽³⁾ USEPA Ambient Water Quality Criteria.

⁽⁴⁾ LTA developed based on Acute and Chronic ECA Multipliers calculated at 99th percentile level per sections 5.4.1 and 5.5.4 of TSD.

⁽⁵⁾ Limitations based on the acute (1-hr) LTA.

Table F-10. WQBEL Calculations for Copper

| | Acute | Chronic | Basin Plan |
|--------------------------------------|----------------------|---------------------|-------------------|
| Criteria, dissolved (µg/L) | 10.63 ⁽¹⁾ | 7.24 ⁽¹⁾ | 10 ⁽²⁾ |
| Dilution Credit | 20:1 | 20:1 | 20:1 |
| Translator ⁽²⁾ | 0.96 | 0.96 | 0.96 |
| Criteria, total recoverable | 11.1 | 7.5 | 10.4 |
| ECA | 145 | 70.4 | 131 |
| ECA Multiplier | 0.32 | 0.53 | N/A |
| LTA | 46.4 | 37.1 | N/A |
| AMEL Multiplier (95 th %) | ⁽⁴⁾ | 1.55 | -- |
| AMEL (µg/L) | ⁽⁴⁾ | 58 | -- |
| MDEL Multiplier (99 th %) | ⁽⁴⁾ | 3.11 | -- |
| MDEL (µg/L) | ⁽⁴⁾ | 116 | 131 |

- ⁽¹⁾ CTR aquatic life criteria, based on the lowest hardness of the effluent of 78 mg/L as CaCO₃.
- ⁽²⁾ Basin Plan site-specific objective for the Delta.
- ⁽³⁾ EPA Translator used as default.
- ⁽⁴⁾ Limitations based on chronic LTA (chronic LTA < acute LTA).

Table F-11. WQBEL Calculations for Dibromochloromethane

| | Human Health |
|-------------------------------------|--------------|
| Criteria (µg/L) | 0.41 |
| Dilution Credit | 1000:1 |
| ECA | 230 |
| AMEL (µg/L) ⁽¹⁾ | 230 |
| MDEL/AMEL Multiplier ⁽²⁾ | 2.01 |
| MDEL (µg/L) | 463 |

- ⁽¹⁾ AMEL = ECA per section 1.4.B, Step 6 of SIP.
- ⁽²⁾ Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-12. WQBEL Calculations for Dichlorobromomethane

| | Human Health |
|-------------------------------------|--------------|
| Criteria (µg/L) | 0.56 |
| Dilution Credit | 1000:1 |
| ECA | 360 |
| AMEL (µg/L) ⁽¹⁾ | 360 |
| MDEL/AMEL Multiplier ⁽²⁾ | 2.01 |
| MDEL (µg/L) | 724 |

- ⁽¹⁾ AMEL = ECA per section 1.4.B, Step 6 of SIP.
- ⁽²⁾ Assumes sampling frequency n<=4. Uses MDEL/AMEL multiplier from Table 2 of SIP.

Table F-13. WQBEL Calculations for Lead

| | Acute | Chronic |
|---|----------------|-----------|
| Criteria, dissolved (µg/L) ⁽¹⁾ | 86 | 2.8 |
| Translator | 0.83 | 0.83 |
| Criteria, Total | 104 | 3.3 |
| Dilution Credit | 20:1 | 20:1 |
| ECA | 2182 | 59.6 |
| ECA Multiplier | 0.32 | 0.53 |
| LTA | 700.6 | 31.4 |
| AMEL Multiplier (95 th %) | ⁽²⁾ | 1.55 |
| AMEL (µg/L) | ⁽²⁾ | 49 |
| MDEL Multiplier (99 th %) | ⁽²⁾ | 3.11 |
| MDEL (µg/L) | ⁽²⁾ | 98 |

⁽¹⁾ CTR aquatic life criteria, based on the lowest hardness of the effluent of 78 mg/L and the highest hardness of the receiving water of 100 mg/L as CaCO₃.

⁽²⁾ Limitations based on chronic LTA (Chronic LTA < Acute LTA).

**Summary of Water Quality-based Effluent Limitations
 Discharge Point No. 001**

Table F-14. Summary of Water Quality-based Effluent Limitations

| Parameter | Units | Effluent Limitations | | | | |
|--------------------------------|------------------------|----------------------|--------------------|----------------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Aluminum, Total Recoverable | µg/L | 411 | 200 ⁽⁶⁾ | 750 | -- | -- |
| Ammonia Nitrogen, Total (as N) | mg/L | 35 | -- | 91 | -- | -- |
| | lbs/day ⁽⁸⁾ | 190 | -- | 493 | -- | -- |
| | lbs/day ⁽⁹⁾ | 671 | -- | 1746 | -- | -- |
| Arsenic, Total Recoverable | µg/L | -- | -- | 6,910 ⁽⁷⁾ | -- | -- |
| Chlorine Total Residual | mg/L | 0.011 ⁽¹⁾ | -- | 0.019 ⁽²⁾ | -- | -- |
| Coliform, Total | MPN/100 mL | -- | 23 ⁽³⁾ | 240 ⁽⁴⁾ | -- | -- |
| Copper, Total Recoverable | µg/L | 58 | -- | 116 | -- | -- |
| Dibromochloromethane | µg/L | 230 ⁽⁷⁾ | -- | 463 ⁽⁷⁾ | -- | -- |
| Dichlorobromomethane | µg/L | 360 ⁽⁷⁾ | -- | 724 ⁽⁷⁾ | -- | -- |
| Iron, Total Recoverable | µg/L | -- | -- | 300 | -- | -- |
| Lead, Total Recoverable | µg/L | 49 ⁽⁷⁾ | -- | 98 ⁽⁷⁾ | -- | -- |
| Manganese, Total Recoverable | µg/L | -- | -- | 1,750 ⁽⁷⁾ | -- | -- |
| Nitrate Nitrogen, Total (as N) | mg/L | 7,810 ⁽⁷⁾ | -- | -- | -- | -- |
| Nitrite Nitrogen, Total (as N) | mg/L | 972 ⁽⁷⁾ | -- | -- | -- | -- |
| pH | Standard Units | -- | -- | -- | 6.5 | 8.5 |
| Settleable Solids | ml/L | 0.1 | -- | 0.2 | -- | -- |

| Parameter | Units | Effluent Limitations | | | | |
|-------------|-------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Temperature | °F | -- | -- | -- | -- | (5) |

- (1) Applied as a 4-day average.
- (2) Applied as a 1-hour average.
- (3) 7-day median
- (4) Effluent total coliform concentration shall not exceed 240 MPN/100 mL more than once in any 30-day period.
- (5) The maximum effluent temperature shall not exceed the natural receiving water temperature by more than 20°F.
- (6) Annual average
- (7) More stringent performance-based limit applies to ensure compliance with BPTC requirements of State Water Board Resolution 68-16.
- (8) Based on a design average dry weather flow capacity of 0.65 mgd (applicable May-Oct).
- (9) Based on a design peak wet weather flow capacity of 2.3 mgd (applicable Nov-Apr).

5. Whole Effluent Toxicity (WET)

For compliance with the Basin Plan’s narrative toxicity objective, this Order requires the Discharger to conduct whole effluent toxicity testing for acute and chronic toxicity, as specified in the Monitoring and Reporting Program (Attachment E, Section V). This Order also contains effluent limitations for acute toxicity and requires the Discharger to implement best management practices to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity.

a. **Acute Aquatic Toxicity.** The Basin Plan contains a narrative toxicity objective that states, “All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.” (Basin Plan at III-8.00) The Basin Plan also states that, “...effluent limits based upon acute biotoxicity tests of effluents will be prescribed where appropriate...”. USEPA Region 9 provided guidance for the development of acute toxicity effluent limitations in the absence of numeric water quality objectives for toxicity in its document titled "Guidance for NPDES Permit Issuance", dated February 1994. In section B.2. "Toxicity Requirements" (pgs. 14-15) it states that, "In the absence of specific numeric water quality objectives for acute and chronic toxicity, the narrative criterion 'no toxics in toxic amounts' applies. Achievement of the narrative criterion, as applied herein, means that ambient waters shall not demonstrate for acute toxicity: 1) less than 90% survival, 50% of the time, based on the monthly median, or 2) less than 70% survival, 10% of the time, based on any monthly median. For chronic toxicity, ambient waters shall not demonstrate a test result of greater than 1 TUc." Accordingly, effluent limitations for acute toxicity have been included in this Order as follows:

Acute Toxicity. Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

- Minimum for any one bioassay ----- 70%
- Median for any three or more consecutive bioassays ----- 90%

- b. **Chronic Aquatic Toxicity.** Based on annual whole effluent chronic toxicity testing performed by the Discharger, the discharge does not have a reasonable potential to cause or contribute to an in-stream excursion above of the Basin Plan’s narrative toxicity objective. A dilution credit of 20:1 has been granted for the chronic condition. Therefore, chronic toxicity testing results exceeding 20 chronic toxicity unit (TUc) demonstrates the discharge has a reasonable potential to cause or contribute to an exceedance of the Basin Plan’s narrative toxicity objective. Table F-15, below, shows chronic whole effluent toxicity testing for 2003 and 2004.

Table F-15. Chronic Toxicity Exceedances

| Date | Chronic Toxicity Unit (TUc) | | | | |
|----------------|-----------------------------|--------------|----------------------------|--------|----------------------------------|
| | <i>Ceriodaphnia dubia</i> | | <i>Pimephales promelas</i> | | <i>Selenastrum capricornutum</i> |
| | survival | reproduction | survival | growth | growth |
| 12 August 2003 | 4.0 | 4.0 | -- | -- | -- |
| 12 August 2003 | -- | -- | 4.0 | 2.0 | -- |
| 12 August 2003 | 8.0 | 8.0 | -- | -- | -- |
| 14 August 2003 | -- | -- | -- | -- | 4.0 |
| 14 August 2003 | -- | -- | -- | -- | 8.0 |
| 31 August 2004 | 1.33 | 4.0 | 4.0 | 4.0 | -- |

To ensure compliance with the Basin Plan’s narrative toxicity objective, the Discharger is required to conduct chronic whole effluent toxicity testing, as specified in the Monitoring and Reporting Program (Attachment E, Section V). Furthermore, Special Provision VI.C.2.a. of this Order requires the Discharger to conduct a Toxicity Reduction Evaluation (TRE), in accordance with an approved TRE work plan, if the discharge demonstrates a pattern of toxicity exceeding the numeric monitoring trigger (16 TUc). The numeric toxicity monitoring trigger is not an effluent limitation, it is the toxicity threshold at which the Discharger is required to perform accelerated chronic toxicity monitoring, as well as the threshold to initiate a TRE if a pattern of effluent toxicity has been demonstrated.

D. Final Effluent Limitations

1. Mass-based Effluent Limitations

Title 40 CFR 122.45(f)(1) requires effluent limitations be expressed in terms of mass, with some exceptions, and 40 CFR 122.45(f)(2) allows pollutants that are limited in terms of mass to additionally be limited in terms of other units of measurement. This Order includes effluent limitations expressed in terms of mass and concentration. In addition, pursuant to the exceptions to mass limitations provided in 40 CFR 122.45(f)(1), some effluent limitations are not expressed in terms of mass, such as pH and temperature, and when the applicable standards are expressed in terms of concentration (e.g., CTR criteria and MCLs) and mass limitations are not necessary to protect the beneficial uses of the receiving water.

Consistent with 40 CFR 122.45(b)(1) for POTWs, permit effluent limitations shall be calculated based on design flow. In Order No.5-01-178 mass limitations were based on a design average daily discharge flow of 0.65 mgd (applicable May through

October) and a design peak wet weather flow (PWWF) of 2.3 mgd (applicable November through April). Mass-based effluent limitations for BOD and TSS in this Order remain unchanged from the previous Order and are based on an average daily discharge flow of 0.65.

Also, due to the concern over bioaccumulation, this Order contains an interim performance-based mass effluent limitation of 0.0071 lbs/month for mercury, which is based on an average daily discharge flow of 0.65 mgd.

2. Averaging Periods for Effluent Limitations

Title 40 CFR 122.45 (d) requires average weekly and average monthly discharge limitations for POTWs unless impracticable. However, for toxic pollutants and pollutant parameters in water quality permitting, the USEPA recommends the use of a maximum daily effluent limitation in lieu of average weekly effluent limitations for two reasons. *“First, the basis for the 7-day average for POTWs derives from the secondary treatment requirements. This basis is not related to the need for assuring achievement of water quality standards. Second, a 7-day average, which could comprise up to seven or more daily samples, could average out peak toxic concentrations and therefore the discharge’s potential for causing acute toxic effects would be missed.”* (TSD, pg. 96) This Order utilizes maximum daily effluent limitations in lieu of average weekly effluent limitations for aluminum, ammonia, copper, dibromochloromethane, dichlorobromomethane, and lead as recommended by the TSD for the achievement of water quality standards and for the protection of the beneficial uses of the receiving stream. Furthermore, for BOD, TSS, pH, settleable solids, and coliform, weekly average effluent limitations have been replaced or supplemented with effluent limitations utilizing shorter averaging periods. For chlorine residual average weekly and average monthly effluent limitations have been replaced or supplemented with effluent limitations utilizing shorter averaging periods.¹ The rationale for using shorter averaging periods for these constituents is discussed in Attachment F, Section IV.C.3., above.

For effluent limitations based on Primary and Secondary MCLs, except nitrate and nitrite, this Order includes annual average effluent limitations. The Primary and Secondary MCLs are drinking water standards contained in Title 22 of the California Code of Regulations. Title 22 requires compliance with these standards on an annual average basis (except for nitrate and nitrite), when sampling at least quarterly. Since it is necessary to determine compliance on an annual average basis, it is impracticable to calculate average weekly and average monthly effluent limitations.

3. Satisfaction of Anti-Backsliding Requirements

¹ This Order applies the USEPA National Ambient Water Quality Criteria for chlorine directly as effluent limitations (1-hour average, acute, and 4-day average, chronic). See Section IV.C.3., above, for rationale regarding the chlorine residual effluent limitations.

The effluent limitations for oil and grease have been removed from this Order. The monitoring data for oil and grease collected during the existing Order term were well below the effluent limitations in the existing Order. The monitoring data submitted by the Facility is considered new information by the Regional Water Board. In addition, due to no detections of pesticides, the effluent limitations for organo-chlorine pesticides have been removed. The removal of the effluent limitations for pesticides and oil and grease is consistent with federal antibacksliding regulations and the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution No. 68-16. The impact to water quality will be insignificant.

4. Satisfaction of Antidegradation Policy

The permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution 68-16. There is no increase in flow or mass of pollutants from this Facility. Therefore, the permitted surface water discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution 68-16. Compliance with these requirements will result in the use of best practicable treatment or control of the discharge. The impact on existing water quality will be insignificant due to the relatively small size of the discharge in relation to the size of the receiving water and the level of treatment of the effluent.

This Order allows a mixing/dilution zone in accordance with the Basin Plan, the SIP, EPA's *Water Quality Standards Handbook, 2d Edition* (updated July 2007) and EPA's *Technical Support Document for Water Quality-based Toxics Control*. As discussed in Finding IV.C.2.c of this Fact Sheet (Assimilative Capacity/Mixing Zone), the mixing zone complies with all applicable requirements. In addition, this Order includes more stringent performance-based requirements for total arsenic, dibromochloromethane, dichlorobromomethane, total lead, manganese, mercury, nitrate as nitrogen and salinity, than would be allowed under the mixing zone analysis alone. Therefore, the mixing zone will be not be adverse to the purpose of the state and federal antidegradation policies.

**Summary of Final Effluent Limitations
 Discharge Point No. 001**

Table F-16. Summary of Final Effluent Limitations

| Parameter | Units | Effluent Limitations | | | | |
|---|------------------------|----------------------|--------------------|----------------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Electrical Conductivity | µmhos/cm | 1,300 ⁽⁶⁾ | -- | -- | -- | -- |
| Aluminum, Total Recoverable | µg/L | 411 | 200 ⁽⁶⁾ | 750 | -- | -- |
| Biochemical Oxygen Demand, 5-day @ 20°C (BOD ₅) | mg/L | 30 | 45 | 60 | -- | -- |
| | lbs/day ⁽⁷⁾ | 163 | 244 | 326 | -- | -- |
| | lbs/day ⁽⁸⁾ | 575 | 863 | 1151 | -- | -- |
| | %removal | 85 | -- | -- | -- | -- |
| Total Suspended Solids (TSS) | mg/L | 30 | 45 | 60 | -- | -- |
| | lbs/day ⁽⁷⁾ | 163 | 244 | 326 | -- | -- |
| | lbs/day ⁽⁸⁾ | 575 | 863 | 1151 | -- | -- |
| | %removal | 85 | -- | -- | -- | -- |
| Ammonia Nitrogen, Total (as N) | mg/L | 15 | -- | 39 | -- | -- |
| | lbs/day ⁽⁷⁾ | 190 | -- | 493 | -- | -- |
| | lbs/day ⁽⁸⁾ | 671 | -- | 1746 | -- | -- |
| Arsenic, Total Recoverable | µg/L | -- | -- | 16 | -- | -- |
| Chlorine Total Residual | mg/L | 0.011 ⁽¹⁾ | -- | 0.019 ⁽²⁾ | -- | -- |
| Coliform, Total | MPN/100 mL | -- | 23 ⁽³⁾ | 240 ⁽⁴⁾ | -- | -- |
| Copper, Total Recoverable | µg/L | 58 | -- | 116 | -- | -- |
| Dibromochloromethane | µg/L | -- | -- | 2.8 | -- | -- |
| Dichlorobromomethane | µg/L | -- | -- | 5.6 | -- | -- |
| Iron, Total Recoverable | µg/L | -- | -- | 300 | -- | -- |
| Lead, Total Recoverable | µg/L | -- | -- | 7.2 | -- | -- |
| Manganese, Total Recoverable | µg/L | -- | -- | 467 | -- | -- |
| Nitrate Nitrogen, Total (as N) | mg/L | -- | -- | 65 | -- | -- |
| Nitrite Nitrogen, Total (as N) | mg/L | -- | -- | 3.1 | -- | -- |
| pH | Standard Units | -- | -- | -- | 6.5 | 8.5 |
| Settleable Solids | ml/L | 0.1 | -- | 0.2 | -- | -- |
| Temperature | °F | -- | -- | -- | -- | (4) |

⁽¹⁾ Applied as a 4-day average.
⁽²⁾ Applied as a 1-hour average.

- ⁽³⁾ 7-day median
- ⁽⁴⁾ Effluent total coliform concentration shall not exceed 240 MPN/100 mL more than once in any 30-day period.
- ⁽⁵⁾ The maximum effluent temperature shall not exceed the natural receiving water temperature by more than 20°F.
- ⁽⁶⁾ Annual average
- ⁽⁷⁾ Based on a design average dry weather flow capacity of 0.65 mgd (applicable May-Oct).
- ⁽⁸⁾ Based on a design peak wet weather flow capacity of 2.3 mgd (applicable Nov-Apr).

E. Interim Effluent Limitations

1. The SIP, section 2.2.1, requires that if a compliance schedule is granted for a CTR or NTR constituent, the Regional Water Board shall establish interim requirements and dates for their achievement in the NPDES permit. The interim limitations must be based on current treatment plant performance or existing permit limitations, whichever is more stringent. The State Water Board has held that the SIP may be used as guidance for non-CTR constituents. Therefore, the SIP requirement for interim effluent limitations has been applied to both CTR and non-CTR constituents in this Order.

In developing performance-based interim limitations, where there are 10 sampling data points or more, sampling and laboratory variability is accounted for by establishing interim limits that are based on log normally distributed data where 99.9% of the data points will lie within 3.3 standard deviations of the mean. Therefore, the interim limitations in this Order are established as the mean plus 3.3 standard deviations of the available data transformed by the natural log.

When there are less than 10 sampling data points available, the *Technical Support Document for Water Quality- Based Toxics Control* ((EPA/505/2-90-001), TSD) recommends a coefficient of variation of 0.6 be utilized as representative of wastewater effluent sampling. The TSD recognizes that a minimum of 10 data points is necessary to conduct a valid statistical analysis. The multipliers contained in Table 5-2 of the TSD are used to determine a maximum daily limitation based on a long-term average objective. In this case, the long-term average objective is to maintain, at a minimum, the current plant performance level. Therefore, when there are less than 10 sampling points for a constituent, interim limitations are based on 3.11 times the maximum observed effluent concentration to obtain the daily maximum interim limitation (TSD, Table 5-2).

Interim limitations are established when compliance with effluent limitations cannot be achieved by the existing discharge. Discharge of constituents in concentrations in excess of the final effluent limitations, but in compliance with the interim effluent limitations, can significantly degrade water quality and adversely affect the beneficial uses of the receiving stream on a long-term basis. The interim limitations, however, establish an enforceable ceiling concentration until compliance with the effluent limitation can be achieved.

The procedure for calculating performance-based interim effluent limitations, discussed above, has been used in this Order to calculate performance-based

effluent limitations for arsenic, dibromochloromethane, dichlorobromomethane, lead, manganese, nitrate, and nitrite. Table F-15 summarizes the calculations of the performance-based effluent limitations.

Table F-17. Performance-based Effluent Limitation Calculation Summary

| Parameter | Unit | MEC | Mean of In | Std. Dev. of In | # of Samples | Performance-based Limit |
|------------------------------|------|-----|------------|-----------------|--------------|-------------------------|
| Arsenic | µg/L | 14 | 2.19 | 0.175 | 30 | 16 |
| Dibromochloromethane | µg/L | 0.9 | -- | -- | 5 | 2.8 |
| Dichlorobromomethane | µg/L | 1.8 | -- | -- | 5 | 5.6 |
| Lead, Total Recoverable | µg/L | 2.3 | -- | -- | 5 | 7.2 |
| Manganese, Total Recoverable | µg/L | 150 | -- | -- | 5 | 467 |
| Nitrate as N | mg/L | 21 | -- | -- | 4 | 65 |
| Nitrite as N | mg/L | 1 | -- | -- | 4 | 3.1 |

- Mercury.** This Order contains an interim performance-based mass effluent limitation of 0.007196 lbs/month for mercury. This limitation is based on maintaining the mercury loading at the current level until a TMDL can be established and USEPA develops mercury standards that are protective of human health.

F. Land Discharge Specifications

[Not applicable]

G. Reclamation Specifications

[Not applicable]

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

Basin Plan water quality objectives to protect the beneficial uses of surface water and groundwater include numeric objectives and narrative objectives, including objectives for chemical constituents, toxicity, and tastes and odors. The toxicity objective requires that surface water and groundwater be maintained free of toxic substances in concentrations that produce detrimental physiological responses in humans, plants, animals, or aquatic life. The chemical constituent objective requires that surface water and groundwater shall not contain chemical constituents in concentrations that adversely affect any beneficial use or that exceed the maximum contaminant levels (MCLs) in Title 22, CCR. The tastes and odors objective states that surface water and groundwater shall not contain taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The Basin Plan requires the application of the most stringent objective necessary to ensure that surface water and groundwater do not contain chemical constituents, toxic substances, radionuclides, or taste and odor producing substances in concentrations that adversely affect domestic drinking water supply, agricultural supply, or any other beneficial use.

A. Surface Water

1. CWA section 303(a-c), requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Regional Water Board adopted water quality criteria as water quality objectives in the Basin Plan. The Basin Plan states that “[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional Board will apply to regional waters in order to protect the beneficial uses.” The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains Receiving Surface Water Limitations based on the Basin Plan numerical and narrative water quality objectives for biostimulatory substances, chemical constituents, color, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, sediment, settleable material, suspended material, tastes and odors, temperature, toxicity, turbidity, and electrical conductivity.

Numeric Basin Plan objectives for bacteria, dissolved oxygen, pH, temperature, and turbidity are applicable to this discharge and have been incorporated as Receiving Surface Water Limitations. Rational for these numeric receiving surface water limitations are as follows:

- a. **Bacteria.** The Basin Plan includes a water quality objective that “[I]n water designated for contact recreation (REC-1), the fecal coliform concentration based on a minimum of not less than five samples for any 30-day period shall not exceed a geometric mean of 200/100 ml, nor shall more than ten percent of the total number of samples taken during any 30-day period exceed 400/100 ml.” Numeric Receiving Water Limitations for bacteria are included in this Order and are based on the Basin Plan objective.
- b. **Biostimulatory Substances.** The Basin Plan includes a water quality objective that “[W]ater shall not contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.” Receiving Water Limitations for biostimulatory substances are included in this Order and are based on the Basin Plan objective.
- c. **Color.** The Basin Plan includes a water quality objective that “[W]ater shall be free of discoloration that causes nuisance or adversely affects beneficial uses.” Receiving Water Limitations for color are included in this Order and are based on the Basin Plan objective.
- d. **Chemical Constituents.** The Basin Plan includes a water quality objective that “[W]aters shall not contain chemical constituents in concentrations that adversely affect beneficial uses.” Receiving Water Limitations for chemical constituents are included in this Order and are based on the Basin Plan objective.
- e. **Dissolved Oxygen.** The Basin Plan includes a water quality objective that “[W]ithin the legal boundaries of the Delta, the dissolved oxygen concentrations shall not be reduced below: 7.0 mg/L in the Sacramento River (below the I

Street Bridge) and in all Delta waters west of the Antioch Bridge; 6.0 mg/L in the San Joaquin River (between Turner Cut and Stockton, 1 September through 30 November); and 5.0 mg/L in all other Delta waters except those bodies of water which are constructed for special purposes and from which fish have been excluded or where the fishery is not important as a beneficial use.” Numeric Receiving Water Limitations for dissolved oxygen are included in this Order and are based on the Basin Plan objective.

- f. **Floating Material.** The Basin Plan includes a water quality objective that “[W]ater shall not contain floating material in amounts that cause nuisance or adversely affect beneficial uses.” Receiving Water Limitations for floating material are included in this Order and are based on the Basin Plan objective.
- g. **Oil and Grease.** The Basin Plan includes a water quality objective that “[W]aters shall not contain oils, greases, waxes, or other materials in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.” Receiving Water Limitations for oil and grease are included in this Order and are based on the Basin Plan objective.
- h. **pH.** The Basin Plan includes water quality objective that “[T]he pH shall not be depressed below 6.5 nor raised above 8.5. Changes in normal ambient pH levels shall not exceed 0.5 in fresh waters with designated COLD or WARM beneficial uses” This Order includes receiving water limitations for both pH range and pH change.

The Basin Plan allows an appropriate averaging period for pH change in the receiving stream. Since there is no technical information available that indicates that aquatic organisms are adversely affected by shifts in pH within the 6.5 to 8.5 range, an averaging period is considered appropriate and a monthly averaging period for determining compliance with the 0.5 receiving water pH limitation is included in this Order.

- i. **Pesticides.** The Basin Plan includes a water quality objective for pesticides beginning on page III-6.00 . Receiving Water Limitations for pesticides are included in this Order and are based on the Basin Plan objective.
- j. **Radioactivity.** The Basin Plan includes a water quality objective that “[R]adionuclides shall not be present in concentrations that are harmful to human, plant, animal or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal or aquatic life.” The Basin Plan states further that “[A]t a minimum, waters designated for use as domestic or municipal supply (MUN) shall not contain concentrations of radionuclides in excess of the maximum contaminant levels (MCLs) specified in Table 4 (MCL Radioactivity) of Section 64443 of Title 22 of the California Code of Regulations...” Receiving Water Limitations for radioactivity are included in this Order and are based on the Basin Plan objective.

- k. **Sediment.** The Basin Plan includes a water quality objective that “[T]he suspended sediment load and suspended sediment discharge rate of surface waters shall not be altered in such a manner as to cause nuisance or adversely affect beneficial uses” Receiving Water Limitations for suspended sediments are included in this Order and are based on the Basin Plan objective.
- l. **Settleable Material.** The Basin Plan includes a water quality objective that “[W]aters shall not contain substances in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.” Receiving Water Limitations for settleable material are included in this Order and are based on the Basin Plan objective.
- m. **Suspended Material.** The Basin Plan includes a water quality objective that “[W]aters shall not contain suspended material in concentrations that cause nuisance or adversely affect beneficial uses.” Receiving Water Limitations for suspended material are included in this Order and are based on the Basin Plan objective.
- n. **Taste and Odors.** The Basin Plan includes a water quality objective that “[W]ater shall not contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to domestic or municipal water supplies or to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.” Receiving Water Limitations for taste- or odor-producing substances are included in this Order and are based on the Basin Plan objective.
- o. **Temperature.** The Thermal Plan is applicable to this discharge. The Thermal Plan requires the following:
- No discharge shall cause a surface water temperature rise greater than 4°F above the natural temperature of the receiving water at any time or place;
 - The maximum temperature shall not exceed the natural receiving water temperature by more than 20°F.

This Order includes receiving water limitations based on these objectives.

- p. **Toxicity.** The Basin Plan includes a water quality objective that “[A]ll waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.” Receiving Water Limitations for toxicity are included in this Order and are based on the Basin Plan objective.
- q. **Turbidity.** The Basin Plan includes a water quality objective that “[I]ncreases in turbidity attributable to controllable water quality factors shall not exceed the following limits:

- *Where natural turbidity is between 0 and 5 Nephelometric Turbidity Units (NTUs), increases shall not exceed 1 NTU.*
- *Where natural turbidity is between 5 and 50 NTUs, increases shall not exceed 20 percent.*
- *Where natural turbidity is between 50 and 100 NTUs, increases shall not exceed 10 NTUs.*
- *Where natural turbidity is greater than 100 NTUs, increases shall not exceed 10 percent.”*

A numeric Receiving Surface Water Limitation for turbidity is included in this Order and is based on the Basin Plan objective for turbidity.

B. Groundwater

1. The discharge shall not cause the groundwater to exceed water quality objectives, unreasonably affect beneficial uses, or cause a condition of pollution or nuisance.
2. The previous Order contained groundwater limitations. This Order carries forward the following groundwater limitations:

Release of waste constituents from any storage, treatment, or disposal component associated with the Facility shall not, in combination with other sources of the waste constituents, cause groundwater within influence of the Facility to contain waste constituents in concentrations in excess of natural background quality or that listed below, whichever is greater:

- a. Total coliform organisms median of 2.2 MPN/100 mL over any 7-day period.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring

1. Influent monitoring is required to collect data on the characteristics of the wastewater and to assess compliance with effluent limitations (e.g., BOD₅ and TSS percent reduction requirements). Continuous flow monitoring, weekly monitoring for BOD₅, TSS, and pH and monthly monitoring for electrical conductivity have been carried over from Monitoring and Reporting Program No. 5-01-178.

B. Effluent Monitoring

1. Pursuant to the requirements of 40 CFR 122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. Effluent monitoring is necessary to assess compliance with effluent limitations, assess the effectiveness of the treatment process, and to assess the impacts of the discharge on the receiving stream.

Monitoring requirements for flow, BOD, TSS, pH, settleable solids, temperature, total coliform, dissolved oxygen, oil and grease, electrical conductivity, ammonia, aluminum, arsenic, total dissolved solids, mercury, and priority pollutants have been retained from the previous Order. The monitoring frequency for chlorine residual has been changed to continuous. Monitoring data collected over the previous permit term for total organic carbon did not demonstrate potential to violate water quality. Therefore, monitoring for total organic carbon will be removed from the Order.

Monthly monitoring requirements for copper, dibromochloromethane, dichlorobromomethane, iron, lead, manganese, nitrate, and nitrite have been added to this Order, since the reasonable potential analysis demonstrated a reasonable potential to exceed water quality objectives/criteria. Quarterly monitoring requirement for boron and bis (2-chloroethyl) ether has been added to this Order in order to collect additional effluent data to evaluate reasonable potential.

C. Whole Effluent Toxicity Testing Requirements

1. **Acute Toxicity.** Consistent with the previous Order, quarterly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity.
2. **Chronic Toxicity.** Consistent with the previous Order, annual chronic whole effluent toxicity testing is required to demonstrate compliance with the Basin Plan's narrative toxicity objective.

D. Receiving Water Monitoring

1. Surface Water

- a. Receiving water monitoring is necessary to assess compliance with receiving water limitations and to assess the impacts of the discharge on the receiving stream.
- b. Quarterly monitoring for priority pollutants upstream of the discharge point is required during the third year of the permit term to collect the necessary data to determine reasonable potential as required in section 1.2 of the SIP. The pH and hardness (as CaCO₃) of the up stream receiving water shall also be monitoring concurrently with the priority pollutants to ensure the water quality

criteria/objectives are correctly adjusted for the receiving water when determining reasonable potential as specified in section 1.3 of the SIP.

2. Groundwater

[Not applicable]

E. Other Monitoring Requirements

1. Biosolids Monitoring

Biosolids monitoring is required to ensure compliance with the biosolids disposal requirements (Special Provision VI.C.5). Biosolids disposal requirements are imposed pursuant to 40 CFR Part 503 to protect public health and prevent groundwater degradation.

2. Water Supply Monitoring

Consistent with the requirements contained in Order No. 5-01-178, monitoring water supply monitoring is required to evaluate the relative contribution of salinity from the source water to the effluent. In particular, quarterly monitoring for electrical conductivity and total dissolved solids is required.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Section 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with section 123.25, this Order omits federal conditions that address enforcement authority specified in sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

B. Special Provisions

1. Reopener Provisions

- a. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.

Conditions that necessitate a major modification of a permit are described in 40 CFR 122.62, including:

- i. If new or amended applicable water quality standards are promulgated or approved pursuant to Section 303 of the CWA, or amendments thereto, this permit may be reopened and modified in accordance with the new or amended standards.
 - ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
- b. **Mercury.** This reopener provision allows the Regional Water Board to reopen this Order if mercury is found to be causing toxicity based on acute or chronic toxicity test results, if a TMDL program is adopted, or if the Regional Water Board determines that a mercury offset program is feasible for Dischargers subject to a NPDES permit.
 - c. **Whole Effluent Toxicity.** This Order requires the Discharger to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity through a Toxicity Reduction Evaluation (TRE). This Order may be reopened to include a numeric chronic toxicity limitation, a new acute toxicity limitation, and/or a limitation for a specific toxicant identified in the TRE. Additionally, if a numeric chronic toxicity water quality objective is adopted by the State Water Board, this Order may be reopened to include a numeric chronic toxicity limitation based on that objective.
 - d. **Water Effects Ratio (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating CTR criteria for applicable priority pollutant inorganic constituents. In addition, default dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable when developing effluent limitations for inorganic constituents. If the Discharger performs studies to determine site-specific WERs and/or site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents. The Discharger is considering performing studies to develop site-specific dissolved-to-total metal translators for iron and manganese. This Order may be reopened

to modify the reasonable potential analysis and/or effluent limitations for iron and manganese based on the results of the Discharger's studies.

2. Special Studies and Additional Monitoring Requirements

- a. **Chronic Whole Effluent Toxicity Requirements.** The Basin Plan contains a narrative toxicity objective that states, "*All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.*" (Basin Plan at III-8.00.) Based on annual whole effluent chronic toxicity testing performed by the Discharger, the discharge has reasonable potential to cause or contribute to an in-stream excursion above of the Basin Plan's narrative toxicity objective.

This provision requires the Discharger to develop a Toxicity Reduction Evaluation (TRE) Work Plan in accordance with EPA guidance. In addition, the provision provides a numeric toxicity monitoring trigger and requirements for accelerated monitoring, as well as, requirements for TRE initiation if a pattern of toxicity has been demonstrated.

Monitoring Trigger. A numeric toxicity monitoring trigger of >16 TUC (where TUC = 100/NOEC) is applied in the provision, because this Order allows up to a 20:1 dilution credit for the chronic condition. Therefore, a TRE is triggered when the effluent exhibits a pattern of toxicity at 6.25% effluent.

Accelerated Monitoring. The provision requires accelerated WET testing when a regular WET test result exceeds the monitoring trigger. The purpose of accelerated monitoring is to determine, in an expedient manner, whether there is a pattern of toxicity before requiring the implementation of a TRE. Due to possible seasonality of the toxicity, the accelerated monitoring should be performed in a timely manner, preferably taking no more than 2 to 3 months to complete.


The provision requires accelerated monitoring consisting of four chronic toxicity tests every 2 weeks using the species that exhibited toxicity. Guidance regarding accelerated monitoring and TRE initiation is provided in the *Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991* (TSD). The TSD at page 118 states, "EPA recommends if toxicity is repeatedly or periodically present at levels above effluent limits more than 20 percent of the time, a TRE should be required." Therefore, four accelerated monitoring tests are required in this provision. If no toxicity is demonstrated in the four accelerated tests, then it demonstrates that toxicity is not present at levels above the monitoring trigger more than 20 percent of the time (only 1 of 5 tests are toxic, including the initial test). However, notwithstanding the accelerated monitoring results, if there is adequate evidence of a pattern of effluent toxicity (i.e., toxicity present exceeding the monitoring trigger more than 20 percent of the time), the Executive Officer may require that the Discharger initiate a TRE.

See the WET Accelerated Monitoring Flow Chart (Figure F-1), below, for further clarification of the accelerated monitoring requirements and for the decision points for determining the need for TRE initiation.

TRE Guidance. The Discharger is required to prepare a TRE Work Plan in accordance with USEPA guidance. Numerous guidance documents are available, as identified below:

- *Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants*, EPA 833/B-99/002, August 1999.
- *Generalized Methodology for Conducting Industrial TREs*, EPA 600/2-88/070, April 1989.
- *Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures*, Second Edition, EPA 600/6-91/005F, February 1991.
- *Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I*, EPA 600/6-91/005F, May 1992.
- *Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting acute and Chronic Toxicity*, Second Edition, EPA 600/R-92/080, September 1993.
- *Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity*, Second Edition, EPA 600/R-92/081, September 1993.
- *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition, EPA 821/R-02/012, October 2002.
- *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA 821/R-02/013, October 2002.
- *Technical Support Document for Water Quality-based Toxics Control*, EPA 505/2-90-001, March 1991.

**Figure F-1
WET Accelerated Monitoring Flow Chart**



b. Groundwater Monitoring

[Not applicable]

3. Best Management Practices and Pollution Prevention

- a. **Salinity Evaluation and Minimization Plan.** An Evaluation and Minimization Plan for salinity is required in this Order to ensure adequate measures are developed and implemented by the Discharger to reduce the discharge of salinity to the Sacramento River within the Sacramento-San Joaquin Delta.
- b. **Salinity Reduction Goal.** In an effort to monitor progress in reducing salinity discharges to the Sacramento River, the Discharger shall provide annual reports demonstrating reasonable progress in the reduction of salinity in its discharge to the Sacramento River. Based on effluent data for this Facility, the Regional Water Board finds that an average annual salinity effluent limitation of 1256 µmhos/cm as EC is a reasonable interim performance-based limitation that can be immediately achieved upon the effective date of this Order. The annual reports shall be submitted in accordance with the Monitoring and Reporting Program (Attachment E, Section X.D.1.).

4. Construction, Operation, and Maintenance Specifications

[Not applicable]

5. Special Provisions for Municipal Facilities

a. Pretreatment Requirements

[Not applicable]

b. Sludge/Biosolids Discharge Specifications

The sludge/biosolids provisions are required to ensure compliance with State disposal requirements (Title 27, CCR, Division 2, Subdivision 1, section 20005, et seq) and USEPA sludge/biosolids use and disposal requirements at 40 CFR Part 503.

c. Collection System

This provision is included to ensure that the Discharger complies with the requirements in the State Water Board adopted Statewide General WDR for Sanitary Sewer Systems (Order 2006-0003).

6. Other Special Provisions

- a. Prior to making any change in the discharge point, place of use, or purpose of use of the wastewater, the Discharger must obtain approval of, or clearance from the State Water Resources Control Board (Division of Water Rights).

In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to this office.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the State of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Regional Water Board and a statement. The statement shall comply with the signatory paragraph of Federal Standard Provision V.B.5 and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the California Water Code. Transfer shall be approved or disapproved in writing by the Executive Officer.

7. Compliance Schedules – Not Applicable

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, Central Valley Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for the City of Rio Vista Beach Wastewater Treatment Facility. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through direct mailing to agencies and known interested parties, posting of the NOPH at the Discharger's offices and the local post office and publication in the local newspaper.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on **8 July 2008**.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: **31 July/1 August 2008**
Time: 8:30 am
Location: Regional Water Quality Control Board, Central Valley Region
11020 Sun Center Dr., Suite #200
Rancho Cordova, CA 95670

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/rwqcb5/> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge (RWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (916) 464-3291.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to James D. Marshall at 916-464-4772.

ATTACHMENT G - SUMMARY OF REASONABLE POTENTIAL ANALYSIS

| Constituent | Units | MEC | B | C | CMC | CCC | Water & Org | Org. Only | Basin Plan | MCL | Reasonable Potential |
|--------------------------------|-------|-------|-------|-------|---------------------|----------------------|----------------------|-----------|------------|----------------------|----------------------|
| Aluminum | µg/L | 100 | 800 | 750 | 750 ⁽¹⁾ | 750 ⁽¹⁾ | -- | -- | -- | 200 ⁽²⁾ | Yes |
| Ammonia Nitrogen, Total (as N) | mg/L | 30 | 0.3 | 1.73 | 2.14 ⁽³⁾ | 1.73 ⁽³⁾ | -- | -- | -- | -- | Yes |
| Antimony | µg/L | 0.5 | 0.3 | 6 | -- | -- | 14 ⁽⁴⁾ | -- | -- | 6 ⁽⁷⁾ | No |
| Arsenic | µg/L | 14 | 3.1 | 10 | 340 | 150 | -- | -- | 10 | 10 ⁽⁷⁾ | Yes |
| Barium | µg/L | 24 | 4 | 100 | -- | -- | -- | -- | 100 | 1,000 ⁽⁷⁾ | No |
| Bis (2-Chloroethyl) Ether | µg/L | 0.12J | ND | 0.031 | -- | -- | 0.031 | -- | -- | 360 | No |
| Boron | µg/L | 1,200 | NA | 1,000 | -- | -- | 1,000 ⁽⁸⁾ | -- | -- | -- | Yes |
| Bromoform | µg/L | 1.3 | ND | 4.3 | -- | -- | 4.3 | -- | -- | 100 ⁽⁶⁾ | No |
| Bromomethane | µg/L | 1.8 | ND | 48 | -- | -- | 48 | -- | -- | -- | No |
| Butylbenzylphthalate | µg/L | 0.2 | ND | 3 | -- | 3 ⁽¹⁾ | 3,000 | -- | -- | -- | No |
| Cadmium | µg/L | 0.1 | 0.09 | 1.61 | 2.44 | 1.61 | -- | -- | -- | 5 | No |
| Chloride | mg/L | 135 | 20 | 106 | 860 | 230 | -- | -- | -- | 250 | Yes |
| Chloroform | µg/L | 2.9 | ND | 100 | -- | -- | -- | -- | -- | 100 ⁽⁶⁾ | No |
| Chromium (VI) | µg/L | 0.7 | ND | 11.43 | 16.29 | 11.43 | -- | -- | -- | 100 ⁽⁵⁾ | No |
| Chromium, Total | µg/L | 1.6 | 14 | 50 | -- | -- | -- | -- | -- | 50 ⁽⁷⁾ | No |
| Copper | µg/L | 41 | 14 | 7.54 | 11.08 | 7.54 | 1,300 | -- | 10 | 200 ⁽⁵⁾ | Yes |
| Cyanide | µg/L | 3 | 3 | 5.2 | 22 | 5.2 | 700 | -- | 10 | 150 | No |
| Diazinon | µg/L | 0.23 | ND | 6 | -- | -- | 6 ⁽⁸⁾ | -- | -- | -- | No |
| Dibromochloromethane | µg/L | 0.9 | ND | 0.41 | -- | -- | 0.41 | -- | -- | 100 ⁽⁶⁾ | Yes |
| 1,2-Dichlorobenzene | µg/L | 0.08 | ND | 600 | -- | 763 ⁽¹⁾ | 2,700 | -- | -- | 600 ⁽⁷⁾ | No |
| 1,3-Dichlorobenzene | µg/L | 0.5 | ND | 400 | -- | 763 ⁽¹⁾ | 400 | -- | -- | -- | No |
| 1,4-Dichlorobenzene | µg/L | 0.7 | ND | 5 | -- | 763 ⁽¹⁾ | 6 | -- | -- | 5 ⁽⁷⁾ | No |
| Dichlorobromomethane | µg/L | 1.8 | ND | 0.56 | -- | -- | 0.56 | -- | -- | 80 | Yes |
| 2,4-Dichlorophenol | µg/L | 0.066 | ND | 70 | -- | 70 ⁽¹⁾ | 93 | -- | -- | -- | No |
| Diethylphthalate | µg/L | 0.37 | ND | 3 | -- | 3 ⁽¹⁾ | 23,000 | -- | -- | -- | No |
| 2,4-Dimethylphenol | µg/L | 0.11 | ND | 540 | -- | 2,120 | 540 | -- | -- | -- | No |
| Dimethylphthalate | µg/L | 0.03 | 0.4 | 3 | -- | 313,000 | 3 | -- | -- | -- | No |
| Di-n-Butylphthalate | µg/L | 1.9 | 1.7 | 3 | -- | 3 ⁽¹⁾ | 2,700 | -- | -- | -- | No |
| Dinoseb | µg/L | 1.11 | 0.1 | 7 | -- | -- | -- | -- | -- | 7 ⁽⁷⁾ | No |
| Fluoride | µg/L | 700 | 400 | 2,000 | -- | -- | -- | -- | -- | 2,000 ⁽⁷⁾ | No |
| Iron | µg/L | 1,800 | 1,600 | 300 | -- | 1,000 ⁽¹⁾ | -- | -- | 300 | 300 ⁽²⁾ | Yes |
| Lead | µg/L | 2.3 | 3.1 | 2.29 | 58.8 | 2.3 | -- | -- | -- | 15 ⁽⁷⁾ | Yes |
| Manganese | µg/L | 150 | 33 | 50 | -- | -- | -- | -- | 50 | 50 ⁽²⁾ | Yes |

| Constituent | Units | MEC | B | C | CMC | CCC | Water & Org | Org. Only | Basin Plan | MCL | Reasonable Potential |
|--------------------------------------|----------|--------|-------|-------|--------------------|-----------------------|--------------------|-----------|-------------------------|------------------------------|----------------------|
| Mercury | µg/L | 0.043 | 0.026 | 0.050 | 1.4 ⁽¹⁾ | 0.77 ⁽¹⁾ | 0.050 | 0.051 | -- | 2.0 | Yes |
| Mercury, Dissolved | µg/L | 0.0087 | ND | 0.050 | 1.4 ⁽¹⁾ | 0.77 ⁽¹⁾ | 0.050 | 0.051 | -- | 2.0 | No |
| Methyl Blue Active Substances (MBAS) | µg/L | 180 | ND | 500 | -- | -- | -- | -- | -- | 500 ⁽²⁾ | No |
| Methyl-T-Butyl Ether (MTBE) | µg/L | 0.3 | 0.8 | 5 | -- | -- | 13 | -- | -- | 5 ⁽²⁾ | No |
| Naphthalene | µg/L | 0.03 | ND | 21 | -- | -- | 170 | -- | -- | 21 ⁽¹⁰⁾ | No |
| Nickel | µg/L | 3.5 | 22 | 32.9 | 295.9 | 32.9 | 610 | -- | -- | 100 | No |
| Nitrate Nitrogen, Total (as N) | mg/L | 21 | 2.2 | 10 | -- | -- | -- | -- | -- | 10 ⁽⁷⁾ | Yes |
| Nitrite Nitrogen, Total (as N) | mg/L | 1 | 0.029 | 1 | -- | -- | -- | -- | -- | 1 ⁽⁷⁾ | Yes |
| 2-Nitrophenol | µg/L | 0.027 | 0.02 | 150 | -- | 150 ⁽¹⁾ | -- | -- | -- | 290 | No |
| 4-Nitrophenol | µg/L | 0.12 | ND | 60 | -- | 150 ⁽¹⁾ | 60 ⁽¹¹⁾ | -- | -- | -- | No |
| Pentachlorophenol | µg/L | 0.11 | 0.04 | 0.28 | -- | 0.28 | 0.4 | -- | -- | 1 | No |
| Picloram | µg/L | 0.98 | ND | 490 | -- | -- | 490 ⁽⁹⁾ | -- | -- | 500 | No |
| Pyrene | µg/L | 0.069 | ND | 960 | -- | -- | 960 | -- | -- | -- | No |
| Selenium | µg/L | 2 | ND | 5 | 20 | 5 | -- | -- | -- | 20 ⁽⁵⁾ | No |
| Silver | µg/L | 0.05 | 0.03 | 1.59 | 1.59 | -- | -- | -- | 10 | 100 ⁽²⁾ | No |
| Specific Conductance (EC) | µmhos/cm | 1,300 | 280 | 450 | -- | -- | -- | -- | 450-2,780 ¹² | 900/1600/2200 ⁽⁵⁾ | Yes |
| Sulfate | µg/L | 120 | 15 | 250 | -- | -- | -- | -- | -- | 250 ⁽⁹⁾ | No |
| Thallium | µg/L | 0.06 | 0.03 | 1.7 | -- | -- | 1.7 | -- | -- | 2.0 | No |
| Toluene | µg/L | 1.5 | ND | 150 | -- | -- | 6,800 | -- | -- | 150 ⁽⁷⁾ | No |
| Total Dissolved Solids (TDS) | mg/L | 760 | 640 | 450 | -- | -- | -- | -- | -- | 450 ⁽⁵⁾ | Yes |
| Tributyltin | µg/L | 0.003 | 0.002 | 0.063 | -- | 0.063 ⁽¹¹⁾ | 2 | -- | -- | -- | No |
| 2,4,6-Trichlorophenol | µg/L | 0.16 | ND | 2.1 | -- | 970 | 2.1 | -- | -- | -- | No |
| Zinc | µg/L | 37 | 24 | 75.52 | 75.52 | 75.52 | -- | -- | 100 | 2,000 ⁽⁵⁾ | No |

General Note: All inorganic concentrations are given as a total recoverable.
MEC = Maximum Effluent Concentration
B = Maximum Receiving Water Concentration or lowest detection level, if non-detect
C = Criterion used for Reasonable Potential Analysis
CMC = Criterion Maximum Concentration (CTR or NTR)
CCC = Criteria Continuous Concentration (CTR or NTR)
Water & Org = Water and Organism Criterion Concentration (CTR or NTR)
Org. Only = Organism Criterion Concentration (CTR or NTR)
Basin Plan = Numeric Site-specific Basin Plan Water Quality Objective
MCL = Drinking Water Standards Maximum Contaminant Level
NA = Not available
ND = Reported as non-detect

Footnotes:

- (1) USEPA National Recommended Ambient Water Quality Standard.
- (2) Secondary MCL.
- (3) USEPA National Recommended Ambient Water Quality Standard. Chronic Criterion (CCC) based on the maximum 30-day average effluent pH (7.8), and the maximum 30-day running average effluent water temperature (24° C). The acute criterion (CMC) based on the maximum effluent pH (8.5).
- (4) National Toxics Rule criteria.
- (5) California Secondary MCL (recommended level/upper level/maximum short-term level).
- (6) California Primary MCL for total trihalomethanes.
- (7) California Primary MCL.
- (8) California DHS Notification Level for Drinking Water.
- (9) USEPA IRIS Reference Dose.
- (10) Odor threshold (Amoore and Hautala).
- (11) USEPA SNARL.
- (12) Basin Plan Objective at Emmaton for protection of agricultural water supply beneficial use (varies during year based on water year)

Attachment H - Constituents to be monitored

| CTR # | Constituent | CAS Number | Controlling Water Quality Criterion for Surface Waters | | Suggested Test Methods | |
|--------------------------|---------------------------------------|------------|--|---|------------------------|-----------|
| | | | Basis | Criterion Concentration (ug/L or noted) (1) | | |
| VOLATILE ORGANICS | | | | | | |
| 28 | 1,1-Dichloroethane | 75343 | Primary MCL | 5 | 0.5 | EPA 8260B |
| 30 | 1,1-Dichloroethene | 75354 | National Toxics Rule | 0.057 | 0.5 | EPA 8260B |
| 41 | 1,1,1-Trichloroethane | 71556 | Primary MCL | 200 | 0.5 | EPA 8260B |
| 42 | 1,1,2-Trichloroethane | 79005 | National Toxics Rule | 0.6 | 0.5 | EPA 8260B |
| 37 | 1,1,2,2-Tetrachloroethane | 79345 | National Toxics Rule | 0.17 | 0.5 | EPA 8260B |
| 75 | 1,2-Dichlorobenzene | 95501 | Taste & Odor | 10 | 0.5 | EPA 8260B |
| 29 | 1,2-Dichloroethane | 107062 | National Toxics Rule | 0.38 | 0.5 | EPA 8260B |
| | cis-1,2-Dichloroethene | 156592 | Primary MCL | 6 | 0.5 | EPA 8260B |
| 31 | 1,2-Dichloropropane | 78875 | Calif. Toxics Rule | 0.52 | 0.5 | EPA 8260B |
| 101 | 1,2,4-Trichlorobenzene | 120821 | Public Health Goal | 5 | 0.5 | EPA 8260B |
| 76 | 1,3-Dichlorobenzene | 541731 | Taste & Odor | 10 | 0.5 | EPA 8260B |
| 32 | 1,3-Dichloropropene | 542756 | Primary MCL | 0.5 | 0.5 | EPA 8260B |
| 77 | 1,4-Dichlorobenzene | 106467 | Primary MCL | 5 | 0.5 | EPA 8260B |
| 17 | Acrolein | 107028 | Aquatic Toxicity | 21 | 2 | EPA 8260B |
| 18 | Acrylonitrile | 107131 | National Toxics Rule | 0.059 | 2 | EPA 8260B |
| 19 | Benzene | 71432 | Primary MCL | 1 | 0.5 | EPA 8260B |
| 20 | Bromoform | 75252 | Calif. Toxics Rule | 4.3 | 0.5 | EPA 8260B |
| 34 | Bromomethane | 74839 | Calif. Toxics Rule | 48 | 1 | EPA 8260B |
| 21 | Carbon tetrachloride | 56235 | National Toxics Rule | 0.25 | 0.5 | EPA 8260B |
| 22 | Chlorobenzene (mono chlorobenzene) | 108907 | Taste & Odor | 50 | 0.5 | EPA 8260B |
| 24 | Chloroethane | 75003 | Taste & Odor | 16 | 0.5 | EPA 8260B |
| 25 | 2-Chloroethyl vinyl ether | 110758 | Aquatic Toxicity | 122 (3) | 1 | EPA 8260B |
| 26 | Chloroform | 67663 | OEHHA Cancer Risk | 1.1 | 0.5 | EPA 8260B |
| 35 | Chloromethane | 74873 | USEPA Health Advisory | 3 | 0.5 | EPA 8260B |
| 23 | Dibromochloromethane | 124481 | Calif. Toxics Rule | 0.41 | 0.5 | EPA 8260B |
| 27 | Dichlorobromomethane | 75274 | Calif. Toxics Rule | 0.56 | 0.5 | EPA 8260B |
| 36 | Dichloromethane | 75092 | Calif. Toxics Rule | 4.7 | 0.5 | EPA 8260B |
| 33 | Ethylbenzene | 100414 | Taste & Odor | 29 | 0.5 | EPA 8260B |
| 88 | Hexachlorobenzene | 118741 | Calif. Toxics Rule | 0.00075 | 1 | EPA 8260B |
| 89 | Hexachlorobutadiene | 87683 | National Toxics Rule | 0.44 | 1 | EPA 8260B |
| 91 | Hexachloroethane | 67721 | National Toxics Rule | 1.9 | 1 | EPA 8260B |
| 94 | Naphthalene | 91203 | USEPA IRIS | 14 | 10 | EPA 8260B |
| 38 | Tetrachloroethene | 127184 | National Toxics Rule | 0.8 | 0.5 | EPA 8260B |
| 39 | Toluene | 108883 | Taste & Odor | 42 | 0.5 | EPA 8260B |
| 40 | trans-1,2-Dichloroethylene | 156605 | Primary MCL | 10 | 0.5 | EPA 8260B |
| 43 | Trichloroethene | 79016 | National Toxics Rule | 2.7 | 0.5 | EPA 8260B |
| 44 | Vinyl chloride | 75014 | Primary MCL | 0.5 | 0.5 | EPA 8260B |
| | Methyl-tert-butyl ether (MTBE) | 1634044 | Secondary MCL | 5 | 0.5 | EPA 8260B |
| | Trichlorofluoromethane | 75694 | Primary MCL | 150 | 5 | EPA 8260B |
| | 1,1,2-Trichloro-1,2,2-Trifluoroethane | 76131 | Primary MCL | 1200 | 10 | EPA 8260B |
| | Styrene | 100425 | Taste & Odor | 11 | 0.5 | EPA 8260B |
| | Xylenes | 1330207 | Taste & Odor | 17 | 0.5 | EPA 8260B |

Attachment G – Summary of Reasonable Potential Analysis

| SEMI-VOLATILE ORGANICS | | | | | | |
|------------------------|----------------------------------|----------|-----------------------|----------|------|-----------|
| 60 | 1,2-Benzanthracene | 56553 | Calif. Toxics Rule | 0.0044 | 5 | EPA 8270C |
| 85 | 1,2-Diphenylhydrazine | 122667 | National Toxics Rule | 0.04 | 1 | EPA 8270C |
| 45 | 2-Chlorophenol | 95578 | Taste and Odor | 0.1 | 2 | EPA 8270C |
| 46 | 2,4-Dichlorophenol | 120832 | Taste and Odor | 0.3 | 1 | EPA 8270C |
| 47 | 2,4-Dimethylphenol | 105679 | Calif. Toxics Rule | 540 | 2 | EPA 8270C |
| 49 | 2,4-Dinitrophenol | 51285 | National Toxics Rule | 70 | 5 | EPA 8270C |
| 82 | 2,4-Dinitrotoluene | 121142 | National Toxics Rule | 0.11 | 5 | EPA 8270C |
| 55 | 2,4,6-Trichlorophenol | 88062 | Taste and Odor | 2 | 10 | EPA 8270C |
| 83 | 2,6-Dinitrotoluene | 606202 | USEPA IRIS | 0.05 | 5 | EPA 8270C |
| 50 | 2-Nitrophenol | 25154557 | Aquatic Toxicity | 150 (5) | 10 | EPA 8270C |
| 71 | 2-Chloronaphthalene | 91587 | Aquatic Toxicity | 1600 (6) | 10 | EPA 8270C |
| 78 | 3,3'-Dichlorobenzidine | 91941 | National Toxics Rule | 0.04 | 5 | EPA 8270C |
| 62 | 3,4-Benzofluoranthene | 205992 | Calif. Toxics Rule | 0.0044 | 10 | EPA 8270C |
| 52 | 4-Chloro-3-methylphenol | 59507 | Aquatic Toxicity | 30 | 5 | EPA 8270C |
| 48 | 4,6-Dinitro-2-methylphenol | 534521 | National Toxics Rule | 13.4 | 10 | EPA 8270C |
| 51 | 4-Nitrophenol | 100027 | USEPA Health Advisory | 60 | 5 | EPA 8270C |
| 69 | 4-Bromophenyl phenyl ether | 101553 | Aquatic Toxicity | 122 | 10 | EPA 8270C |
| 72 | 4-Chlorophenyl phenyl ether | 7005723 | Aquatic Toxicity | 122 (3) | 5 | EPA 8270C |
| 56 | Acenaphthene | 83329 | Taste and Odor | 20 | 1 | EPA 8270C |
| 57 | Acenaphthylene | 208968 | No Criteria Available | | 10 | EPA 8270C |
| 58 | Anthracene | 120127 | Calif. Toxics Rule | 9,600 | 10 | EPA 8270C |
| 59 | Benzidine | 92875 | National Toxics Rule | 0.00012 | 5 | EPA 8270C |
| 61 | Benzo(a)pyrene (3,4-Benzopyrene) | 50328 | Calif. Toxics Rule | 0.0044 | 0.1 | EPA 8270C |
| 63 | Benzo(g,h,i)perylene | 191242 | No Criteria Available | | 5 | EPA 8270C |
| 64 | Benzo(k)fluoranthene | 207089 | Calif. Toxics Rule | 0.0044 | 2 | EPA 8270C |
| 65 | Bis(2-chloroethoxy) methane | 111911 | No Criteria Available | | 5 | EPA 8270C |
| 66 | Bis(2-chloroethyl) ether | 111444 | National Toxics Rule | 0.031 | 1 | EPA 8270C |
| 67 | Bis(2-chloroisopropyl) ether | 39638329 | Aquatic Toxicity | 122 (3) | 10 | EPA 8270C |
| 68 | Bis(2-ethylhexyl) phthalate | 117817 | National Toxics Rule | 1.8 | 3 | EPA 8270C |
| 70 | Butyl benzyl phthalate | 85687 | Aquatic Toxicity | 3 (7) | 10 | EPA 8270C |
| 73 | Chrysene | 218019 | Calif. Toxics Rule | 0.0044 | 5 | EPA 8270C |
| 81 | Di-n-butylphthalate | 84742 | Aquatic Toxicity | 3 (7) | 10 | EPA 8270C |
| 84 | Di-n-octylphthalate | 117840 | Aquatic Toxicity | 3 (7) | 10 | EPA 8270C |
| 74 | Dibenzo(a,h)-anthracene | 53703 | Calif. Toxics Rule | 0.0044 | 0.1 | EPA 8270C |
| 79 | Diethyl phthalate | 84662 | Aquatic Toxicity | 3 (7) | 2 | EPA 8270C |
| 80 | Dimethyl phthalate | 131113 | Aquatic Toxicity | 3 (7) | 2 | EPA 8270C |
| 86 | Fluoranthene | 206440 | Calif. Toxics Rule | 300 | 10 | EPA 8270C |
| 87 | Fluorene | 86737 | Calif. Toxics Rule | 1300 | 10 | EPA 8270C |
| 90 | Hexachlorocyclopentadiene | 77474 | Taste and Odor | 1 | 1 | EPA 8270C |
| 92 | Indeno(1,2,3-c,d)pyrene | 193395 | Calif. Toxics Rule | 0.0044 | 0.05 | EPA 8270C |
| 93 | Isophorone | 78591 | National Toxics Rule | 8.4 | 1 | EPA 8270C |
| 98 | N-Nitrosodiphenylamine | 86306 | National Toxics Rule | 5 | 1 | EPA 8270C |
| 96 | N-Nitrosodimethylamine | 62759 | National Toxics Rule | 0.00069 | 5 | EPA 8270C |
| 97 | N-Nitrosodi-n-propylamine | 621647 | Calif. Toxics Rule | 0.005 | 5 | EPA 8270C |
| 95 | Nitrobenzene | 98953 | National Toxics Rule | 17 | 10 | EPA 8270C |
| 53 | Pentachlorophenol | 87865 | Calif. Toxics Rule | 0.28 | 0.2 | EPA 8270C |
| 99 | Phenanthrene | 85018 | No Criteria Available | | 5 | EPA 8270C |
| 54 | Phenol | 108952 | Taste and Odor | 5 | 1 | EPA 8270C |
| 100 | Pyrene | 129000 | Calif. Toxics Rule | 960 | 10 | EPA 8270C |

Attachment G – Summary of Reasonable Potential Analysis

| INORGANICS | | | | | | |
|--------------------------|---------------------------------------|----------|---|--------------|---------------|-----------------------|
| | Aluminum | 7429905 | Ambient Water Quality | 87 | 50 | EPA 6020/200.8 |
| 1 | Antimony | 7440360 | Primary MCL | 6 | 5 | EPA 6020/200.8 |
| 2 | Arsenic | 7440382 | Ambient Water Quality | 0.018 | 0.01 | EPA 1632 |
| 15 | Asbestos | 1332214 | National Toxics Rule/ Primary MCL | 7 MFL | 0.2 MFL >10um | EPA/600/R-93/116(PCM) |
| | Barium | 7440393 | Basin Plan Objective | 100 | 100 | EPA 6020/200.8 |
| 3 | Beryllium | 7440417 | Primary MCL | 4 | 1 | EPA 6020/200.8 |
| 4 | Cadmium | 7440439 | Public Health Goal | 0.07 | 0.25 | EPA 1638/200.8 |
| 5a | Chromium (total) | 7440473 | Primary MCL | 50 | 2 | EPA 6020/200.8 |
| 5b | Chromium (VI) | 18540299 | Public Health Goal | 0.2 | 0.5 | EPA 7199/ 1636 |
| 6 | Copper | 7440508 | National Toxics Rule | 4.1 (2) | 0.5 | EPA 6020/200.8 |
| 14 | Cyanide | 57125 | National Toxics Rule | 5.2 | 5 | EPA 9012A |
| | Fluoride | 7782414 | Public Health Goal | 1000 | 0.1 | EPA 300 |
| | Iron | 7439896 | Secondary MCL | 300 | 100 | EPA 6020/200.8 |
| 7 | Lead | 7439921 | Calif. Toxics Rule | 0.92 (2) | 0.5 | EPA 1638 |
| 8 | Mercury | 7439976 | TMDL Development | | 0.0002 (11) | EPA 1669/1631 |
| | Manganese | 7439965 | Secondary MCL/ Basin Plan Objective | 50 | 20 | EPA 6020/200.8 |
| 9 | Nickel | 7440020 | Calif. Toxics Rule | 24 (2) | 5 | EPA 6020/200.8 |
| 10 | Selenium | 7782492 | Calif. Toxics Rule | 5 (8) | 5 | EPA 6020/200.8 |
| 11 | Silver | 7440224 | Calif. Toxics Rule | 0.71 (2) | 1 | EPA 6020/200.8 |
| 12 | Thallium | 7440280 | National Toxics Rule | 1.7 | 1 | EPA 6020/200.8 |
| | Tributyltin | 688733 | Ambient Water Quality | 0.063 | 0.002 | EV-024/025 |
| 13 | Zinc | 7440666 | Calif. Toxics Rule/ Basin Plan Objective | 54/ 16 (2) | 10 | EPA 6020/200.8 |
| PESTICIDES - PCBs | | | | | | |
| 110 | 4,4'-DDD | 72548 | Calif. Toxics Rule | 0.00083 | 0.02 | EPA 8081A |
| 109 | 4,4'-DDE | 72559 | Calif. Toxics Rule | 0.00059 | 0.01 | EPA 8081A |
| 108 | 4,4'-DDT | 50293 | Calif. Toxics Rule | 0.00059 | 0.01 | EPA 8081A |
| 112 | alpha-Endosulfan | 959988 | National Toxics Rule | 0.056 (9) | 0.02 | EPA 8081A |
| 103 | alpha-Hexachlorocyclohexane (BHC) | 319846 | Calif. Toxics Rule | 0.0039 | 0.01 | EPA 8081A |
| | Alachlor | 15972608 | Primary MCL | 2 | 1 | EPA 8081A |
| 102 | Aldrin | 309002 | Calif. Toxics Rule | 0.00013 | 0.005 | EPA 8081A |
| 113 | beta-Endosulfan | 33213659 | Calif. Toxics Rule | 0.056 (9) | 0.01 | EPA 8081A |
| 104 | beta-Hexachlorocyclohexane | 319857 | Calif. Toxics Rule | 0.014 | 0.005 | EPA 8081A |
| 107 | Chlordane | 57749 | Calif. Toxics Rule | 0.00057 | 0.1 | EPA 8081A |
| 106 | delta-Hexachlorocyclohexane | 319868 | No Criteria Available | | 0.005 | EPA 8081A |
| 111 | Dieldrin | 60571 | Calif. Toxics Rule | 0.00014 | 0.01 | EPA 8081A |
| 114 | Endosulfan sulfate | 1031078 | Ambient Water Quality | 0.056 | 0.05 | EPA 8081A |
| 115 | Endrin | 72208 | Calif. Toxics Rule | 0.036 | 0.01 | EPA 8081A |
| 116 | Endrin Aldehyde | 7421934 | Calif. Toxics Rule | 0.76 | 0.01 | EPA 8081A |
| 117 | Heptachlor | 76448 | Calif. Toxics Rule | 0.00021 | 0.01 | EPA 8081A |
| 118 | Heptachlor Epoxide | 1024573 | Calif. Toxics Rule | 0.0001 | 0.01 | EPA 8081A |
| 105 | Lindane (gamma-Hexachlorocyclohexane) | 58899 | Calif. Toxics Rule | 0.019 | 0.019 | EPA 8081A |
| 119 | PCB-1016 | 12674112 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |
| 120 | PCB-1221 | 11104282 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |

| | | | | | | |
|-----|------------------------------------|----------|--|--------------|----------|-------------------------|
| 121 | PCB-1232 | 11141165 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |
| 122 | PCB-1242 | 53469219 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |
| 123 | PCB-1248 | 12672296 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |
| 124 | PCB-1254 | 11097691 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |
| 125 | PCB-1260 | 11096825 | Calif. Toxics Rule | 0.00017 (10) | 0.5 | EPA 8082 |
| 126 | Toxaphene | 8001352 | Calif. Toxics Rule | 0.0002 | 0.5 | EPA 8081A |
| | Atrazine | 1912249 | Public Health Goal | 0.15 | 1 | EPA 8141A |
| | Bentazon | 25057890 | Primary MCL | 18 | 2 | EPA 643/ 515.2 |
| | Carbofuran | 1563662 | CDFG Hazard Assess. | 0.5 | 5 | EPA 8318 |
| | 2,4-D | 94757 | Primary MCL | 70 | 10 | EPA 8151A |
| | Dalapon | 75990 | Ambient Water Quality | 110 | 10 | EPA 8151A |
| | 1,2-Dibromo-3-chloropropane (DBCP) | 96128 | Public Health Goal | 0.0017 | 0.01 | EPA 8260B |
| | Di(2-ethylhexyl)adipate | 103231 | USEPA IRIS | 30 | 5 | EPA 8270C |
| | Dinoseb | 88857 | Primary MCL | 7 | 2 | EPA 8151A |
| | Diquat | 85007 | Ambient Water Quality | 0.5 | 4 | EPA 8340/ 549.1/HPLC |
| | Endothal | 145733 | Primary MCL | 100 | 45 | EPA 548.1 |
| | Ethylene Dibromide | 106934 | OEHHA Cancer Risk | 0.0097 | 0.02 | EPA 8260B/ 504 |
| | Glyphosate | 1071836 | Primary MCL | 700 | 25 | HPLC/ EPA 547 |
| | Methoxychlor | 72435 | Public Health Goal | 30 | 10 | EPA 8081A |
| | Molinate (Ordram) | 2212671 | CDFG Hazard Assess. | 13 | 2 | EPA 634 |
| | Oxamyl | 23135220 | Public Health Goal | 50 | 20 | EPA 8318/ 632 |
| | Picloram | 1918021 | Primary MCL | 500 | 1 | EPA 8151A |
| | Simazine (Princep) | 122349 | USEPA IRIS | 3.4 | 1 | EPA 8141A |
| | Thiobencarb | 28249776 | Basin Plan Objective/ Secondary MCL | 1 | 1 | HPLC/ EPA 639 |
| 16 | 2,3,7,8-TCDD (Dioxin) | 1746016 | Calif. Toxics Rule | 1.30E-08 | 5.00E-06 | EPA 8290 (HRGC) MS |
| | 2,4,5-TP (Silvex) | 93765 | Ambient Water Quality | 10 | 1 | EPA 8151A |
| | Diazinon | 333415 | CDFG Hazard Assess. | 0.05 | 0.25 | EPA 8141A/ GCMS |
| | Chlorpyrifos | 2921882 | CDFG Hazard Assess. | 0.014 | 1 | EPA 8141A/ GCMS |

| OTHER CONSTITUENTS | | | | | |
|----------------------------------|----------|-----------------------|--------------|-------|------------|
| Ammonia (as N) | 7664417 | Ambient Water Quality | 1500 (4) | | EPA 350.1 |
| Chloride | 16887006 | Agricultural Use | 106,000 | | EPA 300.0 |
| Flow | | | 1 CFS | | |
| Hardness (as CaCO ₃) | | | 5000 | | EPA 130.2 |
| Foaming Agents (MBAS) | | Secondary MCL | 500 | | SM5540C |
| Nitrate (as N) | 14797558 | Primary MCL | 10,000 | 2,000 | EPA 300.0 |
| Nitrite (as N) | 14797650 | Primary MCL | 1000 | 400 | EPA 300.0 |
| pH | | Basin Plan Objective | 6.5-8.5 | 0.1 | EPA 150.1 |
| Phosphorus, Total (as P) | 7723140 | USEPA IRIS | 0.14 | | EPA 365.3 |
| Specific conductance (EC) | | Agricultural Use | 700 umhos/cm | | EPA 120.1 |
| Sulfate | | Secondary MCL | 250,000 | 500 | EPA 300.0 |
| Sulfide (as S) | | Taste and Odor | 0.029 | | EPA 376.2 |
| Sulfite (as SO ₃) | | No Criteria Available | | | SM4500-SO3 |
| Temperature | | Basin Plan Objective | °F | | |
| Total Dissolved Solids (TDS) | | Agricultural Use | 450,000 | | EPA 160.1 |
| | | | | | |

FOOTNOTES:

- (1) - The Criterion Concentrations serve only as a point of reference for the selection of the appropriate analytical method. They do not indicate a regulatory decision that the cited concentration is either necessary or sufficient for full protection of beneficial uses. Available technology may require that effluent limits be set lower than these values.
- (2) - Freshwater aquatic life criteria for metals are expressed as a function of total hardness (mg/L) in the water body. Values displayed correspond to a total hardness of 40 mg/L.
- (3) - For haloethers
- (4) - Freshwater aquatic life criteria for ammonia are expressed as a function of pH and temperature of the water body. Values displayed correspond to pH 8.0 and temperature of 22 C.
- (5) - For nitrophenols.
- (6) - For chlorinated naphthalenes.
- (7) - For phthalate esters.
- (8) - Basin Plan objective = 2 ug/L for Salt Slough and specific constructed channels in the Grassland watershed.
- (9) - Criteria for sum of alpha- and beta- forms.
- (10) - Criteria for sum of all PCBs.
- (11) - Mercury monitoring shall utilize "ultra-clean" sampling and analytical methods. These methods include:
 Method 1669: Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels, US EPA; and
 Method 1631: Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Atomic Fluorescence, US EPA

Dioxin and Furan Sampling

Section 3 of the State Implementation Plan requires that each NPDES discharger conduct sampling and analysis of dioxin and dibenzofuran congeners. Dioxin and Furan sampling shall be conducted in the effluent and receiving water once during dry weather and once during wet weather.

Each sample shall be analyzed for the seventeen congeners listed in the table below. High Resolution GCMS Method 8290, or another method capable of individually quantifying the congeners to an equivalent detection level, shall be used for the analyses.

For each sample the discharger shall report:

- The measured or estimated concentration of each of the seventeen congeners
- The quantifiable limit of the test (as determined by procedures in Section 2.4.3, No. 5 of the SIP)
- The Method Detection Level (MDL) for the test

The TCDD equivalent concentration for each analysis calculated by multiplying the concentration of each congener by the Toxicity Equivalency Factor (TEF) in the following table, and summing the resultant products to determine the equivalent toxicity of the sample expressed as 2,3,7,8-TCDD.

| Congener | TEF |
|------------------------|--------|
| 2,3,7,8TetraCDD | 1 |
| 1,2,3,7,8-PentaCDD | 1.0 |
| 1,2,3,4,7,8-HexaCDD | 0.1 |
| 1,2,3,6,7,8-HexaCDD | 0.1 |
| 1,2,3,7,8,9-HexaCDD | 0.1 |
| 1,2,3,4,6,7,8-HeptaCDD | 0.01 |
| OctaCDD | 0.0001 |
| 2,3,7,8-TetraCDF | 0.1 |
| 1,2,3,7,8-PentaCDF | 0.05 |
| 2,3,4,7,8-PentaCDF | 0.5 |
| 1,2,3,4,7,8-HexaCDF | 0.1 |
| 1,2,3,6,7,8-HexaCDF | 0.1 |
| 1,2,3,7,8,9-HexaCDF | 0.1 |
| 2,3,4,6,7,8-HexaCDF | 0.1 |
| 1,2,3,4,6,7,8-HeptaCDF | 0.01 |
| 1,2,3,4,7,8,9-HeptaCDF | 0.01 |
| OctaCDF | 0.0001 |