27 AUGUST 2026 BOARD MEETING
UNCONTESTED AGENDA ITEM

AGENDA ITEM: 12.a.

SUBJECT:

The following is a proposed amending Order for consideration of adoption. All agencies and dischargers concur or have offered no comments.

BOARD ACTION:

Consideration of amending Order.

BACKGROUND:

CITY OF BRENTWOOD, WASTEWATER TREATMENT PLANT, CONTRA COSTA COUNTY

The City of Brentwood (Discharger) is the owner and operator of the City of Brentwood Wastewater Treatment Plant (Facility), located at 2251 Elkins Way, Brentwood, CA 94513. The Facility provides sewerage services for the City of Brentwood, serving a population of approximately 64,870. The Facility discharges an average dry weather flow of 5.0 million gallons per day (MGD), and 6.4 MGD upon completion of the Phase II Facility Expansion Project, of tertiary treated municipal wastewater to Marsh Creek, a water of the United States, within the legal boundary of the Sacramento-San Joaquin Delta. The Discharger also conveys Title 22 disinfected tertiary treated recycled water to irrigation customers through the non-potable water supply system or via the recycled water fill station located at the Facility.

Discharges from the Facility are currently regulated by Waste Discharge Requirements Order R5-2024-0020 (NPDES Permit) and Time Schedule Order (TSO) R5-2024-0021, issued by the Central Valley Regional Water Quality Control Board (Central Valley Water Board) on 19 April 2024. The NPDES Permit contains final effluent limitations for dibromochloromethane (DBCM) and dichlorobromomethane (DCBM). TSO R5-2024-0021 contains a compliance schedule and interim effluent limitations for DBCM and DCBM that expire on 30 September 2026. The Discharger has made diligent efforts to comply with the final effluent limitations for DBCM and DCBM but has demonstrated that additional time is needed to comply. Therefore, an amending Order is proposed to amend TSO R5-2024-0021 to allow additional time for compliance with these final effluent limitations until 31 May 2029.

RECOMMENDATION:

Adopt the amending Order**.**

REVIEWS:

Management Review:	AW 8/3/2026
Legal Review:	CM 7/31/2026

BOARD MEETING LOCATION:

Central Valley Regional Water Quality Control Board meeting
11020 Sun Center Dr. 200
Rancho Cordova, CA 95670

☒ ***AND VIA VIDEO AND TELECONFERENCE***