

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION

ORDER R5-2018-XXXX

RESCINDING WASTE DISCHARGE REQUIREMENTS ORDER 94-355

The California Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board), finds that the Central Valley Water Board adopted the following Order which is no longer applicable for the reasons shown:

Waste Discharge Requirements Order 94-355, adopted on 9 December 1994, prescribes requirements for the discharge from the USDI National Park Service, Brandy Creek Recreational Area, Whiskeytown Lake, Shasta County (Facility). The Facility treats combined effluent from different areas. There is a marina with a restroom, fish cleaning station and grinder, two self-service RV dump stations, and three water and sewage hookups for seasonal camp hosts; Lot B (the remote beach area) with a bathroom; and Lot A (lifeguard beach area) with a snack bar and a bathroom. Wastewater from all of these locations combines at lift station 1, located in Lot A, and is pumped to the wastewater treatment plant. The wastewater treatment plant is made up of a 25,000 gallon primary tank, a 12,000 gallon secondary tank, a 15,000 gallon recirculating blending tank that can discharge to two 10,000 gallon emergency overflow tanks or flow to two covered recirculating sand filters, a chlorination dosing vault, a contact basin, and an 813,000 gallon final holding tank with recirculation and aeration (R&A) pump. Wastewater from the final holding tank is injected with chlorine and sodium hydroxide prior to pumping it to the sprayfields, which are located on Dry Creek Area Road in a gated and fenced area of five acres. The Facility is now regulated under Water Quality Order 2014-0153-DWQ (General Order) for discharges to land from small domestic systems with a maximum average daily flow of 100,000 gallons or less. Therefore, it is appropriate to rescind Waste Discharge Requirements Order 94-355.

IT IS HEREBY ORDERED that the above Waste Discharge Requirements Order 94-355 is rescinded.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on \_\_\_\_\_ 2018.

---

**PAMELA C. CREEDON**, Executive Officer