

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER R5-2018-XXXX

RESCINDING WASTE DISCHARGE REQUIREMENTS ORDER R5-2012-0018 AND
TIME SCHEDULE ORDER R5-2012-0019

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Central Valley Water Board), finds that Waste Discharge Requirements (WDR) Order R5-2012-0018 and Time Schedule Order (TSO) R5-2012-0019 are no longer applicable for the reasons below:

- Filter backwash wastewater from the City of Shasta Lake's (hereinafter Discharger) Fisherman's Point Water Treatment Plant (hereinafter Facility) is regulated pursuant to WDR Order R5-2012-0018 (National Pollutant Discharge Elimination System Permit No. CA0004693), adopted by the Central Valley Water Board on 30 March 2012, and TSO R5-2012-0019, adopted by the Central Valley Water Board on 30 March 2012. The Discharger has eliminated discharge of filter backwash wastewater into the unnamed tributary to Churn Creek, a water of the U.S., and no longer operates as described in WDR Order R5-2012-0018 and TSO R5-2012-0019. The Discharger completed construction improvements for a Backwash Waste Dewatering System (System) that completely recycles all filter backwash wastewater, which provides assurance that a surface water discharge will likely not occur following rescission of WDR Order R5-2012-0018 and TSO R5-2012-0019. A site inspection was also completed on 30 January 2018 to observe operation of the System and verify no wastewater was generated from the Facility. Additionally, the Discharger provided a formal request to rescind the WDRs and TSO and provided a technical memo that documented the completed construction and final operation of the System as well as options to prevent surface water discharge in the event of a failure of the System. Therefore, WDR Order R5-2012-0018 and TSO R5-2012-0019 are no longer necessary.

IT IS HEREBY ORDERED that Waste Discharge Requirements Order R5-2012-0018 and Time Schedule Order R5-2012-0019 are rescinded.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on XX June 2018.

PAMELA C. CREEDON, Executive Officer