CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER R5-2019-XXXX

RESCINDING TIME SCHEDULE ORDER R5-2018-0904

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Central Valley Water Board), finds that Time Schedule Order (TSO) R5-2018-0904 is no longer applicable for the reasons below:

- Treated wastewater from the Grizzly Lake Community Services District's (Discharger) Delleker Wastewater Treatment Plant (Facility) is regulated pursuant to Waste Discharge Requirements (WDRs) Order R5-2012-0046 (National Pollutant Discharge Elimination System Permit No. CA0081744), adopted by the Central Valley Water Board on 8 June 2012, and Time Schedule Order (TSO) R5-2018-0904, issued by the Executive Officer of the Central Valley Water Board on 17 December 2018. TSO R5-2018-0904 provides interim effluent limitations for copper until the Discharger can comply with final copper effluent limitations in WDRs R5-2012-0046. The WDRs are being renewed in June 2019 (Order 2019-XXXX) with less stringent final copper effluent limitations based on updated dilution credits and the Discharger stated that no time is required to comply with the final copper effluent limitations included in the renewed WDRs. Therefore, TSO R5-2018-0904 is no longer required.

IT IS HEREBY ORDERED that Time Schedule Order R5-2018-0904 is rescinded.

I, PATRICK PULUPA, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on XX June 2019.

PATRICK PULUPA, Executive Officer

TENTATIVE