

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER R5-2018-XXXX

RESCINDING WASTE DISCHARGE REQUIREMENTS ORDER 5-00-064

The California Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board), finds that the Central Valley Water Board adopted the following Order which is no longer applicable for the reasons shown:

Waste Discharge Requirements Order 5-00-064, adopted on 17 March 2000, prescribes requirements for the discharge from the USDI National Park Service, National Environmental Education (NEED) Camp, Whiskeytown Lake, Shasta County (Facility). The Facility is comprised of 16 environmental camp cabins, a lodge building, Hatcher Hall kitchen, an office area, and a Residence Cabin. The camp cabins are served by an 8,000 gallon septic tank. Hatcher Hall, the kitchen and 3,000 gallon grease trap, and the office areas are served by a 10,000 gallon septic tank. The wastewater from the two septic tanks is dosed to one of two leachfields located in front of the cabins. The Residence Cabin is served by its own 1,200 gallon septic tank and leachfield system. The Facility is now regulated under Water Quality Order 2014-0153-DWQ (General Order) for discharges to land from small domestic systems with a maximum average daily flow of 100,000 gallons or less. Therefore, it is appropriate to rescind Waste Discharge Requirements Order 00-064.

IT IS HEREBY ORDERED that the above Waste Discharge Requirements Order 5-00-064 is rescinded.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on _____ 2018.

PAMELA C. CREEDON, Executive Officer