

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER R5-2018-XXXX

RESCINDING WASTE DISCHARGE REQUIREMENTS ORDER 93-032

The California Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board), finds that the Central Valley Water Board adopted the following Order which is no longer applicable for the reasons shown:

Waste Discharge Requirements Order 93-032, adopted on 26 February 1993, prescribes requirements for the discharge from the USDI National Park Service, Oak Bottom Recreational Area, Whiskeytown Lake, Shasta County (Facility). The Facility is comprised of a marina with an amphitheater, concession office and public bathroom, a boat launch with a fish cleaning station and grinder, public bathrooms, a fire resource center, Oak Bottom store, a snack bar, and the upper and lower campgrounds with two self-service RV dump stations. Wastewater from all of these locations combines at lift station 6, located in the boat launch area, and is pumped to the wastewater treatment plant. The wastewater treatment plant is made up of a 20,000 gallon primary tank, two 6,500 gallon equalization tanks, a biofiltration recirculating filter system, a chlorine dosing system, and a one million gallon final holding tank equipped with a recirculation and aeration (R&A) pump. Wastewater from the holding tank can be dosed with chlorine a second time or be sent directly to the sprayfield. The Facility is now regulated under Water Quality Order 2014-0153-DWQ (General Order) for discharges to land from small domestic systems with a maximum average daily flow of 100,000 gallons or less. Therefore, it is appropriate to rescind Waste Discharge Requirements Order 93-032.

IT IS HEREBY ORDERED that the above Waste Discharge Requirements Order 93-032 is rescinded.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on _____ 2018.

PAMELA C. CREEDON, Executive Officer