

**CENTRAL VALLEY REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION  
TENTATIVE ORDER R5-2026-XXXX**

**RESCINDING WASTE DISCHARGE REQUIREMENTS R5-2002-0069**

The California Regional Water Quality Control Board, Central Valley Region (Central Valley Water Board), finds that the Board adopted the following Waste Discharge Requirements Order, which is no longer applicable for the reasons shown:

**A) SONORA ESTATES MANUFACTURED HOUSING COMMUNITY, LLC  
AND TIKI LAGUN PARTNERS, LLC; SONORA ESTATES MOBILE HOME  
PARK WASTEWATER TREATMENT SYSTEM; WASTE DISCHARGE  
REQUIREMENTS ORDER NO. R5-2002-0069; TUOLUMNE COUNTY**

Waste Discharge Requirements (WDRs) Order R5-2002-0069, adopted on 26 April 2002, prescribes requirements for the discharge of domestic wastewater from the Sonora Estates Manufactured Housing Community, LLC and Tiki Lagun Partners, LLC (Discharger) Sonora Estates Mobile Home Park Wastewater Treatment System (Facility). WDRs Order R5-2002-0069 authorizes the monthly average discharge of up to 20,000 gallons per day of domestic wastewater to percolation ponds. Since adoption of the WDRs Order, the discharge of wastewater to ponds has been eliminated, and the Facility has been upgraded to an extended aeration activated sludge plant and discharges to a subsurface disposal system. On 21 May 2025, the Discharger submitted a Report of Waste Discharge that reflects changes to the treatment and disposal of wastewater at the Facility and requested coverage under State Water Resources Control Board Order 2014-0153-DWQ, *General Waste Discharge Requirements for Small Domestic Wastewater Treatment Systems* (General Order) for the Facility. Subsequently, a 4 June 2025 Form 200 was submitted for the Facility that identifies SEMHC1, LLC as the new owner and Quality Service, Inc. as the operator. Central Valley Water Board staff will issue SEMHC1, LLC a Notice of Applicability that will enroll the Facility under the General Order upon rescission of WDRs Order R5-2002-0069. Therefore, it is appropriate to rescind Waste Discharge Requirements Order R5-2002-0069.

IT IS HEREBY ORDERED that the above Order is rescinded.

I PATRICK PULUPA, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region on 17 April 2026.