

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

MONITORING AND REPORTING PROGRAM R5-2018-XXXX

FOR

SIERRA PACIFIC INDUSTRIES
OROVILLE CEDAR MILL
BUTTE COUNTY

This Monitoring and Reporting Program (MRP) describes requirements for monitoring discharge to an onsite recycle/disposal pond (Pond). This MRP is issued pursuant to Water Code section 13267. The Discharger shall not implement any changes to this MRP unless and until a revised MRP is issued by the Regional Water Quality Control Board (Regional Water Board) Executive Officer.

A glossary of terms used in this MRP is included on the last page.

I. GENERAL MONITORING REQUIREMENTS

A. FLOW MONITORING

Hydraulic flow rates shall be measured at the onsite supply well specified in this MRP and indicated in Attachment B. Central Valley Water Board staff shall approve any proposed changes to flow monitoring locations prior to implementation of the change. All flow monitoring systems shall be appropriate for the conveyance system (i.e., open channel flow or pressure pipeline) and liquid type. Unless otherwise specified, each flow meter shall be equipped with a flow totalizer to allow reporting of cumulative volume as well as instantaneous flow rate. Flow meters shall be calibrated at the frequency recommended by the manufacturer; typically at least once per year and records of calibration shall be maintained for review upon request.

B. MONITORING AND SAMPLING LOCATIONS

Samples shall be obtained at the monitoring points specified in this MRP and depicted on Attachment B. Central Valley Water Board staff shall approve any proposed changes to sampling locations prior to implementation of the change.

The Discharger shall monitor the following locations to demonstrate compliance with the requirements of this Order:

Monitoring Location Name	Monitoring Location Description
MW-1 through MW-3	Locations as indicated on Attachment B of this order.
Pond	5 acre Recycle/stormwater pond southwest corner of property
Supply Well	New supply well, east side of property

C. SAMPLING AND SAMPLE ANALYSIS

All samples shall be representative of the volume and nature of the discharge or matrix of material sampled. Except as specified otherwise in this MRP, grab samples will be considered representative of water, wastewater, soil, solids/sludges and groundwater.

The time, date, and location of each sample shall be recorded on the sample chain of custody form. All analyses shall be performed in accordance with the *Standard Provisions and Reporting Requirements for Waste Discharge Requirements*, dated 1 March 1991 (Standard Provisions).

Field test instruments (such as those used to measure pH, electrical conductivity, dissolved oxygen, wind speed, and precipitation) may be used provided that:

1. The operator is trained in proper use and maintenance of the instruments;
2. The instruments are field calibrated at the frequency recommended by the manufacturer;
3. The instruments are serviced and/or calibrated by the manufacturer at the recommended frequency; and
4. Field calibration reports are submitted as described in the "Reporting" section of this MRP.

Laboratory analytical procedures shall comply with the methods and holding times specified in the following (as applicable to the medium to be analyzed):

- *Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater* (EPA);
- *Test Methods for Evaluating Solid Waste* (EPA);
- *Methods for Chemical Analysis of Water and Wastes* (EPA);
- *Methods for Determination of Inorganic Substances in Environmental Samples* (EPA);
- *Standard Methods for the Examination of Water and Wastewater* (APHA/AWWA/WEF); and
- *Soil, Plant and Water Reference Methods for the Western Region* (WREP 125).

Approved editions shall be those that are approved for use by the United States Environmental Protection Agency or the California Department of Public Health's Environmental Laboratory Accreditation Program (ELAP). The Discharger may propose alternative methods for approval. Where technically feasible, laboratory reporting limits shall be lower than the applicable water quality objectives for the constituents to be analyzed.

If monitoring consistently shows no significant variation in a constituent concentration or parameter after at least 24 months of monitoring, the Discharger may request this MRP be revised to reduce monitoring frequency. The proposal must include adequate

technical justification for reduction in monitoring frequency. This monitoring program shall remain in effect unless and until a revised MRP is issued.

II. SPECIFIC MONITORING REQUIREMENTS

A. RECYCLE/STORM WATER POND MONITORING

Pond 1 used for storage, recycling, and disposal of wastewater shall be monitored as specified below. Dissolved oxygen monitoring applies to any pond containing more than two feet of standing water:

Constituent ¹	Units	Sample Type	Sample Frequency	Reporting Frequency
Freeboard ²	0.1 feet	Measurement	Monthly	Bi-annual
Berm condition	--	Observation	Monthly	Bi-annual
Dissolved Oxygen	mg/L	Grab	Monthly	Bi-annual
pH	units	Grab	Monthly	Bi-annual
EC	umhos/cm	Grab	Monthly	Bi-annual
Sulfate	mg/L	Grab	Quarterly	Bi-annual
COD	mg/L	Grab	Quarterly	Bi-annual
Total Dissolved Solids (TDS)	mg/L	Grab	Quarterly	Bi-annual
Tannins & Lignins	mg/L	Grab	Quarterly	Bi-annual
Standard Minerals ³	mg/L	Grab	Quarterly	Bi-annual
Copper (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual
Zinc (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual
Iron (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual
Manganese (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual

mg/L denotes milligrams per liter.

¹ Samples shall be collected opposite the pond inlet at a depth of one foot.

² Freeboard shall be measured vertically from the surface of the pond water to the lowest elevation of the surrounding berm and shall be measured to the nearest 0.1 feet.

³ At a minimum, general minerals should include Na, K, Ca, Mg, Cl, and NO₃.

In addition, the Discharger shall inspect the condition of the ponds monthly and document visual observations. Notations shall include observations of:

- a. Presence of weeds in the water or along the berm;
- b. Accumulations of dead algae, vegetation, scum, or debris on the pond surface;
- c. Animal burrows in the berms;
- d. Evidence of seepage from the berms or downslope of the ponds;
- e. Evidence of tears, abrasions, cracks, and holes in geosynthetic liners.

B. GROUNDWATER MONITORING

The Discharger shall maintain the groundwater monitoring well network. If a groundwater monitoring well is dry for more than four consecutive sampling events or is damaged, the Discharger shall submit a work plan and proposed time schedule to replace the well(s). The well(s) shall be replaced following approval of the work plan.

The Discharger shall monitor groundwater quality as required herein from Monitoring Wells MW -1, MW-2 and MW-3 as indicated on Attachment B.

Groundwater Sampling and Analysis

Prior to purging or sampling, the groundwater depth shall be measured in each well to the nearest 0.01 feet. Groundwater elevations shall then be calculated to determine groundwater gradient and flow direction.

Low or no-purge sampling methods are acceptable, if described in an approved Sampling and Analysis Plan. Otherwise, each monitoring well shall be purged of at least 3 to 5 casing volumes until pH, electrical conductivity and turbidity have stabilized prior to sampling. Groundwater monitoring for all monitoring wells shall include, at a minimum, the following:

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Groundwater Elevation ^a	0.01 Feet	Calculated	Quarterly	Bi-annual
Depth to Groundwater	0.01 Feet	Measurement	Quarterly	Bi-annual
Gradient	Feet/Feet	Calculated	Quarterly	Bi-annual
Gradient Direction	degrees	Calculated	Quarterly	Bi-annual
pH	Std. Units	Grab	Quarterly	Bi-annual
EC	Umhos/cm	Grab	Quarterly	Bi-annual
COD	mg/L	Grab	Quarterly	Bi-annual
TDS	mg/L	Grab	Quarterly	Bi-annual
Tannins & Lignins	mg/L	Grab	Quarterly	Bi-annual
Standard Minerals ¹	mg/L	Grab	Quarterly	Bi-annual
Copper (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual
Zinc (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual
Iron (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual
Manganese (Total & Dissolved)	ug/L	Grab	Quarterly	Bi-annual

mg/L denotes milligrams per liter.

¹ At a minimum, general minerals should include Na, K, Ca, Mg, Cl, and NO₃.

^a. Groundwater elevation shall be based on depth to water using a surveyed measuring point elevation on the well and a surveyed reference elevation.

C. SUPPLY WELL MONITORING

Flow volume shall be measured from a location that provides a representative sample of the flow rate.

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Flow Rate	gpd	Meter	Continuous	Bi-annual
pH	Std. Units	Grab	Annual	Annual
EC	Umhos/cm	Grab	Annual	Annual
COD	mg/L	Grab	Annual	Annual
TDS	mg/L	Grab	Annual	Annual
Tannins & Lignins	mg/L	Grab	Annual	Annual
Standard Minerals ^a	mg/L	Grab	Annual	Annual

Constituent	Units	Sample Type	Sampling Frequency	Reporting Frequency
Copper (Total & Dissolved)	ug/L	Grab	Annual	Annual
Zinc (Total & Dissolved)	ug/L	Grab	Annual	Annual
Iron (Total & Dissolved)	ug/L	Grab	Annual	Annual
Manganese (Total & Dissolved)	ug/L	Grab	Annual	Annual

mg/L denotes milligrams per liter.

- a. At a minimum, general minerals should include Na, K, Ca, Mg, Cl, and NO₃.

D. Solids Disposal Monitoring

The Discharger shall report the handling and disposal of all Pond solids (e.g., screenings, grit, bark, debris, etc.) generated at the facility and not otherwise sold as a byproduct. Records shall include the name/contact information for the hauling company, the type and amount of waste transported, the date removed from the pond system, the disposal facility name and address, and copies of analytical data required by the entity accepting the waste. These records shall be submitted as part of the annual monitoring report.

III. REPORTING REQUIREMENTS

All monitoring reports should be converted to a searchable Portable Document Format (PDF) and submitted electronically. Documents that are less than 50MB should be emailed to: centralvalleyredding@waterboards.ca.gov.

To ensure that your submittal is routed to the appropriate staff person, the following information should be included in the subject line of the email:

SPI Oroville/Butte/WDR

WDID # 5A042055001

Documents that are 50 MB or larger should be transferred to a CD, DVD, or flash drive and mailed to the following address:

Central Valley Regional Water Quality Control Board
 364 Knollcrest Drive, Suite 205
 Redding, CA 96002

A transmittal letter shall accompany each monitoring report. The letter shall include a discussion of all violations of the WDRs and this MRP during the reporting period and actions taken or planned for correcting each violation. If the Discharger has previously submitted a report describing corrective actions taken and/or a time schedule for implementing the corrective actions, reference to the previous correspondence will be satisfactory. Pursuant to Section B.3 of the Standard Provisions and General Reporting Requirements, the transmittal letter shall contain a statement by the Discharger or the Discharger's authorized agent certifying under penalty of perjury that the report is true, accurate and complete to the best of the signer's knowledge.

In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, sample type (e.g., effluent, pond, etc.), and reported analytical result for each sample are readily discernible. The data shall be summarized in such a manner to clearly illustrate compliance with waste discharge requirements and spatial or temporal trends, as applicable. The results of any monitoring done more frequently than required at the locations specified in the Monitoring and Reporting Program shall be reported in the next scheduled monitoring report.

Laboratory analysis reports do not need to be included in the monitoring reports; however, all laboratory reports must be retained for a minimum of three years in accordance with Standard Provision C.3. For a Discharger conducting any of its own analyses, reports must also be signed and certified by the chief of the laboratory.

In addition to the requirements of Standard Provision C.3, monitoring information shall include the method detection limit (MDL) and the Reporting limit (RL) or practical quantitation limit (PQL). If the regulatory limit for a given constituent is less than the RL (or PQL), then any analytical results for that constituent that are below the RL (or PQL) but above the MDL shall be reported and flagged as estimated.

All monitoring reports that involve planning, investigation, evaluation or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in California pursuant to California Business and Professions Code sections 6735, 7835, and 7835.1.

In the future, the State Water Board or Central Valley Regional Water Board may require electronic submittal of monitoring reports using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site

(<http://www.waterboards.ca.gov/ciwqs/index.html>) or similar system. Electronic submittal to CIWQS, when implemented, will meet the requirements of our Paperless Office System.

A. MONTHLY MONITORING REPORTS

Monthly monitoring reports shall be submitted to the Board by the **1st day of the second month** following the end of the reporting period (i.e. the January monthly report is due by **March 1st**). At a minimum, each monitoring report shall include the following:

1. Results of monthly Influent and Effluent Monitoring.
2. Results of Pond Monitoring.
3. Results of Industrial Wastewater Monitoring, if applicable.
4. Results of Sludge/Biosolids Monitoring, if applicable, and verification of classification of biosolids as nonhazardous per 22 California Code of Regulations (CCR), Article 11, Criteria for Identification of Hazardous and Extremely Hazardous Waste (California Assessment Manual procedures).
5. Copies of laboratory analytical report(s).

6. A comparison of monitoring data to the effluent limitations and discharge specifications and an explanation of any violation of those requirements.
7. A copy of inspection log page(s) documenting inspections completed during the month.
8. A calibration log verifying calibration of all monitoring instruments and devices used to fulfill the prescribed monitoring program.

B. QUARTERLY MONITORING REPORTS

Quarterly monitoring reports shall be submitted to the Board by the **1st day of the second month after the quarter** (i.e. the January-March quarterly report is due by **May 1st**). Each Quarterly Monitoring Report shall include the following:

1. Results of Groundwater Monitoring, if performed during the quarter, including:
 - a. A narrative description of all preparatory, monitoring, sampling, and sample handling for groundwater monitoring.
 - b. A field log for each well documenting depth to groundwater; method of purging; parameters measured before, during, and after purging; sample preparation (e.g., filtering); and sample preservation.
 - c. Calculation of the groundwater elevation at each monitoring well, and determination of groundwater flow direction and gradient on the date of measurement.
 - d. Summary data tables of historical and current water table elevations and analytical results.
 - e. A scaled map showing relevant structures and features of the facility, the locations of monitoring wells, surface waters, and groundwater elevation contours referenced to an appropriate datum (e.g., NGVD).
2. Results of and Sludge/Biosolids Monitoring, if applicable, and verification of classification of biosolids as nonhazardous per 22 CCR, Article 11, Criteria for Identification of Hazardous and Extremely Hazardous Waste (California Assessment Manual procedures).
3. Copies of laboratory analytical report(s).
4. A comparison of monitoring data to the groundwater limitations, and discharge specifications and an explanation of any violation of those requirements.
5. A copy of inspection log page(s) documenting inspections completed during the quarter.
6. A copy of calibration log page(s) verifying calibration of all hand-held monitoring instruments performed during the quarter.

C. ANNUAL MONITORING REPORTS

The Fourth Quarterly Monitoring Report will serve as an **Annual Monitoring Report**. The Fourth Quarterly Monitoring Report for each calendar year shall include the following in addition to the items listed above.

1. Effective 2018, and every five years thereafter, an evaluation of sludge depth and sludge removal plans pursuant to Discharge Specification B.14.
2. Concentration vs. time graphs for each monitored constituent using all historic groundwater monitoring data. Each graph shall show the background groundwater concentration range, the trigger concentration specified above, and the Groundwater Limitation as horizontal lines at the applicable concentration.
3. Sludge monitoring results, if sludge were removed for off-site disposal during the year.
4. A summary of all sludge analytical data and verification of compliance with the sludge monitoring requirements.
5. A summary of information on the disposal of sludge and/or solid waste during the calendar year.
6. An evaluation of the performance of the Facility, including discussion of capacity issues, infiltration and inflow rates, nuisance conditions, and a forecast of the flows anticipated in the next year, as described in Standard Provision E.1.
7. A discussion of compliance and the corrective actions taken, as well as any planned or proposed actions needed to bring the discharge into full compliance with the waste discharge requirements.
8. Monitoring equipment maintenance and calibration records, as described in Standard Provision C.4.
9. A discussion of any data gaps and potential deficiencies or redundancies in the monitoring system or reporting program.

The Discharger shall implement the above monitoring program as of the date of this Order.

Ordered by: _____
PAMELA C. CREEDON, Executive Officer

(Date)

GLOSSARY

BOD ₅	Five-day biochemical oxygen demand
CaCO ₃	Calcium carbonate
DO	Dissolved oxygen
EC	Electrical conductivity at 25° C
FDS	Fixed dissolved solids
NTU	Nephelometric turbidity unit
TKN	Total Kjeldahl nitrogen
TDS	Total dissolved solids
TSS	Total suspended solids
Continuous	The specified parameter shall be measured by a meter continuously.
24-hr Composite	Samples shall be a flow-proportioned composite consisting of at least eight aliquots over a 24-hour period.
Daily	Every day
Twice Weekly	Twice per week on non-consecutive days.
Weekly	Once per week.
Twice Monthly	Twice per month during non-consecutive weeks.
Monthly	Once per calendar month.
Bimonthly	Once every two calendar months (i.e., six times per year) during non-consecutive months.
Quarterly	Once per calendar quarter.
Semiannually	Once every six calendar months (i.e., two times per year) during non-consecutive quarters.
Annually	Once per year.
mg/L	Milligrams per liter
mL/L	Milliliters [of solids] per liter
µg/L	Micrograms per liter
µmhos/cm	Micromhos per centimeter
gpd	Gallons per day
mgd	Million gallons per day
MPN/100 mL	Most probable number [of organisms] per 100 milliliters
MTF	Multiple tube fermentation