CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION ORDER NO. 79-50 WASTE DISCHARGE REQUIREMENTS FOR AZAT MOBILEHOME AND RECREATIONAL VEHICLE PARK South of Desert Hot Springs - Riverside County The California Regional Water Quality Control Board, Colorado River Basin Region, finds that: Dr. Issa Y. Azat (hereinafter also referred to as the discharger), 745 S. Oxford Street, Los Angeles, CA 90005, submitted a Report of Waste Discharge dated February 26, 1979. The discharger proposes to discharge a maximum of 45,000 gallons-per-day of domestic sewage from a mobile home and recreational vehicle park designed to have 144 mobile home spaces, 110 recreational vehicle spaces, 2 laundry

3.

5.

6.

7.

a.

No. 2 and 3 (above).

Coachella Hydrologic Subunit.

Hydrologic Subunit are:

Municipal supply

Agricultural supply.

b. Industrial supply

rooms and 6 restrooms. The wastewater is to be discharged into septic tank/seepage pit disposal systems located in the W 1/2 of the SE 1/4 of Section 12, T3S, R4E, SBB&M.

The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.

The discharger states that wastewater from a swimming pool is to be periodically discharged onto landscape plantings.

The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the

The beneficial uses of the groundwaters of the Coachella


-1-


Resembled by 85-88 by 85-88

There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings

The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge. 9. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge. 10. The Riverside County Planning Department has prepared Negative Declaration EA 10963 (filing date September 13, 1979) for this proposed park. The Regional Board has reviewed this Negative Declaration and has determined that this project will not have any significant adverse effects on water quality. IT IS HEREBY ORDERED, the discharger shall comply with the following: Discharge Specifications Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code. No wastewater other than domestic sewage and swimming pool wastewater shall be discharged at this location. Wastewater discharged subsurface shall be retained underground with no surfacing. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable. Septic tank cleanings shall be discharged only by a duly authorized service. 6. Swimming pool wastewater shall not be discharged into a sewage disposal system. В. Provisions Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system. -2-


Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes. 3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board. 4. Prior to any change of ownership of this mobile home and recreational vehicle park, the discharger shall: Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board. I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 26, 1979 -3CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7





SITE MAP

AZAT MOBILEHOME AND RECREATIONAL VEHICLE PARK South of Desert Hot Springs - Riverside County W 1/2 of the SE 1/4 of Section 12, T3S, R4E, SBB&M USGS Desert Hot Springs 7.5 min. Topographic Map ·CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



PRELIMINARY SEWAGE DISPOSAL FACILITIES SKETCH

AZAT MOBILEHOME AND RECREATIONAL VEHICLE PARK South of Desert Hot Springs - Riverside County