

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 83-11

WASTE DISCHARGE REQUIREMENTS
FOR
GILMORE AND TAYLOR
RECREATION PARK
South of Palo Verde - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. James A. Gilmore and Fred Taylor, a partnership, (hereinafter referred to as the discharger), P. O. Box 425, Palo Verde, CA 92266, verified on December 30, 1982 that the below updated information is accurate.
2. The discharger is discharging 20,000 gallons-per-day of domestic sewage from a mobile home and recreational vehicle park containing 100 recreational vehicle spaces, 200 mobile home spaces, a store, two restrooms with showers, and a service station. Wastewater is discharged into septic tanks and leach fields located in the SE $\frac{1}{4}$ of Section 17, T11S, R22E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the leach fields.
4. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 3 (above).
5. The Water Quality Control Plan for the East Colorado River Basin Region was adopted on April 10, 1975. The Basin Plan contains water quality objectives for the Colorado Hydrologic Unit.
6. The beneficial uses of the ground water of the Colorado Hydrologic Unit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
7. The discharge from this mobile home and recreational vehicle park has been subject to waste discharge requirements adopted in Board Order No. 72-85.
8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge.

*Cancelled
5/12/88*

9. The Board in a public meeting heard and considered all comments pertaining to the discharge.
10. This mobile home and recreational vehicle park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State Guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. There shall be no discharge of sewage within 200 feet of the regulated high water line of the Colorado River.


B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach fields, until such time as this park is connected to a municipal sewerage system.
2. Prior to any modification in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
3. Prior to any change in ownership of this mobile home and recreational vehicle park, the discharger shall:

- a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
- b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.

5. This Order supersedes Board Order No. 72-85.

I, Arthur Swajian, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 16, 1983.



Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 83-11
FOR
GILMORE AND TAYLOR RECREATION PARK
South of Palo Verde - Imperial County

Location: SE $\frac{1}{4}$ of Section 17, T11S, R22E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of mobile home and RV spaces and restrooms presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.
3. Explain any surfacing of wastewater or other failures to the system during the preceding year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered by:

Arthur Sevajian
Executive Officer

August 17, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD B-7



SITE MAP

GILMORE AND TAYLOR
RECREATION PARK

Colorado River - Imperial County
Portion of SE 1/4 of Section 17, T11S, R22E, SBB&M
USGS Picacho NW 7.5 min. Topographic Map

Order No. 83-11