

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION

ORDER NO. 83-62

WASTE DISCHARGE REQUIREMENTS  
FOR  
RAINBO BEACH MOBILE HOME PARK  
Needles - San Bernardino County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Norman Goodin, former owner of Rainbo Beach Mobile Home Park, Route 4, Box 139, Needles, CA 92363, submitted current information on April 14, 1983, to update existing waste discharge requirements. He has since sold the park to Robert Meyers (hereinafter referred to as the discharger), 221 Vista del Praque, Redondo Beach, CA 90277.
2. The discharger is discharging a maximum of 18,000 gallons-per-day of domestic sewage from a mobile home park with a design population of 300. The park contains 79 permanent and 45 overnight camper spaces. In addition there is a washroom with showers, a laundry room, and a pool. Wastewater is discharged into a subsurface disposal system consisting of septic tanks and leach lines. The leach fields are located in the SE 1/4, NW 1/4, Section 13, T9N, R22E, SBB&M.
3. The sewage flows by gravity from the point of origin to the septic tank which is located near the bank of the Colorado River. It is then pumped 500 feet to the leach fields which are to the east of and adjacent to Route 4.
4. There are no domestic wells within 200 feet of the discharge facilities.
5. The discharger states that the leach fields are more than 200 feet from the high water line of the Colorado River.
6. This discharge has been subject to waste discharge requirements adopted in Board Resolution No. 73-40.
7. The Water Quality Control Plan for the East Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Piute Hydrologic Unit and this Order implements those objectives.
8. The beneficial uses of the ground waters of the Needles subunit are:
  - a. Domestic supply
  - b. Agricultural supply
  - c. Municipal supply
  - d. Industrial supply

*Superseded  
by Bd. Ord. #94-030  
3/15/94*

9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the existing discharge.
10. The Board, in a public meeting, heard and considered all comments pertaining to the discharge.
11. This mobile home and recreational vehicle park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State Guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:


A. Discharge Specifications

1. Neither the treatment nor the discharge of wastes shall cause pollution or a nuisance as defined in Sections 13050 (l) and 13050 (m) of the State Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged from the subsurface disposal facilities shall be retained underground with no surfacing.
4. There shall be no discharge of sewage within 200 feet of a water supply well.
5. There shall be no discharge of sewage within 200 feet of the regulated high water line of the Colorado River.
6. Septic tank cleanings shall be discharged only by a duly authorized service.
7. Adequate protective works shall be provided to assure that flood or surface drainage waters do not erode or otherwise render portions of the treatment and disposal facilities inoperable.
8. There shall be no discharge of water softener brines at this location.
9. No part of the waste discharge facilities shall be located closer than five (5) feet vertically from the high ground water elevation.
10. Facilities shall be available to handle wastewater in the event of commercial power failure.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach fields, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material changes in the quality or quantity of wastewater discharged, or any material change in the location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this mobile home and recreational vehicle park, the discharger shall:
  - a. Specify as a condition of transfer that the area specified in Provision B.1. (above) remain servient to the park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
  - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.
5. This Order supersedes this Board's Order No. 73-40.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on September 21, 1983.

  
\_\_\_\_\_  
Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 83-62  
FOR  
RAINBO BEACH MOBILE HOME PARK  
Needles - San Bernardino County**

Location: SE $\frac{1}{4}$  , NW $\frac{1}{4}$ , Section 13, T9N, R22E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of permanent and overnight camper spaces, restrooms, showers, and pools presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.
3. Explain any surfacing of wastewater or other failures to the system during the preceding year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260

2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered by:

Artem Sevajian  
Executive Officer

August 17, 1987  
Date

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 84-62  
FOR  
WATER WHEEL RESORT AND RECREATION AREA  
North of Blythe - Riverside County**

Location of Discharge: NW $\frac{1}{4}$  of NE $\frac{1}{4}$  of Section 14, T3S, R23E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Number of mobile home and RV spaces and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260


2. Immediately report to this office by telephone and follow-up by letter any failures of the sewerage system.

ORDERED BY:

Arthur Swajian  
Executive Officer

Jan. 26, 1988  
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:  
1" = 1 mi.

RAINBO BEACH MOBILE HOME PARK  
Needles - San Bernardino County  
SE 1/4, NW 1/4, Section 13, T9N, R22E, SBB&M  
Needles Quadrangle 15' USGS Topographic Map

Order No. 83-62

6-5