

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 84-108

WASTE DISCHARGE REQUIREMENTS
FOR
LARK SPA
Northwest of Niland - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Jeanne Hain (hereinafter also referred to as the discharger), 7551 Genesta Avenue, Van Nuys, California, 91406, via the park manager verified the below updated information on the discharge of waste on August 3, 1984.
2. The discharger is discharging a maximum of 16,000 gallons-per-day of domestic sewage from a mobile home and recreational vehicle park having 36 mobile home spaces and 39 recreational vehicle spaces. The wastewater is discharged into a septic tank/leach line disposal system located in the NE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 20, T9S, R13E, SBB&M.
3. The discharger has reserved an area of sufficient size for possible future 100 percent replacement of the leach field.
4. The discharge has been subject to waste discharge requirements contained in Board Order No. 77-51.
5. There are no domestic wells within 200 feet of the proposed discharge facilities described in Findings No. 2 and 3 (above).
6. The discharger informs that wastewater from a swimming pool is periodically discharged onto landscape plantings.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on May 16, 1984. The Basin Plan contains water quality objectives for Imperial Hydrologic Unit.
8. The beneficial uses of the ground water of the Imperial Hydrologic Unit are:
 - a. Municipal supply
 - b. Industrial supply
9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
10. The Board in a public meeting heard and considered all comments pertaining to the discharge.

3/29/95
superseded by
Order No. 95-030

11. This mobile home and recreational vehicle park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach field, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications of this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this mobile home and recreational vehicle park, the discharger shall:

- a. Specify as a condition of transfer that the area utilized for sewage collection and disposal, and replacement thereof as set forth in Provision B.1 (above) remain servient to the development until such time as this park is connected to a municipal sewage system.
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
5. This Order supersedes Board Order No. 77-51.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 14, 1984.



Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 84-108
FOR
LARK SPA
Northwest of Niland - Imperial County**

Location: Portion of the NE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 20, T9S, R13E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of spaces presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By:

Arthun Sevajian
Executive Officer

July 29, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:
1" = 1 mi.

Niland 6 mi.

SITE MAP

LARK SPA

Northwest of Niland - Imperial County
 Portion of the NE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 20, T9S, R13E, SBB&M
 USGS Frink 15 min. Topographic Map

Order No. 84-108