

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 84-112

WASTE DISCHARGE REQUIREMENTS
FOR
RED ROOSTER CAMP
North of Blythe - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. William B. Booth (hereinafter also referred to as the discharger), HCR 20, Box 2725, Blythe, California, 92225, verified on August 31, 1984, that the below updated information is accurate.
2. The discharge from this mobile home park has been subject to waste discharge requirements adopted in Board Order No. 77-50.
3. The discharger is discharging a maximum of 4,000 gallons-per-day of domestic sewage from a mobile home park consisting of 32 mobile home spaces and four restrooms. Wastewater is discharged into a septic tank/leach line system, which occasionally becomes saturated and is then pumped to an oxidation basin for disposal by infiltration and evaporation. The park is located in the S $\frac{1}{2}$ of Section 25, T3S, R23E, SBB&M.
4. The discharge site (see attached site map which is a part of this Order) is leased by William B. Booth from the United States Department of the Interior, Bureau of Indian Affairs, Colorado River Agency, Route 1, Box 9-1C, Parker, Arizona, 85344, trustee for the Colorado River Indian Tribes.
5. There are no domestic wells within 500 feet of the sewage discharge facilities described in Finding No. 3 (above).
6. The discharger states that the wastewater disposal facilities are more than 200 feet from the high water line of the Colorado River.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on May 16, 1984. The Basin Plan contains water quality objectives for the Colorado Hydrologic Subunit.
8. The beneficial uses of ground water of the Colorado Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

*Replaced
by 90-009*

10. The Board in a public meeting heard and considered all comments pertaining to the discharge.
11. This mobile home park constitutes an ongoing project in accordance with provisions of the California Environmental Quality Act (Public Resources Code Section 21000 et. seq.) and the State guidelines because the governmental approvals on or after April 5, 1973, do not involve a greater degree of responsibility or control over such activity than the governmental approvals received prior to that date.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Septic tank cleanings shall be discharged only by a duly authorized service.
4. There shall be no discharge of sewage within 200 feet of the regulated high water line of the Colorado River.
5. No part of the waste discharge facilities shall be maintained closer than five (5) feet vertically from the high ground water level elevation.
6. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
7. Wastewater discharged subsurface shall be retained underground with no surfacing.
8. A minimum freeboard depth of two (2) feet shall be maintained in the basin.
9. Treated or untreated sludge, or similar solid waste materials, shall not be discharged to or enter any drainage channels or Colorado River.
10. There shall be no surface flow of wastewater away from the discharge facilities, and there shall be no direct discharge to any drainage channel or to Colorado River.
11. Treatment and disposal by ponding shall be conducted in such a manner that there shall be no stranded or exposed sewage solids.
12. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.
13. Infiltration facilities shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater.

14. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
15. Standby facilities shall be provided in the event of pump and/or commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. In the event of a change in control or ownership of land or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify the Board of such change; and
 - b. Transmit a copy of this Order to the succeeding owner or operator and file a copy of the transmittal letter with this Board.
4. This Order supersedes Board Order No. 77-50.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on November 14, 1984.



Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 84-112
FOR
RED ROOSTER CAMP
North of Blythe - Riverside County

Location of Discharge: S $\frac{1}{2}$ of Section 25, T3S, R23E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Number of mobile home and RV spaces and restrooms presently connected to the sewerage system.
3. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

2. Immediately report to this office by telephone and follow-up by letter any failures of the sewerage system.

ORDERED BY:


Arilton Suajian

Executive Officer

January 7, 1988

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:
1" = 2000'

TERIOR-GEOLOGICAL SURVEY, WASH.D.C.-1956-NS
M R-1853
RIVER BEND LODGE 1 MI. 270 000 FEET (ARIZ.)
BLYTHE (U.S. 60 & 70) 22 MI.

SITE MAP

RED ROOSTER CAMP
North of Blythe - Riverside County
S $\frac{1}{2}$ of Section 25, T3S, R23E, SBB&M
USGS Big Maria Mountains NE 7.5 min. Topographic Map

Order No. 84-112