

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 85-40

**WASTE DISCHARGE REQUIREMENTS
FOR
IMPERIAL SEA VIEW SPA
Northwest of Niland - Imperial County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Pat and Janet McDaniel and Mike Stanley (hereinafter also referred to as the discharger), HCO1 Box 20, Niland, California, 92257, verified on January 31, 1985, that the information contained in Findings No. 3 and 4 (below) is accurate.
2. The discharge has been subject to waste discharge requirements adopted in Board Order No. 75-30.
3. The discharger is discharging a maximum of 38,000 gallons-per-day of domestic sewage from a mobile home and travel trailer park consisting of 70 mobile home spaces, 160 recreational vehicle spaces, a laundry room and four (4) restrooms. Wastewater is alternately discharged into three (3) waste stabilization ponds that are constructed in natural clay (for disposal by infiltration and evaporation), and are located in the N½ of Section 2, T9S, R12E, SBB&M.
4. There are no domestic wells within 500 feet of the sewage disposal facilities described in Finding No. 3 (above).
5. An existing artesian well which supplies hot mineral water to the park swimming pools, discharges to a natural drainage channel where the water infiltrates into the ground before reaching Salton Sea.
6. The discharger informs that wastewater from two (2) swimming pools is periodically discharged into a channel that drains to a leach field for infiltration.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for Imperial Hydrologic Unit.
8. Ground waters in the area, except for local and limited concentrations, are saline and not beneficially used.
9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

*Superseded
by Bd. Ord. # 95-055
June 28, 1995*

10. The Board in a public meeting heard and considered all comments pertaining to the discharge.
11. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301 of Title 14, Chapter 3 of the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:


A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged into the sewage disposal system described in Finding No. 3 (above).
3. A minimum depth of freeboard of at least two (2) feet shall be maintained in each of the earthen basins.
4. Treated or untreated sludge, or similar solid waste materials, shall be disposed only at locations approved by the Regional Board.
5. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
6. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
7. There shall be no surface flow of wastewater away from the discharge facilities.
8. There shall be no discharge, bypass, or flow of treated or untreated sewage to any channel which drains to the Salton Sea.
9. Disposal by ponding shall be conducted in such manner that there shall be no stranded or exposed sewage solids.
10. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.
11. Standby facilities shall be provided in the event of pump and/or commercial power failure.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. In the event of any change in control or ownership of land or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify the Board of such change; and
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
4. This Order supersedes Board Order No. 75-30.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on May 22, 1985.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 85-40
FOR
IMPERIAL SEA VIEW SPA
Northwest of Niland - Imperial County**

Location of Discharge: Portion of the N $\frac{1}{2}$ of Section 2, T9S, R12E, SBB&M

MONITORING

The discharger shall submit the following information in an annual status report:

1. Estimate of maximum daily flow (gpd) of sewage discharged to basin(s).
2. Estimate of number of spaces and restrooms presently discharging to the sewerage system.
3. List of any proposed changes during the coming year.
4. Explain any problems in the sewerage system during the preceding year.

REPORTING

1. Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Report immediately any failures of the sewage system by telephone and follow-up by letter.

ORDERED BY:

Arthur Levajian
Executive Officer

July 29, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:
1" = 1 mile

SITE MAP

IMPERIAL SEA VIEW SPA
Northwest of Niland - Imperial County
N $\frac{1}{2}$ of Section 2, T9S, R12E, SBB&M
USGS Frink 15 min. Topographic Map

Order No. 85-40