

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 85-51

**WASTE DISCHARGE REQUIREMENTS
FOR
RIO BEND RECREATIONAL VEHICLE PARK
South of Seeley - Imperial County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Ed McGrew (hereinafter also referred to as the discharger), 1758 Meloland Road, Holtville, California, 92250, submitted a Report of Waste Discharge, dated February 28, 1985.
2. The discharger proposes to discharge a maximum of 23,000 gallons-per-day of domestic sewage from a recreational vehicle park designed to have a total of 201 spaces, a laundry room and two (2) restrooms. Wastewater would be discharged into septic tanks scattered throughout the park, and then directed into a single pipe to flow to a leach field west of the park, which is to be located in the NE $\frac{1}{4}$ of the NE $\frac{1}{4}$ of Section 23, T16S, R12E, SBB&M.
3. The discharger is reserving an area of sufficient size for possible future 100 percent replacement of the leach field.
4. Depth to ground water in the sewage disposal area is in excess of eight (8) feet.
5. There are no tile under drains in the vicinity of the disposal area.
6. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for Imperial Hydrologic Unit.
7. Shallow ground waters at the discharge location are saline and are not beneficially used, and deep ground waters are highly saline and are being investigated for geothermal development.
8. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
9. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.

01-20-93
superseded by
Order # 93-005 1

10. The Imperial County Planning Department has approved Environmental Impact Report SCH No.# 83102609 approval date May 7, 1984, for this proposed park. The Regional Board has reviewed this E.I.R. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.

B. Provisions


1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach field, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this recreational vehicle park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connectd to a municipal sewerage system.

- b. Transmit a copy of this Order to the succeeding owner or operator,
and file a copy of the transmittal letter with this Board.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true
and correct copy of an Order adopted by the California Regional Water Quality Control
Board, Colorado River Basin Region, on May 22, 1985.


Executive Officer

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD-7



SITE MAP

RIO BEND RECREATIONAL VEHICLE PARK
 South of Seeley - Riverside County
 Portion of the NE 1/4, NE 1/4 of Section 23, T16S, R12E, SBB&M
 USGS Seeley 7.5 min. Topographic Map