

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 85-66

**WASTE DISCHARGE REQUIREMENTS
FOR
SALTON SEA BEACH MARINA
Salton Sea Beach - Imperial County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Milton J. Sutherland (hereinafter also referred to as the discharger), Route 3, Box 512, Thermal, California, 92274, verified the below updated information on the discharge of waste on April 18, 1985.
2. The discharger is discharging a maximum of 28,000 gallons-per-day of domestic sewage from a mobile home park having 141 spaces and two (2) restrooms. Wastewater is discharged into septic tanks and pumped into a holding tank before flowing into two (2) leach fields, which are located in the SE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 23, T9S, R9E, SBB&M.
3. The discharger has reserved an area of sufficient size for possible future 100 percent replacement of the leach fields.
4. The discharge has been subject to waste discharge requirements contained in Board Order No. 78-103.
5. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for West Salton Sea Hydrologic Unit.
6. Shallow ground waters at the discharge location are saline and are not beneficially used. There are no domestic wells in the local area.
7. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
8. The Board in a public meeting heard and considered all comments pertaining to the discharge.
9. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301 of Title 14, Chapter 3, of the California Administrative Code.

*rescinded by
bd ord # 97-121 9/24/94
& replaced by
97-50038*

4-3

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. There shall be no installation of wastewater disposal facilities within 100 feet of the water line of the Salton Sea.
7. Depth of soil between the bottom of the leach lines and ground water shall not be less than four (4) feet.


B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach fields until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications of this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this mobile home park, the discharger shall:
 - a. Specify as a condition of transfer that the area utilized for sewage collection and disposal, and replacement thereof as set forth in Provision B.1 (above) remain servient to the development until such time as this park is connected to a municipal sewerage system.

- b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.

5. This Order supersedes Board Order No. 78-103.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on August 7, 1985.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 85-66
FOR
SALTON SEA BEACH MARINA
Salton Sea Beach - Imperial County**

Location: Portion of the SE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 23, T9S, R9E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

1. Number of spaces and restrooms presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:



California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By: Arthur Swajian
Executive Officer

August 12, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD -7



SITE MAP

SALTON SEA BEACH MARINA
 Salton Sea Beach - Imperial County
 SE $\frac{1}{4}$ of the NW $\frac{1}{4}$ of Section 23, T9S, R9E, SBB&M
 USGS Oasis 7.5 min. Topographic Map

Order No. 85-66

4-5