

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

ORDER NO. 85-70

**WASTE DISCHARGE REQUIREMENTS  
FOR  
THOUSAND TRAILS - ANZA BORREGO  
North of Jacumba - San Diego County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Thousand Trails Inc., (hereinafter also referred to as the discharger), 7825 Engineer Road, Suite 201, San Diego, California, 92111, submitted updated information on the discharge of waste from this park, dated May 15, 1985.
2. The discharger is discharging a maximum of 55,000 gallons-per-day of domestic sewage from a recreational vehicle park having up to 311 RV sites, 10 restrooms, a recreation building and a laundry room. The wastewater is discharged into septic tank/leach field disposal systems situated throughout the park, which is located in the SE $\frac{1}{4}$  of Section 29, T17S, R8E, SBB&M.
3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the leach fields.
4. The discharge has been subject to waste discharge requirements contained in Board Order No. 78-81.
5. There are no domestic wells within 200 feet of the discharge facilities described in Findings No. 2 and 3 (above).
6. The discharger states that wastewater from two swimming pools and a hot pool is periodically discharged into a separate leach line system.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for Anza-Borrego Hydrologic Unit.
8. The beneficial uses of ground water of the Anza-Borrego Hydrologic Unit are:
  - a. Municipal supply
  - b. Industrial supply
  - c. Agricultural supply
9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

6-25-97  
Rescinded  
Order 97-015

Place under  
1

6-25-97  
~~Superseded by~~ General  
Order 97-500 7-2

10. The Board in a public meeting heard and considered all comments pertaining to the discharge.
11. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301 of Title 14, Chapter 3, of the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming and hot pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming pool and hot pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions

1. Sufficient land area shall be reserved for possible future 100 percent replacement of the leach fields, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications of this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any change of ownership of this recreational vehicle park, the discharger shall:

- a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
  - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
5. This Order supersedes Board Order No. 78-81.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region on August 7, 1985.

  
Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 85-70  
FOR  
THOUSAND TRAILS - ANZA BORREGO  
North of Jacumba - San Diego County**

Location: Portion of the SE $\frac{1}{4}$  of Section 29, T17S, R8E, SBB&M

**MONITORING**

This discharger shall submit an annual status report on the following:

1. Number of spaces and restrooms presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.


**REPORTING**

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-271 Highway 111, Suite 21  
Palm Desert, CA 92260


2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By:

  
Executive Officer

  
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7




SITE MAP

THOUSAND TRAILS - ANZA BORREGO  
 North of Jacumba - San Diego County  
 SE $\frac{1}{4}$  of Section 29, T17S, R8E, SBB&M




Order No. 85-70



SCALE 1"  $\approx$  400'



### LEGEND

- PW** -- PROPOSED WELL (NO DRAINFIELD WITHIN 200 FT.)
- W** -- EXISTING WELL (NO DRAINFIELD WITHIN 200 FT.)
-  -- SEPTIC TANK
-  -- PRIMARY LEACH FIELDS
-  -- 100% LEACH BACK-UP AREA
- -- SEWER LINE

## SEWAGE DISPOSAL FACILITY SKETCH

ANZA BORREGO PRESERVE  
THOUSAND TRAILS RESORTS

TO INTERSTATE 8