CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION

ORDER NO. 85-81

WASTE DISCHARGE REQUIREMENTS FOR WHITEWATER RANCH RV PARK Northwest of Palm Springs - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

- 1. John R. Beylik (hereinafter also referred to as the discharger), 591 South Walnut Street, La Habra, California, 90631, verified, via the park grounds superintendent, the below updated information on the discharge of waste on May 2, 1985.
- 2. The discharger proposes to discharge a maximum of 20,000 gallons-perday of domestic sewage from a recreational vehicle park designed to have 131 spaces and four (4) restrooms. The wastewater is to be discharged into septic tank/seepage pit disposal systems located in the SE¹/₄ of the SW¹/₄ of Section 10, T3S, R3E, SBB&M.
- 3. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
- 4. The proposed discharge has been subject to waste discharge requirements contained in Board Order No. 78-66.
- 5. There are no domestic wells within 200 feet of the discharge facilities described in Findings No. 2 and 3 (above).
- 6. The discharger proposes to periodically discharge swimming pool wastewater onto landscape plantings.
- 7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for Coachella Hydrologic Subunit.
- 8. The beneficial uses of ground water of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply

Ruck July 90

9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the proposed discharge.

- 10. The Board in a public meeting heard and considered all comments pertaining to the discharge.
- 11. The Riverside County Planning Commission prepared Negative Declaration EA 556 (filing date March 6, 1974) for this proposed park. The Regional Board reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

- 1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
- 2. No wastewater other than domestic sewage and swimming pool wastewater shall be discharged at this location.
- 3. Wastewater discharged subsurface shall be retained underground with no surfacing.
- 4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
- 5. Septic tank cleanings shall be discharged only by a duly authorized service.
- 6. Swimming pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions

- 1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
- 2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
- 3. Prior to any modifications of this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

- 4. Prior to any change of ownership of this recreational vehicle park, the discharger shall:
 - a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
 - b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.
- 5. This Order suspersedes Board Order No. 78-66.

I,	Arth	ıur	Swajia	n, Ex	ecutive	Officer	, d	o he	ereby	certi	fy	the	for	egoing	is	a	full,	true
an	d co	rrec	t copy	of a	n Order	adopted	by	the	Cali	fornia	Re	egion	al	Water	Qua	alit	у Со	ntrol
Во	ard,	Col	orado	Rive	Basin	Region,	on			Augus	t 7	7, 19	985	_•				

Executive Officer

.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION

MONITORING AND REPORTING PROGRAM NO. 85-81
FOR
WHITEWATER RANCH RV PARK
Northwest of Palm Springs - Riverside County

Location: Portion of the SE4 of the SW4 of Section 10, T3S, R3E, SBB&M

MONITORING

The discharger shall submit an annual status report on the following:

- 1. Number of spaces and restrooms presently connected to the sewerage system.
- 2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board Colorado River Basin Region 73-271 Highway 111, Suite 21 Palm Desert, CA 92260


2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By:

Executive Office

Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



SITE MAP

WHITEWATER RANCH RV PARK
Northwest of Palm Springs - Riverside County
SE¹4, SW¹4 of Section 10, T3S, R3E, SBB&M
USGS Palm Springs 15 min. Topographic Map

Scale: 1"=1mi.