CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION

IN THE MATTER OF:) FAILURE TO MEET THE) REQUIREMENTS OF BOARD) ORDER NO. 92-014) AGAINST:) CITY OF WESTMORLAND,) WESTMORLAND, CALIFORNIA)

NOTICE OF VIOLATION ORDER NO. 93-074

YOU ARE HEREBY NOTIFIED THAT:

As of July 19, 1993, you are in violation of the following:

- Failure to submit the self monitoring reports required by Board Order No. 92-014.
- Failure to comply with Prohibition #2 of Board Order No. 92-014, which prohibits the discharge of untreated wastewater to the Trifolium Drain No. 6.
- 3. Failure to comply with Provision #3 of Board Order No. 92-014, which requires implementation of acceptable operation and maintenance at the wastewater treatment plant so that needed repair and maintenance are performed in a timely manner.

As of July 19, 1993, the above violations have not been satisfactorily corrected. This Notice of Violation serves as a final notice to submit a workplan to correct the above violations by August 31, 1993. If you fail to submit the said workplan, the Board may take appropriate enforcement action authorized by the Porter-Cologne Water Quality Control Act, Division 7 of the California Water Code, commencing with section 13,000, including Administrative Civil Liabilities of \$5,000 per day of violation, or referral to the State Attorney General for judicial sanctions.

This notice is based on the following specific circumstances:

1.

The Annual Monitoring Report for 1992 required by Board Order No. 92-014 has not been submitted.

2. The City's wastewater ponds developed leaks in 1986, which have not been adequately repaired. At the time of the last inspection on July 14, 1993, the ponds were almost empty, close to anaerobic conditions and 100% of the flow was through illegal discharge points.

adminded

Notice of Violation

Page 2

Links

D-12 PHIL GRUENBERG Executive Officer

NJK/jj

File Ref: Westmorland; Case 92-014