

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD COLORADO RIVER BASIN REGION

Office
73-720 Fred Waring Dr. #100
Palm Desert, CA 92260
waterboards.ca.gov/coloradoriver/

ORDER R7-2021-0008



Order Information

Dischargers:	Imperial Magma LLC, Magma Land Company I, Imperial Magma, Salton Sea Power Generation Company, Salton Sea Power LLC, CalEnergy Operating Corporation
Facility:	Region 1 Salton Sea Power Plant Units 1-5
Address:	6922 Crummer Road, Calipatria, CA 92233
County:	Imperial County
WDID:	7A132249001
GeoTracker ID:	T10000006248
Prior Order(s):	R7-2015-0048, R7-2011-0005, R7-2003-0127, R7-2003-0128, 94-019, 94-082, 94-081, 94-084

I, PAULA RASMUSSEN, Executive Officer, hereby certify that the following is a full, true, and correct copy of the order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 9, 2020.

PAULA RASMUSSEN
Executive Officer

Contents

Findings.....	1
Facility History	2
Facility Operations and Wastewater Disposal	4
Waste and Unit Classification	8
Hydrogeologic and Climate Conditions.....	10
Regional Geology	11
Basin Plan and Other Regulatory Considerations	12
Antidegradation Analysis	15
Stormwater	16
Financial Assurances.....	17
CEQA and Public Participation	17
IT IS HEREBY ORDERED	18
A. Discharge Prohibitions	18
B. Discharge Specifications	19
C. Stormwater Specifications.....	21
D. Construction Specifications.....	22
E. Monitoring Specifications	23
F. Corrective Action Specifications.....	24
G. Financial Assurances Specifications	25
H. Closure and Post-Closure Specifications	26
I. Special Provisions	26
J. Standard Provisions	27
Attachment A—Site Location Map	1

ORDER R7-2021-0008	2
CALENERGY OPERATING CORP. ET AL	
REGION 1 SALTON SEA POWER PLANT UNITS 1-5	
Attachment B—General Facility Map	2
Attachment C—Monitoring WELL Map	3
ATTACHMENT F – Monitoring and Reporting Program R7-2021-0008	1
Part I: Sampling and Analysis General Requirements.....	1
A. Sampling and Analysis General Requirements	1
B. Standard Monitoring Provisions	1
Part II: Site-Specific Monitoring Requirements.....	4
A. Groundwater Monitoring.....	4
B. Unsaturated Zone Monitoring.....	7
C. Surface Water Monitoring.....	7
D. Surface Impoundment Monitoring	8
E. Evaluation Monitoring.....	11
F. Corrective Action Monitoring	13
Part III: Evaluation of Monitoring Data.....	14
A. Water Quality Protection Standard.....	14
B. Statistical and Non-Statistical Analysis of Data	15
Part IV: Reports to be Filed With the Regional Water Board.....	17
A. Required Reports	17
B. Report Schedule	21
C. Standard Reporting Procedures.....	21

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER R7-2021-0008

WASTE DISCHARGE REQUIREMENTS
FOR
CALENERGY OPERATING CORPORATION, OPERATOR
SALTON SEA POWER GENERATION COMPANY, SALTON SEA POWER LLC,
IMPERIAL MAGMA LLC, MAGMA LAND COMPANY I, AND IMPERIAL MAGMA,
OWNERS
REGION 1 SALTON SEA POWER PLANT UNITS 1-5
CLASS II SURFACE IMPOUNDMENT
IMPERIAL COUNTY

The California Regional Water Quality Control Board, Colorado River Basin Region (Regional Water Board) hereby makes the following Findings:

1. CalEnergy Operating Corporation (CalEnergy), a wholly owned subsidiary of CE Generation, LLC, operates the Region 1 Salton Sea Power Plant Units 1-5, a 167-megawatt geothermal power plant (Facility). The Facility includes one Class II surface impoundment – a waste management unit regulated under California Code of Regulations, title 27, section 20005 et seq.¹ – that is used for the temporary holding of geothermal wastewater, including geothermal brine and solids. The Facility is also comprised of the associated geothermal well field, conveyance pipelines, and other infrastructure needed to properly operate the Facility.
2. The power plant is owned by Salton Sea Power Generation Company (Units 1-4) and Salton Sea Power, LLC (Unit 5) and located at 7030 Gentry Road, Calipatria, CA 92233. The property on which Units 1 and 2 are located is owned by Imperial Magma LLC. The property on which Units 3 and 4 are located (including the class II surface impoundment) is owned by Magma Land Company. The property on which the Salton Sea Power Plant Unit 5 is located is owned by Imperial Magma. The parties named above are collectively referred to herein as the “Owners.” The Owners and CalEnergy are collectively referred to herein as “Discharger.”²
3. The Class II surface impoundment (Brine Pond) is located at 6922 Crummer Road, Calipatria, CA 92233. The Facility is located in the Salton Sea Known Geothermal

¹ “Waste management unit” is as defined in California Code of Regulations, title 27, section 20164. Unless otherwise specified, all terms have the meaning specified in California Code of Regulations, title 27, division 2, subdivision 1, chapter 2, article 1.

² Primary responsibility is assigned to CalEnergy and secondary responsibility to the Owners. If CalEnergy fails to meet the requirements of this Order, then the Owners will become the primary responsible parties for Order compliance.

Resource Area (KGRA), approximately seven miles west of the town of Calipatria in the south $\frac{1}{2}$, southwest $\frac{1}{4}$, southeast $\frac{1}{4}$, Section 5, Township 12 South, Range 13 East, San Bernardino Base and Meridian, Imperial County, as shown on **Attachment A**, Location Map, made part of this Order by reference. Primary access to the Facility is via farm access roads.

4. In a letter dated April 22, 2019, the Discharger submitted an application and Report of Waste Discharge (ROWD) to the Regional Water Board, applying for updated Waste Discharge Requirements (WDRs) for the Facility. The Facility is assigned California Integrated Water Quality System (CIWQS) number Waste Discharge Identification Number (WDID) 7A132249001 and GeoTracker Global Identification number T10000006248.
5. The Facility was most recently regulated under Order R7-2015-0048, adopted on November 19, 2015. Among other things, the WDRs have been updated to reflect proposed changes in site operations, including the addition of a lithium extraction pilot project plant that will use process effluent from the Facility's clarifiers and return wastewater from the Brine Pond with little to no change in chemical makeup, besides the loss of the extracted lithium; the installation of three new clarifier units to help with the solid geothermal waste management; and updated mechanical separator Best Management Practices (BMPs) to also more effectively manage the buildup of geothermal solids in the Brine Pond.
6. This Order supersedes Orders R7-2015-0048 upon the effective date of this Order, except for enforcement purposes.

Facility History

7. The Salton Sea Power Plant Units 1 and 2, together a 30-megawatt geothermal power plant, were originally regulated under Orders 94-019 and 94-082, adopted on June 29, 1994 and September 13, 1994, respectively. The orders regulated a 200,000-gallon brine pond and associated geothermal exploration mud sumps, respectively. The two orders were later combined into a single order, Order R7-2003-0127, on November 5, 2003.
8. The brine pond at Units 1 and 2 was constructed above ground with a 1-foot-thick reinforced concrete (pad) and had four different chambers separated by concrete walls. Two of the chambers were used for the temporary containment of geothermal brine, one for steam condensate from the cooling towers, and one for fresh make-up water. A relatively small amount of the geothermal brine (including the liquid geothermal brine and the solid geothermal waste that had fallen out of the geothermal brine during the facility's process) was temporarily held in one of the brine pond's chambers before the geothermal brine was rejected into the geothermal reservoir, and the geothermal solids were disposed of at a waste management facility. The majority of the geothermal brine was directly reinjected into the reservoir and never entered the brine pond. The brine pond originally associated with Units 1 and 2 is currently closed and no longer operates as a pond.

9. Units 1 and 2 also had associated wellfields and mud sumps. Wells consisted of production, injection, and observation wells. Mud sumps were constructed next to each well and used for the temporary discharges of drilling and cutting mud during well construction. Additionally, if the production or injection wells needed to have the wells redeveloped, the mud sumps were periodically utilized for well maintenance. The mud sumps were earthen, bermed surface impoundments that had a minimum of 12 inches of compacted clay with a maximum hydraulic permeability of 1×10^{-6} centimeters per sec. The sumps varied in size and capacity depending on the number of wells they were associated with. Geothermal fluids and drilling muds were left to evaporate in the mud sumps for a maximum of 1 year. Afterwards, solid wastes from the mud sumps were analyzed and disposed of according to the resulting analyses at a landfill.
10. Located close to Units 1 and 2, but on a separate parcel, was the Salton Sea Power Plant Units 3 and 4, together a 95-megawatt geothermal power plant. This power plant was originally regulated under Orders 94-0081 and 94-084, both adopted on September 13, 1994. The orders regulated a 473,000-gallon brine pond and associated geothermal exploration mud sumps, respectively. The orders were combined into a single order, Order R7-2003-0128, on November 5, 2003.
11. The brine pond at Units 3 and 4 had bottom and sides lined with Seaman XR-5 40 mil flexible membrane and Enkadrain drainage fabric, as well as an 8-inch fiber reinforced concrete primary layer. The brine pond also had a Leak Detection System (LDS) located beneath the membrane liner that consisted of a drainage net system. The pond was sloped to the east, towards the LDS, to facilitate the earliest detection of any releases.
12. Units 3 and 4 also had an associated geothermal well field, which included mud sumps that were similar in description to those for Units 1 and 2.
13. On January 20, 2011, the orders regulating Units 1 and 2 (Order R7-2003-0127) and Units 3 and 4 (Order R7-2003-0128) were combined under a single order, Order R7-2011-0005. The WDRs reflected changes in the operation of the units, including the addition of Unit 5, and other administrative modifications. The 473,000-gallon brine pond that used to service Units 3 and 4 was expanded to a size of approximately 1,092,000-gallons, and the brine pond that used to service Units 1 and 2 was decommissioned. The combined facility consisting of Units 1 through 5, with a total energy generating capacity of 175.9-megawatts, was renamed "Region 1."
14. On November 19, 2015, Order R7-2011-0005 was rescinded and replaced with Order R7-2015-0048, documenting the closure of all the Facility's geothermal mud sumps³ and the addition of plate filter press technology as an accepted mechanical

³ All of the Facility's mud sumps were abandoned pursuant to the Mud Sump Abandonment Plan submitted to the Colorado River Basin Water Board on February 25, 2008. This plan included the abandonment of all

separator Best Management Practice (BMP) for solid geothermal waste management.

Facility Operations and Wastewater Disposal

15. The Facility layout is shown on **Attachment B**, General Facility Map, made part of this Order by reference.
16. Units 1 through 5 are each connected to surrounding geothermal well fields by a series of conveyance pipes, which transport geothermal brine to and from each unit. Inside the unit, heat exchangers utilize the geothermal fluid to heat and vaporize a secondary working fluid, which generates vapors/steam that drive the generator turbine. The geothermal turbines are cooled using a water-based closed-loop system with air cooling towers. When the ambient air at the Facility is too hot to efficiently cool the closed-loop system, water-based cooling towers are used to cool the ambient air for the closed-loop system.
17. After steam is extracted for power generation, the majority of the Facility's generated wastewater (geothermal brine, cooling water tower blowdown, and wastewater collected in the Facility's conveyance system) is routed directly to process injection wells. Approximately 15 million pounds per hour of brine of geothermal brine generated at the Facility. However, only small volumes of spent brine and cooling tower blowdown enter the Brine Pond during startup, shutdown, or malfunction events.
18. The Facility's Brine Pond (1,092,000 gallons) is located at the Unit 3 section of the Facility and was constructed before Order R7-2011-0005 was adopted. In addition to temporarily retaining geothermal brines prior to reinjection, the Brine Pond temporarily stores solids that have either precipitated or settled out of the geothermal brine during the energy generating process. The Brine Pond also holds fluids generated during emergency situations, maintenance operations, spills and water from hydroblasting, portable shower effluent, vehicle wash station effluent, water from the plant conveyance system, lime sump effluent, and effluent from emission abatement equipment.
19. Geothermal brine is routinely piped from the Brine Pond back to four clarifiers for reuse in the energy-generating process. A pump moves the brine from the Brine Pond, through a closed piping system, to the reactor vessel, which is routed to the clarifier, where it reenters the process flow of the Facility.
20. The Facility currently has four clarifiers – two in the Unit 5 area of the Facility and two in the Unit 3 area of the Facility. The Discharger proposes to add three new clarifiers. A fifth clarifier (Clarifier #5) will be added Unit 3 to allow for the removal

mud sumps at all of the Facility's units (Units 1-5). The Discharger has identified that they intend to use prefabricated containers such as roll off bins to contain any potential Geothermal drilling waste.

of additional solids before the spent brine and process fluids are reinjected to the aerated injection well, thereby preventing well plugging. The maximum dimensions expected for Clarifier #5 is a diameter of 93 feet, a wall height of 26 feet, and a total height above grade of approximately 41 feet. The maximum tank capacity is expected to be 1.25 million gallons. The clarifier will rest on a concrete foundation that will be designed with sufficient secondary containment to accommodate any incidental spillage from the tank. Two new clarifiers (Clarifiers #6 and #7) will also be built to function as the primary clarifiers for the process (prior to injection of the spent brine to the geothermal reservoir). The Discharger plans to maintain Clarifiers #3 and #4 as backup units that will be used to hold material when repairs or inspections are being performed Clarifiers #6 and #7. When construction is complete, the site will have a total of seven clarifier vessels.

21. The Discharger plans to use several mechanical separator BMPs to more effectively remove geothermal solid waste from the Brine Pond, in order to be able to maintain the 2 feet of freeboard required by this Order. The mechanical separator BMPs are be limited to techniques that use only inert materials, such as sand or diatomaceous earth inside a “sock” of polypropylene yarns or other permeable material; metallic filter press plates (Filter Plates) that dewater solids from the clarifiers; or woven geotextile bags, usually made of 100% polypropylene yarns, that are permeable by design to retain solids while allowing liquid to seep out. The Discharger proposes to place the passive, mechanical separator BMPs on a concrete pad or other impervious surface. The slurry from the Brine Pond will be pumped to the separator and the effluent from the separator will be returned to the Brine Pond. The specific arrangement of any new separator will be submitted to the Regional Water Board at least 90 days prior to use, in accordance with the Construction Specifications of this Order.
22. Additionally, the Discharger plans to begin a lithium pilot project that will withdraw geothermal brine from the Facility’s clarifiers and will return the geothermal brine, now devoid of lithium, to the Brine Pond. The pilot project’s process will not alter the geothermal waste’s chemical properties other than lowering the TDS concentrations by a few parts per million (as a result of minor amounts of extracted lithium). The supply rate for the project will not exceed 100 gallons per minute and is tentatively scheduled to begin in the first quarter of 2021.
23. The Facility also has a freshwater makeup pond used to supply water to the cooling towers. Chemicals are added to the cooling water system and cooling towers to prevent scaling, biological growth, and corrosion and to adjust the water’s pH. Chemical classes currently used include Class 5 oxidizing organic peroxides and biocide in the cooling tower; Class 8 corrosives as industrial strength oxidants and biocides; hydrochloric acid for pH control at some locations in the process, and sodium hydroxide for control at other locations in the process, among other chemicals. Table 1 includes a list of the chemical products currently used at the Facility.

Table 1: Approved Chemical Products

Chemical Treat. Product Names	Purpose	Nalco Equivalent
CL5428	Dispersants	3DT121, 3DT133, 3DT191, 3DT102
CL456, CL452, CL453	Biodetergent/Surfactant	73551, 73550
CT775, CT709, CT788, CL5788, CT790, CL1495	Corrosion Inhibitor - phosphate based	3DT487, 3DT184, 3DT195
CL216, CL2250, CL2150, CL2115, CL2065	Non Oxidizing Biocides	7614, 7330, 7320, 7338
12.5% Sodium Hypochlorite (Bleach)	Bleach Oxidizing Biocide	-
CL41, CL4520	chlorine / bromine oxidizing biocides used in conjunction with an oxidant such as bleach (NaOCl)	1318
CL241	Anti-Foam	7471
C2187T	TowerBrom tablets	TowerBrom 991
C2184G	TowerBrom granular	TowerBrom 960
GS5810	Tower Cleaning	-
CL4822, P8000L	Prevent Iron Deposition	-

24. The actual number and location of geothermal production and injection wells used at any given time at the Facility varies. The Department of Conservation, Geologic Energy Management Division (CalGEM, formerly DOGGR) regulates the drilling, operation, and closure of geothermal wells, as well as the reinjection of geothermal brine from the well head into the geothermal aquifer, including but not limited to: approval of wells for reinjection; flow rate and volume of geothermal fluids reinjected; well location; casing design; casing leak detection; additives; and leak detection and inspection.
25. Table 2 reflects current number and ownership of properties associated with the Facility's geothermal production and injection wells:

Table 2: Location and Ownership of Geothermal Wells

Well	Abbreviated Name	Well Type	Assessor Parcel Number	Surface Owner ID#
Vonderahe 1	Von-1	Production	APN 020-110-039	4
Vonderahe 2	Von-2	Production	APN 020-110-049	2
Vonderahe 3	Von-3	Production	APN 020-110-019	2
Vonderahe 4	Von-4	Production	APN 020-110-049	2
Vonderahe 5	Von-5	Production	APN 020-110-019	2
Vonderahe 6	Von-6	Production	APN 020-110-39	4
Elmore101	Elmore 101	Injection	APN 020-110-051	1
IID- 04	IID- 04	Injection	APN 020-110-019	2
IID- 05	IID-04	Injection	APN 020-110-019	2
IID- 06	IID-06	Injection	APN 020-110-019	2
IID- 7	IID-7	Injection	APN 020-110-019	2
IID- 9	IID-9	Injection	APN 020-110-019	2
IID- 10	IID-10	Injection	APN 020-110-019	2
IID- 11	IID-11	Injection	APN 020-110-019	2
IID- 16	IID - 16	Production	APN 020-110-019	2
IID- 17	IID-17	Injection	APN 020-110-051	1
Sinclair 10	Sin-10	Production	APN 020-110-039	4
Sinclair 11	Sin-11	Production	APN 020-110-049	2
Sinclair 15	Sin-15	Injection	APN 020-110-051	1
Sinclair 21	Sin-21	Injection	APN 020-110-050	3
Sinclair 22	Sin-22	Injection	APN 020-110-050	3
Sinclair 23	Sin-23	Injection	APN 020-110-050	3
Sinclair 24	Sin-24	Injection	APN 020-110-050	3
Sinclair 26	Sin-26	Injection	APN 020-110-050	3
Sinclair 27	Sin 27	Injection	APN 020-110-050	3

¹ John Jameson Elmore & Ann Kelly Elmore

² Imperial Magma LLC

³ Mary M. Troisi, Robert T. DuPuis, Helen A. Landerman, Joan DuPuis, and Peter Landerman

⁴ Magma Land Company I

Waste and Unit Classification

26. The Discharger is permitted to place geothermal liquids and geothermal solids along with geothermal drilling waste in the Brine Pond, which is a Class II surface impoundment and waste management unit under title 27 of the California Code of Regulations. As depicted in Table 3, the Brine Pond is the only waste management unit at the Facility:

Table 3: Waste Management Units at the Facility

Unit	Capacity	Liner System	Unit Status
Brine Pond	1.1 million gallons	Protective Layer –8” of fiber reinforced concrete; Primary Layer- Seaman XR-5 40-mil flexible membrane; LCRS – Enkadrain; Secondary Layer - Seaman XR-5 40-mil flexible membrane.	Active

27. The Brine Pond is a double-lined, rectangular pond with an approximate footprint of 220 feet by 109 feet with sloped sides and a depth of 7.4 feet. Each layer of the liner is made with Seaman XR-5 40-mil flexible membrane, with Enkadrain drainage fabric in between the two layers. The entire geosynthetic liner system is covered with eight inches of fiber reinforced concrete to protect its exposed surface from any unnecessary mechanical harm. The pond is sloped at a grade of 0.33%, towards a Leachate Collection and Removal System (LCRS) that is used to detect any leaks in the primary layer. Based on the sole and dimensions of the pond, the total volume of the impoundment is 1,157,137 gallons. This maximum allowable volume is 1,092,000 gallons in order to maintain the 2 feet of freeboard for brine that is required by this Order.
28. Any liquid that is collected by the LCRS is stored within a sump that has top dimensions of approximately three-feet wide by three-feet long. The LCRS sump is the lowest point in the Brine Pond system that is still above the secondary

geosynthetic liner. The LCRS sump has a volume of approximately 201 gallons before the liquid begins to accumulate in the Enkadrain drainage-layer.

29. All of the following wastewater streams are directed to the Brine Pond and/or to the injection wells for direct injection into the geothermal reservoir:
- a. Cooling tower blowdown;
 - b. Geothermal waste:
 - i. Geothermal brine (liquids),
 - ii. Geothermal brine precipitates (solids);
 - c. Portable shower effluent;
 - d. Spills and water from hydroblasting;
 - e. Wastewater generated from plant cleanups and washdowns from the plant conveyance system;
 - f. Vehicle wash station effluent;
 - g. Process filtrate from the Brine Pond filter press, geotextile solids-dewatering bags (used to dewater geothermal solids before final disposal), or other mechanical separator BMPs that the Discharger is granted approval to use by the Executive Officer;
 - h. Lime sump effluent; and
 - i. Effluent from emission abatement equipment.
30. The geothermal brine at the Facility, which is highly saline (over 10,000 m/L TDS) and may also contain high concentrations of metals, is considered designated waste.⁴ Designated waste is defined in Water Code section 13173 and California Code of Regulations, title 27, section 20210 as nonhazardous waste containing pollutants that, under ambient environmental conditions at a waste management unit, could be released in concentrations exceeding applicable water quality objectives or adversely affect beneficial uses of the waters of the state. Constituents of concern in the geothermal brine that have the potential to exceed water quality objectives for areal surface waters and groundwater include total dissolved solids (TDS) and heavy metals. Therefore, the discharge is of designated waste and, as such, must be discharged to waste management units regulated under title 27 of the California Code of Regulations.

⁴ Geothermal fluids managed in surface impoundments such as the Brine Pond are expressly exempted from management as "hazardous waste" pursuant to Health and Safety Code section 25143.1.

31. Periodically, the Discharger may need to remove solids from the Brine Pond that precipitate out of the liquid brine as it cools or settles. The Discharger is responsible for conducting confirmation sampling of the removed solids and disposing of the waste at a proper final disposal facility. With proper maintenance, the Brine Pond will continue to function as designed and the required freeboard level of two feet can be maintained.
32. According to the Discharger, any hazardous waste generated or stored at the Facility, that is not a designated waste, is stored and disposed of in a manner compliant with federal and state regulations, and not placed into the Brine Pond.

Hydrogeologic and Climate Conditions

33. The Discharger reports that shallow groundwater in the area of the Facility occurs approximately 5-15 feet below ground surface, flows generally to the northwest towards the Salton Sea, and has a total dissolved solids concentration ranging from approximately 1,600 to approximately 43,000 mg/L and has naturally occurring levels of heavy metals, such as Arsenic, that are often found above the California Primary and Secondary Maximum Contaminant Levels.
34. The amount of usable near-surface groundwater in the central Imperial Valley is unknown, but this resource has not been significantly exploited because of low well yields and poor chemical quality. The upper 500 feet of fine-grained deposits in the central portion of the Imperial Valley are estimated to have a transmissivity of less than 10,000 gallons per day. Even lower permeabilities are estimated to occur at greater depths (Westec, 1981), and low vertical permeability inhibits mixing of waters from different depths, such as between the shallow aquifer system and underlying deeper groundwater that includes the geothermal resources.
35. The Facility is largely surrounded by farmland that is drained by an extensive network of ditches and drains in agricultural areas. These drains discharge into the Alamo and New Rivers, which are tributary to the Salton Sea. Canal seepage and tiled agricultural drains recharge the shallow aquifer, the Salton Sea, and even the deeper aquifer in the form of seepage from canals and irrigated agricultural lands. Groundwater in the basin is constantly being mixed with imported Colorado River water that is used for irrigating large parts of the valley. Colorado River water is generally of a calcium-sodium chloride-sulfate type. The Colorado River is located several miles east of the Facility.
36. Climatological data obtained from 1903 to 2015 indicates an average seasonal precipitation of 3.15 inches, and an average annual pan evaporation rate greater than 100 inches.
37. The wind direction in the immediate vicinity of the Facility follows two general patterns:

- a. Seasonally from late fall through early spring, prevailing winds are from the west and northwest. Humidity is lowest under these conditions.
 - b. Summer weather patterns are often dominated by an intense, heat-induced low-pressure area that forms over the interior deserts, drawing air from the south; humidity is highest under these “monsoon” conditions.
38. Four groundwater monitoring wells numbered MWM-2, MWM-3, MWM-4 and U35-1 are monitored semi-annually to evaluate for a release to groundwater from the Brine Pond. Downgradient wells MWM-2, MWM-3, and MWM-4 surround the Brine Pond. Upgradient well U35-1 is located approximately 600 feet southeast of the Brine Pond. The location of the monitoring wells is shown on **Attachment C**, Monitoring Well Map, made part of this Order by reference.
39. There are no domestic wells within 500 feet of the Facility.

Regional Geology

40. The Facility is located in Imperial Valley within the Salton Trough, a closed basin located below sea level and separated from the Gulf of California by the Colorado River delta. The Trough is a structural and topographic depression containing thousands of feet of heterogeneous Tertiary and Quaternary aged lacustrine and deltaic sediments associated with the Colorado River delta. The area is tectonically active and has numerous faults associated with the San Andreas Fault Zone. The lowest area of the basin is the Salton Sea at 227 feet below mean sea level.
41. The Salton Trough was filled as it subsided by sediments from the Colorado River, which constructed a transverse alluvial delta, effectively forming a dam across the basin, impeding further intrusions of marine water from the Gulf of California. Thereafter, frequent diversions of the Colorado River northward into the Salton Trough rather than the Gulf of California supplied enormous volumes of water and sediments to the developing and subsiding land-locked basin. As a result, the Salton Trough contains up to 21,000 feet of fluid-saturated sandstone, siltstone, and mudstones. Though individual sedimentary layers are discontinuous over long distances, internally consistent packages of sedimentary layers can be traced a mile or more across the field.
42. The sedimentary sequence in the area is interpreted to encompass the Brawley and Borrego Formations, and possibly the Palm Springs Formation with great depth. The Brawley Formation, which is Pleistocene to Holocene in age, is dominated by a 1,000 to 1,300-foot-thick evaporate-bearing clay and siltstone unit that acts as the cap rock to the geothermal reservoir. This is followed by the Pleistocene aged Borrego Formation down to a depth of at least 5,000 to 6,000 feet. The sequence from 1,000 to about 3,500 feet is mostly mudstones with minor associated argillaceous siltstones and lesser amounts of very fine-grained subarkosic sandstones. These sandstones, that are obviously not hydrothermally altered, are partially cemented with diagenetic calcite. The estimated intrinsic inter-granular

porosity tends to decrease with depth from about 30% to less than 10%. From about 3,500 feet to about 5,000 to 6,000 feet the sequence is more or less subequal amounts of mudstones, siltstones and fine-grained sandstones. There is a formational change below 5,000 to 6,000 feet to a sequence of dominantly fine to medium grained subarkosic sandstones with subordinate amounts of siltstone and shale. This is tentatively interpreted to be the Pleistocene to Pliocene aged Palm Springs Formation. Mafic and silicic volcanic rocks are occasionally found from 5,000 feet to below 8,000 feet.

43. The Salton Sea geothermal reservoir occurs in fractured sedimentary rocks within the Salton Trough, a structural depression on the boundary between two tectonic plates. The northwest motion of the Pacific Plate on the west, relative to the North American Plate on the east, has created regional right-lateral faults-oriented Northwest-Southeast and local conjugate left-lateral faults, oriented Northeast-Southwest. The thermal anomaly of the Salton Sea field is aligned Northeast-Southwest and appears to be centered on a major left-lateral fault some of which acts as a conduit for geothermal brines upwelling from depth. Within the Salton Sea field, past volcanic activity is indicated by four outcrops of rhyolite lava (Obsidian Butte, Rock Hill, Red Island and Mullet Island), as well as rhyolite sections of volcanic rocks encountered in several wells. Due to circulating groundwater through salt-bearing beds within the Salton Trough, the geothermal brines at the Salton Sea are highly saline, with TDS in the range of 21 to 28 percent by weight. Reservoir temperatures at the Salton Sea are among the hottest of any geothermal field in the world, with encountered temperatures in excess of 700 degrees Fahrenheit.

Basin Plan and Other Regulatory Considerations

44. The Water Quality Control Plan for the Colorado River Basin Region (Basin Plan), adopted on November 17, 1993 and most recently amended on January 8, 2019, designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Pursuant to Water Code section 13263, subdivision (a), WDRs must implement the Basin Plan and take into consideration the beneficial uses to be protected, the water quality objectives reasonably required for that purpose, other waste discharges, the need to prevent nuisance, and the provisions of Water Code section 13241.
45. The Facility is located in the Imperial Hydrologic Unit. The Basin Plan states that the beneficial uses of groundwater in the Imperial Hydrologic Unit are:
 - a. Municipal Supply (MUN), and
 - b. Industrial Supply (IND).
46. Surface waters in the area of the Facility include the Imperial Irrigation District (IID) irrigation delivery canals and surface drains, the Alamo River, and the Salton Sea. The beneficial uses of surface waters in the area of the Facility are as follows:

- a. Imperial Valley Drains
 - i. Freshwater Replenishment (FRSH),
 - ii. Water Contact Recreation (REC I),
 - iii. Non-contact Water Recreation (REC II),
 - iv. Warm Freshwater Habitat (WARM),
 - v. Wildlife Habitat (WILD), and
 - vi. Preservation of Rare, Threatened, or Endangered Species (RARE).
 - b. Alamo River
 - i. Freshwater Replenishment (FRSH),
 - ii. Water Contact Recreation (REC I),
 - iii. Non-Contact Water Recreation (REC II),
 - iv. Warm Freshwater Habitat (WARM),
 - v. Wildlife Habitat (WILD),
 - vi. Hydropower Generation (POW), and
 - vii. Preservation of Rare, Threatened, or Endangered Species (RARE).
 - c. Salton Sea
 - i. Aquaculture (AQUA),
 - ii. Industrial Service Supply (IND),
 - iii. Water Contact Recreation (RECI),
 - iv. Noncontact Water Recreation (RECII),
 - v. Warm Water Habitat (WARM),
 - vi. Wildlife Habitat (WILD), and
 - vii. Preservation of Rare, Threatened, or Endangered Species (RARE).
47. This Order establishes WDRs pursuant to division 7, chapter 4, article 4 of the Water Code for discharges that are not subject to regulation under Clean Water Act section 402 (33 U.S.C. § 1342).
48. These WDRs implement numeric and narrative water quality objectives for groundwater and surface waters established by the Basin Plan and other applicable state and federal laws and policies. The numeric objectives for groundwater designated for municipal and domestic supply (MUN) include the Maximum Contaminant Levels (MCLs) and bacteriological limits specified in California Code of Regulations, title 22, section 64421 et seq. The Basin Plan states that groundwater for use as domestic or municipal water supply (MUN) must not contain taste- or odor-

producing substances in concentrations that adversely affect beneficial uses as a result of human activity.

49. It is the policy of the State of California that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes. This Order promotes that policy by requiring the Discharger to maintain waste containment systems that prevent discharges of waste to waters of the state.
50. These WDRs also implement state regulations applicable to the discharge of solid/designated waste to land found in California Code of Regulations, title 27, division 2, subdivision 1, commencing with section 20005 ("Consolidated Regulations for Treatment, Storage, Processing or Disposal of Solid Waste"). These regulations contain classification criteria for wastes and for disposal sites, and prescribe minimum standards for the siting, design, construction, monitoring, and closure of waste management units.
51. Consistent with Water Code section 13241, the Regional Water Board, in establishing the requirements contained herein, considered factors including, but not limited to, the following:
 - a. Past, present, and probable future beneficial uses of water.
 - b. Environmental characteristics of the hydrographic unit under consideration, including the quality of water available thereto.
 - c. Water quality conditions that could reasonably be achieved through the coordinated control of all factors which affect water quality in the area.
 - d. Economic considerations.
 - e. The need for developing housing within the region.
 - f. The need to develop and use recycled water.
52. Water Code section 13267 authorizes the Regional Water Board to require technical and monitoring reports. Monitoring and Reporting Program (MRP) R7-2021-0008 establishes monitoring and reporting requirements to implement state requirements and demonstrate compliance with this Order and to identify the Facility's impact, if any, on receiving waters. The State Water Resources Control Board's (State Water Board) electronic database, GeoTracker Information Systems, facilitates the submittal and review of facility correspondence, Discharger requests, and monitoring and reporting data. The burden, including costs, of the MRP bears a reasonable relationship to the need for the information and the benefits to be obtained from that information.
53. Pursuant to Water Code section 13263, subdivision (g), the discharge of waste is a privilege, not a right, and adoption of this Order does not create a vested right to continue the discharge.

Antidegradation Analysis

54. State Water Board Resolution 68-16, *Statement of Policy with Respect to Maintaining High Quality Waters in California* (Resolution 68-16), generally prohibits the Regional Water Board from authorizing discharges that will result in the degradation of high quality waters, unless it is demonstrated that any change in water quality will: (a) be consistent with maximum benefit to the people of the state, (b) not unreasonably affect beneficial uses, and (c) not result in water quality less than that prescribed in state and regional policies (e.g., the violation of one or more water quality objectives). The discharger must also employ best practicable treatment or control (BPTC) to minimize the degradation of high quality waters. High quality waters are surface waters or areas of groundwater that have a baseline water quality better than required by water quality control plans and policies.
55. Geothermal brine and the resulting solid and liquid geothermal waste may vary naturally in their chemical makeup depending on the location of the production well within the geothermal reservoir and the amount of heat the material was exposed to during the energy generating process. The relative concentration of geothermal solids to geothermal liquid may also cause a slight variation in chemical makeup.
56. Based on the analytical data gathered from previous monitoring periods and waste investigations, the main Potential Constituents of Concern (PCOCs) for this Facility include TDS and heavy metals. These PCOCs are monitored for during each monitoring period from the Brine Pond and from the groundwater monitoring wells that surround the Brine Pond. Migration of PCOCs through the Brine Pond's protective layers and into the surrounding soil or the local groundwater is not expected to occur and is prohibited by this Order, and therefore no degradation should occur to the state's surface water, groundwater, or soils.
57. The temporary discharge of wastewater to the Brine Pond, as permitted herein, reflects BPTC. These WDRs incorporate specific containment requirements for all discharged materials, including a:
 - a. Liner system with 1×10^{-6} cm/sec permeability, or synthetic liner with equivalent permeability;
 - b. Protected working face consisting of fiber reinforced concrete and other materials as identified in construction diagrams for the Brine Pond;
 - c. LCRS to collect leachate through the primary liner and prevent pressure from accumulating on the secondary liner;
 - d. Groundwater monitoring well network;
 - e. Minimum of two (2) feet of freeboard in the Brine Pond; and

- f. Sufficient construction and protection to withstand a 1000-year storm event because the Facility was constructed within the 1000-year floodplain, as authorized by this and previous Regional Water Board orders.
58. This Order complies with Resolution 68-16 by requiring the Discharger to maintain waste containment systems that prevent discharges of waste to waters of the state. Although no degradation from discharge to the surface impoundments is expected to occur, the Facility is equipped with sufficient controls to detect and minimize any impacts. Any minimal degradation of groundwater by some of the typical waste constituents is consistent with the maximum benefit to the people of the state. The discharge is necessary to accommodate essential public services providing renewable energy to local municipalities, businesses, and residents, which is an important benefit to the state. The Discharger also supports the economic prosperity of the community by the employment of full-time and part-time personnel at the Facility. Accordingly, the discharge as authorized is consistent with the antidegradation provisions of Resolution 68-16.

Stormwater

59. Federal regulations for stormwater discharges were promulgated by the U.S. Environmental Protection Agency on November 16, 1990 (40 C.F.R. parts 122, 123, and 124) to implement the Clean Water Act's stormwater program set forth in Clean Water Act section 402(p) (33 U.S.C. § 1342(p)). In relevant part, the regulations require specific categories of facilities that discharge stormwater associated with industrial activity to "waters of the United States" to obtain National Pollutant Discharge Elimination System (NPDES) permits and to require control of such pollutant discharges using Best Available Technology Economically Achievable (BAT) and Best Conventional Pollutant Control Technology (BCT) to prevent and reduce pollutants and any more stringent controls necessary to meet water quality standards.
60. The State Water Board adopted Order 2014-0057-DWQ (NPDES No. CAS000001), *General Permit for Storm Water Discharges Associated with Industrial Activities* (Industrial General Permit), which became effective on July 1, 2015. The Industrial General Permit regulates discharges of stormwater associated with certain industrial activities, excluding construction activities, and requires submittal of a Notice of Intent (NOI) to be covered under the permit. The Industrial General Permit contains several exemptions in Attachment A of the permit, including one for "Steam Electric Power Generating Facilities." Because the Facility generates steam electric power, the Discharger indicates that it has not enrolled in the Industrial General Permit.
61. The State Water Board also adopted Order 2012-0006-DWQ (NPDES NO. CAS000002), *General Permit for Storm Water Discharges Associated with Construction and Land Disturbance Activities* (Construction General Permit), which regulates dischargers whose project disturbs one or more acres of soil, or whose project disturbs less than one acre but is part of a larger common plan of

development that in total disturbs one or more acres. Construction of additional geothermal wells or other ancillary facilities may require the Discharger's enrollment under the Construction General Permit, if applicable.

62. The Discharger states that under normal working conditions, the capacity of the Brine Pond, freshwater makeup pond, and facility conveyance system is large enough to accept wastewater generated at the Facility as well as precipitation within the footprint of the Brine Pond for a storm event with a 1000-year return.
63. The Discharger must comply with all pertinent stormwater requirements contained in title 27 of the California Code of Regulations and in this Order.

Financial Assurances

64. The State Water Board-promulgated provisions of title 27 of the California Code of Regulations require maintenance of appropriate financial assurance mechanisms to cover all expenses related to the Brine Pond for the following:
 - a. Closure Activities (Cal. Code Regs., tit. 27, § 22207) – in at least the amount of the current closure cost estimate;
 - b. Post-closure Maintenance (Cal. Code Regs., tit. 27, § 22212) – in at least the amount of the current post-closure cost estimate; and
 - c. Corrective Action (Cal. Code Regs., tit. 27, § 22222) – for initiating and completing corrective action for all known or reasonably foreseeable corrective action.
65. The Discharger has indicated that it plans to “clean close” the Brine Pond in accordance with California Code of Regulations, title 27, section 21400. Post-closure financial assurances are therefore not needed.
66. **Within 90 days** following the issuance of this Order, the Discharger must provide appropriate assurances of financial responsibility for clean closure and for corrective action in compliance with title 27 of the California Code of Regulations.

CEQA and Public Participation

67. Pursuant to California Code of Regulations, title 14, section 15301, the issuance of these WDRs, which govern the operation of an existing facility involving negligible or no expansion of use beyond that previously existing, is exempt from the provisions of the California Environmental Quality Act (Public Resources Code, § 21000 et seq.).
68. The Regional Water Board has notified the Discharger and all known interested agencies and persons of its intent to issue waste discharge requirements for this

discharge and provided them with an opportunity for a public meeting and to submit comments.

69. The Regional Water Board, in a public meeting, heard and considered all comments pertaining to this discharge.

IT IS HEREBY ORDERED, pursuant to section 13263 and 13267 of the California Water Code, that Order R7-2015-0048 is rescinded, except for the purposes of enforcement, and in order to meet the provisions contained in division 7 of the Water Code and regulations adopted thereunder, the Discharger shall comply with the following:

A. Discharge Prohibitions

1. The discharge of waste classified as “hazardous,” as defined by California Code of Regulations, title 27, section 20164 is prohibited.
2. Extremely hazardous chemicals and chromates may not be used in the cooling tower water treatment process without prior approval from the Regional Water Board’s Executive Officer.
3. The disposal of incompatible wastes or wastes that, when mixed or commingled with other wastes, may create heat, pressure, fire, explosion, toxic by-products, or other chemical reactions that: (1) impair the integrity of the containment structures, or (2) generate products requiring a higher level of containment than provided by the waste management unit into which the wastes are placed, is prohibited.
4. The discharge of wastewater to a location or in a manner different from that described in this Order is prohibited.
5. The discharge of waste to land not owned or controlled by the Discharger, or not authorized for such use, is prohibited.
6. The discharge of wastes to the unsaturated/vadose zone or to groundwater is prohibited.
7. The discharge of waste to surface waters or surface drainage courses is prohibited.
8. The discharge of solid geothermal waste (i.e., brine particulates or precipitates) to the Brine Pond as a final form of disposal is prohibited.
9. The discharge of domestic waste or sewage to the Brine Pond is prohibited.
10. The storage, treatment, or disposal of wastes from the Facility shall not cause contamination, pollution, or nuisance as defined in Water Code section 13050, subdivisions (k), (l), and (m).

B. Discharge Specifications

1. The Discharger shall comply with all applicable provisions of title 27 (Cal. Code Regs., tit. 27, § 20005 et seq.), even if not specifically referenced in this Order.
2. Wastes shall be discharged only into waste management units specifically designed for their containment and/or treatment, as described in this Order.
3. The Discharger is responsible for accurate characterization of wastes, including determinations of whether wastes will be compatible with containment features and other wastes at the waste management unit, and whether the wastes are required to be managed as a “hazardous” waste or “designated” waste.
4. The discharge shall not cause the concentration of any Constituent of Concern (including Monitoring Parameters), as defined in the MRP R7-2021-0008 and incorporated herein by reference, to exceed its representative concentration limit in any monitoring medium (i.e., exceed the Water Quality Protection Standard). The concentration limit for each constituent will be set in accordance with the MRP. Data analysis shall be performed in accordance with the MRP.
5. All waste management units shall be operated to ensure that wastes, including leachate, will be a minimum of 5 feet above the highest anticipated elevation of underlying groundwater, including the capillary fringe.
6. The Discharger shall promptly notify the Regional Water Board of any slope failure occurring at a waste management unit. The Discharger shall promptly correct any failure which threatens the integrity of containment features or the unit in accordance with the method approved by the Regional Water Board’s Executive Officer.
7. The Discharger shall promptly remove and properly dispose of any unpermitted wastes that are discharged at the Facility in violation of these requirements.
8. Leachate collected from a waste management unit shall be discharged to the unit from which it came, or discharged to an appropriate waste management unit in accordance with California Code of Regulations, title 27, sections 20200(d) and 20340(g), and in a manner consistent with the waste classification of the liquid.
9. The Brine Pond is only permitted to receive the following waste streams:
 - a. Geothermal brine and brine precipitates (solids);
 - b. Wastewater generated from plant cleanups and washdowns discharged via the conveyance system;
 - c. Cooling tower blowdown;
 - d. Portable shower effluent;

- e. Water from hydroblasting;
 - f. Vehicle washing station effluent;
 - g. Filtrate of Brine Pond solids dewatering that is being returned to the Brine Pond from the filter press or other dewatering process allowed by this permit;
 - h. Lime sump effluent; and
 - i. Effluent from air emission abatement equipment.
- 10.** At least **30 days prior** to the use of a new chemical class for control of microbes, pH, scale, and corrosion of cooling tower water and/or geothermal brine, the Discharger shall notify the Regional Water Board's Executive Officer in writing. The use of a new class of chemicals may not be utilized until approved in writing by the Regional Water Board's Executive Officer.
- 11.** The Brine Pond shall contain an independent leachate collection and removal system (LCRS) between the inner and outer liners.
- 12.** The Discharger shall maintain sufficient freeboard in the Brine Pond to accommodate seasonal precipitation and to contain a 1,000 year 24-hour storm event, but in no case no less than two (2) feet of freeboard (measured vertically).
- 13.** Any direct-line discharge to the Brine Pond shall have fail-safe equipment or operating procedures to prevent overfilling. Discharges shall be stopped in the event of any containment system failure which causes a threat to water quality.
- 14.** If during the active life of the Brine Pond, the wastes are removed and the bottom of the impoundment is cleaned down to the liner, an inspection shall be made of the bottom of the liner prior to refilling of the impoundment.
- 15.** The LCRS shall be designed, constructed, maintained, and operated to collect and remove twice the maximum anticipated daily volume of leachate from the waste management unit.
- 16.** The LCRS shall be operated to function without clogging through the scheduled closure of the Brine Pond and during the post-closure maintenance period. The LCRS shall be tested at least annually to demonstrate proper operation. The results of the tests shall be compared with earlier tests made under comparable conditions.
- 17.** The liquid entering the LCRS sump shall not accumulate to an extent that it extends out of the LCRS sump and into the collection portion of the LCRS. The Discharger shall remove fluids from the LCRS sump as often as needed to prevent the liquid in the LCRS from backing up into the collection portion of the LCRS.

18. LCRS maintenance and repair plans shall generally be submitted to the Regional Water Board in advance of any work. The Discharger is only authorized without prior approval to conduct ongoing, minor maintenance repairs to minimize the exposure of the liner and keep any tears from the edges of the liner from worsening. Surface impoundment repair plans and liner Construction Quality Assurance (CQA) Plans shall be developed and stamped by a licensed professional experienced in this type of work.
19. Residual solids obtained from wastewater discharged to the Brine Pond shall be discharged only at a waste management facility licensed to receive such wastes. The Discharger shall maintain legible records on the volume and type of waste removed from the Brine Pond and shall submit a shipping manifest or other appropriate documentation showing the disposal method and location.
20. Public contact with material in the Brine Pond shall be precluded through fences, signs, or other appropriate alternatives.

C. Stormwater Specifications

1. The Brine Pond shall be designed, constructed, operated, and maintained to limit, to the greatest extent possible, erosion, slope failure, overtopping, inundation or washout, and damage resulting from natural disasters such as: flood volumes from a 24-hour storm event having a predicted frequency of once in 1,000 years, pursuant to California Code of Regulations, title 27, section 20375; the Maximum Credible Earthquake (MCE) pursuant to section 20310, Table 4.1; and severe wind storms.
2. Surface and subsurface drainage from outside of a waste management unit shall be diverted from the unit.
3. Surface drainage from tributary areas, and internal site drainage from surface or subsurface sources, shall not contact or percolate through the wastes discharged at the Facility.
4. Diversion and drainage facilities shall be designed, constructed, and maintained to:
 - a. Accommodate the anticipated volume of precipitation and peak flows from surface runoff and under the precipitation conditions for the waste management unit.
 - b. Effectively divert sheet flow runoff laterally, via the shortest distance, into the drainage and collection facilities.
 - c. Prevent surface erosion through the use of energy dissipators, where required, to decrease the velocity of runoff, slope protection, and other erosion control measures where needed to prevent erosion.

- d. Control and intercept run-on, in order to isolate uncontaminated surface waters from water that might have come into contact with waste.
 - e. Take into account:
 - i. For closed waste management units and for closed portions of units, the expected final contours of the closed unit, including its planned drainage pattern.
 - ii. For operating portions of waste management units other than surface impoundments, the unit's drainage pattern at any given time.
 - iii. The possible effects of the waste management unit's drainage pattern on and by the regional watershed.
 - iv. The design capacity of drainage systems of downstream and adjacent properties by providing for the gradual release of retained water downstream in a manner which does not exceed the expected peak flow rate at the point of discharge if there were no waste management units or facility.
 - f. Preserve the system's function. The Discharger shall periodically remove accumulated sediment from the sedimentation or detention basins as needed to preserve the design capacity of the system.
5. Collection and holding facilities associated with precipitation and drainage control systems shall be emptied immediately following each storm or otherwise managed to maintain the design capacity of the system.

D. Construction Specifications

- 1. Construction on waste management units shall be performed in accordance with a Construction Quality Assurance Plan that complies with California Code of Regulations, title 27, section 20324 and is prepared by a registered civil engineer or certified engineering geologist.
- 2. The Construction Quality Assurance (CQA) program, including all relevant aspects of construction quality control, shall provide evidence that materials and procedures utilized in the placement of any containment feature at any waste management unit will be tested and monitored to assure the structure is constructed in accordance with the design specifications approved by the Regional Water Board.
- 3. **Preconstruction Notice.** At least **60 days** prior to the commencement of construction, the Discharger shall submit a technical report to the Regional Water Board for approval by the Executive Officer, which shall include a plan showing in detail the proposed construction. Any portion of the 60-day

requirement may be waived in writing by the Executive Officer at the request of the Discharger.

4. **Pre-operations Notification.** At least **10 days** prior to commencement of operations at any newly-constructed component, the Discharger shall submit a certificate to the Regional Water Board, signed by a California Registered Civil Engineer or Certified Engineering Geologist, stating that the component is constructed in accordance with the respective technical report as approved by the Executive Officer.
5. **CQA Final Report.** Within **90 days** of the completion of construction, the Discharger shall submit a final Construction Quality Assurance (CQA) report documenting the construction process and containing the quality assurance documentation described in the ROWD and required by section 20324(d) of title 27 of the California Code of Regulations.

E. Monitoring Specifications

1. The Discharger shall implement MRP R7-2021-0008 and any revisions thereto to detect at the earliest opportunity unauthorized discharges of waste constituents from the Facility, or any impairment of beneficial uses that result from discharges of waste at the Facility. The Discharger shall report the results of all onsite monitoring in accordance with MRP R7-2021-0008 and revisions thereto.
2. The Discharger shall conduct a water quality monitoring and response program in accordance with MRP R7-2021-0008 and any future amendments thereto, including:
 - a. Detection Monitoring. The Discharger shall institute a detection monitoring program pursuant to California Code of Regulations, title 27, section 20420.
 - b. Evaluation Monitoring. The Discharger shall institute an evaluation monitoring program under California Code of Regulations, title 27, section 20425:
 - i. Whenever there is “measurably significant” (as defined in section 20164) evidence of a release from the waste management unit under the detection monitoring program; or
 - ii. Whenever there is significant physical evidence of a release from the waste management unit. Significant physical evidence of a release includes unexplained volumetric changes in surface impoundments, unexplained stress in biological communities, unexplained changes in soil characteristics, visible signs of leachate migration, and unexplained water table mounding beneath or adjacent to the unit and any other change

to the environment that could reasonably be expected to be the result of a release from the unit.

- c. Corrective Action Monitoring. The Discharger shall institute a corrective action monitoring program under California Code of Regulations, title 27, section 20430 when the Regional Water Board determines that the assessment of the nature and extent of the release and the design of a corrective action program have been satisfactorily completed.
3. **Sample Collection and Analysis Plan**. Within **90 days** of the adoption of these WDRs, the Discharger shall submit, for review and approval by the Regional Water Board's Executive Officer, a comprehensive Sample Collection and Analysis Plan (SCAP) that shall describe in detail the methods to be used to perform all monitoring activities for all onsite features, including:
- a. Sample collection procedures describing purging techniques, sampling equipment, and decontamination of sampling equipment;
 - b. Sample preservation information and shipment procedures;
 - c. Sample analytical methods and procedures;
 - d. Sample quality assurance/quality control (QA/QC) procedures;
 - e. Chain of custody control; and
 - f. Sample analysis information including sample preparation techniques to avoid matrix interferences, method detection limits (MDLs), practical quantitation limits (PQLs) and reporting limits (RLs), and procedures for reporting trace results between the MDL and PQL.

Once the SCAP is approved, the Discharger may request changes to the approved SCAP, as needed, but shall use the procedures described in the approved SCAP until such changes are authorized by the Regional Water Board's Executive Officer.

F. Corrective Action Specifications

1. For all waste management units in a corrective action program to address a release from the unit, the Discharger shall implement all corrective measures necessary to remediate the release and to ensure that the Discharger achieves compliance with the Water Quality Protection Standard (as defined in the MRP) adopted for that unit. To confirm cleanup of all water-bearing media affected by the release, the Discharger shall complete the demonstration required under California Code of Regulations, title 27, section 20430(g).
2. The cessation of any corrective action measure (e.g. landfill gas, leachate, and groundwater extraction) is prohibited without written approval from the Regional Water Board's Executive Officer. If routine maintenance or a breakdown results in cessation of corrective action for greater than **24 hours**, the Discharger shall notify Regional Water Board staff.

3. Following an earthquake that generates significant ground shaking (Modified Mercalli Intensity Scale V or greater) at or near the Facility, the Discharger shall submit a detailed post-earthquake inspection and corrective action plan. The plan shall address damage to and corrective measures for: containment structures; leachate control and stormwater management systems; wells and equipment to monitor groundwater; and any other system/structure potentially impacted by static and seismic deformations of the waste management unit. The Discharger shall notify the Regional Water Board Executive Officer immediately, but no later than **24 hours**, of damage to the waste management units due to an earthquake, and provide a post-earthquake inspection report within **15 business days**.

G. Financial Assurances Specifications

1. The Discharger shall obtain and maintain adequate assurances of financial responsibility for closure, post-closure maintenance, and corrective action for all known and reasonably foreseeable releases from a waste management unit at the Facility in accordance with California Code of Regulations, title 27, sections 20380(b) and 20950 and subchapter 2 ("Financial Assurance Requirements") of division 2, subdivision 1, chapter 6 of title 27.
2. The Discharger shall demonstrate to the Regional Water Board that it has established acceptable financial assurance mechanisms described in subchapter 3 ("Allowable Mechanisms") of California Code of Regulations, title 27, division 2, subdivision 1, chapter 6 in at least the amount of the cost estimates for closure, post-closure maintenance, and corrective action approved by the Regional Water Board's Executive Officer.
3. **Corrective Action Financial Assurance.** Within **90 days** of the adoption of this Order, the Discharger shall submit to the Regional Water Board, in accordance with California Code of Regulations, title 27, section 22222, assurance of financial responsibility acceptable to the Regional Water Board's Executive Officer for initiating and completing corrective action for all known or reasonably foreseeable releases from the Brine Pond.
4. **Closure Financial Assurance.** Within **90 days** of the adoption of this Order, the Discharger shall submit to the Regional Water Board, in accordance with California Code of Regulations, title 27, section 22207, an updated assurance of financial responsibility acceptable to the Regional Water Board's Executive Officer for initiating and completing clean closure for the Brine Pond.
5. **Yearly Financial Assurances Report.** The Discharger shall submit, by **June 1** of each year, a report calculating the increase in the cost estimates for closure, post-closure maintenance, and corrective action due to the inflation factor (specified in Cal. Code Regs., tit. 27, § 22236) for the previous calendar year.

6. Documents supporting the amount and active status of the required financial assurance mechanisms shall be included in the Facility's ROWD and revisions. Annual cost estimates and inflation factors shall be submitted to the Regional Water Board as an addendum to the ROWD.

H. Closure and Post-Closure Specifications

1. The Discharger shall notify the Regional Water Board in writing of the final closure or partial final closure of a waste management unit as follows:
 - a. Landfill Units. For landfill waste management units, notice shall be given either: (1) at the same time that CalRecycle is notified under California Code of Regulations, title 27, section 21110, or (2) **180 days** prior to beginning any final closure activities, whichever is sooner.
 - b. Non-Landfill Units. For non-landfill waste management units (including Class II surface impoundments), notice shall be given at least **180 days** prior to beginning any final closure activities.
 - c. Affirmation. The notice shall include a statement that all closure activities will conform to the most recently-approved final or partial final closure plan and that the plan provides for site closure in compliance with all applicable federal and state regulations.
2. The Discharger shall carry out closure of a waste management unit or a portion of a unit only in accordance with a closure and post-closure maintenance plan approved by the Regional Water Board (Cal. Code Regs., tit. 27, §§ 20950(a)(1), 21769(d)) through the issuance of closure WDRs.

I. Special Provisions

1. **Spill Prevention Plan**. Within **90 days** of the adoption of this Order, the Discharger shall submit the Spill Prevention Plan for approval by the Regional Water Board's Executive Officer. The Discharger shall develop and implement a plan for immediate detection of leaks or failures in the aboveground pipelines carrying geothermal fluids. If an automatic pump is being used, an alarm or shutoff device shall be installed on the pump used in the pipelines. Pumping of geothermal fluids shall be suspended immediately following major pipeline failure. The plan shall include routine inspection of the entire length of aboveground line in operation at the time, and the maintenance of an inspection log. Minor leaks shall be repaired immediately upon being identified. A sign should be posted to identify the fluid being pumped and alerting the public of the potential danger.
2. **Geothermal Brine Spill Reporting**. If leaks or failures in the aboveground pipelines carrying geothermal solution occur in excess of 150 gallons, or if there is any spill of geothermal solution from the Brine Pond, the Discharger shall do the following:

- a. Orally report to the Regional Water Board office and the Office of Emergency Services within **24 hours** of when the Discharger becomes aware of the incident. If noncompliance occurs outside of business hours, the Discharger shall leave a message on the Regional Water Board's office voicemail.
- b. Provide a written report within **five business days** of the time the Discharger becomes aware of the incident. The written report shall contain a description of the noncompliance and its cause, the period of noncompliance, the anticipated time to achieve full compliance, and the steps taken or planned, to reduce, eliminate, and prevent recurrence of the noncompliance. The Discharger shall estimate the total volume as well as the vertical and horizontal extent of the spill/leak/release.
- c. Submit a follow-up report within **30 days** of receipt of final test results that includes **confirmation sampling results** indicating that cleanup goals have been achieved.

J. Standard Provisions

1. **Noncompliance.** The Discharger shall comply with all of the terms, requirements, and conditions of this Order and MRP R7-2020-008. Noncompliance is a violation of the Porter-Cologne Water Quality Control Act (Water Code, § 13000 et seq.) and grounds for: (1) an enforcement action; (2) termination, revocation and reissuance, or modification of these WDRs; or (3) denial of an Order renewal application.
2. **Enforcement.** The Regional Water Board reserves the right to take any enforcement action authorized by law. Accordingly, failure to timely comply with any provisions of this Order may subject the Discharger to enforcement action. Such actions include, but are not limited to, the assessment of administrative civil liability pursuant to Water Code sections 13323, 13268, and 13350, a Time Schedule Order (TSO) issued pursuant to Water Code section 13308, or referral to the California Attorney General for recovery of judicial civil liability.
3. **Proper Operation and Maintenance.** The Discharger shall at all times properly operate and maintain all systems and components of collection, treatment, and control installed or used by the Discharger to achieve compliance with this Order. Proper operation and maintenance includes, but is not limited to, effective performance, adequate process controls, and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities/systems when necessary to achieve compliance with this Order. All systems in service or reserved shall be inspected and maintained on a regular basis. Records of inspections and maintenance shall be retained and made available to the Regional Water Board on request.

- 4. Reporting of Noncompliance.** The Discharger shall report any noncompliance that may endanger human health or the environment. Information shall be provided orally to the Regional Water Board office and the Office of Emergency Services within 24 hours of when the Discharger becomes aware of the incident. If noncompliance occurs outside of business hours, the Discharger shall leave a message on the Regional Water Board's office voicemail. A written report shall also be provided within five (5) business days of the time the Discharger becomes aware of the incident. The written report shall contain a description of the noncompliance and its cause, the period of noncompliance, the anticipated time to achieve full compliance, and the steps taken or planned, to reduce, eliminate, and prevent recurrence of the noncompliance. All other forms of noncompliance shall be reported with the Discharger's next scheduled Self-Monitoring Reports (SMRs), or earlier if requested by the Regional Water Board's Executive Officer.
- 5. Duty to Mitigate.** The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment.
- 6. Material Changes.** Before initiating a new discharge or making a material change in the character, location, or volume of an existing discharge, the Discharger shall report all pertinent information in writing to the Regional Water Board, and if required by the Regional Water Board, obtain revised requirements before any modifications are implemented. A material change includes, but is not limited to, the following:

 - a. An increase in area or depth to be used for solid waste disposal beyond that specified in waste discharge requirements;
 - b. A significant change in disposal method, location, or volume (e.g., change from land disposal to land treatment);
 - c. A change in the type of waste being accepted for disposal; or
 - d. A change to previously-approved liner systems or final cover systems that would eliminate components or reduce the engineering properties of components.
- 7. Familiarity with Order.** The Discharger shall ensure that all site-operating personnel are familiar with the content of this Order and maintain a copy of this Order at the site.
- 8. Inspection and Entry.** The Discharger shall allow the Regional Water Board, or an authorized representative, upon presentation of credentials and other documents as may be required by law, to:

 - a. Enter the premises regulated by this Order, or the place where records are kept under the conditions of this Order;

- b. Have access to and copy, at reasonable times, records kept under the conditions of this Order;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order; and
 - d. Sample or monitor at reasonable times, for the purpose of assuring compliance with this Order or as otherwise authorized by the Water Code, any substances or parameters at this location.
- 9. **Change in Ownership.** This Order is not transferable to any person without written approval by the Regional Water Board's Executive Officer. Prior to any change in ownership of this operation, the Discharger shall notify the Regional Water Board's Executive Officer in writing at least 30 days in advance. The notice must include a written transfer agreement between the existing owner and the new owner. At a minimum, the transfer agreement must contain a specific date for transfer of responsibility for compliance with this Order and an acknowledgment that the new owner or operator is liable for compliance with this Order from the date of transfer. The Regional Water Board may require modification or revocation and reissuance of this Order to change the name of the Discharger and incorporate other requirements as may be necessary under the Water Code.
- 10. **Monitoring Wells.** The Discharger shall comply with all notice and reporting requirements of the California Department of Water Resources and with any well permitting requirements imposed by a local agency regarding the construction, alteration, destruction, maintenance, or abandonment of any monitoring wells used for compliance with this Order and the accompanying MRP, as required under Water Code sections 13750 and 13755 and local agency requirements.
- 11. **Format of Technical Reports.** The Discharger shall furnish, under penalty of perjury, technical monitoring program reports, and such reports shall be submitted in accordance with California Code of Regulations, title 23, division 3, chapter 30, as groundwater raw data uploads electronically over the Internet into the State Water Board's [GeoTracker](#) database. Documents that were formerly mailed by the Discharger to the Regional Water Board, such as regulatory documents, narrative monitoring reports or materials, and correspondence, shall be uploaded into GeoTracker in the appropriate Microsoft Office software application format, such as Word or Excel files, or as a Portable Document Format (PDF) file. Large documents must be split into appropriately-labelled, manageable file sizes and uploaded into GeoTracker.
- 12. **Qualified Professionals.** In accordance with Business and Professions Code sections 6735, 7835, and 7835.1, engineering and geologic evaluations and judgments shall be performed by or under the direction of California registered professionals (i.e., civil engineer, engineering geologist, geologist, etc.) competent and proficient in the fields pertinent to the required activities. All

technical reports required under this Order that contain work plans, describe the conduct of investigations and studies, or contain technical conclusions and recommendations concerning engineering and geology shall be prepared by or under the direction of appropriately qualified professional(s), even if not explicitly stated. Each technical report submitted by the Discharger shall contain a statement of qualifications of the responsible licensed professional(s) as well as the professional's signature and/or stamp of the seal. Additionally, all field activities are to be conducted under the direct supervision of one or more of these professionals.

13. **Certification Under Penalty of Perjury.** All technical reports required in conjunction with this Order shall include a statement by the Discharger, or an authorized representative of the Discharger, certifying under penalty of perjury under the laws of the State of California, that the reports were prepared under his or her supervision in accordance with a system designed to ensure that qualified personnel properly gathered and evaluated the information submitted, and that based on his or her inquiry of the person or persons who manage the system, the information submitted is, to the best of his or her knowledge and belief, true, complete, and accurate.
14. **Violation of Law.** This Order does not authorize violation of any federal, state, or local laws or regulations.
15. **Property Rights.** This Order does not convey property rights of any sort, or exclusive privileges, nor does it authorize injury to private property or invasion of personal rights.
16. **Modification, Revocation, Termination.** This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for an Order modification, rescission, or reissuance, or the Discharger's notification of planned changes or anticipated noncompliance, does not stay any Order condition. Causes for modification include, but are not limited to, the violation of any term or condition contained in this Order, a material change in the character, location, or volume of discharge, a change in land application plans or sludge use/disposal practices, or the adoption of new regulations by the State Water Board, Regional Water Board (including revisions to the Basin Plan), or federal government.
17. **Severability.** The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of these requirements shall not be affected.


Any person aggrieved by this Regional Water Board action may petition the State Water Board for review in accordance with Water Code section 13320 and California Code of Regulations, title 23, section 2050 et seq. The State Water Board must receive the petition by 5:00 p.m. on the 30th day after the date of this Order; if the 30th day falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board by 5:00 p.m. on the next business day. Copies of the statutes and regulations

applicable to filing petitions are available on the State Water Board's website and can be provided upon request.


Order Attachments

Attachment A—Site Location Map
Attachment B—General Facility Map
Attachment C—Monitoring Well Map
Attachment D—MRP R7-2021-0008

ATTACHMENT A—SITE LOCATION MAP



ATTACHMENT B—GENERAL FACILITY MAP



The map shows the layout of Units 3, 4, and 5. Key features include:

- Roads:** CRUMMER ROAD (top), KUHN'S ROAD (bottom), and VAL LATERAL LINE (top right).
- Units:** UNIT 3, 4 & 5 MONITOR WELLS (top right), UNIT 5 (center left).
- Monitor Wells:**
 - Downgradient Monitoring Well MW-4 (blue star, top right)
 - Downgradient Monitoring Well MW-3 (blue star, center left)
 - Downgradient Monitoring Well MW-2 (blue star, bottom right)
 - Monitoring Well U35-1 (red star, bottom left)
- Other Features:**
 - Chemical Storage Area (center)
 - Tank 1 and Tank 2 (center right)
 - Brine Pond (center)
 - Hose Down Areas (center)
 - Fresh Water Makeup Pond (bottom center)
- Legend:**
 - U35-1: MONITOR WELL W/ LABEL
 - U35-2: CONTROL MONITOR W/ NO LABEL
 - U35-3: TEST WELL W/ LABEL
 - U35-4: BACKGROUND WELL W/ LABEL
- Scale and Orientation:**
 - Graphic Scale: 1" = 50'
 - North arrow pointing right.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ATTACHMENT F – MONITORING AND REPORTING PROGRAM R7-2021-0008

FOR

CALENERGY OPERATING CORPORATION, OPERATOR
SALTON SEA POWER GENERATION COMPANY, SALTON SEA POWER LLC,
IMPERIAL MAGMA LLC, MAGMA LAND COMPANY I, AND IMPERIAL MAGMA,
OWNERS

REGION 1 SALTON SEA POWER PLANT UNITS 1-5
CLASS II SURFACE IMPOUNDMENT
IMPERIAL COUNTY

This Monitoring and Reporting Program (MRP) is issued pursuant to Water Code section 13267 and incorporates requirements for groundwater, surface water, and unsaturated zone detection monitoring, special monitoring provisions relating to individual waste management units (WMUs). Monitoring requirements in this MRP are necessary to determine if the Region 1 Salton Sea Power Plant Units 1-5 (Facility) is in compliance with Waste Discharge Requirements (WDRs) Order R7-2021-0008 (Order) and to ensure early detection of any releases of waste constituents from the Facility. The Discharger shall not implement any changes to this MRP unless a revised MRP is issued by the California Regional Water Quality Control Board, Colorado River Basin Region (Regional Water Board) or its Executive Officer.

PART I: SAMPLING AND ANALYSIS GENERAL REQUIREMENTS

A. Sampling and Analysis General Requirements

1. As provided in Monitoring Specification E.3 of the Order, the Discharger shall submit a Sample Collection and Analysis Plan (SCAP) that incorporates the standard monitoring provisions below and describes the sampling and analysis protocols to be used for all monitoring activities. The SCAP must be received by the Regional Water Board within 90 days of adoption of the Order and this MRP.
2. Once the SCAP is approved, the Discharger may request changes to the approved SCAP, as needed, but shall use the procedures described in the approved SCAP until such changes are authorized by the Regional Water Board's Executive Officer.

B. Standard Monitoring Provisions

1. **Analytical Methods.** Specific methods of analysis for monitored waste constituents shall be identified in the SCAP. If the Discharger proposes to use methods other than those in the latest edition of the U.S. Environmental Protection Agency's (USEPA) *Test Methods for Evaluating Solid Waste: Physical/Chemical Methods Compendium* (SW-846) or *Guidelines Establishing*

Test Procedures for Analysis of Pollutants, 40 Code of Federal Regulations part 136, the SCAP must explain the rationale for the change. The change must be approved by the Regional Water Board's Executive Officer prior to use.

2. **Monitoring Test Procedures.** The collection, preservation, and holding times of all samples shall be in accordance with protocols included in USEPA's SW-846 or 40 Code of Federal Regulations part 136, or as otherwise approved by the Regional Water Board. The Regional Water Board may, in its discretion, require methods more sensitive than those specified by USEPA.
3. **30-Day Sample Procurement Limitation.** For any given monitored medium, the samples collected from all monitoring points and background monitoring points to satisfy the data analysis requirements for a given reporting period shall all be collected within a span not to exceed 30 days, unless a longer time period is approved by the Regional Water Board's Executive Officer, and shall be collected in a manner that ensures sample independence to the greatest extent feasible. The 30-day limit does not apply to media that (1) are resampled to confirm the results of the initial round of samples, or (2) are resampled due to errors in the original sampling and analysis, but the Discharger shall conduct the resampling as expeditiously as practical.
4. **Laboratory Certification.** Unless otherwise approved by the Regional Water Board's Executive Officer, all analyses shall be conducted by a laboratory certified by the State Water Resources Control Board (State Water Board), Division of Drinking Water's Environmental Laboratory Accreditation Program (ELAP).
5. **Reporting Levels.** All analytical data shall be reported with method detection limits (MDLs) and with either the reporting level or limits of quantitation (LOQs) according to 40 Code of Federal Regulations part 136, Appendix B. The laboratory reporting limit for all reported monitoring data shall be no greater than the practical quantitation limit (PQL).
6. **QA/QC Data.** All quality control / quality assurance (QA/QC) data shall be reported, along with the sample results to which they apply, including the method, equipment, and analytical detection limits, the recovery rates, an explanation of any recovery rate that is less than 80%, the results of equipment and method blanks, the results of spiked and surrogate samples, the frequency of quality control analyses, and the name and qualifications of the person(s) performing the analyses. Sample results shall be reported unadjusted for blank results or spike recovery. In cases where contaminants are detected in QA/QC samples (i.e., field, trip, or lab blanks), the accompanying sample results shall be appropriately flagged, but the analytical results shall not be adjusted.
7. **Instrumentation and Calibration.** All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated, as necessary, to ensure their continued accuracy. If

continuous monitoring equipment is out of service for a period greater than 24 hours, the Discharger shall obtain representative grab samples each day the equipment is out of service. The Discharger shall correct the cause(s) of failure of the continuous monitoring equipment as soon as practicable. The Discharger shall report the period(s) during which the equipment was out of service and if the problem has not been corrected, shall identify the steps which the Discharger is taking or proposes to take to bring the equipment back into service and the schedule for these actions.

8. **Field Test Instruments.** Field test instruments (such as those used to test pH, dissolved oxygen, and electrical conductivity) may be used provided that:
 - a. The user is trained in proper use and maintenance of the instruments,
 - b. The instruments are field calibrated prior to monitoring events at the frequency recommended by the manufacturer,
 - c. Instruments are serviced and/or calibrated by the manufacturer at the recommended frequency, and
 - d. Field calibration reports are submitted.
9. **Records Retention.** The Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, for a minimum of five years from the date of the sampling or measurement. This period may be extended by request of the Regional Water Board's Executive Officer at any time. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurement(s);
 - b. The individual(s) who performed the sampling or measurement(s);
 - c. The methods used for groundwater purging/sampling;
 - d. The date(s) analyses were performed;
 - e. The individual(s) who performed the analyses;
 - f. The analytical techniques or method used; and
 - g. All sampling and analytical results, including:
 - i. units of measurement used,
 - ii. minimum reporting limit for the analyses,
 - iii. results less than the reporting limit but above the method detection limit (MDL),
 - iv. data qualifiers and a description of the qualifiers,
 - v. quality control test results (and a written copy of the laboratory quality assurance plan),

- vi. dilution factors, if used, and
- vii. sample matrix type.

PART II: SITE-SPECIFIC MONITORING REQUIREMENTS

This part describes the site-specific monitoring program requirements to be implemented for the Facility and is organized by the type of monitoring to be performed. The methods used shall be as described in the approved SCAP.

The site-specific monitoring program of this MRP includes:

Table 1. Summary of Site-Specific Monitoring

Section	Monitoring Program
A	Groundwater Monitoring
B	Unsaturated/Vadose Zone Monitoring
C	Surface Water Monitoring
D	Surface Impoundment Monitoring
F	Evaluation Monitoring
G	Corrective Action Monitoring

A. Groundwater Monitoring

The Discharger shall operate and maintain a groundwater monitoring system that complies with the applicable provisions of California Code of Regulations, title 27, sections 20415 and 20420. Monitoring shall be performed in accordance with the locations, frequencies, and parameters described below:

1. Monitoring Well Locations

Upgradient wells are considered background monitoring points. Downgradient wells where no releases have been detected are used for detection monitoring. The groundwater monitoring network shall consist of the following monitoring wells and any new monitoring wells added at the Facility (as approved by the Regional Water Board's Executive Officer):

Table 2. Monitoring Wells Summary

Well	Gradient Direction	Monitoring Status	Frequency
U35-1	Up	Detection	Semi-Annually
MW-2	Down	Detection	Semi-Annually

Well	Gradient Direction	Monitoring Status	Frequency
MW-3	Down	Detection	Semi-Annually
MW-4	Down	Detection	Semi-Annually

2. Parameters/Constituents Monitored

Groundwater samples shall be collected from the detection monitoring wells and any additional wells added as part of the approved groundwater monitoring system. The collected samples shall be analyzed for the Monitoring Parameters and Constituents of Concern specified below in accordance with the specified methods and frequencies.

“Monitoring Parameters” and “Constituents of Concern” shall have the meaning specified in California Code of Regulations, title 27, section 20164. “Monitoring Parameters” means the group of constituents specified below and includes physical parameters, waste constituents, reaction products, and hazardous constituents that provide a reliable indication of a release from a waste management unit. “Constituents of Concern” (COCs) include a larger group of waste constituents and mean any waste constituents, reaction products, and hazardous constituents reasonably expected to be in or derived from waste contained in a waste management unit.

Various Constituents of Concern are included as Monitoring Parameters, although the full list of Constituents of Concern are not included as Monitoring Parameters and need only be sampled for once every 5 years, as specified below.

a. Monitoring Parameters

“Monitoring Parameters” shall consist of the (1) Field Monitoring Parameters and (2) Laboratory Monitoring Parameters specified below:

- i. Field Monitoring Parameters – During each groundwater monitoring event,⁵ the following field parameters shall be measured:

Table 3. Field Parameters Monitoring

Parameter	Unit
pH	pH units

⁵ Pursuant to Cal. Code Regs., tit. 27, § 20415(e)(13).

Parameter	Unit
Groundwater elevation ⁶	Feet above sea level (USGS Datum)
Specific conductance	Micromhos/cm
Temperature	Degrees F
Turbidity	Nephelometric Turbidity Units (NTU)
Dissolved oxygen	Milligrams per liter (mg/L) and percent saturation
Oxidation-Reduction Potential (ORP)	Millivolts (mV)

- II. Laboratory Monitoring Parameters – Twice per year (semi-annually), groundwater samples shall be analyzed at a laboratory for the following constituents (at a minimum):

Table 4. Laboratory Monitoring Parameters Monitoring

Constituents	Units	Sample Type	Reporting Freq.
Total Dissolved Solids	mg/L	Grab	Semi-Annually
Arsenic	µg/L	Grab	Semi-Annually
Barium	µg/L	Grab	Semi-Annually
Cadmium	µg/L	Grab	Semi-Annually
Lead	µg/L	Grab	Semi-Annually
Zinc	µg/L	Grab	Semi-Annually
Oil & Grease	mg/L	Grab	Semi-Annually

- b. **Additional Constituents of Concern, Required Every Five Years (5-Year COCs)**

In addition to the Monitoring Parameters listed above, the groundwater shall be analyzed at a laboratory every five years, with the next monitoring event to be performed in the second half of 2022, and alternating between the two monitoring episodes for each five-year reporting period thereafter, for the following 5-Year COCs (and any additional COCs required by the Regional Water Board's Executive Officer):

⁶ Semi-annual measurement of groundwater elevations is approved pursuant to title 27, section 20380(e), allowing engineered alternatives provided they achieve the goals of the monitoring program.

Table 5. List of 5-Year COCs

Constituent
1. Alkalinity
2. General Chemistry (Ca, Mg, Na, K, SO ₄ , Cl, HCO ₃)
3. Carbonate (CO ₃)
4. Total Petroleum Hydrocarbons
5. 17 Heavy Metals (Cal. Code Regs., tit. 22, § 66261.24 / CAM 17)
6. Herbicides (40 C.F.R., Appendix II)
7. Semi-Volatile Phenols (USEPA Method 8270)
8. Volatile Organic Compounds (USEPA Method 8260)

The results of the 5-Year COC sampling shall be reported in the Annual Monitoring Report for the year in which the samples were collected.

Note that the broader term “COCs” includes both the Monitoring Parameters and 5-Year COCs.

B. Unsaturated Zone Monitoring

There is no unsaturated/vadose zone action monitoring program required at this time.

C. Surface Water Monitoring

Perennial streams are not located at the Facility and the occurrence of surface water should be limited to (1) immediately after significant storm events, and (2) if seeps develop along the perimeter of a waste management unit.

1. **Observed Surface Water Monitoring.** If surface water is observed near a waste management unit, the source of the surface water shall be identified, and observations of the following shall be included in the next Semi-Annual Monitoring Report:
 - a. Flow rate and source of water;
 - b. Floating and suspended materials of waste origin: Presence or absence, source, and size of affected area;
 - c. Discoloration and turbidity: Description of color, source, and size of affected area;

- d. Evidence of odors: Presence or absence, characterization, source, and distance of travel from source; and
- e. Weather conditions: Wind direction and estimated velocity, total precipitation during the previous five (5) days and on the day of observation.

2. Seep Monitoring. If a seep is identified in proximity to a waste management unit:

- a. The location, flow rate, and other characteristics (such as color and odor) shall be orally reported to the Regional Water Board within **48 hours**, and a written report concerning the seep shall be submitted to the Regional Water Board **within seven (7) days**.
- b. Flow from the seep shall be contained to preclude the seep from adversely affecting surface waters.
- c. A sample of the seepage shall be collected and tested for the Field Monitoring Parameters described in Part II.A.2.a.i.
- d. If the Field Monitoring Parameters indicate the seepage is not groundwater, or if it is unlikely the source of the seep is groundwater, the sample shall be analyzed for the Monitoring Parameters and 5-Year COCs described in Part II.A.2.a and b.
- e. The results of all testing shall be reported to the Regional Water Board **within seven (7) days** of receipt of the written laboratory report.
- f. Seeps that continue to exist for more than one reporting period shall be monitored during each reporting period and the results shall be included in the Semi-Annual Monitoring Report.

D. Surface Impoundment Monitoring

1. Pond Capacity Monitoring

The Brine Pond and Freshwater Makeup Pond shall be monitored at least monthly and included in the Semi-Annual Monitoring Report for the following:

- a. The available freeboard in each pond and/or pond cell.
- b. The average monthly volume and maximum monthly volume of wastewater and/or freshwater discharged into the surface impoundments in gallons.
- c. The average daily volume and maximum daily volume of wastewater and/or freshwater removed from the surface impoundments in gallons.
- d. Observations of erosion, settlement, and/or subsidence along the visible areas of the surface impoundment(s), including the top of the berm, outer

slopes, and upper region of the inner slope. Repairs shall be performed as needed and documented in the inspection logs.

2. Geothermal Solids Monitoring – Brine Pond Only

When solid geothermal waste is removed from the Brine Pond for final disposal at proper facility, the solid waste shall be monitored and sampled for the following information and will be included in each Semi-Annual Monitoring Report:

Table 6. Geothermal Solids Monitoring

Parameter	Unit	Reporting Frequency	Monitoring Frequency
Volume of solids removed	Tons	Quarterly	Monthly
Location of final disposal	Facility Name	Quarterly	Monthly
Volume of solids/liquids contained	Gallons	Quarterly	Monthly

Table 7. Geothermal Solids Sampling

Constituents	Units	Sample Type	Reporting Freq.
Arsenic	µg/kg	Grab	Semi-Annually
Barium	µg/kg	Grab	Semi-Annually
Cadmium	µg/kg	Grab	Semi-Annually
Lead	µg/kg	Grab	Semi-Annually
Zinc	µg/kg	Grab	Semi-Annually

3. Geothermal Wastewater Monitoring – Brine Pond Only

- a. Samples of wastewater shall be collected from the Brine Pond and analyzed for the following:

Table 8. Class II Surface Impoundment Monitoring

Constituents	Units	Sample Type	Reporting Freq.
pH	mg/L	Composite	Semi-Annually
Total Dissolved Solids	mg/L	Composite	Semi-Annually
Specific Conductance	mg/L	Composite	Semi-Annually
Arsenic	µg/L	Grab	Semi-Annually
Barium	µg/L	Grab	Semi-Annually
Cadmium	µg/L	Grab	Semi-Annually
Lead	µg/L	Grab	Semi-Annually
Zinc	µg/L	Grab	Semi-Annually
General Chemistry (Ca, Mg, Na, K, SO ₄ , Cl, HCO ₃)	mg/L	Composite	Annually
Carbonate (CO ₃)	mg/L	Composite	Annually
Total Alkalinity	mg/L	Composite	Annually

4. LCRS Monitoring

- a. The LCRSs must be designed and operated to function without clogging through the scheduled closure of the waste management unit and during any post-closure maintenance period. The Discharger shall test each LCRS annually pursuant to California Code of Regulations, title 27, section 20340(d) to demonstrate proper operation. Except for the first annual test, the results of this testing shall be compared to earlier tests made under comparable conditions.
- b. If the LCRS high-water alarm system is functioning properly, the Facility shall monitor the height of liquid in each LCRS sump at least **quarterly** to an accuracy of one-quarter (1/4) inch. If the alarm system is not functioning properly, the frequency of this monitoring shall be **weekly**. The Discharger shall record the data in the monitoring logs and include the data in the Semi-Annual Monitoring Report.
- c. The Discharger shall measure the electrical conductivity and pH of any liquid in the sumps **quarterly**.
- d. The Discharger shall remove fluids from the LCRS sumps as often as needed to prevent the liquid in the sump from backing up into the collection portion of the LCRS. The removed liquid may be discharged back into the surface impoundment for that sump. The volume removed shall be measured and used to identify the leakage rate into each sump. The

removal dates, volumes, and calculated leakage rates shall be included in the Semi-Annual Monitoring Report.

- e. If an automated sump-pump is installed, an alarm shall also be installed to indicate if the sump fills beyond the upper limit of the sump-pump settings. Automated systems shall also include a means of monitoring changes in the height of liquid in the sump and measuring the frequency and volume of pumping. This data shall be converted to a daily leakage rate and summarized in the Semi-Annual Monitoring Report. Automated sump pumps shall be tested at least annually to ensure they are functioning properly.
- f. If leakage rates exceed the reporting threshold (RT), the Discharger shall follow the steps in Part II.E.3 – Excessive Leachate Production. The RT for this Facility shall be the removal of 300 gallons of water from a sump over a 24-hour period.
- g. A workplan describing proposed changes to the LCRS monitoring system shall be submitted to the Regional Water Board for review and approval prior to implementing any proposed changes.

E. Evaluation Monitoring

1. Notification of a Release

Should the Discharger discover a release from the Facility, the Discharger shall:

- a. Initial Notification. Notify the Regional Water Board by phone or e-mail **within 24 hours**, and by mail **within seven days**, when the Discharger determines from monitoring results that there is measurably significant evidence of a release. (Cal. Code Regs., tit. 27, § 20420(j)(1).)
- b. Retest. The Discharger may immediately initiate the verification procedure specified in Part III.B.3 to verify that there is “measurably significant” evidence of a release of particular constituent.⁷ (Cal. Code Regs., tit. 27, § 20420(j)(2).)
- c. Notice to Nearby Landowners. The Discharger shall, **within 14 days** of confirming measurably significant evidence of a release, notify all persons who own the land or reside on the land that directly overlies any portion of the plume of contamination, if sampling of detection monitoring wells indicates contaminants have migrated off-site. (40 C.F.R. § 258.55(g)(1)(iii).)

⁷ Under California Code of Regulations, title 27, section 20420(k)(7), the Discharger may also demonstrate that a source other than the waste management unit caused the release.

2. Evaluation of a Release

If the Discharger determines that a previously unknown release from the Facility has occurred, the following actions shall be taken:

- a. Non-Statistical COC Scan. If the detection was made based upon sampling and analysis for Monitoring Parameters, the Discharger shall immediately sample all monitoring points in the affected medium at that waste management unit and determine the concentration of all Monitoring Parameters and Constituents of Concern for comparison with established concentration limits. Because this scan does not involve statistical testing, the Discharger will only need to collect and analyze a single water sample from each monitoring point in the affected medium. (Cal. Code Regs., tit. 27, § 20420(k)(1).)
- b. Amended ROWD for Evaluation Monitoring Program (EMP). The Discharger shall, **within 90 days** of confirming a measurably significant evidence of a release, submit an amended Report of Waste Discharge (ROWD) proposing an evaluation monitoring program that meets the requirements of California Code of Regulations, title 27, sections 20420(k)(5) and 20425. The evaluation monitoring program shall be designed for the collection and analysis of all data necessary to assess the nature and extent of the release and to determine the spatial distribution and concentration of each constituent throughout the zone affected by the release. (Cal. Code Regs., tit. 27, §§ 20420(k)(5) and 20425(b).) For releases from MSW landfill units, the evaluation monitoring program shall also include any additional proposals necessary to comply with 40 C.F.R. § 258.55, particularly the additional monitoring wells required by 40 C.F.R. § 258.55(g)(1)(ii). Additionally, the Discharger shall add any 5-Year COC for which there is a confirmed measurably significant release to the list of Monitoring Parameters.
- c. Preliminary Engineering Feasibility Study (EFS). The Discharger shall, **within 180 days** of confirming a measurably significant evidence of a release, submit to the Regional Water Board a preliminary engineering feasibility study (EFS) report for a corrective action program that meets the requirements of California Code of Regulations, title 27, sections 20420(k)(6) and 20430. At a minimum, the feasibility study shall contain a detailed description of the corrective action measures that could be taken to achieve background concentrations for all COCs.
- d. Additional EMP Required Actions. The Discharger shall, **within 90 days** of establishing an evaluation monitoring program (i.e., from the date of Regional Water Board approval of the program), complete and submit the following:

- i. A report with the results and assessment/delineation of the release based on the approved evaluation monitoring program. (Cal. Code Regs, tit. 27 § 20425(b).)
- ii. An updated engineering feasibility study for corrective action based on the data collected to delineate the release and data from the ongoing monitoring program required under title 27, section 20425(e). (Cal. Code Regs., tit. 27, § 20425(c).)
- iii. An amended ROWD to establish a corrective action program meeting the requirements of title 27, section 20430 based on the data collected to delineate the release and based on the updated engineering feasibility study. (Cal. Code Regs., tit. 27, § 20425(d).)⁸

3. Excessive Leachate Production

- a. If leakage rates in any LCRS exceed the reporting threshold (RT) of 300 gallons per day, the Discharger shall report this to the Regional Water Board within **48 hours** and propose further actions to evaluate whether repairs are needed. Unless a Facility-specific RT is approved by the Regional Water Board, the default RT shall be one half of the volume of the sump per day.
- b. The first time liquid is found in the LCRS sump, the Discharger shall:
 - i. The Regional Water Board shall be notified verbally within **seven days**, and
 - ii. Collect at least one sample of the leachate within **30 days** and analyze it for the Monitoring Parameters and 5-Year COCs used for groundwater monitoring.

F. Corrective Action Monitoring

There is no corrective action monitoring program required at this time.

⁸ The Discharger shall (for releases from MSW landfill units) discuss the results of the updated engineering feasibility study, prior to the final selection of a remedy, in a public meeting with interested and affected parties. (40 C.F.R. § 258.56(d).)

PART III: EVALUATION OF MONITORING DATA

Part III of this MRP provides the requirements for the analysis of detection, evaluation, and corrective action monitoring data collected from monitoring wells associated with the Facility.

A. Water Quality Protection Standard

For each waste management unit, the Water Quality Protection Standard (Water Standard) consists of all COCs (under title 27, section 20395), the concentration limit for each COC (under title 27, section 20400), and the points of compliance for each monitored medium (under title 27, section 20405) for the duration of the compliance period (under title 27, section 20410).

1. Constituents of Concern (COCs)

- a. The COCs are as defined above in Part II.A.2 and include both Monitoring Parameters and 5-Year COCs.

2. Concentration Limits

- a. **Default Limits.** The following concentration limits shall apply, unless the Regional Water Board approves a Concentration Limit Greater than Background (CLGB), as provided in Part III.A.2.b below:
 - i. **Non-natural Constituents.** For COCs that are not naturally occurring, the concentration limit shall be the detection limit of the laboratory testing procedure.
 - ii. **Naturally-Occurring Constituents.** For naturally-occurring COCs, the concentration limit shall be the background concentration determined through either inter-well or intra-well comparisons.
- b. **CLGB.** Use of a CLGB may be proposed by the Discharger provided it is justified through a statistical analysis of relevant data (including the background dataset) and a demonstration that background concentrations would not be technologically or economically feasible for the COCs for a given monitoring well. (Cal. Code Regs., tit. 27, § 20400, subd. (c).) A concentration limit greater than background will only be considered for COCs present in monitoring wells associated with corrective action monitoring. (Cal. Code Regs., tit. 27, § 20400, subd. (h).)
- c. **Procedure for Approval of Concentration Limits.** The Discharger shall submit a report proposing applicable background concentrations for each COC under Part III.A.2.a in the next Annual Monitoring Report. The Regional Water Board will review proposed concentration limits from the Discharger

and approve, modify, or disapprove each proposed limit. (Cal. Code Regs., title 27, § 20400.) Following initial approval of the concentration limits, the Discharger shall reevaluate and propose any updates to the concentration limits **every five years** thereafter.

3. Compliance Period

- a. The compliance period for each waste management unit includes the active life of each waste management unit, the closure period, the post-closure maintenance period, and any compliance period under California Code of Regulations, title 27, section 20410.

4. Points of Compliance

- a. All monitoring wells established for the detection monitoring program shall constitute the points of compliance for the Water Standard.

B. Statistical and Non-Statistical Analysis of Data

1. General Requirements

- a. California Code of Regulations, title 27, section 20415(e) describes a range of statistical and non-statistical data analysis methods that can be used to evaluate data collected during monitoring. In addition, USEPA published *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance* (EPA 530/R-09-007) in 2009.
- b. The Discharger shall evaluate the data obtained during a monitoring period using either a statistical or non-statistical method described in title 27 or may propose another method for approval by the Regional Water Board's Executive Officer, as long as it achieves the goal of the monitoring program at least as well as the most appropriate method described in title 27, section 20415.
- c. The Discharger shall propose data analysis methods to be used in evaluating water quality monitoring data for each COC. (Cal. Code Regs., tit. 27, § 20415(e)(7).) The specifications for each data analysis method shall include a detailed description of the criteria to be used for determining "measurably significant" (as that term is defined in title 27, section 20164) evidence of any release from the waste management unit and for determining compliance with the Water Standard.
- d. Monitoring reports shall describe the statistical or non-statistical method used for each COC at each monitoring point.

2. Background Values

- a. Pursuant to California Code of Regulations, title 27, section 20415(e)(10), the Discharger shall in a technical report justify the use of a procedure for determining the background value for each COC.
- b. Inter-well comparisons may be used where upgradient and downgradient wells intercept the same aquifer and are expected to have similar concentrations of naturally-occurring constituents. Intra-well comparisons shall be used where uncontaminated background wells are not present, or the chemical composition of upgradient and downgradient wells are significantly different.
- c. In establishing background values for COCs, the Discharger shall ensure that sampling methods used comply with California Code of Regulations, title 27, section 20415(e)(12), including that the number and kinds of samples collected must be appropriate for the form of data analysis employed and, in the case of statistical data analysis, follow generally accepted statistical principles. The sampling method (including the sampling frequency and the interval of time between successive samples) shall be appropriate for the medium from which samples are taken (e.g., groundwater, surface water, and soil-pore liquid). (See also Cal. Code Regs., tit. 27, § 20415(e)(6).) For groundwater, sampling shall be scheduled to include the times of expected highest and lowest elevations of the potentiometric surface.

3. Determination of Measurably Significant Evidence of a Release

- a. Initial Determination of Measurably Significant Evidence of a Release. The Discharger shall use a statistical or nonstatistical data analysis method that complies with California Code of Regulations, title 27, section 20415(e)(7)-(10) to compare the concentration of each COC with its respective background concentration to determine whether there has been measurably significant evidence of a release from the waste management unit. Whenever a COC is detected at a detection monitoring point at a concentration that exceeds the concentration limit from the Water Standard, the Discharger shall preliminarily conclude that there is measurably significant evidence of a release and follow the notification procedures in Part II.E.1. (Cal. Code Regs., tit. 27, § 20420(i).)
- b. Confirmation of a Measurably Significant Evidence of a Release. If there is a preliminary indication of a release, within **30 days** of such indication (Cal. Code Regs., tit. 27, § 20415(e)(8)(E)(3)), the Discharger may implement a

verification procedure/retest option in accordance with California Code of Regulations, title 27, section 20415(e)(8)(E).⁹

- i. Retest Method. The verification procedure shall include either: (1) a single “composite” retest (i.e., a statistical analysis that augments and reanalyzes the data from the monitoring point that indicated a release), or (2) at least two “discrete” retests (i.e., statistical analyses, each of which analyzes only newly-acquired data from the monitoring point that indicated a release). (Cal. Code Regs., tit. 27, § 20415(e)(8)(E).) The Discharger may use an alternate method with prior approval by the Regional Water Board that complies with the requirements of title 27, section 20415(e)(8)(E) in addition to the performance standards of title 27, section 20415(e)(9).
- ii. Retest Samples. The retest samples shall be collected from the monitoring point where the release is preliminarily indicated and shall be analyzed for the constituents that caused the need for the retest. (Cal. Code Regs., tit. 27, § 20415(e)(8)(E)(7).)
- iii. Retest Reporting. The Discharger shall report to the Regional Water Board the results of both the initial statistical test and the results of the verification procedure, as well as all concentration data collected for use in these tests, within **seven days** of the last laboratory analysis of the samples collected for the verification procedure. (Cal. Code Regs., tit. 27, § 20415(e)(8)(E)(6).)

If the retest results of one or more of the retest data suites confirm the original indication, the Discharger shall conclude that measurably significant evidence of a release has been confirmed. The Discharger shall then follow the procedures identified in Part II.E.2.

PART IV: REPORTS TO BE FILED WITH THE REGIONAL WATER BOARD

Part IV provides a description of the reports required to be submitted to the Regional Water Board for the Facility.

A. Required Reports

1. **Semi-Annual Monitoring Reports** – For each monitored medium, all monitoring results shall be reported semi-annually. Semi-Annual Monitoring Reports shall include, at a minimum, the following:

⁹ Under California Code of Regulations, title 27, section 20420(k)(7), the Discharger may also demonstrate that a source other than the waste management unit caused the release.

- a. **Topographic Map.** A topographic map (or copy of an aerial photograph), at an appropriate scale, identifying the Facility, the locations of observation stations, monitoring points, background monitoring points, and the groundwater elevation contours with interpreted groundwater flow direction and gradient.
- b. **Groundwater Elevations.** The method and time of groundwater elevation measurements, a description of the method used to purge the well and collect groundwater samples, and quality assurance/quality control (QA/QC) procedures used.
- c. **Field Logs.** Field logs used during well purging and sampling. At a minimum, the field logs should include the following:
 - i. The well number,
 - ii. The sampling date and time,
 - iii. The method of monitoring Field Monitoring Parameters and calibration of equipment used to monitor Field Monitoring Parameters,
 - iv. The purge method (if a pump is used, include the depth of pump placement in each well and the pumping rate), and
 - v. The purge and sample collection information such as: date each well was purged; well recovery time; method of disposal of the purged water; an estimate of the volume of water purged from each well; the results of all field analyses; depth to groundwater prior to purging, at the conclusion of purging, and when the sample was collected; the method of measuring the water level; and field personnel names and signature.
- d. **Data Tables.** Cumulative tabulated monitoring data for all monitoring points and constituents (including the Monitoring Parameters and 5-Year COCs). Concentrations below the laboratory reporting limit shall not be reported as "ND," unless the reporting limit is also given in the table. Otherwise, they shall be reported "<" next to the reporting limit (e.g., <0.10). Upon request of Regional Water Board staff, data files shall be provided electronically in a file format approved by the Regional Water Board. Any electronic files submitted to the Regional Water Board in accordance with Order R7-2021-0008 and this MRP, shall not be password protected.
- e. **Graphical Display.** For monitoring wells in corrective action or evaluation monitoring, a graphical display of groundwater concentrations for all COCs for which there is measurably significant evidence of a release, including all historical data for those COCs from at least 5 years prior to the detection of a release at that location. Each graph shall plot the

concentration of one or more constituents at an appropriate scale that allows changes in concentrations to be discerned, including the use of a semi-log scale for concentrations that change by more than three orders of magnitude.

- f. **Summary of Groundwater Conditions.** A written summary of the monitoring results and any changes to the groundwater monitoring system since the previous report. The written summary shall include a discussion of the groundwater flow rate and direction,¹⁰ the appearance of trends or other information that may indicate a potential change in the hydrogeologic conditions beneath and adjacent to the Facility.
 - g. **Evaluation of Groundwater Data.** An evaluation of the groundwater monitoring data analyzed according to the methods described in Part III of this MRP, and whether the analysis indicates a release of waste constituents or waste degradation products from the Facility.
 - h. **Leachate Evaluation.** A summary of leachate data for each applicable waste management unit, including any laboratory results and measurements of the height of liquids in LCRS sumps. The Discharger shall also calculate the leakage rate.
 - i. **Sludge/Solids Evaluation.** A summary of sludge data for each applicable waste management unit.
 - j. **Waste Volumes.** A summary of all required information concerning waste volumes for each applicable waste management unit.
2. **Annual Summary Report** – The Discharger shall submit an annual report covering the period from January 1 through December 31 to the Regional Water Board. If desired, the Annual Monitoring Report may be combined with the Semi-Annual Monitoring Report, but if so, shall clearly state that it is both a semi-annual and annual monitoring report in its title. The Annual Summary Report shall include, at a minimum, the following:
- a. **Summary of Groundwater Monitoring Data.** A written summary of the groundwater monitoring results, indicating any changes made or observed since the previous Annual Summary Report. If a 5-year COC event was performed, then these parameters shall be presented in tabular format. All analytical data obtained during the previous year shall be presented in tabular form. Upon request of the Regional Water Board, the data shall be provided electronically in a file format and media acceptable to the Regional Water Board.

¹⁰ The estimated quarterly groundwater flow rate and direction in the uppermost aquifer, in any zones of perched water, and in any additional zone of saturation monitored based upon water level elevations taken prior to the collection of the water quality data submitted in the report. (Cal. Code Regs., tit 27, § 20415(e)(15).)

- b. **Graphical Display.** A graphical display for all data collected for each monitoring point and background monitoring point. Each graph shall plot the concentration of one or more constituents over time for a given monitoring point. For any given constituent, the scale for all plots should be the same to facilitate comparison and identification of trends. On the basis of any outliers noted in the plotted data, the Regional Water Board may direct the Discharger to carry out a preliminary investigation, in accordance with Part II.E of this MRP, to determine whether a release is indicated. Trend analyses shall include identification of current trends, a comparison to previously identified trends, and a discussion of any significant changes in the trends. This shall be prepared for groundwater and any unsaturated/vadose zone monitoring points (including subdrains, lysimeters, or landfill gas).
- c. **Background Concentration Limits Update.** Reevaluate background concentration limits (required every five years per Part III.A.2.c) and propose any appropriate changes.
- d. **Leachate Data Summary.** A summary of leachate data for each applicable waste management unit, consisting of the monthly total volume of leachate collected during the reporting year from the LCRS and any other leachate collection systems to demonstrate the effectiveness of the leachate collection and removal system. This summary shall contain a brief discussion of the leachate sampling results and volume produced and how the leachate was disposed of during the reporting period. This summary shall also include a table consisting of the last five years of leachate data collected at the Facility.
- e. **Annual Waste Summary.** An annual summary consisting of the total volume of geothermal wastes generated at the Facility. The summary shall contain a table that lists each category of waste and the volume accepted at the Facility during the reporting period.
- f. **Site Conditions Summary.** Include a comprehensive discussion regarding the condition of the Facility, including, but not limited to, interim cover areas, the current operational area, maintenance roads, the erosion and drainage control measures implemented to control run-on and run-off during the rainy season, the condition of monitoring wells, piezometers, and any other monitoring device located at the Facility. The discussion should also highlight any areas of noncompliance observed and repaired during the previous year and should be documented with photographs and inspection reports.
- g. **Compliance Summary.** Include a comprehensive discussion of the compliance issues during the reporting period (the past year), and of any corrective actions taken or planned which may be needed to bring the Discharger into full compliance with the Order or this MRP.

B. Report Schedule

Semi-annual monitoring reports shall be submitted to the Regional Water Board in accordance with the following schedule:

Table 9. Semi-Annual Reporting Schedule

Monitoring Period	Report Due
January – June	August 15
July - December	March 15

Annual monitoring reports shall be submitted to the Regional Water Board by March 15 of the following year.

C. Standard Reporting Procedures

1. A transmittal letter explaining the essential points shall accompany each report. At a minimum, the transmittal letter shall identify any violations found since the last report was submitted, and if the violations were corrected. If no violations have occurred since the last submittal, this shall be stated in the transmittal letter. The transmittal letter shall also state that a discussion of any violations found since the last report was submitted, and a description of the actions taken or planned for correcting those violations, including any references to previously submitted time schedules, is contained in the accompanying report.
2. In reporting monitoring data, the Discharger shall arrange the data in tabular form so that the date, the constituents, and the concentrations are readily discernible. The data shall be summarized in such a manner as to clearly illustrate whether the Facility is operating in compliance with the WDRs. Where appropriate, the Discharger shall include supporting calculations (e.g., for monthly averages).
3. The results of any analysis taken more frequently than required at the locations specified in this MRP shall be reported to the Regional Water Board.
4. As specified in Standard Provisions J.13, all monitoring reports shall be certified under penalty of perjury to be true and correct. Each report shall contain the following completed declaration:

“I certify under the penalty of law that this document, including all attachments and supplemental information, was prepared under my direction or supervision in accordance with a system designed to ensure that qualified personnel properly gathered and evaluated the information submitted. I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there

are significant penalties for submitting false information, including the possibility of a fine and imprisonment.

Executed on the _____ day of _____ at _____

_____(Signature)

_____(Title)"

5. The monitoring reports and any other information requested by the Regional Water Board shall be signed by a principal executive officer or ranking elected official. A duly authorized representative of the Discharger may sign the documents if:
 - a. The authorization is made in writing by the person described above;
 - b. The authorization specified an individual or person having responsibility for the overall operation of the regulated disposal system; and
 - c. The written authorization is submitted to the Regional Water Board's Executive Officer.
6. As specified in Standard Provisions J.12, technical reports shall be prepared by or under the direction of appropriately qualified professional(s). Each technical report submitted shall contain a statement of qualifications of the responsible licensed professional(s) as well as the professional's signature and/or stamp of the seal.
7. As specified in Standard Provisions J.11, the Discharger shall comply with Electronic Submittal of Information (ESI) requirements by submitting all correspondence and reports required under this MRP and future revisions thereto, including groundwater monitoring data and discharge location data (latitude and longitude), correspondence, and monitoring reports to the State Water Board's Geotracker database. Documents that are too large to be uploaded into Geotracker should be broken down into smaller electronic files and labelled properly prior to uploading into Geotracker.