

**Date:**

May 30, 2019

**Applicant:**

Southern California Edison  
2244 Walnut Grove Avenue, GO-1, Quad 2C  
Rosemead, CA, 91770  
Contact: Hazem Gabr  
(626) 302-7608  
Hazem.gabr@sce.com

**Applicant's Representative:**

Southern California Edison  
Contact: Richard Haywood  
2244 Walnut Grove Avenue, GO-1, Quad 2C  
Rosemead, CA 91770  
(626) 302-2892  
Richard.haywood@sce.com

**Project Name:**

Grid Reliability Maintenance Program Footing Erosion Mitigation (Tower M42-T2) Project  
WDID No. 7B363045001 (RM: 430449, Place ID: 858240)

**Receiving Water:**

Lucerne Dry Lake

**Location:**

City or area: Approximately 15 miles NE of Lucerne Valley, San Bernardino County, CA  
Latitude/Longitude: N 34° 36' 9.036"/ W 116° 45' 22.2078"

**Project Description:**

The proposed Project consists of:

- A gabion wall is to be constructed around the tower footings to redirect water flow and will be backfilled with native soil
- A terraced trench will be dug with one step approximately 3 ft wide by 2 ft deep and the second approximately 3 ft wide by 1 foot deep running roughly 120 ft in length
- Some grading will occur near the tower footings to convey water flow from the tower
- Construction equipment will include a backhoe, track excavator, dump truck, flatbed truck, pickup truck, and water truck

**Proposed Schedule (Start-up, duration, and completion dates):**

The work is scheduled to begin in Fall 2019.

Duration: 10 days

**Action:**

Pending

**Water Board Contact:**

Kai Dunn, Senior Water Resources Control Engineer  
(760) 776-8986  
[Kai.Dunn@waterboards.ca.gov](mailto:Kai.Dunn@waterboards.ca.gov)