

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
<b>Alameda</b>					
	Alameda County Water District	0110001	Optimal fluoridation is normally provided.	0.9	0.90
	City of Hayward [c]	0110006	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Pleasanton	0110008	Optimal fluoridation is normally provided.	0.8	0.90
	Dublin San Ramon Services District	0110009	Optimal fluoridation is normally provided.	0.8	0.89
	East Bay Municipal Utility District	0110005	Optimal fluoridation is normally provided.	0.8	0.87
<b>Butte</b>					
	Cal-Water Service Co. (Oroville)	0410005	Optimal fluoridation is normally provided.	0.8	0.85
	City of Gridley	0410004	Optimal fluoridation is normally provided.	0.8	0.78
<b>Contra Costa</b>					
	City of Antioch	0710001	Optimal fluoridation is normally provided.	0.8	0.82
	City of Brentwood [m]	0710004	[m].....Water system receives fluoridated water from both PWSID 0710003 & PWS ID 0710010, and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Martinez	0710006	Optimal fluoridation is normally provided.	0.8	0.83
	City of Pittsburg	0710008	Optimal fluoridation is normally provided.	0.8	0.80
	Contra Costa Water District (Bollman)	0710003	Optimal fluoridation is normally provided.	0.8	0.89
	Contra Costa Water District (Randall-Bold)	0710010	Optimal fluoridation is normally provided.	0.8	0.86
	Diablo Water District	0710007	Optimal fluoridation is normally provided.	0.8	0.80
	Golden State Water Co. (Bay Point) [l]	0710002	[l].....Water system receives fluoridated water from PWSID 0710003 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
<b>Del Norte</b>					
	Bertsch Ocean View CSD [a]	0810003	Bertsch Ocean View CSD obtains all of its water from Crescent City. On November 8, 2012 the City of Crescent City ceased adding Fluoride to its water per ballot measure A.	N/A	
	City of Crescent City	0810001	The City of Crescent City ceased adding Fluoride to its water supply on November 8, 2012 per ballot Measure A.	N/A	
<b>Fresno</b>					
	City of Coalinga	1010004	Optimal fluoridation is normally provided.	N/A	0.83
	City of Fresno [f]	1010007	[f].....Water system has fluoridated and non-fluoridated service areas. Contact the water system for their detailed fluoride level information.	N/A	
<b>Humboldt</b>					
	City of Arcata	1210001	Optimal fluoridation is normally provided.	1.0	0.34
	City of Eureka	1210004	Optimal fluoridation is normally provided.	1.0	0.74
	Jacoby Creek Co. WD [b]	1210021	[b].....Water system receives fluoridated water from PWSID 1210001 (100%). Listed Fluoride levels are from this system.	1.00	0.14
<b>Kern</b>					
	Indian Wells Valley Water District [1.]	1510017	[1.].....Water system has naturally occurring fluoride, below the MCL. Monthly amounts in this table based on routine source water monitoring and not monthly distribution sampling.	N/A	
<b>Kings</b>					
	City of Hanford	1610003	See the water systems annual Consumer Confidence Report for information on naturally occurring fluoride levels in this water system.	N/A	
<b>Los Angeles</b>					
	Azusa Light And Water [p]	1910007	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Bellflower Home Gardens WC [p]	1910012	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Bellflower Municipal Water Sys. [p]	1910018	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.38

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Bellflower Somerset Mutual WC [p]	1910013	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Cal State Polytechnic Univ (Pomona) [p]	1910022	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Cal-American Water Co. (San Marino) [p]	1910139	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Cal-American WC (Baldwin Hills) [p]	1910052	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.54
	Cal-Water SC (City of Montebello)	1910117	A mixture of fluoridated and non-fluoridated water is provided. Contact the water system for details.	0.8	0.69
	Cal-Water SC (East Los Angeles) [p]	1910036	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.59
	Cal-Water SC (Hermosa/Redondo) [p]	1910134	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.75
	Cal-Water Service Co. (Dominguez) [p]	1910033	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.71
	Cal-Water Service Co. (Palos Verdes) [o]	1910104	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.84
	City of Alhambra [p]	1910001	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Bell Gardens [p]	1910108	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Beverly Hills	1910156	Optimal fluoridation is normally provided.	0.8	0.88
	City of Burbank [p]	1910179	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.69
	City of Cerritos [p]	1910019	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Commerce [p]	1910050	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.38
	City of Compton [p]	1910026	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Covina [p]	1910127	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of El Segundo [o]	1910040	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	City of Glendale [p] (quarterly)	1910043	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.66
	City of Glendora [p]	1910044	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.54
	City of Hawthorne [p]	1910047	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.56
	City of Huntington Park [p]	1910049	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	City of Inglewood [p] (quarterly beginning Jul)	1910051	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.76
	City of Lakewood [p]	1910239	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Lomita [o]	1910073	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	City of Long Beach	1910065	Optimal fluoridation is normally provided.	0.8	0.87
	City of Los Angeles (LADWP)	1910067	Optimal fluoridation is normally provided.	0.8	0.62
	City of Lynwood [p]	1910079	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Manhattan Beach [p]	1910083	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Norwalk [p]	1910191	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.49
	City of Paramount [p]	1910105	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Pasadena [p]	1910124	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.96
	City of Pomona [p]	1910126	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of San Fernando [p]	1910143	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Santa Fe Springs [p]	1910245	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Santa Monica [p]	1910146	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.81
	City of Sierra Madre	1910148	See the water systems annual Consumer Confidence Report for information on naturally occurring fluoride levels in this water system.	N/A	0.90
	City of Signal Hill [p]	1910149	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of South Pasadena [p]	1910154	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Torrance [p]	1910213	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.95
	City of Vernon [p] (biannual)	1910167	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.43
	Crescenta Valley Water District [p]	1910028	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.45
	Foothill Municipal Water District [o]	1910032	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Golden State Water Co. (Artesia) [p]	1910004	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State Water Co. (Claremont)	1910024	[x] System does not report fluoride results; contact the water system for information on fluoride levels.	N/A	

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Golden State Water Co. (Culver City) [o]	1910030	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Golden State Water Co. (Norwalk) [p]	1910098	[z].....Optimal fluoridation is provided.	0.8	0.82
	Golden State Water Co. (San Dimas) [p]	1910142	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State Water Co. (Southwest) [p]	1910155	[z].....Optimal fluoridation is provided.	0.8	0.84
	Golden State WC (Bell, Bell Garden) [p]	1910011	[z].....Optimal fluoridation is provided.	0.8	0.73
	Golden State WC (Florence/Graham) [p]	1910077	[z].....Optimal fluoridation is provided.	0.8	0.81
	Golden State WC (Hollydale)	1910195	[z].....Optimal fluoridation is provided.	0.8	0.69
	Golden State WC (So. San Gabriel) [p]	1910223	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State WC (Willowbrook) [p]	1910072	[z].....Optimal fluoridation is provided.	0.8	0.72
	Kinneloa Irrigation District (quarterly)	1910035	See the water systems annual Consumer Confidence Report for information on naturally occurring fluoride levels in this water system.	N/A	
	La Canada Irrigation District [p]	1910054	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	LA CWWD 29 & 80 (Malibu & Marina Del Rey)	1910204	[u].....Water system receives fluoridated water from both PWSID 1910067 & PWSID 1910087 (100%). Listed Fluoride levels are the average from both systems.	0.80	
	La Habra Heights County WD [p]	1910218	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Las Flores Water Co. [p]	1910061	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.67
	Las Virgenes Municipal Water District [p]	1910225	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Lincoln Avenue Water Co. [p]	1910063	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Los Angeles CWWD 21 (Kagel Canyon) [h]	1910075	[h].....Water system receives fluoridated water from PWSID 1910067 (100%). Listed Fluoride levels are from this system.	0.80	
	Maywood Mutual Water Co. #1 [p]	1910084	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Maywood Mutual Water Co. #2 [p]	1910085	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Maywood Mutual Water Co. #3 [p]	1910086	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Mesa Crest Water Co. [o]	1910241	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Metropolitan Water District of So. Cal Central Pool	1910087	Optimal fluoridation is normally provided.	0.8	0.80
	Orchard Dale Water District [p]	1910101	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Park Water Co. (Compton) [p]	1910021	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.92
	Park Water Co. (Lynwood) [p]	1910161	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.80	0.94
	Park Water Co. (Norwalk/Bellflower)	1910211	Optimal fluoridation is normally provided.	0.8	0.92

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Rowland Water District [p]	1910194	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	
	Rubio Canon Land And Water Assn. [t]	1910140	[t]....Water system uses naturally fluoridated water sources and receives fluoridated water from PWSID 1910087.	0.8	0.81
	Suburban Water Sys (Whittier) [p]	1910174	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Suburban Water Sys. (Covina Knolls) [p]	1910200	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.41
	Suburban Water Sys. (Glendora) [p]	1910046	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.35
	Suburban Water Sys. (La Mirada) [p]	1910059	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.38
	Suburban Water Sys. (San Jose) [p]	1910205	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.34
	Valley Water Co. [p] (quarterly)	1910166	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.69
	Walnut Park Mutual Water Co. [p]	1910169	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Walnut Valley Water District [p]	1910234	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
<b>Marin</b>					
	Marin Municipal Water District	2110002	Optimal fluoridation is normally provided.	0.9	0.92
	NPS GG NRA [j]	2110350	[j]....Water system receives fluoridated water from PWSID 2110002 (100%). Listed Fluoride levels are from this system	0.9	0.92
<b>Merced</b>					
	City of Los Banos	2410005	Optimal fluoridation is normally provided.	0.8	0.90
	City of Merced	2410009	Optimal fluoridation is normally provided.	0.9	0.84
<b>Napa</b>					
	City of American Canyon [n]	2810005	[n]....Water system receives fluoridated water from PWSID 4810007 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
<b>Orange</b>					
	City of Anaheim [p]	3010001	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Brea [p]	3010002	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Buena Park [p]	3010003	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Fountain Valley	3010069	Optimal fluoridation is normally provided.	0.8	0.93
	City of Fullerton [p]	3010010	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Garden Grove [p]	3010062	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Huntington Beach	3010053	Optimal fluoridation is normally provided.	0.8	0.88
	City of La Habra [p]	3010018	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	City of La Palma [p]	3010100	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Orange [p]	3010027	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of San Clemente [p]	3010036	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of San Juan Capistrano [p]	3010030	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Santa Ana [p]	3010038	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.60
	City of Seal Beach [p]	3010041	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Tustin [p]	3010046	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Westminster [p]	3010064	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.8	0.55
	East Orange County WD (Retail Zone) [p]	3010068	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	East Orange County WD (Wholesale Zone) [o]	3010093	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	El Toro Water District [o]	3010079	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Golden State Water Co. (Placentia) [p]	3010035	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State Water Co. (West Orange-Cypres:	3010022	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State Water Co. (West Orange-Los Ala	3010022	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State Water Co. (West Orange-Stantor	3010022	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State Water Co. (Yorba Linda) [p]	3010070	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State WC (Cowan Heights) [p]	3010047	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Irvine Ranch Water District (Santiago) [p]	3010095	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Irvine Ranch Water District [p]	3010092	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.64
	Joint Regional Water Supply Sys. [o]	3010071	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Knott's Berry Farm [p]	3000734	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Laguna Beach County Water District [o]	3010017	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Mesa Consolidated WD [p]	3010004	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Moulton Niguel Water District [o]	3010073	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Orange Park Acres MWC [p]	3010028	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Santa Margarita Water District [o]	3010101	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	South Coast Water Dist. (South Coast) [o]	3010042	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	South Coast WD (Capistrano Beach) [o]	3010055	[o]....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Trabuco Canyon Water District [p]	3010094	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Yorba Linda Water District [p]	3010037	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.62
<b>Placer</b>					
	Cal-American Water Co. (West Placer) [v]	3110150	[v]....Water system receives fluoridated water from PWSID 3110008 (100%). Listed Fluoride levels are from this system	N/A	
	City of Roseville - East Train	3110008	Optimal fluoridation is normally provided.	0.8	0.73
	City of Roseville - West Train	3110008	Optimal fluoridation is normally provided.	0.8	0.75
	Placer CWA - (Bianchi Estates) [v]	3110040	[v]....Water system receives fluoridated water from PWSID 3110008 (100%). Listed Fluoride levels are from this system	N/A	
<b>Riverside</b>					
	Box Springs Mutual Water Co. [p]	3310004	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Corona [p]	3310037	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	0.30
	City of Hemet [r]	3310016	[r]....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Norco [p]	3310025	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Perris [q]	3310029	[q]....Water system receives fluoridated water from PWSID 3310009 (100%). Listed Fluoride levels are from this system.	N/A	0.00
	City of Riverside [p]	3310031	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of San Jacinto [r]	3310032	[r]....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Eastern Municipal WD	3310009	[x] System does not report fluoride results; contact the water system for information on fluoride levels.	N/A	
	Elsinore Valley Municipal WD [r]	3310012	[r]....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Elsinore Water District (Country Club) [r]	3310013	[r]....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Elsinore Water District (Lakeland) [r]	3310079	[r]....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Home Gardens County WD [p]	3310018	[p]....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Indio Water Authority	3310020	[x] System does not report fluoride results; contact the water system for information on fluoride levels.	N/A	
	Lee Lake Water District [p]	3310074	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Nuevo Water Co. [r]	3310026	[r].....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Rancho California WD [p]	3310038	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	The Farm Mutual Water Co. [r]	3310046	[r].....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Western MWD - Murrieta Division [r]	3310036	[r].....Water system receives fluoridated water from PWSID 3310009 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.80	0.71
	Western MWD (ID A - Rainbow) [o]	3310076	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.93
	Western MWD [o]	3310049	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.88
<b>Sacramento</b>					
	Cal-American Water Co. (Arden)	3410045	Optimal fluoridation is normally provided.	0.8	0.84
	Cal-American Water Co. (Parkway)	3410017	Optimal fluoridation is normally provided.	0.8	0.88
	Cal-American Water Co. (Rosemont)	3410034	See Cal-American Water Company (Suburban)	0.8	
	Cal-American Water Co. (Suburban)	3410010	Optimal fluoridation is normally provided.	0.8	0.90
	City of Sacramento	3410020	Optimal fluoridation is normally provided.	0.8	0.85
	Sacramento County WA (Arden Park Vista) {e}	3410002	[e].....Water system receives fluoridated water from PWSID 3410020 and uses non-fluoridated water sources. Contact the water system for detailed fluoride	0.8	0.56
	Sacramento County WA (Laguna/Vineyard) [e]	3410029	[e].....Water system receives fluoridated water from PWSID 3410020 and uses non-fluoridated water sources. Contact the water system for detailed fluoride	N/A	0.77
	Sacramento County WA (Mather-Sunrise) {e}	3410704	[e].....Water system receives fluoridated water from PWSID 3410020 and uses non-fluoridated water sources. Contact the water system for detailed fluoride	0.8	0.82
	Sacramento Suburban Water District -	3410001	Optimal fluoridation is normally provided.	0.8	0.87
<b>San Bernardino</b>					
	Redlands MUD	3610037	[x] System does not report fluoride results; contact the water system for information on fluoride levels.	N/A	
<b>San Diego</b>					
	Carlsbad MWD[o]	3710005	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	City of Escondido	3710006	Optimal fluoridation is normally provided.	0.8	0.81
	City of Oceanside [p]	3710014	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of San Diego [p]	3710020	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	0.7	0.77
	Fallbrook Public Utility District [o]	3710008	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Helix Water District	3710010	Optimal fluoridation is normally provided.	0.8	0.76
	Lakeside Water District [g]	3710013	[g].....Water system receives fluoridated water from both PWSID 1910087 & PWS ID 3710010, and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Olivenhain Municipal WD [p]	3710029	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	



California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Otay Water District [g]	3710034	[g].....Water system receives fluoridated water from both PWSID 1910087 & PWS ID 3710010, and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Padre Dam Municipal WD [s]	3710037	[s].....Water system receives fluoridated water from PWSID 3710010 (100%). Listed Fluoride levels are from this system.	N/A	0.76
	Rainbow MWDistrict [o]	3710016	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Ramona Municipal Water District [o]	3710019	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Rincon Del Diablo MWD (ID-1) [o]	3710018	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Vallecitos Water District [o]	3710002	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Valley Center Municipal WD [o]	3710026	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Vista Irrigation District [o]	3710027	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.8	0.80
	Yuima Municipal WD (IDA) [p]	3700938	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Yuima Municipal WD [p]	3701408	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
<b>San Francisco</b>					
	Presidio of San Francisco	3810700	Optimal fluoridation is normally provided.	1.0	1.13
	San Francisco International Airport [c]	3810010	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.0	0.76
	San Francisco Public Utility Comm. SFWS [c]	3810011	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.0	0.76
	San Francisco Regional Water Sys.	3810001	Optimal fluoridation is normally provided.	1.0	0.93
	Treasure Island [c]	3810702	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.0	0.76
<b>San Luis Obispo</b>					
	City of San Luis Obispo	4010009	Optimal fluoridation is normally provided.	0.8	0.85
<b>San Mateo</b>					
	Cal-Water Service Co. (San Carlos) [c]	4110007	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	Cal-Water Service Co. (San Mateo) [c]	4110008	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Brisbane [c]	4110002	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Burlingame [c]	4110003	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Daly City	4110013	Optimal fluoridation is normally provided.	1.0	1.00
	City of East Palo Alto [c]	4110024	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Hillsborough [c]	4110016	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Menlo Park [c]	4110017	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Millbrae [c]	4110018	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Redwood City [c]	4110022	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	Estero MID [c]	4110021	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	Guadalupe Valley MID [c]	4110005	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Mid-Peninsula Water District [c]	4110001	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	North Coast County WD [c]	4110025	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	Skyline County Water District [c]	4110015	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	Westborough County WD [c]	4110027	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
<b>Santa Barbara</b>					
	City of Santa Maria	4210011	Optimal fluoridation is normally provided.	0.9	0.92
	Vandenberg Air Force Base	4210700	Optimal fluoridation is normally provided.	0.9	0.73
<b>Santa Clara</b>					
	Cal-Water Service Co. (Bear Gulch) [i]	4110006	[i].....Water system receives fluoridated water from PWSID 3810001 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Cal-Water Service Co. (So. San Francisco) [i]	4110009	[i].....Water system receives fluoridated water from PWSID 3810001 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Milpitas [i]	4310005	[i].....Water system receives fluoridated water from PWSID 3810001 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Mountain View	4310007	Optimal fluoridation is normally provided.	0.9	0.93
	City of Palo Alto [c]	4310009	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of San Bruno [i]	4110023	[i].....Water system receives fluoridated water from PWSID 3810001 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of San Jose (Evergreen)	4310020	Optimal fluoridation is normally provided.	0.8	0.87
	City of San Jose (NSJ/Alviso) [c]	4310019	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	City of Santa Clara [i]	4310012	[i].....Water system receives fluoridated water from PWSID 3810001 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Sunnyvale [i]	4310014	[i].....Water system receives fluoridated water from PWSID 3810001 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Purissima Hills WD [c]	4310021	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
	Stanford University [c]	4310013	[c].....Water system receives fluoridated water from PWSID 3810001 (100%). Listed Fluoride levels are from this system.	1.00	0.76
<b>Solano</b>					
	City of Benicia	4810001	Optimal fluoridation is normally provided.	0.9	0.91
	City of Fairfield	4810003	Optimal fluoridation is normally provided.	0.8	0.87
	City of Vacaville	4810008	Optimal fluoridation is normally provided.	0.8	0.83
	City of Vallejo	4810007	Optimal fluoridation is normally provided.	0.9	0.96
	City of Vallejo (Travis AFB WTP)	4810015	Optimal fluoridation is normally provided.	0.9	0.97
	Travis Air Force Base	4810701	Optimal fluoridation is normally provided.	0.8	0.94
<b>Sonoma</b>					
	City of Healdsburg	4910005	Optimal fluoridation is normally provided.	0.8	0.83
	Sonoma Co. #41-Fitch Mountain [k]	4910010	[k].....Water system receives fluoridated water from PWSID 4910005 (100%). Listed Fluoride levels are from this system	0.8	0.83
	US Coast Guard Training Center Petaluma	4910701	Optimal fluoridation is normally provided.	0.9	
<b>Sutter</b>					
	City of Yuba City	5110002	Optimal fluoridation is normally provided.	0.8	0.82
<b>Ventura</b>					

California Department of Public Health  
Drinking Water Program  
2013 Annual Fluoridation Report

County	Public Water System Name	System ID	Status / Notations	Optimum Fluoride Level	Year-to-Date 2013 Average Monthly Fluoride
	Academy Mutual Water Co. [o]	5603104	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Brandeis Bardin Institute [o]	5603301	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Cal-American WC (Las Posas Estates) [o]	5610081	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Cal-American WC (Village District) [o]	5610040	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Calleguas MWD [o]	5610050	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.79
	Cal-Water Service Co. (Westlake) [o]	5610016	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.78
	Camrosa Water District [p]	5610063	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Channel Islands Beach CSD [d]	5610039	[d].....Water system receives fluoridated water from PWSID 5610080 (100%). Listed Fluoride levels are from this system.	0.90	0.92
	City of Camarillo [p]	5610019	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Oxnard [p]	5610007	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	City of Port Hueneme [d]	5610009	[d].....Water system receives fluoridated water from PWSID 5610080 (100%). Listed Fluoride levels are from this system.	0.90	0.92
	City of Thousand Oaks [o]	5610020	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Crestview Mutual Water Co. [p]	5610058	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Golden State WC (Simi Valley) [p]	5610059	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Lake Sherwood CSD [o]	5610069	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Oak Park Water Service [o]	5610043	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Pleasant Valley Mutual Water Co. [p]	5610008	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Point Mugu Naval Base [d]	5610700	[d].....Water system receives fluoridated water from PWSID 5610080 (100%). Listed Fluoride levels are from this system.	0.90	0.92
	Port Hueneme Naval Base [d]	5610701	[d].....Water system receives fluoridated water from PWSID 5610080 (100%). Listed Fluoride levels are from this system.	0.90	0.92
	Port Hueneme Water Agency	5610080	Optimal fluoridation is normally provided.	0.9	0.92
	Solano Verde Mutual Water Co. [o]	5602130	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Thermic Mutual Water Co. [p]	5603108	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	USN - Camarillo Housing [o]	5610704	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Ventura CWWD No. 1 (Moorpark) [p]	5610018	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	
	Ventura CWWD No. 17 (Bell Canyon) [o]	5610003	[o].....Water system receives fluoridated water from PWSID 1910087 (100%). Listed Fluoride levels are from this system.	0.80	0.80
	Ventura CWWD No. 19 (Somis) [p]	5610015	[p].....Water system receives fluoridated water from PWSID 1910087 and uses non-fluoridated water sources. Contact the water system for detailed fluoride level information.	N/A	

