

MCLs, DLRs, PHGs, for Regulated Drinking Water Contaminants

(Units are in milligrams per liter (mg/L), unless otherwise noted.)

Last Update: September 14, 2021

The following tables includes California's maximum contaminant levels (MCLs), detection limits for purposes of reporting (DLRs), public health goals (PHGs) from the Office of Environmental Health Hazard Assessment (OEHHA). For comparison, Federal MCLs and Maximum Contaminant Level Goals (MCLGs) (USEPA) are also displayed.

Inorganic Chemicals Table, Chemicals with MCLs in 22 CCR §64431

State Regulated Inorganic Chemical Contaminant	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Aluminum	1	0.05	0.6	2001	--	--
Antimony	0.006	0.006	0.001	2016	0.006	0.006
Arsenic	0.010	0.002	0.000004	2004	0.010	zero
Asbestos (MFL = million fibers per liter; for fibers >10 microns long)	7 MFL	0.2 MFL	7 MFL	2003	7 MFL	7 MFL
Barium	1	0.1	2	2003	2	2
Beryllium	0.004	0.001	0.001	2003	0.004	0.004
Cadmium	0.005	0.001	0.00004	2006	0.005	0.005
Chromium, Total - OEHHA withdrew the 0.0025-mg/L PHG	0.05	0.01	withdrawn Nov. 2001	1999	0.1	0.1

State Regulated Inorganic Chemical Contaminant	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Chromium, Hexavalent - 0.01-mg/L MCL & 0.001-mg/L DLR repealed September 2017	--	--	0.00002	2011	--	--
Cyanide	0.15	0.1	0.15	1997	0.2	0.2
Fluoride	2	0.1	1	1997	4.0	4.0
Mercury (inorganic)	0.002	0.001	0.0012	1999 (rev2005)*	0.002	0.002
Nickel	0.1	0.01	0.012	2001	--	--
Nitrate (as nitrogen, N)	10 as N	0.4	45 as NO3 (=10 as N)	2018	10	10
Nitrite (as N)	1 as N	0.4	1 as N	2018	1	1
Nitrate + Nitrite (as N)	10 as N	--	10 as N	2018	--	--
Perchlorate	0.006	0.002	0.001	2015	--	--
Selenium	0.05	0.005	0.03	2010	0.05	0.05
Thallium	0.002	0.001	0.0001	1999 (rev2004)	0.002	0.0005

Copper and Lead Table, 22 CCR §64672.3

Values referred to as MCLs for lead and copper are not actually MCLs; instead, they are called “Action Levels” under the lead and copper rule.

State Regulated Copper and Lead Contaminant	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Copper	1.3	0.05	0.3	2008	1.3	1.3
Lead	0.015	0.005	0.0002	2009	0.015	zero

Radiological Table, Radionuclides with MCLs in 22 CCR §64441 and §64443

[units are picocuries per liter (pCi/L), unless otherwise state; n/a = not applicable]

State Regulated Radionuclides Contaminant	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Gross alpha particle activity - OEHHA concluded in 2003 that a PHG was not practical	15	3	none	n/a	15	zero
Gross beta particle activity - OEHHA concluded in 2003 that a PHG was not practical	4 mrem/yr	4	none	n/a	4 mrem/yr	zero
Radium-226	--	1	0.05	2006		
Radium-228	--	1	0.019	2006		
Radium-226 + Radium-	5	--	--	--	5	zero

State Regulated Radionuclides Contaminant	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
228						
Strontium-90	8	2	0.35	2006	--	--
Tritium	"20,000"	"1,000"	400	2006	--	--
Uranium	20	1	0.43	2001	30 µg/L	zero

Organic Chemicals Table, Chemicals with MCLs in 22 CCR §64444

Volatile Organic Chemicals (VOCs)

State Regulated Volatile Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Benzene	0.001	0.0005	0.00015	2001	0.005	zero
Carbon tetrachloride	0.0005	0.0005	0.0001	2000	0.005	zero
1,2-Dichlorobenzene	0.6	0.0005	0.6	1997 (rev2009)	0.6	0.6
1,4-Dichlorobenzene (p-DCB)	0.005	0.0005	0.006	1997	0.075	0.075
1,1-Dichloroethane (1,1-DCA)	0.005	0.0005	0.003	2003	--	--
1,2-Dichloroethane (1,2-DCA)	0.0005	0.0005	0.0004	1999 (rev2005)	0.005	zero

State Regulated Volatile Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
1,1-Dichloroethylene (1,1-DCE)	0.006	0.0005	0.01	1999	0.007	0.007
cis-1,2-Dichloroethylene	0.006	0.0005	0.013	2018	0.07	0.07
trans-1,2-Dichloroethylene	0.01	0.0005	0.05	2018	0.1	0.1
Dichloromethane (Methylene chloride)	0.005	0.0005	0.004	2000	0.005	zero
1,2-Dichloropropane	0.005	0.0005	0.0005	1999	0.005	zero
1,3-Dichloropropene	0.0005	0.0005	0.0002	1999 (rev2006)	--	--
Ethylbenzene	0.3	0.0005	0.3	1997	0.7	0.7
Methyl tertiary butyl ether (MTBE)	0.013	0.003	0.013	1999	--	--
Monochlorobenzene	0.07	0.0005	0.07	2014	0.1	0.1
Styrene	0.1	0.0005	0.0005	2010	0.1	0.1
1,1,2,2-Tetrachloroethane	0.001	0.0005	0.0001	2003	0.1	0.1
Tetrachloroethylene (PCE)	0.005	0.0005	0.00006	2001	0.005	zero

State Regulated Volatile Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Toluene	0.15	0.0005	0.15	1999	1	1
1,2,4-Trichlorobenzene	0.005	0.0005	0.005	1999	0.07	0.07
1,1,1-Trichloroethane (1,1,1-TCA)	0.200	0.0005	1	2006	0.2	0.2
1,1,2-Trichloroethane (1,1,2-TCA)	0.005	0.0005	0.0003	2006	0.005	0.003
Trichloroethylene (TCE)	0.005	0.0005	0.0017	2009	0.005	zero
Trichlorofluoromethane (Freon 11)	0.15	0.005	1.3	2014	--	--
"1,1,2-Trichloro-1,2,2-Trifluoroethane (Freon 113)"	1.2	0.01	4	1997 (rev2011)	--	--
Vinyl chloride	0.0005	0.0005	0.00005	2000	0.002	zero
Xylenes	1.750	0.0005	1.8	1997	10	10

Non-Volatile Synthetic Organic Chemicals (SOCs)

State Regulated Non-Volatile Synthetic Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Alachlor	0.002	0.001	0.004	1997	0.002	zero

State Regulated Non-Volatile Synthetic Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Atrazine	0.001	0.0005	0.00015	1999	0.003	0.003
Bentazon	0.018	0.002	0.2	1999 (rev2009)	--	--
Benzo(a)pyrene	0.0002	0.0001	0.000007	2010	0.0002	zero
Carbofuran	0.018	0.005	0.0007	2016	0.04	0.04
Chlordane	0.0001	0.0001	0.00003	1997 (rev2006)	0.002	zero
Dalapon	0.2	0.01	0.79	1997 (rev2009)	0.2	0.2
1,2-Dibromo-3-chloropropane (DBCP)	0.0002	0.00001	0.000003	2020	0.0002	zero
2,4-Dichlorophenoxyacetic acid (2,4-D)	0.07	0.01	0.02	2009	0.07	0.07
Di(2-ethylhexyl)adipate	0.4	0.005	0.2	2003	0.4	0.4
Di(2-ethylhexyl)phthalate (DEHP)	0.004	0.003	0.012	1997	0.006	zero
Dinoseb	0.007	0.002	0.014	1997	0.007	0.007

State Regulated Non-Volatile Synthetic Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
				(rev2010)		
Diquat	0.02	0.004	0.006	2016	0.02	0.02
Endothal	0.1	0.045	0.094	2014	0.1	0.1
Endrin	0.002	0.0001	0.0003	2016	0.002	0.002
Ethylene dibromide (EDB)	0.00005	0.00002	0.00001	2003	0.00005	zero
Glyphosate	0.7	0.025	0.9	2007	0.7	0.7
Heptachlor	0.00001	0.00001	0.000008	1999	0.0004	zero
Heptachlor epoxide	0.00001	0.00001	0.000006	1999	0.0002	zero
Hexachlorobenzene	0.001	0.0005	0.00003	2003	0.001	zero
Hexachlorocyclopentadiene	0.05	0.001	0.002	2014	0.05	0.05
Lindane	0.0002	0.0002	0.000032	1999 (rev2005)	0.0002	0.0002
Methoxychlor	0.03	0.01	0.00009	2010	0.04	0.04
Molinate	0.02	0.002	0.001	2008	--	--
Oxamyl	0.05	0.02	0.026	2009	0.2	0.2

State Regulated Non-Volatile Synthetic Organic Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Pentachlorophenol	0.001	0.0002	0.0003	2009	0.001	zero
Picloram	0.5	0.001	0.166	2016	0.5	0.5
Polychlorinated biphenyls (PCBs)	0.0005	0.0005	0.00009	2007	0.0005	zero
Simazine	0.004	0.001	0.004	2001	0.004	0.004
Thiobencarb	0.07	0.001	0.042	2016	--	--
Toxaphene	0.003	0.001	0.00003	2003	0.003	zero
1,2,3-Trichloropropane	0.000005	0.000005	0.0000007	2009	--	--
2,3,7,8-TCDD (dioxin)	3x10 ⁻⁸	5x10 ⁻⁹	5x10 ⁻¹¹	2010	3x10 ⁻⁸	zero
2,4,5-TP (Silvex)	0.05	0.001	0.003	2014	0.05	0.05

Disinfection Byproducts Table, Chemicals with MCLs in 22 CCR §64533

State Regulated Disinfection Byproducts Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Total Trihalomethanes	0.080	--	--	--	0.080	--

State Regulated Disinfection Byproducts Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
Bromodichloromethane	--	0.0010	0.00006	2020	--	zero
Bromoform	--	0.0010	0.0005	2020	--	zero
Chloroform	--	0.0010	0.0004	2020	--	0.07
Dibromochloromethane	--	0.0010	0.0001	2020	--	0.06
Haloacetic Acids (five) (HAA5)	0.060	--	--	--	0.060	--
Monochloroacetic Acid	--	0.0020	--	--	--	0.07
Dichloroacetic Acid	--	0.0010	--	--	--	zero
Trichloroacetic Acid	--	0.0010	--	--	--	0.02
Monobromoacetic Acid	--	0.0010	--	--	--	--
Dibromoacetic Acid	--	0.0010	--	--	--	--
Bromate	0.010	0.0050**	0.0001	2009	0.01	zero
Chlorite	1.0	0.020	0.05	2009	1	0.8

Chemicals with PHGs established in response to DDW requests. These are not currently regulated drinking water contaminants.

State Regulated Disinfection Byproducts Contaminants	State MCL	State DLR	State PHG	State Date of PHG	Federal MCL	Federal MCLG
N-Nitrosodimethylamine (NDMA)	--	--	0.000003	2006	--	--

*OEHHA's review of this chemical during the year indicated (rev20XX) resulted in no change in the PHG.

**The DLR for Bromate is 0.0010 mg/L for analysis performed using EPA Method 317.0 Revision 2.0, 321.8, or 326.0.