STATE OF CALIFORNIA

WATER RESOURCES CONTROL BOARD

DIVISION OF DRINKING WATER

TO: Linns Valley School Water System
Water System No. 1502163

Attn: Tammy Pritchard, Principal
Linns Valley School
P. O. Box 399
Glenville, CA 93226

CERTIFIED MAIL

CITATION FOR VIOLATION OF CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1(b)(2) - WATER SYSTEM NO. 1502163

June 2016, July 2016, August 2016, November 2016

and

January 2017 and February 2017

C I T A T I O N NO. 03-19-17C-016

Issued on April 04, 2017

STATEMENT OF FACTS

Linns Valley School Water System (hereinafter Water System) is classified as a non-tranisient, non-community Water System and serves a population of approximately 106 persons through four service connections.

The Water System operates under the authority of a domestic water supply permit (No. E-97) issued on July 17, 1984, by the Kern County Environmental Health Services

COURT PAPER
STATE OF CALIFORNIA
STD. 113 (REV. 3-95)
OSP 10 119947

Department. The Water System is currently under regulatory jurisdiction of the State Water Resources Control Board (hereinafter State Board), Division of Drinking Water.

The Southern California Drinking Water Field Operations Branch, Division of Drinking Water (hereinafter Division), State Water Resources Control Board, is responsible for enforcing the Safe Drinking Water Act and regulations promulgated pursuant thereto. The Division of Drinking Water was transferred from the California Department of Public Health to the State Water Resources Control Board, effective July 1, 2014.

Section 116650 of the California Health and Safety Code authorizes the issuance of a citation to a public water system for violation of the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order issued or adopted thereunder.

The State Board, acting by and through its Division of Drinking Water and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a citation to Linns Valley School Water System (mailing address: P.O. Box 399, Glennville, CA 93226) for violation of California Code of Regulations (CCR), Title 22, Section 64426.1 subsection (b)(2).

COURT PAPER
STATE OF CALIFORNIA
STD. 113 (REV. 3-95)
OSP 10 119947

- The Water System previously failed the total coliform maximum contaminant level (MCL) in September 2015 and received Citation No. 03-19-16C-0032, on January 20, 2016, from the State Board.
- The Water System again failed the total coliform maximum contaminant level (MCL) in February 2016 and March 2016 and received Citation No. 03-19-16C-032, on May 19, 2016, from the State Board.
- Due to ongoing bacteriological quality problems, on March 9, 2016, the State Board issued a Do Not Drink Notice to the Water System which continues to be in effect until the Water System is inactivated. The Water System has received emergency funding from the State Board to physically connect to Glennville Mutual Water Company and the project is almost complete.
- The Water System collects one (1) routine distribution system bacteriological sample per month in accordance with its approved Bacteriological Sample Siting Plan.
- One (1) routine bacteriological quality samples collected on June 14, 2016, from the distribution system, tested positive for total coliform bacteria.
- Five (5) repeat bacteriological quality samples collected on June 22, 2016, from the distribution system, tested positive for total coliform bacteria.
- **Linns Valley School Water System failed the total coliform maximum contaminant level (MCL) for June 2016 [Section 64426.1(b)(2), *Authorities*].**

- One (1) repeat sample collected on June 22, 2016, from Well 01, for compliance with the Ground Water Rule, as well as the total coliform rule, tested positive for total coliform bacteria.
- Four out of five (5) special bacteriological quality samples collected on July 11, 2016, from the distribution system, tested positive for total coliform bacteria.
- One (1) bacteriological quality sample (Ground Water Rule), collected on July 11, 2016, from Well 01, tested negative for total coliform bacteria.
- **Linns Valley School Water System failed the total coliform maximum contaminant level (MCL) for July 2016 [Section 64426.1(b)(2), *Authorities*].**
- On August 1, 2016, the Water System was disinfected and flushed. Five (5) routine samples, collected on August 4, 2016, from the distribution system, showed the presence of total coliform bacteria, when analyzed by the Most Probable Number (MPN) method. One (1) sample collected on August 4, 2016, from the Water System's storage tank, tested negative for total coliform bacteria.
- **Linns Valley School Water System failed the total coliform maximum contaminant level (MCL) for August 2016 [Section 64426.1(b)(2), *Authorities*].**
- Due to widespread coliform contamination, on August 8, 2016, the State Board issued an updated Do Not Drink Notice to the Water System.

- Five (5) routine samples collected on September 13, 2016, from the distribution system, tested negative for total coliform bacteria.
- Five (5) routine samples collected on October 10, 2016, from the distribution system, tested negative for total coliform bacteria.
- Five (5) routine samples, collected on November 1, 2016, from the distribution system, showed the presence of total coliform bacteria, when analyzed by the Most Probable Number (MPN) method. Two (2) bacteriological samples collected on November 9, 2016, from Well 01 and Water System's storage tank, tested negative for total coliform bacteria.
- **Linns Valley School Water System failed the total coliform maximum contaminant level (MCL) for November 2016 [Section 64426.1(b)(2), *Authorities*].**
- One (1) out of the five (5) routine samples collected on December 15, 2016, from the distribution system, tested positive for total coliform bacteria.
- Three (3), repeat samples collected on December 8, 2016, from the distribution system, tested negative for total coliform bacteria.
- One (1) repeat sample collected on December 8, 2016, from Well 01, tested negative for total coliform bacteria.
- Five (5) routine samples, collected on January 17, 2017, from the distribution system, tested positive for total coliform bacteria.
- **Linns Valley School Water System failed the total coliform maximum contaminant level (MCL) for January 2017 [Section 64426.1(b)(2), *Authorities*].**

COURT PAPER
STATE OF CALIFORNIA
STD. 113 (REV. 3-95)
OSP 10 119947

- Four (4) out of the five (5) routine samples, collected on February 15, 2017, from the distribution system, tested positive for total coliform bacteria.
- **Linns Valley School Water System failed the total coliform maximum contaminant level (MCL) for February 2017 [Section 64426.1(b)(2), *Authorities*].**
- After connecting to Glennville MWC, the Water System collected six (6) special samples from the distribution system, on February 21, 2017, and all six samples tested negative for total coliform bacteria.
- A second round of bacteriological sampling, consisting of five (5) samples, was conducted on March 13, 2017, and all five samples tested negative for total coliform bacteria.
- None of the above-mentioned total coliform positive samples, collected between June 2016 and February 2017, from the distribution system or the system well, tested positive for *E.coli* bacteria.
- Above-mentioned total coliform positive samples may be attributed to Well 01, storage tank, and/or distribution system. A Level 1 Assessment for the total coliform treatment technique trigger (under the revised total coliform rule), in June 2016, was completed by Scott More, certified distribution operator of the Water System, and is available on file. As discussed above, the Water System has recently connected to Glennville Mutual Water Company and is in the process of being inactivated. Well 01, existing storage tank and distribution piping are no longer being used for domestic supply. A new distribution system has been installed.

COURT PAPER
STATE OF CALIFORNIA
STD. 113 (REV. 3-95)
OSP 10 119947

- Results of all (source and distribution) bacteriological samples collected from January 2016 to March 2017 are summarized in **Attachment A.**

AUTHORITIES

Section 116577 of the CHSC, states in relevant part:
"(a) Each public water system shall reimburse the State Board for the actual costs incurred by the State Board for any of the following enforcement activities related to that water system:
(1) Preparing, issuing, and monitoring compliance with, an order or citation.
(2) Preparing, and issuing public notification
...
(b) The State Board shall submit an invoice for these enforcement costs to the public water system that requires payment prior to September 1 of the fiscal year following the fiscal year in which the costs were incurred. The invoice shall indicate the total hours expended, the reasons for the expenditure, and the hourly cost rate of the State Board. The costs set forth in the invoice shall not exceed the total actual costs to the State Board of the enforcement activities specified in this section."...

Section 116650 of the CHSC, states in relevant part:
"(a) If the State Board determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the State Board may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
(c) A citation may specify a date for elimination or correction of the condition constituting the violation.
(d) A citation may include the assessment of a penalty as specified in subdivision (e).
(e) The department may assess a penalty in an amount not to exceed one thousand dollars ($1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation."

Section 116655 of the CHSC, states in relevant part:
"(a) Whenever the State Board determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:
(1) Directing compliance forthwith.
(2) Directing compliance in accordance with a time schedule set by the State Board.
(3) Directing that appropriate preventive action be taken in the case of a threatened violation.
(b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:
(1) That the existing plant, works, or system be repaired, altered, or added to.
(2) That purification or treatment works be installed.
(3) That the source of the water supply be changed.
(4) That no additional service connection be made to the system.
(5) That the water supply, the plant, or the system be monitored.
(6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the State Board."

California Code of Regulations (hereinafter, CCR), Title 22, Section 64423, Table 64423-A establishes the minimum routine sampling requirements, and states in relevant part:

Monthly Population Served	*Service Connections*	*Minimum Number of Samples*
25 to 1000	15 to 400	1 per month
1,001 to 2,500	401 to 890	2 per month
2,501 to 3,300	891 to 1,180	3 per month
3,301 to 4,100	1,181 to 1,460	4 per month
4,101 to 4,900	1,461 to 1,750	5 per month
4,901 to 5,800	1,751 to 2,100	6 per month
5,801 to 6,700	2,101 to 2,400	7 per month
6,701 to 7,600	2,401 to 2,700	2 per week
7,601 to 12,900	2,701 to 4,600	3 per week
12,901 to 17,200	4,601 to 6,100	4 per week
17,201 to 21,500	6,101 to 7,700	5 per week
21,501 to 25,000	7,701 to 8,900	6 per week
25,001 to 33,000	8,901 to 11,800	8 per week
33,001 to 41,000	11,801 to 14,600	10 per week
41,001 to 50,000	14,601 to 17,900	12 per week
50,001 to 59,000	17,901 to 21,100	15 per week

CCR, Title 22, Section 64424 establishes the repeat sampling requirements, and states in relevant part:

"(a) If a routine sample is total coliform-positive, the water supplier shall collect a repeat sample set as described in paragraph (a)(1) within 24 hours of being notified of the positive result. The repeat samples shall all be collected within the same 24 hour time period. A single service connection system may request that the State Board allow the collection of the repeat sample set over a four-day period.

(1) For a water supplier that normally collects more than one routine sample a month, a repeat sample set shall be at least three samples for each total coliform-positive sample. For a water supplier that normally collects one or fewer samples per month, a repeat sample set shall be at least four samples for each total coliform-positive sample.

(2) If the water supplier is unable to collect the samples within the 24-hour time period specified in subsection (a) or deliver the samples to the laboratory within the 24 hours after collection because of circumstances beyond its control, the water supplier shall notify the State Board within 24 hours. The State Board will then determine how much time the supplier will have to collect the repeat samples.

(b) When collecting the repeat sample set, the water supplier shall collect at least one repeat sample from the sampling tap where the original total coliform-positive sample was taken. Other repeat samples shall be collected within five service connections upstream or downstream unless there is no upstream and/or downstream service connection.

(c) If one or more samples in the repeat sample set is total-coliform positive, the water supplier shall collect and have analyzed an additional set of repeat samples as specified in subsections (a) and (b). The supplier shall repeat this process until either no coliforms are detected in one complete repeat sample set or the supplier determines that the MCL for total coliforms specified in 64426.1 has been exceeded and notifies the State Board."

CCR, Title 22, Section 64426.1 establishes the total coliform maximum contaminant level and states in relevant part:

"(a) Results of all samples collected in a calendar month pursuant to Sections 64423, 64424, and 64425 that are not invalidated by the State Board or the laboratory shall be included in determining compliance with the total coliform MCL. Special purpose samples such as those listed in 64421(b) and samples collected by the water supplier during special investigations shall not be used to determine compliance with the total coliform MCL.

(b) A public water system is in violation of the total coliform MCL when any of the following occurs:

(1) For a public water system which collects at least 40 samples per month, more than 5.0

percent of the samples collected during any month are total coliform-positive; or
(2) For a public water system with collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or
(3) Any repeat sample is fecal coliform-positive or E. coli-positive; or
(4) Any repeat sample following a fecal coliform-positive or E. coli-positive routine sample is total coliform-positive.

DETERMINATIONS

Based upon the above Statement of Facts and Authorities, the State Board has determined that the Linns Valley School Water System has violated the following:

1. CCR, Title 22, Section 64426.1(b)(2); Specifically, the Water System violated the total coliform MCL for the months of June 2016, July 2016, August 2016, November 2016, January 2017, and February 2017, when more than one samples during the above-mentioned months, tested positive for total coliform bacteria.

The above violations are classified as non-continuing violations.

DIRECTIVES

Linns Valley School Water System is hereby directed to take the following actions:

1. Cease and desist from failing to comply with Section 116555(a) of the California Health and Safety Code (CHSC) and Section 64426(b)(2), of Title 22, California Code of Regulations.

2. The Water System shall not use any water from Well 01 for domestic supply and keep Well 01 physically isolated from the domestic water supply system. The existing storage tank of the Water System shall also be kept isolated from the domestic water supply system. Only water supplied by Glennville Mutual Water Company shall be used for domestic supply.

3. The Water System shall reimburse the State Board, in accordance with an invoice that shall be provided to the Water System, the costs for enforcement activities, and such reimbursement shall be made prior to September 1 (or by a different date if specified by the State Board) of the fiscal year following the fiscal year in which such costs are incurred as described in CHSC Sections 116577(a)(1-2) and 116577(b).

FURTHER ENFORCEMENT ACTIONS

Section 116270, Chapter 4, Part 12, Division 104 of the CHSC authorizes the State Board to: issue additional citations with assessment of penalties if a public water system continues to fail or correct a violation identified in a citation; take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with orders of the State Board; and petition the superior court to take various enforcement measures against a public water system that has failed to comply with orders of the State Board. The State Board does not waive any further enforcement action by issuance of this citation.

COURT PAPER
STATE OF CALIFORNIA
STD. 113 (REV. 3-95)
OSP 10 119947

PARTIES BOUND

This citation shall apply to and be binding upon Linns Valley School Water System, its officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The directives of this citation are severable, and Linns Valley School Water System shall comply with each and every provision thereof, notwithstanding the effectiveness of any other provision.

CIVIL PENALTIES

Section 116650, subsections (d) and (e) of the CHSC allow for the assessment of a civil penalty for failure to comply with the requirements of the Safe Drinking Water Act. Failure to comply with any provision of this Citation may result in the State Board imposing an administrative penalty in an amount not to exceed $1000 (one thousand dollars) per day as of the date of violation of any provision of this Citation.

April 4, 2017
Date

Jaswinder S. Dhaliwal, P.E.
Senior Sanitary Engineer
Drinking Water Field Operations Branch

Certified Mail No. 7015 1520 0000 4433 2058

ATTACHMENT

Attachment A: Summary of Bacteriological Samples Collected from January 2016 – March 2017

CC: Kern County Dept. of Public Health, Env. Health Services Division (w/o attachment)
Scott Moore, Seaco Technologies, Inc., Certified Distribution Operator (via email)

Attachment A

Linns Valley School

1502163

Distribution System Freq: 1/M

Sample Date	Time	Location	T Coli	E Coli	F Coli	Type	Cl2	Violation	Comment
1/7/2016	10:34	Classroom #1	A	A		Routine	2.04		
2/8/2016	11:20	Classroom #1 (SF	P	A		Routine			
2/8/2016	11:24	Classroom #5 (SF	P	A		Routine		TC MCL	Cit #03-19-16C-032 issued 5/19/2016.
2/8/2016	11:33	254 White River (	P	A		Routine			
2/8/2016	11:40	230 White River (	P	A		Routine			
2/8/2016	11:48	117 Dunlap (HB	P	A		Routine			
2/10/2016	12:12	Storage Tank (SP)	94	A		Repeat			
2/16/2016	11:22	Storage Tank (SP)	1.0	<1		Repeat			
2/16/2016	11:28	Kitchen (SF)	<1	<1		Repeat			
2/16/2016	11:35	Classroom #1 (SF	1.0	<1		Repeat			
2/16/2016	11:40	Classroom #5 (SF	2.0	<1		Repeat			
2/16/2016	11:51	230 White River (	1.0	<1		Repeat			
2/16/2016	11:58	254 White River (	2.0	<1		Repeat			
2/16/2016	12:04	117 Dunlap (HB)	1.0	<1		Repeat			
3/7/2016	11:56	Classroom #1 (SF	P	A		Other			
3/7/2016	12:08	Classroom #5 (SF	P	A		Other		TC MCL	Citation # 03-19-16C-032 issued 5/19/2016.
3/7/2016	12:23	254 White River (	P	A		Other			
3/7/2016	12:30	230 White River (	P	A		Other			
3/7/2016	12:36	117 Dunlap (HB)	P	A		Other			
3/15/2016	11:37	Storage Tank (HB)	<1	<1		Other			
3/15/2016	11:44	Classroom #1 (SF	<1	<1		Other			
3/15/2016	11:47	Classroom #5 (SF	<1	<1		Other			
3/15/2016	11:54	117 Dunlap (HB)	<1	<1		Other			
3/15/2016	12:08	254 White River (	<1	<1		Other			
3/15/2016	12:12	230 White River (	<1	<1		Other			
3/23/2016	9:50	Classroom #5 (SF	P	A		Other			
3/23/2016	9:52	Classroom #1 (SF	P	A		Other			
3/23/2016	10:00	117 Dunlap (HB)	P	A		Other			
3/23/2016	10:10	254 White River	P	A		Other			
3/23/2016	10:14	230 White River (	P	A		Other			
3/29/2016	9:14	Classroom #1 (SF	A	A		Other			
3/29/2016	9:18	Classroom #5 (SF	A	A		Other			
3/29/2016	9:21	Storage Tank (HB)	A	A		Routine			
3/29/2016	9:31	254 White River (	A	A		Other			
3/29/2016	9:36	230 White River (	P	A		Other			

Sample Date	Time	Location	T Coli	E Coli	F Coli	Type	Cl2	Violation	Comment
3/29/2016	9:42	117 Dunlap (HB)	P	A		Other			
4/11/2016	9:55	Classroom #1 (SF	<1	<1		Other			
4/11/2016	9:58	Classroom #5	<1	<1		Other			
4/11/2016	10:02	Storage Tank (HB)	<1	<1		Other			
4/11/2016	10:24	254 White River	<1	<1		Other			
4/11/2016	10:29	230 White River	<1	<1		Other			
4/11/2016	10:37	117 Dunlap	<1	<1		Routine			
4/18/2016	9:28	Classroom #1 (SF	27	<1		Other			
4/18/2016	9:34	Classroom #5 (SF	21	<1		Other			
4/18/2016	9:42	Storage Tank (HB)	24	<1		Other			
4/18/2016	9:57	254 White River (	36	<1		Other			
4/18/2016	10:04	230 White River (	27	<1		Other			
4/18/2016	10:12	117 Dunlap (HB)	19	<1.1		Other			
5/11/2016	10:10	117 Dunlap	A	A		Routine			
5/11/2016	10:10	117 Dunlap	A	A		Routine	0		
6/14/2016	11:08	Classroom #1	P	A		Routine	0		
6/22/2016	11:51	Classroom #5	P	A		Repeat	0	TC MCL	Cit. #03_19_17C_016 issued.
6/22/2016	11:54	Classroom #1	P	A		Repeat	0		
6/22/2016	12:14	230 White River	P	A		Repeat	0		
6/22/2016	12:20	254 White River	P	A		Repeat	0		
6/22/2016	12:28	117 Dunlap	P	A		Repeat	0		
7/11/2016	11:15	Classroom #1	A	A		Routine	0		
7/11/2016	11:17	Classroom #5	A	A		Routine	0		
7/11/2016	11:36	230 White River	P	A		Routine	0	TC MCL	Cit. #03_19_17C_016 issued.
7/11/2016	11:40	254 White River	P	A		Routine	0		
7/11/2016	11:48	117 Dunlap	P	A		Routine	0		
7/25/2016	11:25	Mgrs Office	P	A		Routine	0		
7/25/2016	11:27	RM #7	P	A		Routine	0		
7/25/2016	11:31	RM #14	A	A		Routine	0		
7/25/2016	11:33	RM #17	P	A		Routine	0		
7/25/2016	11:38	Pool Area	P	A		Routine	0		
8/4/2016	10:22	117 Dunlap	2.0	A		Routine	0		
8/4/2016	10:51	Room #1	1.0	A		Routine	0		
8/4/2016	10:51	Room #5	4.2	A		Routine	0		
8/4/2016	11:05	254 White River	2.0	A		Routine	0	TC MCL	Cit. #03_19_17C_016 issued.
8/4/2016	11:12	230 White River	2.0	A		Routine	0		
9/13/2016	11:30	117 Dunlap	A	A		Routine	0		
9/13/2016	11:37	Classroom #1	A	A		Routine	0		

Sample Date	Time	Location	T Coli	E Coli	F Coli	Type	Cl2	Violation	Comment
9/13/2016	11:40	Classroom #5	A	A		Routine	0		
9/13/2016	11:47	254 White River	A	A		Routine	0		
9/13/2016	11:54	230 White River	A	A		Routine	0		
10/10/2016	10:56	117 Dunlap	A	A		Routine	0		
10/10/2016	11:07	254 White River	A	A		Routine	0		
10/10/2016	11:13	230 White River	A	A		Routine	0		
10/10/2016	11:21	Classroom #1	A	A		Routine	0		
10/10/2016	11:26	Classroom #5	A	A		Routine	0		
11/1/2016	11:37	117 Dunlap	25	A		Routine	0		
11/1/2016	11:46	230 White River	34	A		Routine	0		
11/1/2016	11:50	254 White River	27	A		Routine	0		
11/1/2016	11:57	Classroom #1	18	A		Routine	0		
11/1/2016	12:02	Classroom #5	22	A		Routine	0	TC MCL	Cit. #03_19_17C_016 issued.
11/9/2016	10:20	Storage Tank	A	A		Repeat			
12/5/2016	10:45	117 Dunlap	<1.1	<1.1		Routine			
12/5/2016	10:52	230 White River	<1.1	<1.1		Routine			
12/5/2016	10:55	254 White River	1.0	<1.1		Routine			
12/5/2016	11:07	Classroom #5	<1.1	<1.1		Routine			
12/5/2016	11:11	Classroom #1	<1.1	<1.1		Routine			
12/8/2016	9:21	254 White River	<1.1	<1.1		Repeat			
12/8/2016	9:26	230 White River	<1.1	<1.1		Repeat			
12/8/2016	9:40	Classroom #5	<1.1	<1.1		Repeat			
1/17/2017	12:35	117 Dunlap	P	A		Routine			
1/17/2017	12:41	254 White River	P	A		Routine			
1/17/2017	12:50	230 White River	P	A		Routine			
1/17/2017	12:57	Classroom #5	P	A		Routine			
1/17/2017	13:02	Classroom #1	P	A		Routine		TC MCL	Cit. #03_19_17C_016 issued.
2/15/2017	10:25	117 Dunlap	P	A		Routine	0		
2/15/2017	10:37	230 White River	P	A		Routine	0		
2/15/2017	10:40	254 White River	A	A		Routine	0		
2/15/2017	10:49	Classroom #5	P	A		Routine	0		
2/15/2017	10:52	Classroom #1	P	A		Routine	0	TC MCL	Cit. #03_19_17C_016 issued.
2/21/2017		6 Samples	A	A		Special			Samples collected after connecting to Glennville MWC
3/13/2017		5 Samples	A	A		Other			Second round of samples collected after connecting to Glennville MWC

Linns Valley School

1502163

Source Monitoring Freq:

Sample Date	Time	Source	T Coli	E Coli	F Coli	Violation	Comment
2/2/2016	11:12	Well 001/ Other	<1	<1			
2/10/2016	12:04	Well 001/Repeat	3.1	A			GWR & TCR Repeat
3/7/2016	12:00	Well 001/Other	4.2	<1			GWR
3/15/2016	11:35	Well 001/Other	<1	<1			
3/24/2016	11:00	Well 001/Routine	A	A			
4/11/2016	10:05	Well #01	<1	<1			
4/18/2016	9:40	Well #01 (SP)	<1	<1			
6/22/2016	12:03	Well #001 / Repeat	P	A			
7/11/2016	11:25	Well #001 / Routine	A	A			
8/4/2016	10:39	Storage Tank / Special	A	A			
11/9/2016	10:18	Well 001 / Repeat	A	A			
12/8/2016	9:45	Well 001 / Repeat	<1.1	<1.1			