COUNTY OF MONTEREY
HEALTH DEPARTMENT
Elsa Jimenez, Director of Health

Administration
Behavioral Health

Clinic Services
Emergency Medical Services
Environmental Health/Animal Services

Public Health
Public Administrator/Public Guardian

December 16, 2016

Arroyo Seco Recreation Area Water System
ATTN: Adam Furlow, U.S. Forest Service
406 South Mildred
King City, CA 93930

CITATION LETTER, CITATION #16-025
Arroyo Seco Recreation Area WS, I. D. No. 2701166

Coliform Bacteria MCL Violations for **November 2016**
Transient Non-Community Water System

Dear Mr. Furlow,

Section 116650, Chapter 4 of Part 12 of the California Health and Safety Code (CHSC) authorizes the issuance of a citation for failure to comply with a requirement of Chapter 4 (California Safe Drinking Water Act), or any regulation, standard permit, or order issued thereunder. The Monterey County Health Department, Environmental Health Bureau (hereinafter EHB) under its Delegation agreement with the State Water Resources Control Board and pursuant to Section 116650 of CHSC, hereby issues this citation to the Mesa del Toro WS (hereinafter Water System) for violation of CHSC, Section 116555(a)(1) and Title 22, California Code of Regulations (hereinafter "CCR"), Sections 64426.1(b)(2). Specifically:

1. The Water System was in violation of the Total Coliform Maximum Contaminant Level (MCL) set forth in Section 64426.1(b)(2), Title 22, CCR for the month of November 2016. Specifically;
    a. In October 2016, 2 of the 5 samples collected were total coliform positive.

History
On November 8, 2016, the Water System notified EHB and the water system users that the water system failed the total coliform MCL. The Water System disinfected the system and started an investigation. The investigation indicated the cause may have been that the screens on the tanks were larger that recommended and the water system is working to replace the screens. Follow-up sample in December met standards.

Directives
Pursuant to Section 116655 of the Health and Safety Code, the EHB hereby orders Mesa del Toro WS to do the following to ensure the water supplied by the Water System shall at all times be pure, wholesome, potable, and healthful:

1. The Water System shall comply with Section 64426.1, Title 22, CCR in all future monitoring periods.

All submittals required by this order shall be addressed to:

Environmental Health Bureau
1270 Natividad Road
Salinas, CA 93906-3198

EHB reserves the right to make such modifications to this Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of the California SDWA (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or order issued or adopted thereunder.

Parties Bound
This Citation shall apply to and be binding upon the Water System, its owners, shareholders, officers, directors, agents, employees, contractors, successors, and assignees.

Severability
The directives of this Citation are severable, and the Water System shall comply with each and every provision thereof notwithstanding the effectiveness of any provision.

Further Enforcement Action
The California SDWA authorizes EHB under its delegation agreement with SWRCB to: issue a citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any regulation, permit, standard, citation, or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes EHB to take action to suspend or revoke a permit that has been issued to a public water system if the public water system has violated applicable law or regulations or has failed to comply with an order of EHB, and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order of EHB. EHB does not waive any further enforcement action by issuance of this

If you have any questions, please contact me at (831)755-8924 or ayalasa@co.monterey.ca.us.

Sincerely,

Sandy Ayala

Sandy Ayala, REHS
Senior Environmental Health Specialist

Monterey County Health Department, Environmental Health Bureau
Bacteriological Monitoring Requirements

Flow Chart



DETAILS (See Title 22, California Code of Regulations)

Sampling Frequency-Routine Samples (section 64423)

Community and Nontransient-Noncommunity water system - minimum of one sample per month
Transient-Noncommunity water system – groundwater-minimum of one sample per quarter, except one sample per month in which 1,000 or more persons can be served by the water system
Transient-Noncommunity water system – surface water-minimum of one sample per month
If any samples are E.coli positive, the water system must notify EHB immediately.

Repeat Sampling Requirements – Required when Routine Sample is total coliform positive

The water system must require the laboratory to notify the system within 24 hours whenever any coliforms are present in a sample. A repeat sample set must be collected by the system within 24 hours of notification. This set must consist of at least four samples for each total coliform-positive sample and be collected in accordance with an approved sample siting plan. Generally, repeat samples shall be collected from:

- the site of the original positive (required),
- the well,
- the storage tank(s),
- another point in the distribution system within 5 service connections of the original positive
- Goundwater systems must sample each source-sample may count towards 1 repeat sample
- If well is E. coli/fecal positive, contact EHB within 24 hrs for New Groundwater rule guidance

This collection scheme is designed to identify the origin of the contamination. Systems with multiple wells and tanks may sample within 5 service connections upstream and downstream of the original positive or from combined well and tank taps, if available.

The samples shall be collected prior to disinfection of the water system and the water system shall be inspected by the water system during the sampling to identify any potential causes of the original positive sample. Chlorine residual readings shall be analyzed and reported for all repeat samples.

Maximum Contaminant Level Exceedence (MCL) (64426.1)

If one or more samples in the repeat sample set are total coliform-positive, the water system has exceeded the MCL for coliform bacteria and must notify this office within 24 hours. The system must investigate the cause of the positive samples and continue to collect a set of repeat samples until one set has no coliform positive samples. The system must also submit a report of findings including the following (64426):

- Current operating procedures that are or could potentially be related to the increase in bacterial count, such as main repairs or well work conducted without disinfection,
- System pressure loss to less than 5 psi,
- Potential cross connections,
- Physical evidence indicating bacteriological contamination of facilities (such as openings in the well casing, storage tank or evidence of animal activity in the vicinity of the well),
- Analytical results of any additional investigative samples collected, including well samples,
- residents' illness suspected of being waterborne.
- Records of the investigation and any action taken.

Follow-up Sampling
The water system must collect five routine samples the month following any total coliform sample (64424). May be waived if the Department conducts a site visit and determines why the sample(s) were positive and established that the problem has been corrected.

Additional Sampling Requirements
Samples for bacteriological testing must also be collected whenever either of the following conditions apply:
- loss of water pressure below 5 psig within the distribution system
- upon completion of construction, installation, or repair of wells, water mains, or storage facilities.

Samples are to be collected in accordance with an approved Sample Siting Plan (SSP). The sample must be tested by a laboratory certified by the State of California. The water system must direct the laboratory to submit copies of all required bacteriological monitoring directly to this office by the tenth day of the following month.

Collecting Bacteriological Water Samples

Collect samples at cold water faucets that are free of contaminating devices such as screens, aeration devices, hoses, point-of-use devices, or swiveled faucets. To prevent contamination, do not obtain samples from taps that leak around the valve stem and allow water to flow over the outside of the tap. Faucets must be high enough to put the bottle underneath without contacting the mouth of the container with the faucet.

Taking the sample:
1. Open the faucet and thoroughly flush the line for at least two to five minutes. The longer the water runs the better the chance of flushing out bacteria that may be in the building plumbing.
2. Reduce the flow until the water leaving the tap has a continuous, gentle flow without any turbulence.
3. Sterile containers provided by your laboratory must be used. Do not rinse the bottle prior to taking the sample. The powder in the bottle is sodium thiosulfate which inactivates any chlorine-based disinfectant. Be sure this substance stays in the bottle.
4. Remove the cap from the sample bottle and keep it in your hand facing down. Do not touch the inside of the cap or the bottle's inner surface as these actions can contaminate the sample.
5. Carefully place the sample bottle under the running water. Fill the bottle just to the fill-line; do not overfill the sample bottle or allow the water to splash.
6. Quickly replace the cap on the bottle and label the sample clearly. If samples cannot be delivered to the lab immediately, place samples in a cooler with cold packs. If ice is used, at no time should the sample container be immersed or submerged in the ice or melted ice water. The sample must be delivered to the laboratory within 24 hours from the time of collection.