**State Water Resources Control Board**
Division of Drinking Water

May 16, 2018

System No. 5400810

Mr. Yad Virk, Owner
Akal Travel Plaza
Rt 1 973-2
Delano, CA 93215

**CITATION NO. 03-24-18C-058**
**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION**
**FOR April 2018**

Enclosed is a Citation issued to the Akal Travel Plaza (hereinafter "Water System") public water system.

The Water System will be billed at the State Water Resources Control Board's (hereinafter "State Board") hourly rate (currently estimated at $167) for the time spent on issuing this Citation. California Health and Safety Code, Section 116577, provides that a public water system must reimburse the State Board for actual costs incurred by the State Board for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation. At this time, the State Board has spent approximately one hour on enforcement activities associated with this violation.

The Water System will receive a bill sent from the State Board in August of the next fiscal year. This bill will contain fees for any enforcement time spent on the Water System for the current fiscal year.

Any person who is aggrieved by a citation, order or decision issued by the Deputy Director of the Division of Drinking Water under Article 8 (commencing with Health and Safety Code, Section 116625) or Article 9 (commencing with Health and Safety Code, Section 116650), of the Safe Drinking Water Act (Chapter 4, Part 12, Division 104, of the Health and Safety Code), may file a petition with the State Water Board for reconsideration of the citation, order or decision. Appendix 1 to the enclosed Citation contains the relevant statutory provisions for filing a petition for reconsideration (Health and Safety Code, Section 116701).

Petitions must be received by the State Water Board within 30 days of the issuance of the citation, order or decision by the Deputy Director. The date of issuance is the date when the Division of Drinking Water mails a copy of the citation, order or decision. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day by 5:00 p.m.

Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact Tulare District Staff at (559) 447-3300 or by email at dwpdist24@waterboards.ca.gov.

Sincerely,

Chad Fischer, P.E.
Senior Sanitary Engineer, Tulare District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

Certified Mail No.: 7018 0040 0000 3159 6547

cc: Tulare County Environmental Health Department
Mr. Tom Day, Contract Operator (P.O. Box 10642, Terra Bella, CA 93270)

03_24_18C_056_5400810_MB

**Citation No. 03-24-18C-058**

STATE OF CALIFORNIA

STATE WATER RESOURCES CONTROL BOARD

DIVISION OF DRINKING WATER

**Name of Public Water System:** Akal Travel Plaza

**Water System No:** 5400810

**Attention:** Mr. Yad Virk, Owner
Rt 1 973-2
Delano, CA 93215

**Issued:** May 16, 2018

**CITATION FOR NONCOMPLIANCE WITH**

**CALIFORNIA HEALTH AND SAFETY CODE, SECTION 116555(a)(1) AND**

**CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1**

**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION**

**April 2018**

The California Health and Safety Code (hereinafter "CHSC"), Section 116650 authorizes the State Water Resources Control Board (hereinafter "State Water Board"), to issue a citation to a public water system when the State Water Board determines that the public water system has violated or is violating the California Safe Drinking Water Act (hereinafter "California SDWA"), (CHSC, Division 104, Part 12, Chapter 4, commencing

with Section 116270), or any regulation, standard, permit, or order issued or adopted thereunder.

The State Water Board, acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division, hereby issues Citation No. 03-24-18C-058 (hereinafter "Citation"), pursuant to Section 116650 of the CHSC to the Akal Travel Plaza (hereinafter "Water System"), for violation of CHSC, Section 116555(a)(1) and California Code of Regulations (hereinafter "CCR"), Title 22, Section 64426.1.

A copy of the applicable statutes and regulations are included in Appendix 1, which is attached hereto and incorporated by reference.

## STATEMENT OF FACTS

The Water System is classified as a transient-noncommunity public water system with a population of 200, serving three service connections. The Water System operates under a Domestic Water Supply Permit No. 03-24-17P-057 issued by the Division on May 31, 2017.

CHSC, Section 116555(a)(1) requires all public water systems to comply with primary drinking water standards as defined in CHSC, Section 116275(c). Primary drinking water standards include maximum levels of contaminants and the monitoring and reporting requirements as specified in regulations adopted by the State Water Board that pertain to maximum contaminant levels.

CCR, Title 22, Section 64426.1, Total Coliform Maximum Contaminant Level (hereinafter "MCL"), states that a public water system is in violation of the total coliform MCL if it collects fewer than 40 bacteriological samples per month and if more than one sample collected during any month is total coliform-positive.

The State Water Board received laboratory results for nine bacteriological samples collected during April 2018 from the Water System. All samples were analyzed for the presence of total coliform bacteria. Two of the nine samples analyzed were positive for total coliform bacteria. None of the total coliform positive samples showed the presence of fecal coliform or *Escherichia coli (E. coli)* bacteria.

## DETERMINATION

The Water System took fewer than 40 bacteriological samples during April 2018. The results of two routine samples were total coliform positive. Therefore, the State Water Board has determined that the Water System has failed to comply with drinking water standards pursuant to CHSC, Section 116555(a)(1) and CCR, Title 22, Section 64426.1 during April 2018.

## DIRECTIVES

The Water System is hereby directed to take the following actions:

1. Comply with CCR, Title 22, Section 64426.1, in all future monitoring periods.

2. On or before **June 15, 2018,** notify all persons served by the Water System of the violation of CCR, Title 22, Section 64426.1, in conformance with Sections 64463.4(b) and (c) and 64465. Copies of Sections 64463.4 and 64465 are included in Appendix 1. Appendix 2: Notification Template shall be used to fulfill this Directive, unless otherwise approved by the State Water Board. The notification shall be completed in accordance with the following:

   - Posting of the Public Notification in conspicuous places within the area served by the water system. The notice shall remain posted for a minimum of seven (7) consecutive days and;

- By one of the following secondary methods to reach persons not likely to be reached by posting;

  - By publication in a local newspaper or newsletter distributed to customers, by internet posting of the notice or by direct delivery to each customer served by the Water System. If the water system opts to issue the notice via internet website, the public notice shall remain posted for a minimum of seven (7) consecutive days.

3. Complete Appendix 3: Compliance Certification Form. Submit it together with a copy of the public notification required by Directive 2 to the State Water Board on or before **June 15, 2018.**

4. On or before **June 15, 2018**, complete and return to the State Water Board the "Notification of Receipt" form attached to this Citation as Appendix 4. Completion of this form confirms that the Water System has received this Citation and understands that it contains legally enforceable directives(s) with due dates.

All submittals required by this Citation shall be electronically submitted to the State Water Board at the following address. The subject line for all electronic submittals corresponding to this Citation shall include the following information: Water System name and number, citation number and title of the document being submitted.

Chad Fischer, P.E.

dwpdist24@waterboards.ca.gov

The State Water Board reserves the right to make such modifications to this Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of the California SDWA (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or order issued or adopted thereunder.

## PARTIES BOUND

This Citation shall apply to and be binding upon the Water System, its owners, shareholders, officers, directors, agents, employees, contractors, successors, and assignees.

## SEVERABILITY

The directives of this Citation are severable, and the Water System shall comply with each and every provision thereof notwithstanding the effectiveness of any provision.

## FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the State Water Board to: issue a citation or order with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any regulation, permit, standard, citation, or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the State Water Board to take action to suspend or revoke a permit that has been issued to a public water system if the public water system has violated applicable law or regulations or has failed to comply with an order of the State Water Board, and to petition the superior court to take various enforcement measures against a public water

system that has failed to comply with an order of the State Water Board. The State Water Board does not waive any further enforcement action by issuance of this Citation.

5/16/18

Chad Fischer, P.E.
Senior Sanitary Engineer, Tulare District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

Date

Appendices (4):

1. Applicable Statutes and Regulations
2. Notification Template
3. Compliance Certification Form
4. Notification of Receipt Form

Certified Mail No. 7018 0040 0000 3159 6547

**APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS FOR CITATION NO. 03-24-18C-058**
**Total Coliform Maximum Contaminant Level Violation**

*NOTE: The following language is provided for the convenience of the recipient, and cannot be relied upon as the State of California's representation of the law. The published codes are the only official representation of the law. Regulations related to drinking water are in Titles 22 and 17 of the California Code of Regulations. Statutes related to drinking water are in the Health & Safety Code, the Water Code, and other codes.*

**California Health and Safety Code (CHSC):**

**Section 116271 states in relevant part**:
(a) The State Water Resources Control Board succeeds to and is vested with all of the authority, duties, powers, purposes, functions, responsibilities, and jurisdiction of the State Department of Public Health, its predecessors, and its director for purposes of all of the following:

(1) The Environmental Laboratory Accreditation Act (Article 3 (commencing with Section 100825) of Chapter 4 of Part 1 of Division 101).
(2) Article 3 (commencing with Section 106875) of Chapter 4 of Part 1.
(3) Article 1 (commencing with Section 115825) of Chapter 5 of Part 10.
(4) This chapter and the Safe Drinking Water State Revolving Fund Law of 1997 (Chapter 4.5 (commencing with Section 116760)).
(5) Article 2 (commencing with Section 116800), Article 3 (commencing with Section 116825), and Article 4 (commencing with Section 116875) of Chapter 5.
(6) Chapter 7 (commencing with Section 116975).
(7) The Safe Drinking Water, Water Quality and Supply, Flood Control, River and Coastal Protection Bond Act of 2006 (Division 43 (commencing with Section 75001) of the Public Resources Code).
(8) The Water Recycling Law (Chapter 7 (commencing with Section 13500) of Division 7 of the Water Code).
(9) Chapter 7.3 (commencing with Section 13560) of Division 7 of the Water Code.
(10) The California Safe Drinking Water Bond Law of 1976 (Chapter 10.5 (commencing with Section 13850) of Division 7 of the Water Code).
(11) Wholesale Regional Water System Security and Reliability Act (Division 20.5 (commencing with Section 73500) of the Water Code).
(12) Water Security, Clean Drinking Water, Coastal and Beach Protection Act of 2002 (Division 26.5 (commencing with Section 79500) of the Water Code).

(b) The State Water Resources Control Board shall maintain a drinking water program and carry out the duties, responsibilities, and functions described in this section. Statutory reference to "department," "state department," or "director" regarding a function transferred to the State Water Resources Control Board shall refer to the State Water Resources Control Board. This section does not impair the authority of a local health officer to enforce this chapter or a county's election not to enforce this chapter, as provided in Section 116500...

(k) (1) The State Water Resources Control Board shall appoint a deputy director who reports to the executive director to oversee the issuance and enforcement of public water system permits and other duties as appropriate. The deputy director shall have public health expertise.

(2) The deputy director is delegated the State Water Resources Control Board's authority to provide notice, approve notice content, approve emergency notification plans, and take other action pursuant to Article 5 (commencing with Section 116450), to issue, renew, reissue, revise, amend, or deny any public water system permits pursuant to Article 7 (commencing with Section 116525), to suspend or revoke any public water system permit pursuant to Article 8 (commencing with Section 116625), and to issue citations, assess penalties, or issue orders pursuant to Article 9 (commencing with Section 116650). Decisions and actions of the deputy director taken pursuant to Article 5 (commencing with Section 116450) or Article 7 (commencing with Section 116525) are deemed decisions and actions taken, but

are not subject to reconsideration, by the State Water Resources Control Board. Decisions and actions of the deputy director taken pursuant to Article 8 (commencing with Section 116625) and Article 9 (commencing with Section 116650) are deemed decisions and actions taken by the State Water Resources Control Board, but any aggrieved person may petition the State Water Resources Control Board for reconsideration of the decision or action. This subdivision is not a limitation on the State Water Resources Control Board's authority to delegate any other powers and duties.

**Section 116275 states in relevant part:**
(c) "Primary drinking water standards" means:

(1) Maximum levels of contaminants that, in the judgment of the state board, may have an adverse effect on the health of persons.

(2) Specific treatment techniques adopted by the state board in lieu of maximum contaminant levels pursuant to subdivision (j) of Section 116365.

(3) The monitoring and reporting requirements as specified in regulations adopted by the state board that pertain to maximum contaminant levels.

**Section 116555 states in relevant part:**
(a) Any person who owns a public water system shall ensure that the system does all of the following:

(1) Complies with primary and secondary drinking water standards.

(2) Will not be subject to backflow under normal operating conditions.

(3) Provides a reliable and adequate supply of pure, wholesome, healthful, and potable water.

**Section 116577. Enforcement fee states:**

(a) Each public water system shall reimburse the state board for actual costs incurred by the state board for any of the following enforcement activities related to that water system:

(1) Preparing, issuing, and monitoring compliance with, an order or a citation.

(2) Preparing and issuing public notification.

(3) Conducting a hearing pursuant to Section 116625. *NOTE: This publication includes a variety of* (b) The state board shall submit an invoice for these enforcement costs to the public water system that requires payment before September 1 of the fiscal year following the fiscal year in which the costs were incurred. The invoice shall indicate the total hours expended, the reasons for the expenditure, and the hourly cost rate of the state board. The costs set forth in the invoice shall not exceed the total actual costs to the state board of enforcement activities specified in this section.

(c) Notwithstanding the reimbursement of enforcement costs of the local primacy agency pursuant to subdivision (a) of Section 116595 by a public water system under the jurisdiction of the local primacy agency, a public water system shall also reimburse enforcement costs, if any, incurred by the state board pursuant to this section.

(d) "Enforcement costs," as used in this section, does not include "litigation costs" pursuant to Section 116585.

(e) The state board shall not be entitled to enforcement costs pursuant to this section if a court determines that enforcement activities were in error.

(f) Payment of the invoice shall be made within 90 days of the date of the invoice. Failure to pay the invoice within 90 days shall result in a 10-percent late penalty that shall be paid in addition to the invoiced amount.

(g) The state board may, at its sole discretion, waive payment by a public water system of all or any part of the invoice or penalty.

**Section 116625 (Revocation and suspension of permits) states:**

(a) The department, after a hearing noticed and conducted as provided in Section 100171, may suspend or revoke any permit issued pursuant to this chapter if the department determines pursuant to the hearing that the permittee is not complying with the permit, this chapter, or any regulation, standard, or order issued or adopted thereunder, or that the permittee has made a false statement or representation on any application, record, or report maintained or submitted for purposes of compliance with this chapter. If the permit at issue has been temporarily suspended pursuant to subdivision (c), the accusation shall be served and notice of the hearing date given within 15 days of the effective date of the temporary suspension order. The commencement of the hearing shall be as soon as practicable, but in no case later than 60 days after the effective date of the temporary suspension order.

(b) The permittee may file with the superior court a petition for a writ of mandate for review of any decision of the department made pursuant to subdivision (a). Failure to file a petition shall not preclude a party from challenging the reasonableness or validity of a decision of the department in any judicial proceeding to enforce the decision or from pursuing any remedy authorized by this chapter.

(c) The department may temporarily suspend any permit issued pursuant to this chapter prior to any hearing when the action is necessary to prevent an imminent or substantial danger to health. The director shall notify the permittee of the temporary suspension and the effective date thereof and, at the same time, notify the permittee that a hearing has been scheduled. The hearing shall be held as soon as possible, but not later than 15 days after the effective date of the temporary suspension and shall deal only with the issue of whether the temporary suspension shall remain in place pending a hearing on the merits. The temporary suspension shall remain in effect until the hearing is completed and the director has made a final determination on the temporary suspension, that in any event shall be made within 15 days after the completion of the hearing. If the determination is not transmitted within 15 days after the hearing is completed, the temporary suspension shall be of no further effect. Dissolution of the temporary suspension does not deprive the department of jurisdiction to proceed with a hearing on the merits under subdivision (a).

**Section 116650 states in relevant part**:

(a) If the state board determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the state board may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.

(c) A citation may specify a date for elimination or correction of the condition constituting the violation.

(d) A citation may include the assessment of a penalty as specified in subdivision (e).

(e) The state board may assess a penalty in an amount not to exceed one thousand dollars ($1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation and shall be in addition to any liability or penalty imposed under any other law.

**Section 116701 (Petitions to Orders and Decisions) states**:

(a) Within 30 days of issuance of an order or decision issued by the deputy director under Article 8 (commencing with Section 116625) or Article 9 (commencing with Section 116650), an aggrieved person may petition the state board for reconsideration. Where the order or decision of the deputy director is issued after a hearing under Chapter 5 (commencing with Section 11500) of Part 1 of Division 3 of Title 2 of the Government Code, this section shall apply instead of Section 11521 of the Government Code.

(b) The petition shall include the name and address of the petitioner, a copy of the order or decision for which the petitioner seeks reconsideration, identification of the reason the petitioner alleges the issuance of the order was inappropriate or improper, the specific action the petitioner requests, and other information as the state board may prescribe. The petition shall be accompanied by a statement of points and authorities of the legal issues raised by the petition.

(c) The evidence before the state board shall consist of the record before the deputy director and any other relevant evidence that, in the judgment of the state board, should be considered to implement the policies of this chapter. The state board may, in its discretion, hold a hearing for receipt of additional evidence.

(d) The state board may refuse to reconsider the order or decision if the petition fails to raise substantial issues that are appropriate for review, may deny the petition upon a determination that the issuance of the order or decision was appropriate and proper, may set aside or modify the order or decision, or take other appropriate action. The state board's action pursuant to this subdivision shall constitute the state board's completion of its reconsideration.

(e) The state board, upon notice and hearing, if a hearing is held, may stay in whole or in part the effect of the order or decision of the deputy director.

(f) If an order of the deputy director is subject to reconsideration under this section, the filing of a petition for reconsideration is an administrative remedy that must be exhausted before filing a petition for writ of mandate under Section 116625 or 116700.

**California Code of Regulations (CCR), Title 22:**

**Section 64421 (General Requirements) states**:

(a) Each water supplier shall:

(1) Develop a routine sample siting plan as required in section 64422;

(2) Collect routine, repeat and replacement samples as required in Sections 64423, 64424, and 64425;

(3) Have all samples analyzed by laboratories approved to perform those analyses by the State Board and report results as required in section 64423.1;

(4) Notify the State Board when there is an increase in coliform bacteria in bacteriological samples as required in section 64426; and

(5) Comply with the Maximum Contaminant Level as required in section 64426.1.

(b) Water suppliers shall perform additional bacteriological monitoring as follows:

(1) After construction or repair of wells;

(2) After main installation or repair;

(3) After construction, repair, or maintenance of storage facilities; and

(4) After any system pressure loss to less than five psi. Samples collected shall represent the water quality in the affected portions of the system.

**Section 64422 (Routine Sample Siting Plan) states:**

(a) By September 1, 1992, each water supplier shall develop and submit to the State Board a siting plan for the routine collection of samples for total coliform analysis, subject to the following:

(1) The sample sites chosen shall be representative of water throughout the distribution system including all pressure zones, and areas supplied by each water source and distribution reservoir.

(2) The water supplier may rotate sampling among the sample sites if the total number of sites needed to comply with (a)(1) above exceeds the number of samples required according to Table 64423-A. The rotation plan shall be described in the sample siting plan.

(b) If personnel other than certified operators will be performing field tests and/or collecting samples, the sample siting plan shall include a declaration that such personnel have been trained, pursuant to §64415 (b).

(c) The supplier shall submit an updated plan to the State Board at least once every ten years and at any time the plan no longer ensures representative monitoring of the system.

**Section 64423 (Routine Sampling) states:**

(a) Each water supplier shall collect routine bacteriological water samples as follows:

(1) The minimum number of samples for community water systems shall be based on the known population served or the total number of service connections, whichever results in the greater number of samples, as shown in Table 64423-A. A community water system using groundwater which serves 25-1000 persons may request from the State Board a reduction in monitoring frequency. The minimum reduced frequency shall not be less than one sample per quarter.
(2) The minimum number of samples for nontransient-noncommunity water systems shall be based on the known population served as shown in Table 64423-A during those months when the system is operating. A nontransient-noncommunity water system using groundwater which serves 25-1000 persons may request from the State Board a reduction in monitoring frequency if it has not violated the requirements in this article during the past twelve months. The minimum reduced frequency shall not be less than one sample per quarter.
(3) The minimum number of samples for transient-noncommunity water systems using groundwater and serving 1000 or fewer persons a month shall be one in each calendar quarter during which the system provides water to the public.
(4) The minimum number of samples for transient-noncommunity water systems using groundwater and serving more than 1000 persons during any month shall be based on the known population served as shown in Table 64423-A, except that the water supplier may request from the State Board a reduction in monitoring for any month the system serves 1000 persons or fewer. The minimum reduced frequency shall not be less than one sample in each calendar quarter during which the system provides water to the public.
(5) The minimum number of samples for transient-noncommunity water systems using approved surface water shall be based on the population served as shown in Table 64423-A. A system using groundwater under the direct influence of surface water shall begin monitoring at this frequency by the end of the sixth month after the State Board has designated the source to be approved surface water.
(6) A public water system shall collect samples at regular time intervals throughout the month, except that a system using groundwater which serves 4,900 persons or fewer may collect all required samples on a single day if they are taken from different sites.

(b) In addition to the minimum sampling requirements, all water suppliers using approved surface water which do not practice treatment in compliance with Sections 64650 through 64666, shall collect a minimum of one sample before or at the first service connection each day during which the turbidity level of the water delivered to the system exceeds 1 NTU. The sample shall be collected within 24 hours of the exceedance and shall be analyzed for total coliforms. If the water supplier is unable to collect and/or analyze the sample within the 24-hour time period because of extenuating circumstances beyond its control, the supplier shall notify the State Board within the 24-hour time period and may request an extension. Sample results shall be included in determining compliance with the MCL for total coliforms in Section 64426.1.

(c) If any routine, repeat, or replacement sample is total coliform-positive, then the water supplier shall collect repeat samples in accordance with Section 64424 and comply with the reporting requirements specified in Sections 64426 and 64426.1.

**Table 64423-A**

Minimum Number of Routine Total Coliform Samples

| Monthly Population Served | Service Connections | Minimum Number of Samples |
|---|---|---|
| 25 to 1000 | 15 to 400 | 1 per month |
| 1,001 to 2,500 | 401 to 890 | 2 per month |
| 2,501 to 3,300 | 891 to 1,180 | 3 per month |
| 3,301 to 4,100 | 1,181 to 1,460 | 4 per month |
| 4,101 to 4,900 | 1,461 to 1,750 | 5 per month |
| 4,901 to 5,800 | 1,751 to 2,100 | 6 per month |
| 5,801 to 6,700 | 2,101 to 2,400 | 7 per month |
| 6,701 to 7,600 | 2,401 to 2,700 | 2 per week |
| 7,601 to 12,900 | 2,701 to 4,600 | 3 per week |

| | | |
|---|---|---|
| 12,901 to 17,200 | 4,601 to 6,100 | 4 per week |
| 17,201 to 21,500 | 6,101 to 7,700 | 5 per week |
| 21,501 to 25,000 | 7,701 to 8,900 | 6 per week |
| 25,001 to 33,000 | 8,901 to 11,800 | 8 per week |
| 33,001 to 41,000 | 11,801 to 14,600 | 10 per week |
| 41,001 to 50,000 | 14,601 to 17,900 | 12 per week |
| 50,001 to 59,000 | 17,901 to 21,100 | 15 per week |
| 59,001 to 70,000 | 21,101 to 25,000 | 18 per week |
| 70,001 to 83,000 | 25,001 to 29,600 | 20 per week |
| 83,001 to 96,000 | 29,601 to 34,300 | 23 per week |
| 96,001 to 130,000 | 34,301 to 46,400 | 25 per week |
| 130,001 to 220,000 | 46,401 to 78,600 | 30 per week |
| 220,001 to 320,000 | 78,601 to 114,300 | 38 per week |
| 320,001 to 450,000 | 114,301 to 160,700 | 50 per week |
| 450,001 to 600,000 | 160,701 to 214,300 | 55 per week |
| 600,001 to 780,000 | 214,301 to 278,600 | 60 per week |
| 780,001 to 970,000 | 278,601 to 346,400 | 70 per week |
| 970,001 to 1,230,000 | 346,401 to 439,300 | 75 per week |
| 1,230,001 to 1,520,000 | 439,301 to 542,900 | 85 per week |
| 1,520,001 to 1,850,000 | 542,901 to 660,700 | 90 per week |
| 1,850,001 to 2,270,000 | 660,701 to 810,700 | 98 per week |
| 2,270,001 to 3,020,000 | 810,701 to 1,078,600 | 105 per week |
| 3,020,001 to 3,960,000 | 1,078,601 to 1,414,300 | 110 per week |
| 3,960,001 or more | 1,414,301 or more | 120 per week |

**Section 64423.1 (Sample Analysis and Reporting of Results) states:**
(a) The water supplier shall designate (label) each sample as routine, repeat, replacement, or "other" pursuant to Section 64421(b), and have each sample analyzed for total coliforms. The supplier also shall require the laboratory to analyze the same sample for fecal coliforms or Escherichia coli (E. coli) whenever the presence of total coliforms is indicated. As a minimum, the analytical results shall be reported in terms of the presence or absence of total or fecal coliforms, or E. coli in the sample, whichever is appropriate.
(b) The water supplier shall require the laboratory to notify the supplier within 24 hours, whenever the presence of total coliforms, fecal coliforms or E. coli is demonstrated in a sample or a sample is invalidated due to interference problems, pursuant to Section 64425(b), and shall ensure that a contact person is available to receive these analytical results 24-hours a day. The water supplier shall also require the laboratory to immediately notify the State Board of any positive bacteriological results if the laboratory cannot make direct contact with the designated contact person within 24 hours.
(c) Analytical results of all required samples collected for a system in a calendar month shall be reported to the State Board not later than the tenth day of the following month, as follows:

(1) The water supplier shall submit a monthly summary of the bacteriological monitoring results to the State Board.

(2) For systems serving fewer than 10,000 service connections or 33,000 persons, the water supplier shall require the laboratory to submit copies of all required bacteriological monitoring results directly to the State Board.

(3) For systems serving more than 10,000 service connections, or 33,000 persons, the water supplier shall require the laboratory to submit copies of bacteriological monitoring results for all positive routine samples and all repeat samples directly to the State Board.

(d) Laboratory reports shall be retained by the water supplier for a period of at least five years and shall be made available to the State Board upon request.

**Section 64424 (Repeat Sampling) states in relevant part:**
(a) If a routine sample is total coliform-positive, the water supplier shall collect a repeat sample set as described in paragraph (1) within 24 hours of being notified of the positive result. The repeat

samples shall all be collected within the same 24 hour time period. A single service connection system may request that the State Board allow the collection of the repeat sample set over a four-day period.

(1) For a water supplier that normally collects more than one routine sample a month, a repeat sample set shall be at least three samples for each total coliform-positive sample. For a water supplier that normally collects one or fewer samples per month, a repeat sample set shall be at least four samples for each total coliform-positive sample.

(2) If the water supplier is unable to collect the samples within the 24-hour time period specified in subsection (a) or deliver the samples to the laboratory within 24 hours after collection because of circumstances beyond its control, the water supplier shall notify the State Board within 24 hours. The State Board will then determine how much time the supplier will have to collect the repeat samples.

(b) When collecting the repeat sample set, the water supplier shall collect at least one repeat sample from the sampling tap where the original total coliform-positive sample was taken. Other repeat samples shall be collected within five service connections upstream or downstream of the original site. At least one sample shall be from upstream and one from downstream unless there is no upstream and/or downstream service connection.

(c) If one or more samples in the repeat sample set is total coliform-positive, the water supplier shall collect and have analyzed an additional set of repeat samples as specified in subsections (a) and (b). The supplier shall repeat this process until either no coliforms are detected in one complete repeat sample set or the supplier determines that the MCL for total coliforms specified in Section 64426.1 has been exceeded and notifies the State Board.

(d) If a public water system for which fewer than five routine samples/month are collected has one or more total coliform-positive samples, the water supplier shall collect at least five routine samples the following month. If the supplier stops supplying water during the month after the total coliform-positive(s), at least five samples shall be collected during the first month the system resumes operation. A water supplier may request the State Board waive the requirement to collect at least five routine samples the following month, but a waiver will not be granted solely on the basis that all repeat samples are total coliform-negative. To request a waiver, one of the following conditions shall be met:

(1) The State Board conducts a site visit before the end of the next month the system provides water to the public to determine whether additional monitoring and/or corrective action is necessary to protect public health.

(2) The State Board determines why the sample was total coliform-positive and establishes that the system has corrected the problem or will correct the problem before the end of the next month the system serves water to the public. If a waiver is granted, a system shall collect at least one routine sample before the end of the next month it serves water to the public and use it to determine compliance with Section 64426.1.

**Section 64425 (Sample Invalidation) states:**

(a) A water supplier may request the Department to invalidate a sample for which a total coliform-positive result has been reported if the supplier demonstrates:

(1) All repeat sample(s) collected at the same tap as the original total coliform-positive sample also are total coliform- positive and all repeat samples collected within five service connections of the original tap are not total coliform-positive; or

(2) The laboratory did not follow the prescribed analytical methods pursuant to §64415(a), based on a review of laboratory documentation by the Department. The supplier shall submit to the Department a written request for invalidation along with the laboratory documentation, the supplier's sample collection records and any observations noted during sample collection and delivery. The water supplier shall require the laboratory to provide the supplier with documentation which shall include, but not be limited to:

(A) A letter from the director of the laboratory having generated the data, confirming the invalidation request by reason of laboratory accident or error;

(B) Complete sample identification, laboratory sample log number (if used), date and time of collection, date and time of receipt by the laboratory, date and time of analysis for the sample(s) in question;

(C) Complete description of the accident or error alleged to have invalidated the result(s);

(D) Copies of all analytical, operating, and quality assurance records pertaining to the incident in question; and

(E) Any observations noted by laboratory personnel when receiving and analyzing the sample(s) in question.

(b) Whenever any total coliform sample result indicative of the absence of total coliforms has been declared invalid by the laboratory due to interference problems as specified at 40 Code Federal Regulations, Section 141.2100(c)(2), the supplier shall collect a replacement sample from the same location as the original sample within 24 hours of being notified of the interference problem, and have it analyzed for the presence of total coliforms. The supplier shall continue to re-sample at the original site within 24 hours and have the samples analyzed until a valid result is obtained.

**Section 64426 (Significant Rise in Bacterial Count) states in relevant part:**

(a) Any of the following criteria shall indicate a possible significant rise in bacterial count:

(1) A system collecting at least 40 samples per month has a total coliform-positive routine sample followed by two total coliform-positive repeat samples in the repeat sample set;

(2) A system has a sample which is positive for fecal coliform or E. coli; or

(3) A system fails the total coliform Maximum Contaminant Level (MCL) as defined in Section 64426.1.

(b) When the coliform levels specified in subsection (a) are reached or exceeded, the water supplier shall:

(1) Contact the State Board by the end of the day on which the system is notified of the test result or the system determines that it has exceeded the MCL, unless the notification or determination occurs after the State Board office is closed, in which case the supplier shall notify the State Board within 24 hours; and

(2) Submit to the State Board information on the current status of physical works and operating procedures which may have caused the elevated bacteriological findings, or any information on community illness suspected of being waterborne. This shall include, but not be limited to:

(A) Current operating procedures that are or could potentially be related to the increase in bacterial count;

(B) Any interruptions in the treatment process;

(C) System pressure loss to less than 5 psi;

(D) Vandalism and/or unauthorized access to facilities;

(E) Physical evidence indicating bacteriological contamination of facilities;

(F) Analytical results of any additional samples collected, including source samples;

(G) Community illness suspected of being waterborne; and

(H) Records of the investigation and any action taken.

**Section 64426.1 (Total Coliform Maximum Contaminant Level (MCL)) states in relevant part**:

(b) A public water system is in violation of the total coliform MCL when any of the following occurs:

(1) For a public water system which collects at least 40 samples per month, more than 5.0 percent of the samples collected during any month are total coliform-positive; or

(2) For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or

(3) Any repeat sample is fecal coliform-positive or E. coli-positive; or

(4) Any repeat sample following a fecal coliform-positive or E. coli-positive routine sample is total coliform-positive.

(c) If a public water system is not in compliance with paragraphs (b)(1) through (4), during any month in which it supplies water to the public, the water supplier shall notify the State Board by the end of the business day on which this is determined, unless the determination occurs after the State Board office is closed, in which case the supplier shall notify the State Board within 24 hours of the determination. The water supplier shall also notify the consumers served by the water system. A Tier 2 Public Notice shall be given for violations of paragraph (b)(1) or (2), pursuant to section 64463.4.

A Tier 1 Public Notice shall be given for violations of paragraph (b)(3) or (4), pursuant to section 64463.1.

**Section 64463.1 (Tier 1 Public Notice) states in relevant part:**
(a) A water system shall give public notice pursuant to this section and section 64465 if any of the following occurs:
(1) Violation of the total coliform MCL when:
(A) Fecal coliform or E. coli are present in the distribution system; or
(B) When any repeat sample tests positive for coliform and the water system fails to test for fecal coliforms or E. coli in the repeat sample;...
(b) As soon as possible within 24 hours after learning of any of the violations in subsection (a) or being notified by the State Board that it has determined there is a potential for adverse effects on human health [pursuant to paragraph (a)(4), (5), or (6)], the water system shall:
(1) Give public notice pursuant to this section;
(2) Initiate consultation with the State Board within the same timeframe; and
(3) Comply with any additional public notice requirements that are determined by the consultation to be necessary to protect public health.
(c) A water system shall deliver the public notice in a manner designed to reach residential, transient, and nontransient users of the water system and shall use, as a minimum, one of the following forms:
(1) Radio or television;
(2) Posting in conspicuous locations throughout the area served by the water system;
(3) Hand delivery to persons served by the water system; or
(4) Other method approved by the State Board, based on the method's ability to inform water system users.

**Section 64463.4 (Tier 2 Public Notice) states**:
(a) A water system shall give public notice pursuant to this section if any of the following occurs:
(1) Any violation of the MCL, MRDL, and treatment technique requirements, except:
(A) Where a Tier 1 public notice is required under section 64463.1; or
(B) Where the State Board determines that a Tier 1 public notice is required, based on potential health impacts and persistence of the violations;
(2) All violations of the monitoring and testing procedure requirements in sections 64421 through 64426.1, article 3 (Primary Standards – Bacteriological Quality), for which the State Board determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations;
(3) Other violations of the monitoring and testing procedure requirements in this chapter, and chapters 15.5, 17 and 17.5, for which the State Board determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations; or
(4) Failure to comply with the terms and conditions of any variance or exemption in place.
(b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the State Board's written approval based on the violation or occurrence having been resolved and the State Board's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:
(1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
(2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the State Board's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case less than once per year. No allowance for reduced frequency of

notice shall be given in the case of a total coliform MCL violation or violation of a Chapter 17 treatment technique requirement; and

(3) For turbidity violations pursuant to sections 64652.5(c)(2) and 64653(c), (d) and (f), as applicable, a water system shall consult with the State Board as soon as possible within 24 hours after the water system learns of the violation to determine whether a Tier 1 public notice is required. If consultation does not take place within 24 hours, the water system shall give Tier 1 public notice within 48 hours after learning of the violation.

(c) A water system shall deliver the notice, in a manner designed to reach persons served, within the required time period as follows:

(1) Unless otherwise directed by the State Board in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by;

(A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and

(B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):

1. Publication in a local newspaper;
2. Posting in conspicuous public places served by the water system, or on the Internet; or
3. Delivery to community organizations.

(2) Unless otherwise directed by the State Board in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, noncommunity water systems shall give the public notice by:

(A) Posting in conspicuous locations throughout the area served by the water system; and

(B) Using one or more of the following methods to reach persons not likely to be reached by a public posting:

1. Publication in a local newspaper or newsletter distributed to customers;
2. E-mail message to employees or students;
3. Posting on the Internet or intranet; or
4. Direct delivery to each customer.

**Section 64465 (Public Notice Content and Format) states in relevant part**:

(a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:

(1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);

(2) The date(s) of the violation or occurrence;

(3) Any potential adverse health effects from the violation or occurrence, including the appropriate standard health effects language from appendices 64465-A through G;

(4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;

(5) Whether alternative water supplies should be used;

(6) What actions consumers should take, including when they should seek medical help, if known;

(7) What the water system is doing to correct the violation or occurrence;

(8) When the water system expects to return to compliance or resolve the occurrence;

(9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;

(10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: —Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail; and

(11) For a water system with a monitoring and testing procedure violation, this language shall be included: "We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [compliance period dates], we ['did not monitor or test' or 'did not complete all monitoring or testing'] for [contaminant(s)], and therefore, cannot be sure of the quality of your drinking water during that time." ...

(c) A public water system providing notice pursuant to this article shall comply with the following multilingual-related requirements:

(2) For a Tier 2 or Tier 3 public notice:

(A) The notice shall contain information in Spanish regarding the importance of the notice, or contain a telephone number or address where Spanish-speaking residents may contact the public water system to obtain a translated copy of the notice or assistance in Spanish; and

(B) When a non-English speaking group other than Spanish-speaking exceeds 1,000 residents or 10 percent of the residents served by the public water system, the notice shall include:

1. Information in the appropriate language(s) regarding the importance of the notice; or

2. A telephone number or address where such residents may contact the public water system to obtain a translated copy of the notice or assistance in the appropriate language; and

(3) For a public water system subject to the Dymally-Alatorre Bilingual Services Act, Chapter 17.5, Division 7, of the Government Code (commencing with section 7290), meeting the requirements of this Article may not ensure compliance with the Dymally-Alatorre Bilingual Services Act.

(d) Each public notice given pursuant to this article shall:

(1) Be displayed such that it catches people's attention when printed or posted and be formatted in such a way that the message in the public notice can be understood at the eighth-grade level;

(2) Not contain technical language beyond an eighth-grade level or print smaller than 12 point; and

(3) Not contain language that minimizes or contradicts the information being given in the public notice.

**Appendix 64465-A. Health Effects Language - Microbiological Contaminants.**

| Contaminant | Health Effects Language |
|---|---|
| Total Coliform | Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. |
| Fecal coliform/E. coli | Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems. |
| Turbidity | Turbidity has no health effects. However, high levels of turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. |

**Section 64469 (Reporting Requirements) states in relevant part:**

(d) Within 10 days of giving initial or repeat public notice pursuant to Article 18 of this Chapter, except for notice given under section 64463.7(d), each water system shall submit a certification to the State Board that it has done so, along with a representative copy of each type of public notice given.

**Section 64481 (Content of the Consumer Confidence Report) states in relevant part:**

(g) For the year covered by the report, the Consumer Confidence Report shall note any violations of paragraphs (1) through (7) and give related information, including any potential adverse health effects, and the steps the system has taken to correct the violation.

(1) Monitoring and reporting of compliance data.

## APPENDIX 2. NOTIFICATION TEMPLATE

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

**Este informe contiene informacion muy importante sobre su agua potable.**
**Por favor hable con alguien que lo pueda tradúcir.**

**Akal Travel Plaza Had Levels of Coliform Bacteria**

**Above the Drinking Water Standard**

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We routinely monitor for drinking water contaminants. We took nine samples to test for the presence of coliform bacteria during April 2018. Two of those samples showed the presence of total coliform bacteria. The standard is that no more than one (1) sample per month may test positive for coliform bacteria.

**What should I do?**

- **You do not need to boil your water or take other corrective actions.**
- This is not an emergency. If it had been, you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- Usually, coliforms are a sign that there could be a problem with the system's treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as *E. coli*, are present. **We did not find any of these bacteria in our subsequent testing, and further testing shows that this problem has been resolved.**
- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

**What was done?**

In instances like this, federal law requires that we conduct a Level 1 Assessment of our water system immediately after learning of the violation to determine the source of contamination. We are required to report to the State Water Board within 30 days of triggering the assessment the actions we took to correct the deficiencies found and a schedule for correcting other deficiencies not corrected within 30 days.

What happened? What is being done? _____

_____

[Describe corrective action]_____

_____

We anticipate resolving the problem within [estimated time frame]

---

For more information, please contact:

[Name of Contact] _____

[Phone Number] or _____

[Mailing Address] _____

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

**Secondary Notification Requirements**

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by Akal Travel Plaza in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

State Water System ID: 5400810. Date distributed: _____

## APPENDIX 3. COMPLIANCE CERTIFICATION

**Citation Number:** 03-24-18C-058

**Name of Water System:** Akal Travel Plaza

**System Number:** 5400810

**Certification**

I certify that the users of the water supplied by this water system were notified of the bacteriological monitoring violation of California Code of Regulations, Title 22, Section 64426.1, for the compliance period of April 2018 and the required actions listed below were completed.

| Required Action | Date Completed |
|---|---|
| *(Citation Directive 2) Public Notification Method(s) Used:*_____ | |

_____ _____

Signature of Water System Representative Date

**THIS FORM MUST BE COMPLETED AND RETURNED TO THE STATE WATER BOARD, DIVISION OF DRINKING WATER, NO LATER THAN June 15, 2018.**

**Disclosure:** Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars ($5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than $25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment.

## Appendix 4 – Notification of Receipt

**Citation Number:** 03-24-18C-058

**Name of Water System:** Akal Travel Plaza

**System Number:** 5400810

### Certification

I certify that I am an authorized representative of the Akal Travel Plaza and that Citation No. **03-24-18C-058** was received on _____. Further I certify that the Citation has been reviewed by the appropriate management staff of the Akal Travel Plaza and it is clearly understood that Citation No. **03-24-18C-058** contains legally enforceable directives with specific due dates.

_____ _____

Signature of Water System Representative Date

**THIS FORM MUST BE COMPLETED AND RETURNED TO THE STATE WATER BOARD, DIVISION OF DRINKING WATER, NO LATER THAN June 15, 2018.**

**Disclosure:** Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars ($5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than $25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment.