

State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION

ORDER NO. 95-145
(AMENDING ORDER NO. 95-028)

NPDES NO. CA0000353

WASTE DISCHARGE REQUIREMENTS
for
CITY OF LOS ANGELES, DEPARTMENT OF WATER AND POWER
(Haynes Generating Station)

The California Regional Water Quality Control Board, Los Angeles Region, finds:

1. City of Los Angeles, Department of Water and Power (LA,DWP), operates the Haynes Generating Station, a 1,580 megawatts plant, at 6801 Westminster Avenue, Long Beach, and discharges wastes under waste discharge requirements contained in Order No. 95-028 (NPDES Permit No. CA0000353), adopted by this Board on February 27, 1995. This Order serves as a permit under the National Pollutant Discharge Elimination System (NPDES No. CA0000353).
2. Inadvertent omission of the seawater background concentrations for arsenic, copper, mercury, silver and zinc resulted in errors in calculation of daily maximum values of these elements. These background concentrations are available in the California Ocean Plan, adopted on March 22, 1990, by the State Water Resources Control Board.
3. This revision of waste discharge requirements is exempt from the provisions of Chapter 3 (commencing with Section 21100) of Division 13 of the Public Resources Code in accordance with Water Code Section 13389.

The Regional Board has notified the discharger and interested agencies and persons of its intent to revise the waste discharge requirements for this discharge and has provided them with an opportunity to submit their written views and recommendations.

The Board in a public hearing heard and considered all comments pertaining to the tentative revised requirements.

This Order shall serve as a National Pollutant Discharge Elimination System permit pursuant to Section 402 of the Federal Clean Water Act or amendments thereto, and shall take effect at the end of ten days from the date of its adoption, provided the Regional Administrator of the Environmental Protection Agency, EPA, has no objections.


IT IS HEREBY ORDERED that Order No. 95-028, adopted by this Board on February 27, 1995, is hereby amended as follows:

- Changes the daily maximum discharge limitations for arsenic, copper, mercury, silver, and zinc in Item I.A:3 on pages 7 and 8 as follows:

<u>Constituents</u>	<u>Units</u>	<u>Discharge Limitations^[1]</u>	
		<u>30-Day Average</u>	<u>Daily Maximum</u>
Arsenic	ug/l	30.5	122 162.5
	lbs/day	70.2 (116.7)	280.2 373.9 (466.8 621.8)
Copper	ug/l	7.5	30 57
	lbs/day	17.3 (28.7)	69.2 131.2 (114.8 218.1)
Mercury	ug/l	0.218	0.872 0.878
	lbs/day	0.50 (0.83)	2.00 2.02 (3.32 3.36)
Silver	ug/l	3.13	12.52 14.68
	lbs/day	7.2 (12.0)	28.8 33.8 (48.0 56.2)
Zinc	ug/l	74	296 404
	lbs/day	170.3 (283.1)	681.2 929.6 (1,132.4 1,546.0)

- The Expiration Date, and all other Limitations, Requirements, and Provisions of Order No. 95-028 are unchanged and shall remain in full force and effect.

I, Robert P. Ghirelli, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on October 30, 1995.



ROBERT P. GHIRELLI, D.Env.
 Executive Officer

/KKY