

Table D2
 Receiving Water Data
 City of Thousand Oaks
 Hill Canyon Wastewater Treatment Plant
 (CA0056294, CI#4916)

CTR #	1	2	4	5A	5B	6	7	8	9	10	11	12	13	14	20		
Pollutant	Antimony	Arsenic	Cadmium	Chromium III	Chromium VI	Copper	Lead	Mercury	Nickel	Selenium	Silver	Thallium	Zinc	Cyanide	Bromoform		
Units	ug/L	ug/L	ug/L		ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L		
04/16/02	<0.5	<2	<0.2		2	<10	5	0.3	<0.01		4	2	<0.2	50	<5	<1	
04/23/02	<0.5	<2	<0.2		1	10	4	0.4	0.01		3	3	<0.2	30	<5	<1	
05/07/02	<0.5		2	<0.2	1	<10	4	0.3	<0.01		2	<2	<0.2	20	<5	<1	
05/23/02	0.5		3	<0.2	1	<10	4	<0.2	<0.01		3	3	<0.2	20	<5	<1	
06/04/02	<0.5		2	<0.2	1	<10	3	<0.2	0.02		2	2	<0.2	<10	<5	<1	
06/18/02	<0.5	<2	<0.2		2	<10	3	0.3	<0.01		3	<2	<0.2	<10	<5	<1	
07/02/02	<0.5		3	<0.2	<1	<10	5	<0.2	<0.01		3	<2	<0.2	<10	<5	<1	
07/23/02	<0.5		2	0.3	1	<10	3	0.2	<0.01		3	3	<0.2	<10	20	<5	<1
08/06/02	0.6	<2	<0.2		2	<10	5	0.2	<0.01		4	3	<0.2	<10		5.5	<1
8/20/02	<0.5	<2	<0.2		2	<10	4	0.3	<0.01		3	2	<0.2	<10	<5	<1	
9/3/02	0.9	<2	<0.2		3	<10	4	0.2	0.01		3	<2	<0.2	<20	<5	<1	
9/18/02	0.6	<2	<0.2		2	<10	10	0.2	0.01		4	<2	<0.2	<20	<5	<1	
10/1/02	1.3		3	<0.2	2	<10	11	0.06	0.06		7		<0.2		50	<5	<1
10/22/02	<0.5	<2	<0.2		1	<10	10	1.4	0.02		4	3	<0.2		60	<5	<1
11/12/02	0.6		3	<0.2	3	<10	15		0.04		5	4		3	180	<5	<1
11/26/02	<0.5	<2	<0.2	<1	<10		11	2.1	0.01		4	3	<0.2		40	<5	<1
12/3/02	<0.5	<2	<0.2		1	<10	10	2.2	<0.01		3	3	<0.2		40	<5	<1
12/19/02	0.5		3	<0.2	2	<10	11	2.2	<0.01		3	3	<0.2		90	<5	<1
MEC	1.3	3	0.3		3	10	15	2.2	0.06		7	4	0.1	3	180	5.5	<1
MAXIMUM	1.3	3	0.3		3	10	15	2.2	0.06		7	4	0	3	180	5.5	<1
MINIMUM	<0.5	<2	<0.2	<1	<10		3	<0.2	<0.01		2	<2	0	<0.2	<10	<5	<1
DETECTS	7	8	1		16	1	18	14	8		18	13	0	1	11	1	0
COUNT	18	18	18		18	18	18	17	18		18	18	0	18	18	18	18
% NONDETECT	61.11111	55.55556	94.44444	11.11111	94.44444	0	17.64706	55.55556	0	27.77778	#DIV/0!	94.44444	38.88889	94.44444		100	

Table D2
 Receiving Water Data
 City of Thousand Oaks
 Hill Canyon Wastewater Treatment Plant
 (CA0056294, CI#4916)

CTR #	23	26	27	68	81	126							
Pollutant	Dibromochloromethane	Chloroform	Bromodichloromethane	Diethylhexyl phthalate [a.k.a. Bis(2-Ethylhexyl) Phthalate]	Di-n-Butyl Phthalate	Toxaphene	Hardness	Default Hardness	pH	TSS	Salinity	Rec.W. Flow	
Units	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	mg/L	mg/L		mg/L	ppm	cfs	
04/16/02	<1	<1	<1	∅	<10	<0.4	726	400	8.27	4	0.9	0.95	
04/23/02	<1	<1	<1	∅	<10	<0.4	708	400	8.13	12.2	0.9	0.94	
05/07/02	<1	<1	<1	∅	<10	<0.4	712	400	8.17	16	0.9	1.76	
05/23/02	<1	<1	<1	∅	<10	<0.4	644	400	8.14	3	0.8	0.93	
06/04/02	<1	<1	<1	∅	<10	<0.4	680	400	8.51	4.1	0.7	0.6	
06/18/02	<1	<1	<1	∅	<10	<0.4	710	400	8.41	2.4	0.9	0.66	
07/02/02	<1	<1	<1	∅	<10	<0.4	694	400	8.19	2.1	0.7	0.93	
07/23/02	<1	<1	<1	∅	<10	<0.4	672	400	8.34	2.3	0.9	0.66	
08/06/02	<1	<1	<1	∅	<10	<0.4	710	400	8.26	3.8	0.9	1.93	
8/20/02	<1	<1	<1	∅	<10	<0.4	670	400	8.24	1.9	0.9	1.17	
9/3/02	<1	<1	<1	∅	<10	<0.4	686	400	8.11	2.4	0.9	0.765	
9/18/02	<1	<1	<1	5	<10	<0.4	688	400	8.24	3.6	0.9	0.933	
10/1/02	<1	<1	<1	∅	<10	<0.4	678	400	8.16	2.8	0.9	1.24	
10/22/02	<1	<1	<1	1.8	0.51	<0.4	710	400	8.33	3.2	0.9	0.7	
11/12/02	<1	<1	<1	∅	<10	<0.4	714	400	8.24	2.2	0.7	1.12	
11/26/02	<1	<1	<1	∅	<10	<0.4	746	400	7.19	1.5	0.8	1.28	
12/3/02	<1	<1	<1	∅	<10	<0.4	682	400	8.36	160.2	0.7	1.45	
12/19/02	<1	<1	<1	∅	<10	<0.4	554	400	8.33	3.5	0.6	1.03	
MEC	<1	<1	<1	5	0.51	<0.4							
MAXIMUM	<1	<1	<1	5	0.51	<0.4	746	400	8.51	160.2	0.9	1.930	
MINIMUM	<1	<1	<1	1.8	<10	<0.4	554	400	7.19	1.5	0.6	0.600	
DETECTS	0	0	0	2	1	0	18	18	18	18	18	18	
COUNT	18	18	18	18	18	18	18	18	18	18	18	18	
% NONDETECT	100	100	100	88.88889	94.44444	100	0	0	0.00	0.0	0.0	0	