

State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION

ORDER NO. 95-079

NPDES NO. CA0053911

WASTE DISCHARGE REQUIREMENTS  
FOR  
COUNTY SANITATION DISTRICTS OF LOS ANGELES COUNTY  
(San Jose Creek Water Reclamation Plant)

The California Regional Water Quality Control Board, Los Angeles Region (Regional Board), finds:

1. County Sanitation Districts of Los Angeles County (herein after CSDLAC or Discharger) discharge treated wastewater from the San Jose Creek Water Reclamation Plant (WRP) under waste discharge requirements contained in Order No. 89-026 (NPDES No. CA0053911), adopted by this Regional Board on March 27, 1989.
2. CSDLAC have filed a Report of Waste Discharge and have applied for renewal of their waste discharge requirements and National Pollutant Discharge Elimination System (NPDES) permit.
3. The San Jose Creek WRP, located at 1965 South Workman Mill Road, Whittier, is a tertiary wastewater treatment plant with a design capacity of 100 million gallon per day (MGD). Treatment consists of primary sedimentation, activated sludge biological treatment, secondary sedimentation, coagulation, inert media filtration chlorination, and dechlorination. All sewage solids separated from the wastewater are returned to the trunk sewer for final disposal at the CSDLAC's Joint Water Pollution Control Plant (JWPCP).

The San Jose Creek WRP is part of CSDLAC's integrated network of facilities, known as the Joint Outfall System, which includes six treatment plants. The upstream treatment plants (Whittier Narrows, Pomona, Long Beach, Los Coyotes, and San Jose Creek) are connected to the JWPCP. This system allows for the diversion of desired flows into or around each upstream plant. Sludge from upstream plants is returned to the trunk sewer for treatment at JWPCP.

Figure 1 and 2 show the location of the plant and the schematic of wastewater flow.

May 4, 1995  
Revised June 12, 1995

4. The San Jose Creek WRP discharges tertiary treated municipal and industrial wastewater via two discharge points (001 and 003), to the San Gabriel River, a water of the United States, above the tidal prism. Treated effluent is also discharged to San Jose Creek (002), a tributary of San Gabriel River.

Points of discharge are as follows:

Discharge Serial No. 001 - San Gabriel River at Latitude 33° 55' 50" and Longitude 118° 06' 24"

Discharge No. 001 is the primary discharge outfall which is some eight miles south of the plant near Firestone Boulevard. From this point treated effluent flows directly to a lined, low flow channel (San Gabriel River) and travels about 9 miles prior to reaching the tidal prism. Aquatic habitat is severely limited by the physical nature of the lined channel.

Discharge Serial No. 002 - San Jose Creek at Latitude 34° 02' 08" and Longitude 118° 01' 02"

Discharge No. 002 is used for groundwater recharge at Rio Hondo spreading grounds from the existing facilities. San Jose Creek is unlined from the discharge point to the San Gabriel River.

Discharge Serial No. 003 - San Gabriel River at Latitude 34° 02' 10" and Longitude 118° 01' 48"

Discharge No. 003 is the new outfall for the expansion facility and delivers treated effluent to both the unlined portion of the San Gabriel River and the larger Rio Hondo spreading grounds for groundwater replenishment.

5. The Report of Waste Discharge describes the 1994 discharge as follows:

<u>Constituent</u>	<u>Unit</u>	<u>Effluent Annual Average</u>
Flow	mgd	84
pH		7.0
Temperature	°F	77.7
BOD	mg/l	7.8
Total dissolved solids	mg/l	639

<u>Constituent</u>	<u>Unit</u>	<u>Effluent Annual Average</u>
Suspended solids	mg/l	2.0
Settleable	ml/l	<0.1

6. The U.S. Environmental Protection Agency (USEPA) and the Regional Board have classified this discharge as a major discharge.
7. In addition to groundwater recharge, a portion of the treated effluent is used for irrigation and street sweeping and is regulated under Order No. 87-50 adopted by this Board on April 27, 1987. CSDLAC are promoting additional uses of treated effluent.
8. Treated effluent for groundwater recharge and discharged to lined channels is partially dechlorinated; and that used for reuse is not dechlorinated. Discharge to Serial No. 001 (lined channel) leaves the treatment plant at about 1 mg/l residual chlorine.
9. The Regional Board adopted a revised Water Quality Control Plan for the Los Angeles River Basin (4) on June 13, 1994. The plan contains water quality objectives for San Gabriel River and its tributaries.
10. The beneficial uses of the receiving waters are:  
  
San Jose Creek - potential: municipal and domestic supply; water contact recreation. existing: groundwater recharge; non-contact water recreation; warm freshwater habitat; wildlife habitat.  
San Gabriel River Estuary - potential: shellfish harvesting. existing: industrial service supply; navigation; water contact recreation; non-contact water recreation; commercial and sport fishing; estuarine habitat; wildlife habitat; rare, threatened, or endangered species; marine habitat; migration of aquatic organisms; spawning, reproduction, and/or early development.
11. There is public contact in the downstream areas; hence, the quality of treated effluent discharged to the San Gabriel River must be such that no health hazard is created.
12. This discharge is subject to USEPA's 304(1) regulations which prescribe biological and other laboratory testing procedures and toxicity limits, particularly for chronic toxicity, for the implementation of USEPA's "Policy for the Development of

Water Quality-based Permit Limitations for Toxic Pollutants"  
(49 FR 9016, dated March 9, 1984).

13. To implement Section 405 (d) of the Clean Water Act, on February 19, 1993, USEPA promulgated 40 CFR Part 503 to regulate the use and disposal of municipal sewage sludge. This permit implements the regulations and it is the responsibility of the Discharger to comply with said regulations, which are enforceable by USEPA.
14. Pursuant to Section 402(p) of the Clean Water Act and 40 CFR Parts 122, 123, and 124, the State Water Resources Control Board (State Board) adopted a general NPDES permit to regulate stormwater discharges associated with industrial activity (State Board Order No. 91-13-DWQ adopted in September 1992) and construction activity (State Board Order No. 92-008-DWQ adopted in August 1992). Stormwater discharges from San Jose Creek WRP is subject to requirements under these general permits.
15. Pursuant to 40 CFR Part 403, the CSDLAC developed and have implemented a USEPA approved industrial wastewater pretreatment program.
16. Effluent limitations, national standards of performance, toxic and pretreatment effluent standards, regulations, requirements, and/or guidelines established pursuant to Sections 208(b), 301, 302, 303(d), 304, 306, 307, and 405 of the Clean Water Act, and amendments thereto, are applicable to the discharges.
17. Except for constituents imposed in the previous permit, no numerical limit is prescribed for any toxic constituent that is consistently not detectable in the effluent and where it has been determined that there is a very low probability of causing or contributing to excursions in water quality standards. A narrative limit to comply with all water quality objectives is provided in lieu of such numerical limits.
18. The requirements contained in this Order are based on the Basin Plan, other federal and state plans, policies, guidelines, plant performance, and best engineering judgement; and, as they are met, will be in conformance with the goals of the aforementioned water quality control plans and will protect and maintain existing beneficial uses of the receiving water.
19. The Discharger's monitoring data during 1989-1994 consistently showed high effluent quality. To maintain the plant

performance, effluent quality performance goals are prescribed in this Order. This approach requires the Discharger to maintain its treatment efficiency, while recognizing normal variations in treatment plant operations, influent quality, and sampling and analytical techniques. However, this approach does not address substantial changes in plant operations that may occur in the future and could affect the quality of the treated effluent. As such, the performance goals may be modified by the Executive Officer, if warranted.

For pollutants which have been routinely detected in the effluent, the performance goals are statistically set at the 95th percentile of the 1989-1994 plant performance data. At the 95th percentile, it is expected that one sample in twenty would exceed the goal in the long term.

For other pollutants whose effluent monitoring data have consistently showed non-detectable levels or occasionally detected at levels less than the Practical Quantitation Level (PQL), the effluent quality performance goals are set at the PQL. The PQL is determined by multiplying the USEPA published method detection limit (MDL) or the Discharger's MDL approved by the Executive Officer with the factor five (5) for carcinogens and ten (10) for non-carcinogens.

20. The issuance of waste discharge requirements for this discharge is exempt from the provisions of Chapter 3 (commencing with Section 21100) of Division 13 of the Public Resources Code (California Environmental Quality Act) in accordance with Water Code Section 13389.

The Regional Board has notified the discharger and interested agencies and persons of its intent to issue waste discharge requirements for this discharge and has provided them with an opportunity to submit their written views and recommendations.

The Regional Board, in a public hearing, heard and considered all comments pertaining to the discharge and to the tentative requirements.

This Order shall serve as a National Pollutant Discharge Elimination System permit pursuant to Section 402 of the Federal Clean Water Act or amendments thereto, and shall take effect at the end of ten days from the date of its adoption provided the Regional Administrator, USEPA, has no objections.

**IT IS HEREBY ORDERED** that County Sanitation Districts of Los Angeles, in order to meet the provisions contained in Division 7 of the California Water Code and regulations adopted thereunder, and

the provisions of the Federal Clean Water Act and regulations and guidelines adopted thereunder, shall comply with the following:

I. DISCHARGE REQUIREMENTS

A. Effluent Limitations

1. Wastes discharged shall be limited to treated municipal wastewater only, as proposed.
2. The pH of wastewater discharged shall at all times be within the range of 6.0 and 9.0.
3. The temperature of wastewater discharged shall not exceed 100°F.
4. The discharge of an effluent with constituents in excess of the following limits is prohibited:

a. Discharge Serial Nos. 001,002, 003

<u>Constituents</u>	<u>Units</u>	<u>Discharge Limitations</u>		
		<u>30-Day Average<sup>1/</sup></u>	<u>7-Day Average<sup>1/</sup></u>	<u>Daily Maximum<sup>2/</sup></u>
Settleable solids	ml/l	0.1	-----	0.3
Suspended solids	mg/l	15	40	45
	lbs/day <sup>3/</sup>	12,510	33,360	37,530
Oil and grease	mg/l	10	-----	15
	lbs/day <sup>3/</sup>	8,340	-----	12,510
BOD <sub>5</sub> 20°C	mg/l	20	30	45
	lbs/day <sup>3/</sup>	16,680	25,020	37,530

<u>Constituents</u>	<u>Units</u>	<u>Discharge Limitations</u>
		<u>30-Day Average<sup>5/</sup></u>
Antimony	µg/l	6 <sup>4/</sup>
	lbs/day <sup>3/</sup>	5
Arsenic	µg/l	50 <sup>4/</sup>
	lbs/day <sup>3/</sup>	41

<u>Constituents</u>	<u>Units</u>	<u>Discharge Limitations</u>
		30-Day <u>Average</u> <sup>5/</sup>
Barium	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	1,000 <sup>4/</sup> 834
Cadmium	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	5 <sup>4/</sup> 4.2
Chromium (VI) <sup>6/</sup>	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	50 <sup>4/</sup> 42
Lead	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	50 <sup>4/</sup> 42
Mercury	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	2 <sup>4/</sup> 1.7
Nickel	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	100 <sup>4/</sup> 83.4
Selenium	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	50 <sup>4/</sup> 42
Silver	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	50 <sup>4/</sup> 42
Zinc	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	5,000 <sup>4/</sup> 4,200
Cyanide <sup>7/</sup>	$\mu\text{g/l}$ lbs/day <sup>3/</sup>	5.2 4.4

b. Discharge Serial Nos. 002, 003

<u>Constituents</u>	<u>Units</u>	<u>Discharge Limitations</u>
		Daily <u>Maximum</u>
Total dissolved solids	mg/l lbs/day <sup>3/</sup>	750 625,500
Chloride <sup>8/</sup>	mg/l lbs/day <sup>3/</sup>	150 125,100
Sulfate	mg/l lbs/day <sup>3/</sup>	250 208,500

<u>Constituents</u>	<u>Units</u>	<u>Discharge Limitations</u>
		Daily <u>Maximum</u>
Boron	mg/l lbs/day <sup>3/</sup>	1.5 1,250
Nitrate-N + Nitrite-N (as Nitrogen)	mg/l lbs/day <sup>3/</sup>	10 8,340
Fluoride	mg/l lbs/day	1.6 1,334
Detergents (as MBAS)	mg/l lbs/day	0.5 417

- 
- 1/ As defined in Standard Provisions, Attachment N.
  - 2/ Except for grab sample, the daily maximum effluent concentration limit shall apply to flow-weighted 24-hour composite samples.
  - 3/ Based on the plant design flow rate of 100 mgd. The mass discharge rate limitations will accordingly be modified upon certification and approval of increased treatment capacity. During events such as storms in which the flow exceeds the design capacity, the mass discharge rate limitations will be tabulated using the concentration limits and the actual flow rates
  - 4/ Based on total recoverable metals. These limits may be modified to total dissolved metals if the Discharger requests and has conducted a study on the water-effect ratio (WER) according to the USEPA guidance document and/or state protocols, if available.
  - 5/ Compliance may be determined from a single analysis or from the average of the initial analysis and three additional analyses taken one week apart once the results of the initial analysis are obtained,
  - 6/ The Discharger may, at his option, meet this limitation as total chromium.
  - 7/ The recovery of free cyanide from metal complexes must be comparable to that achieved by Standard Methods 412 F, G, and H (Standard Methods for the Examination of Water and Wastewater; Joint Editorial Board, American Public Health Association, American Water Works, and Water Pollution Control Federation [Water Environment Federation]; Most recent edition).
  - 8/ In accordance with the Resolution 90-004, the chloride limitation shall not be considered to be violated unless the effluent concentrations of chlorides exceed 250 mg/l or water supply concentrations plus 85 mg/l, which is less.
5. Radioactivity of the wastes discharged shall not exceed the limits specified in Title 22, Chapter 15, Article 5, Section 64443, of the California Code of Regulations, or subsequent revisions.
6. The arithmetic mean of BOD<sub>5</sub>20°C and suspended solids values, by weight, for effluent samples collected in a period of 30 consecutive calendar days shall not exceed 15 percent of the arithmetic mean of values, by weight, for influent samples collected at approximately the same time during the same period.
7. The wastes discharged to watercourses shall at all times be adequately disinfected. For the purpose of this



requirement, the wastes shall be considered adequately disinfected if the median number of coliform organisms at some point in the treatment process does not exceed 2.2 per 100 milliliters, and the number of coliform organisms does not exceed 23 per 100 milliliters in more than one sample within any 30-day period. The median value shall be determined from the bacteriological results of the last seven (7) days for which analysis have been completed. Samples shall be collected at a time when wastewater flow and characteristics are most demanding on treatment facilities and disinfection processes.

8. The wastes discharged to water courses shall have received treatment equivalent to that of filtered wastewater. Filtered wastewater means oxidized and coagulated wastewater which has been passed through natural undisturbed soils or filter media, such as sand or distomaceous earth, so that the turbidity of the filtered wastewater does not exceed (a) a daily average of 2 Nephelometric turbidity units (NTU's), (b) and does not exceed 5 NTU's more than 5 percent of the time (72 minutes) during any 24 hour period.

"Oxidized wastewater" means wastewater in which the organic matter has been stabilized, is nonputrescible, and contains dissolved oxygen. "Coagulated wastewater" means oxidized wastewater in which colloidal and finely divided suspended matter have been destabilized and agglomerated upstream of a filter by the addition of suitable floc-forming chemicals.

NTU means a measurement of turbidity as determined by the ratio of the intensity of light scattered by the sample to the intensity of incident light using approved laboratory methods.

9. Acute Toxicity Limitation:

- a. The acute toxicity of the effluent shall be such that the average survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, with no single test less than 70% survival.
- b. If the discharge consistently exceeds the acute toxicity limitations, a toxicity reduction evaluation (TRE) is required. The TRE shall include all reasonable steps to identify the source(s) of toxicity.

B. Effluent Quality Performance Goals

The Discharger shall make best efforts to maintain the following effluent quality goals. Any exceedance of any goal shall trigger an investigation by the Discharger on the cause of the exceedance. The Discharger shall report to the Regional Board on a quarterly basis any exceedance of any of these effluent quality goals. If exceedance of any particular goal persists on two succeeding quarterly monitoring periods, the Discharger shall submit with the second quarterly report the investigation results including but not limited to the description of the exceedance, cause(s) of the exceedance, and proposed corrective measures, if necessary. If the exceedance of any goal become chronic, the Discharger shall proceed to implement the proposed action plan to correct the exceedance. The Executive Officer may modify the action plan.

The Executive Officer may modify any of the performance goals if the Discharger requests and has demonstrated that the change is warranted.

<u>EFFLUENT QUALITY PERFORMANCE GOALS</u>			
<u>Constituents</u>	<u>Units</u>	<u>30-day Average</u>	<u>Daily Maximum</u>
BOD <sub>5</sub> 20°C	mg/l	18.0 <sup>9/</sup>	----
Suspended solids	mg/l	3.2 <sup>9/</sup>	----
Arsenic	µg/l	-----	4 <sup>9/</sup>
Chromium(VI) <sup>6/</sup>	µg/l	-----	20 <sup>9/</sup>
Copper	µg/l	-----	40 <sup>9/</sup>
Lead	µg/l	-----	30 <sup>9/</sup>
Nickel	µg/l	-----	40 <sup>9/</sup>
Selenium	µg/l	-----	10 <sup>9/</sup>
Silver	µg/l	-----	20 <sup>9/</sup>
Zinc	µg/l	-----	1,000 <sup>9/</sup>
Remaining priority pollutants	µg/l	-----	PQL <sup>10/</sup>

9/ Numerical effluent quality performance goals were derived statistically using effluent performance data for the period of 1989 through 1994. Effluent values (Xi) are assumed to be lognormally distributed. The use of logarithmic transformation equation, Yi = Ln (Xi), results in effluent values (Yi) that are normally distributed. Effluent quality performance goals are determined by the equation:

$$X_{0.95} = \exp [un + (Z_{95th}) (\sigma_n)]$$

where X<sub>0.95</sub> = discharge effluent quality performance goal at the 95th percentile of the normal distribution.

un = mean of the distribution of the average of n values transformed.

Z<sub>0.95</sub> = z-value from the Table of Areas under the Standard Normal Curve: equal to 1.645 at 95 percent.

σ<sub>n</sub> = standard deviation of the distribution of the average of n values transformed.

Exp is a base "e" exponential, value = 2.7183

10/ PQL (Practical Quantitation Limit) shall be determined by multiplying the USEPA published method detection limit (MDL) (Attachment 1) or the Discharger's MDL approved by the Executive Officer with the factor five (5) for carcinogens and ten (10) for non-carcinogens).

C. RECEIVING WATER REQUIREMENTS

1. The pH of the receiving water shall not be depressed below 6.5 or raised above 8.5 as a result of wastes discharged. Ambient pH levels shall not be changed more than 0.5 units from natural conditions.
2. The temperature of the receiving water at any time or place and within any given 24-hour period shall not be increased by more than 5°F (or above 70°F if the ambient received water temperature is less than 60°F) as a result of the wastes discharged.
3. The discharge of wastes to lined watercourses or flood control channels shall not result in residual chlorine in concentrations greater than 0.1 mg/l at the points(s) of transition from a lined structure to an unlined structure or at the point of upstream beginning of the tidal prism of San Gabriel River.
4. The dissolved oxygen in the receiving water shall not be depressed below 5 mg/l as a result of the wastes discharged.
5. The fecal coliform concentration shall not exceed a log mean of 200/100 ml (based on a minimum of not less than four samples for any 30-day period), nor shall more than 10% of total samples during any 30-day period exceed 400/100 ml.
6. The wastes discharged shall not produce concentrations of toxic substances in the receiving water that are toxic to or causes detrimental physiological responses in human, animal, or aquatic life.
7. The concentration of contaminants in waters which are existing or potential sources of drinking water shall not occur at levels which are harmful to human health.
8. The concentrations of toxic pollutants in the water column, sediments, or biota shall not adversely affect beneficial uses.
9. The wastes discharged shall not contain substances that result in increases in the BOD which adversely affect beneficial uses of the receiving water.

10. The wastes discharged shall not cause the receiving water to contain any substance in concentrations that adversely affect any designated beneficial use.
11. The wastes discharged shall not alter the natural taste, odor, color of fish, shellfish, or other surface water resources used for human consumption.
12. The wastes discharged shall not result in problems due to breeding of mosquitos, gnats, black flies, midges, or other pests.
13. The wastes discharged shall not result in visible floating particulates, foams, and oil and grease in the receiving water.
14. The wastes discharged shall not contain any individual pesticide or combination of pesticides in concentrations that adversely affect beneficial uses of the receiving waters. There shall be no increase in pesticide concentration found in bottom sediments or aquatic life.
15. The wastes discharged shall not increase the turbidity of the receiving water to the extent that such an increase causes nuisance or adversely affects beneficial uses.

D. Receiving Water Objective

1. To protect aquatic life, ammonia in receiving water shall not exceed concentrations specified in Tables 3-2 and 3-4 of the Basin Plan (Attachment 2) as a result of the wastes discharged, subject to the following conditions:.

The Discharger shall have up to 8 years following the adoption of this Order: (i) to make the necessary adjustments/improvements to meet these objectives; or (ii) to conduct studies leading to an approved less restrictive site specific objective for ammonia. If it is determined that there is an immediate threat or impairment of beneficial uses due to ammonia, the objectives in Table 3-2 and 3-4 of Attachment 2 shall apply and the timing of compliance will be determined on a case-by-case basis.

2. To protect underlying groundwater basins, ammonia shall not be present in the wastes discharged at levels that when oxidized to nitrate will pose a threat to groundwater.

3. There shall be no chronic toxicity in ambient waters as a result of wastes discharged.

If the chronic toxicity in the receiving water downstream of the discharge point consistently exceeds 1.0 TU<sub>c</sub> in a critical life stage test, the Discharger shall determine if the cause of the exceedance is the wastes discharged. If it is determined that the wastes discharged caused the exceedance, the Discharger shall conduct a toxicity reduction evaluation (TRE). The TRE shall include all reasonable steps to identify the sources of toxicity. Once the sources are identified, the Discharger shall take all reasonable steps to reduce toxicity to meet the objective.

## II. SLUDGE REQUIREMENTS

For biosolids management, the Discharger must comply with all requirements of 40 CFR Parts 257, 258, 501, and 503, including all monitoring, recordkeeping, and reporting requirements.

Since the State of California, hence the Regional Board, has not been delegated the authority to implement the sludge program, enforcement of the sludge requirements contained in this Order and permit shall be the sole responsibility of USEPA.

## III. PRETREATMENT REQUIREMENTS

1. This Order includes the Discharger's pretreatment program as previously submitted to this Regional Board. Any change to the program shall be reported to the Regional Board and USEPA in writing and shall not become effective until approved by the Executive Officer and the USEPA Regional Administrator.
2. The Discharger shall implement and enforce its approved pretreatment program. The Discharger shall be responsible and liable for the performance of all pretreatment requirements contained in Federal Regulations 40 CFR Part 403 including subsequent regulatory revisions thereof. Where Part 403 or subsequent revision places mandatory actions upon the Discharger as Control Authority but does not specify a timetable for completion of the actions, the Discharger shall complete the required actions within six months from the effective date of this Order and permit or the effective date of the Part 403 revisions,

whichever comes later. For violations of pretreatment requirements, the Discharger shall be subject to enforcement actions, penalties, fines, and other remedies by USEPA, Regional Board, or other appropriate parties, as provided in the Clean Water Act. USEPA or the Regional Board may initiate enforcement action against an industrial user for noncompliance with applicable standards and requirements as provided in the Clean Water Act and/or the California Water Code.

3. The Discharger shall enforce the requirements promulgated under Sections 307(b), 307(c), 307(d), and 402(b) of the Clean Water Act. The Discharger shall cause industrial users subject to the Federal Categorical Standards to achieve compliance no later than the date specified in those requirements or, in the case of a new industrial user, upon commencement of the discharge.
4. The Discharger shall perform the pretreatment functions as required in the Federal Regulations 40 CFR Part 403 including, but not limited to:
  - a. Implement the necessary legal authorities as provided in 40 CFR 403.8(f) (1);
  - b. Enforce the pretreatment requirements under 40 CFR 403.5 and 403.6;
  - c. Implement the programmatic functions as provided in 40 CFR 403.8(f) (2); and
  - d. Provide the requisite funding and personnel to implement the pretreatment program as provided in 40 CFR 403.8(f) (3).
5. The Discharger shall submit annually a report to the USEPA, Region 9, the Regional Board, and the State Board, describing the Discharger's pretreatment activities over the previous twelve months. In the event of noncompliance with any conditions or requirements of this permit, then the Discharger will also include the reasons for noncompliance and state how and when the Discharger shall comply with such conditions and requirements. This annual report shall cover operations from January 1 through December 31 of the previous year and is due on April 1 of each year and shall contain, but not be limited to, the information required in the attached "Requirements for Pretreatment Annual Report." (Attachment 3), or an approved revised version thereof.

#### IV. REQUIREMENTS AND PROVISIONS

1. This Order and permit includes the attached Monitoring and Reporting Program (Attachment T). If there is any conflict between provisions stated in the Monitoring and Reporting Program and the Standard Provisions,, those provisions in the former prevail.
2. This Order includes the attached "Standard Provisions and General Monitoring and Reporting Requirements". (Standard Provisions, Attachment N). If there is any conflict between provisions stated hereinbefore and said "Standard Provisions", those provisions stated hereinbefore prevail.
3. Any discharge of wastes at any point other than specifically described in this order and permit is prohibited, and constitute a violation thereof.
4. This Order and permit include the requirements of the State Water Resources Control Board's General NPDES permits for discharge of storm water associated with industrial activity (Order No. 91-13-DWQ, as amended by Order No. 92-12-DWQ, Attachment S-I).
5. Standby or emergency power facilities and/or storage capacity or other means shall be provided so that in the event of plant upset or outage due to power failure or other cause, discharge of raw or inadequately treated sewage does not occur.
6. The Discharger shall comply with all applicable effluent limitations, national standards of performance, toxic and pretreatment effluent standards, and all federal regulations established pursuant to Sections 301, 302, 303(d), 304, 306, 307, 316, and 405 of the Clean Water Act and amendments thereto.
7. The Discharger shall protect the facility from inundation which could occur as a result of a flood having a predicted frequency of once in 100 years.
8. This order and permit may be modified, revoked, and reissued or terminated in accordance with the provisions of 40 CFR Parts 122.44, 122.62, 122.63, 122.64, 125.62, and 125.64.

V. Expiration Date

This Order expires on May 10, 2000.

The Discharger must file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, not later than 180 days in advance of the expiration date as application for issuance of new waste discharge requirements.

VI. Rescission

Order No. 89-026 adopted by this Board on March 27, 1989 is hereby rescinded, except for purposes of enforcement.

I, Robert P. Ghirelli, Executive Officer, do hereby certify that the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region on June 12, 1995.



ROBERT P. GHIRELLI, D.Env.  
Executive Officer

/JT