



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

Los Angeles Regional Water Quality Control Board

October 9, 2013

Mr. Adrian Rosu
Environmental Engineer
Tesoro Refining & Marketing Company, LLC
Los Angeles Refinery – Calciner Operations
1175 Carrack Avenue
Wilmington, CA 90748 -1028

VIA CERTIFIED MAIL
RETURN RECEIPT REQUESTED
7099 3220 0006 2237 7555

Dear Mr. Rosu:

TRANSMITTAL OF WASTE DISCHARGE REQUIREMENTS AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT (ORDER NO. R4-2013-0157), AND TIME SCHEDULE ORDER (ORDER NO. R4-2013-0158), FOR TESORO REFINING & MARKETING COMPANY LLC, (FORMER BP WEST COAST PRODUCTS LLC) TESORO (FORMER BP) WILMINGTON CALCINER, WILMINGTON, CA. (NPDES NO. CA0059153, CI 6571)

Our letter dated September 24, 2013, transmitted the revised tentative Waste Discharge Requirements (WDRs) for renewal of your permit for the discharge of wastes under the National Pollutant Discharge Elimination System (NPDES) Program and a revised tentative Time Schedule Order (TSO).

Pursuant to Division 7 of the California Water Code, this Regional Water Board at a public hearing held on October 3, 2013, reviewed the revised tentative requirements, considered all factors in the case, and adopted Order No. R4-2013-0157 (NPDES permit) and TSO No. R4-2013-0158.

Order R4-2013-0157 serves as an NPDES permit, and it is scheduled to expire on November 22, 2018. Section 13376 of the California Water Code requires that an application/Report of Waste Discharge for a new permit must be filed at least 180 days before the expiration date. The TSO No. R4-2013-0158 is scheduled to expire on November 22, 2018.

You are required to implement the Monitoring and Reporting Program (MRP) on the effective date (November 22, 2013) of Order No. R4-2013-0157. Your first monitoring report for the period of November 2013 through December 2013 is due by February 1, 2014. The first technical and/or progress report required under TSO No. R4-2013-0158 is due by the 15th of February 2014, as listed on page 7 of the TSO. Submit all monitoring and technical/progress reports to the Regional Water Board, ATTN: Information Technology Unit.

The Regional Water Board is implementing a paperless office system to reduce paper use, increase efficiency and provide a more effective way for our staff, the public and interested parties to view water quality documents. Therefore, please convert all regulatory documents, submissions, data and correspondence that you would normally submit to us as hard copies to

MARIA MEHRANIAN, CHAIR | SAMUEL UNGER, EXECUTIVE OFFICER

320 West 4th St., Suite 200, Los Angeles, CA 90013 | www.waterboards.ca.gov/losangeles

a searchable Portable Document Format (PDF). Documents that are less than 10 megabyte (MB) should be emailed to losangeles@waterboards.ca.gov. Documents that are 10 MB or larger should be transferred to a disk and mailed to the address listed below. If you need additional information regarding electronic submittal of documents please visit the Regional Water Board's website listed above and navigate to Paperless Office.

**California Regional Water Quality Control Board
Los Angeles Region
320 W. 4th Street, Suite 200
Los Angeles, CA 90013**


When submitting monitoring or technical reports to the Regional Water Board per these requirements, please include a reference to Compliance File CI-6571 and NPDES No. CA0059153, which will assure that the reports, are directed to the appropriate file and staff. Please do not combine your discharge monitoring reports with other reports, such as technical/progress reports. Submit each type of report as a separate document.

We are sending the paper copy of the Permit and TSO to the Discharger only. For those on the mailing list or other interested parties who would like access to a copy of the Permit, please go to the Regional Water Board's website at:

[http://www.waterboards.ca.gov/losangeles/board decisions/adopted orders/by permits tools.shtml](http://www.waterboards.ca.gov/losangeles/board%20decisions/adopted%20orders/by%20permits%20tools.shtml).

If you would like a hard copy of the TSO or if you have any questions, please contact Rosario Aston at (213) 576-6653.

Sincerely,



Cassandra D. Owens, Chief
Industrial Permitting Unit

cc: See Mailing List

Enclosure: Order No. R4-2013-0157 - Waste Discharge Requirements
Attachment E - Monitoring and Reporting Program (MRP No. 6571)
Attachment F - Fact Sheet
Order No. R4-2013-0158 - Time Schedule Order

Mailing List (Via Email Only)

Environmental Protection Agency, Region 9, Permits Branch (WTR-5)
U.S. Army Corps of Engineers
NOAA, National Marine Fisheries Service
Department of Interior, U.S. Fish and Wildlife Service
NPDES Wastewater Unit, State water Resources Control Board, Division of Water Quality
Mr. William Paznokas, Department of Fish and Game, Region 5
Department of Health Services, Sanitary Engineering Section
California Coastal Commission, South Coast Region
South Coast Air Quality Management District
Water Replenishment District of Southern California
Los Angeles County, Department of Public Works, Waste Management Division
Ms. Leah G. Walker, Department of Public Health, Division of Drinking Water and
Environment Management
City of Wilmington
Ms. Kirsten James, Heal the Bay
Ms. Liz Crosson, Los Angeles WaterKeeper
Ms. Anna Kheyfets, Natural Resources Defense Council
Mr. Jae Kim, Tetra Tech

**ORDER NO. R4-2013-0157
NPDES NO. CA0059153**

**WASTE DISCHARGE REQUIREMENTS
FOR
TESORO REFINING & MARKETING COMPANY LLC
TESORO WILMINGTON CALCINER**

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

LOS ANGELES REGION

320 W. 4th Street, Suite 200, Los Angeles, California 90013
Phone (213) 576 - 6600 • Fax (213) 576 - 6640
<http://www.waterboards.ca.gov>

ORDER NO. R4-2013-0157
NPDES NO. CA0059153

**WASTE DISCHARGE REQUIREMENTS
FOR
TESORO REFINING & MARKETING COMPANY LLC
(FORMER BP WEST COAST PRODUCTS LLC)
TESORO WILMINGTON CALCINER
(FORMER BP WILMINGTON CALCINER)**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

| | |
|--|---|
| Discharger | Tesoro Refining & Marketing Company LLC (Former BP West Coast Products LLC) |
| Name of Facility | Tesoro Wilmington Calciner (Former BP Wilmington Calciner) |
| Facility Address | 1175 Carrack Avenue |
| | Wilmington, CA 90744 |
| | Los Angeles County |
| The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a minor discharge. | |

The discharge by Tesoro Refining & Marketing Company LLC from the discharge points identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location


| Discharge Point | Effluent Description | Discharge Point Latitude | Discharge Point Longitude | Receiving Water |
|------------------------|---|---------------------------------|----------------------------------|---|
| 001 | Treated wastewater consisting of green coke drainage and miscellaneous wash water, boiler safety relief system blowdown, boiler feed water pump seal flush, cooling tower overflow, and storm water runoff. | 33° 46' 29" N | 118° 13' 39" W | Cerritos Channel (Los Angeles-Long Beach Inner Harbors) |

Table 3. Administrative Information

| | |
|---|--|
| This Order was adopted by the Regional Water Quality Control Board on: | October 3, 2013 |
| This Order shall become effective on: | November 22, 2013 |
| This Order shall expire on: | November 22, 2018 |
| The Discharger shall file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than: | 180 days prior to the Order expiration date |

IT IS HEREBY ORDERED, that Order No. R4-2007-0031 is terminated upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted pursuant thereto, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted pursuant thereto, the Discharger shall comply with the requirements in this Order.

I, Samuel Unger, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Los Angeles Region, on October 3, 2013.



Samuel Unger, P.E.
Executive Officer

Table of Contents

| | | |
|------|---|----|
| I. | Facility Information | 5 |
| II. | Findings | 6 |
| III. | Discharge Prohibitions..... | 14 |
| IV. | Effluent Limitations and Discharge Specifications | 14 |
| | A. Effluent Limitations..... | 14 |
| | B. Land Discharge Specifications..... | 16 |
| | C. Reclamation Specifications..... | 17 |
| V. | Receiving Water Limitations | 17 |
| | A. Surface Water Limitation..... | 17 |
| | B. Groundwater Limitations | 19 |
| VI. | Provisions | 19 |
| | A. Standard Provisions..... | 19 |
| | B. Monitoring and Reporting Program (MRP) Requirements | 22 |
| | C. Special Provisions..... | 22 |
| | 1. Reopener Provisions..... | 22 |
| | 2. Special Studies, Technical Reports, and Additional Monitoring Requirements..... | 23 |
| | 3. Storm Water Pollution Prevention Plan, Best Management Practices, and Spill Contingency Plan..... | 25 |
| | 4. Construction, Operation and Maintenance Specifications..... | 26 |
| | 5. Special Provisions for Municipal Facilities (POTWs Only) | 26 |
| | 6. Other Special Provisions..... | 26 |
| | 7. Compliance Schedules | 26 |
| VII. | Compliance Determination | 26 |

List of Tables

| | | |
|----------|--|----|
| Table 1. | Discharger Information | 1 |
| Table 2. | Discharge Location..... | 1 |
| Table 3. | Administrative Information | 2 |
| Table 4. | Facility Information | 5 |
| Table 5. | Basin Plan Beneficial Uses..... | 10 |
| Table 6. | Effluent Limitations for Discharge Point No. 001 | 15 |
| Table 7. | Monitoring Thresholds..... | 24 |
| Table 8. | Sediment Chemistry Monitoring Requirements | 25 |

List of Attachments

| | |
|---|-----|
| Attachment A – Definitions | A-1 |
| Attachment B – Map | B-1 |
| Attachment C – Flow Schematic..... | C-1 |
| Attachment D – Standard Provisions..... | D-1 |
| Attachment E – Monitoring and Reporting Program (MRP No. 6571) | E-1 |
| Attachment F – Fact Sheet..... | F-1 |
| Attachment G – Storm Water Pollution Prevention Plan Requirements | G-1 |
| Attachment H – State Water Board Minimum Levels (µg/L) | H-1 |
| Attachment I – List of Priority Pollutants | I-1 |
| Attachment J – Reasonable Potential Analysis and Calculation of Effluent limitations..... | J-1 |

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

| | |
|---|---|
| Discharger | Tesoro Refining & Marketing Company LLC |
| Name of Facility | Tesoro Wilmington Calciner |
| Facility Address | 1175 Carrack Avenue |
| | Wilmington, CA 90744 |
| | Los Angeles County |
| Facility Contact, Title, and Phone | Adrian Rosu, Environmental Engineer, 562-499-3210 |
| Mailing Address | P.O. Box 1028 Wilmington, CA 90748 |
| Type of Facility | Petroleum Coke Calcining Facility (SIC 2999) |
| Facility Design Flow | 1.1 million gallons per day (MGD) |

II. FINDINGS

The California Regional Water Quality Control Board, Los Angeles Region (hereinafter Regional Water Board), finds:

A. Background. Tesoro Refining & Marketing Company LLC, Former BP West Coast Products LLC (hereinafter Discharger) is currently discharging storm water and wastewater associated with industrial activities from the Tesoro Wilmington Calciner, Former BP Wilmington Calciner (hereinafter Facility) pursuant to Order No. R4-2007-0031 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0059153. Order No. R4-2007-0031 was adopted by the Regional Water Board adopted on June 7, 2007, and expired on May 10, 2012. As per 40 CFR section 122.6, Order No. R4-2007-0031 has been administratively extended and remains in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order.

The Discharger submitted a Report of Waste Discharge (ROWD), dated October 14, 2011, and applied for an NPDES permit renewal to discharge up to 1.1 million gallons per day (MGD) of treated wastewater from the Facility. Supplemental information was received on January 10, 2012, and January 26, 2012. The application was deemed complete on January 26, 2012.

On November 28, 2011, and April 2, 2013, PG Environmental, LLC (contractor with the U.S. Environmental Protection Agency) and Regional Water Board staff, respectively, conducted a site visit to review current site conditions and operations of the Facility.

For the purposes of this Order, references to the “Discharger” or “Permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

B. Facility Description. The Facility is owned and operated by Tesoro Refining & Marketing Company LLC. The Facility is a petroleum coke calcining facility located at 1175 Carrack Avenue in Wilmington, California. The green coke comes from BP’s Carson Refinery and is transported by truck and occasionally by rail car to the Facility. The green coke (petroleum coke from a refinery’s coke unit) is run through a large rotary kiln to remove water and other impurities to produce calcined coke. The industrial and sanitary wastewaters generated by the Facility are discharged into a Los Angeles County sanitary sewer under an industrial pretreatment permit issued by the Sanitation Districts of Los Angeles County, California (Permit No. 015671).

The Facility has a reverse osmosis (RO) system utilized to treat potable water (from the City) to be used as boiler feed water. The potable water that is rejected by the RO system is conveyed to the cooling tower. The wastewater generated by the RO system is discharged to the sanitary sewer under Permit No. 015671.

The remaining wastewaters generated by the Facility, consist of storm water combined with process wastewaters (boiler safety relief system blowdown, boiler feed

water pump seal flush, green coke drainage, miscellaneous wash waters, and cooling tower overflow) are discharged to surface waters only when the retention basin reaches full capacity. The Facility's impervious areas are sloped to convey storm water and process waters to one of two lift stations which pump collected water to the Facility's settling basins. The treatment system consists of two, concrete-lined, 2-compartment settling basins (eastern and western basin; 110,000 gallons each) which are used for removal of settleable solids. Following treatment in the settling basins, the waste stream flows into a 680,000-gallon retention basin for additional settling and neutralization with sulfuric acid (as needed). The treated wastewater is recycled back to the Facility for use as cooling water. During normal operations, the Facility recycles all water from the forge basin and uses it as cooling tower make up water in all but extremely large storm events where rainfall is higher than the recycling rate.

Using this storm water intake and recycling system, the Facility has eliminated most discharge events from the Facility to the receiving water. In December 2010, the Facility encountered the largest amount of rainfall in the Long Beach area since about 1984 and successfully managed all storm water on site without discharging. The December 2010 storm event enabled the Facility to evaluate its retention capacity and storm water handling procedures and to enhance its management of storm water significantly such that now the Facility ensures that 80 percent of its basin remains available for storm events. The Facility has also secured an increased discharge limit to the local LACSD to enable it to discharge additional wastewater, including cooling tower blowdown, if necessary, at all times (including during storm events) thereby enabling the Facility to recycle a higher amount of storm water through the cooling tower. Based on experience and recent engineering studies, the Facility confirmed that its design enables the retention of a 50-year, 24-hour storm event (i.e. a 24-hour amount of precipitation that will occur once in a 50-year period, on average).

When the retention basin reaches full capacity, usually during or following significant storm events, the treated wastewater is discharged from Discharge Point No. 001 to the Cerritos Channel, a water of the United States and a tributary to Los Angeles-Long Beach Inner Harbor within the Dominguez Channel/Los Angeles-Long Beach Harbor Watershed.

No discharges occurred during the term of Order No. R4-2007-0031. The most recent discharge event occurred in January 2005.

C. Legal Authorities. This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the USEPA and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with Section 13260).

D. Background and Rationale for Requirements. The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact

Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E and G through J are also incorporated into this Order.

E. California Environmental Quality Act (CEQA). Under Water Code Section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code Sections 21100-21177.

F. Technology-based Effluent Limitations. Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, Title 40 of the Code of Federal Regulations¹ (40 CFR), require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Best Professional Judgment (BPJ) in accordance with 40 section 125.3. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet (Attachment F).

G. Water Quality-Based Effluent Limitations. Section 301(b) of the CWA and 40 CFR section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

40 CFR section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA Section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR section 122.44(d)(1)(vi).

H. Watershed Management Approach and Total Maximum Daily Loads (TMDLs).

The Regional Water Board has implemented the Watershed Management Approach to address water quality issues in the region. Watershed management may include diverse issues as defined by stakeholders to identify comprehensive solutions to protect, maintain, enhance, and restore water quality and beneficial uses. To achieve this goal, the Watershed Management Approach integrates the Regional Water Board's many diverse programs, particularly NPDES with TMDLs, to better assess cumulative impacts of pollutants from all point and nonpoint sources. A TMDL is a tool for implementing water quality standards and is based on the relationship between pollution sources and in-stream water quality conditions. The TMDL establishes the allowable

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

loadings or other quantifiable parameters for a waterbody and thereby provides the basis to establish water quality based controls. These controls should provide the pollution reduction necessary for a waterbody to meet water quality standards. This process facilitates the development of watershed-specific solutions that balance the environmental and economic impacts within the watershed. The TMDLs will establish waste load allocations (WLAs) and load allocations (LAs) for point and non-point sources, and will result in achieving water quality standards for the waterbody.

The USEPA approved the State's 2010 303(d) list of impaired water bodies on November 12, 2010. Certain receiving waters in the Los Angeles and Ventura Counties' watersheds do not fully support beneficial uses and therefore have been classified as impaired on the 2010 303(d) list and have been scheduled for TMDL development. The 2010 State Water Resources Control Board (State Water Board) 303(d) List classifies the Los Angeles/Long Beach Inner Harbor, to which the Cerritos Channel is tributary, as impaired due to beach closures, benthic community effects, benzo(a)pyrene (3,4-benzopyrene-7-d), chrysene (C1-C4), copper, dichlorodiphenyltrichloroethane (DDT), polychlorinated biphenyls (PCBs), sediment toxicity, and zinc.

The following are summaries of the TMDLs for the Los Angeles/Long Beach Harbor Inner Harbor:

- 1. Bacteria TMDL.** The Regional Water Board approved the Los Angeles Harbor Bacteria TMDL through Resolution 2004-011 on July 1, 2004. The State Water Board, Office of Administrative Law (OAL), and USEPA approved the TMDL on October 21, 2004, January 5, 2005, and March 1, 2005, respectively. The Bacteria TMDL became effective on March 10, 2005. The Bacteria TMDL addresses Inner Cabrillo Beach and the Main Ship Channel of the Los Angeles Inner Harbor. This Order includes bacteria limitations based on water quality standards (WQS) applicable to Cerritos Channel. These WQS (and WQBELs) are identical to the WQS used to develop the Bacteria TMDL that is applicable to the Main Ship Channel immediately downstream of Cerritos Channel.
- 2. Harbor Toxics TMDL.** The Regional Water Board adopted Resolution No. R11-008 on May 5, 2011, that amended the Basin Plan to incorporate the *TMDL for Toxic Pollutants in Dominguez Channel and Greater Los Angeles and Long Beach Harbors Waters* (Harbor Toxics TMDL). The Harbor Toxic TMDL was approved by the State Water Board on February 7, 2012, the OAL on March 21, 2012, and the USEPA on March 23, 2012. The Harbor Toxics TMDL contains requirements applicable to this discharge. Therefore, this Order contains effluent limitations and monitoring requirements based on the TMDL. The provisions of this permit implement and are consistent with the assumptions and requirements of all waste load allocations (WLAs) established in the Harbor Toxics TMDLs.

For Cerritos Channel which is located within the Long Beach Inner Harbor the Harbor Toxics TMDL included:

- a. Sediment interim concentration-based allocations (in mg/kg sediment) for copper, lead, zinc, DDT, PAHs, and PCBs (Attachment A to Resolution No. R11-008, p. 11).
- b. Water column final concentration-based waste load allocations (WLAs) (ug/L) for copper, lead, zinc, 4,4'-DDT and total PCBs (Attachment A to Resolution No. R11-008, pp. 13-14).
- c. Provisions for monitoring discharges and/or receiving waters during the TMDL's 20 year implementation schedule to determine attainment with waste load and load allocations as appropriate.

I. Water Quality Control Plans. The Regional Water Board adopted a Water Quality Control Plan for the Los Angeles Region (hereinafter Basin Plan) on June 13, 1994, that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply.

The Basin Plan on Page 2-4 states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan does not specifically identify beneficial uses for the Cerritos Channel, but does identify present and potential uses for Los Angeles-Long Beach Harbor (all other inner areas), to which the Cerritos Channel, via the Los Angeles-Long Beach Inner Harbor, is tributary. Thus, the beneficial uses applicable to the Cerritos Channel are as follows:

Table 5. Basin Plan Beneficial Uses

| Discharge Point | Receiving Water Name | Beneficial Use(s) |
|-----------------|---|--|
| 001 | Cerritos Channel Within Los Angeles/Long Beach Inner Harbor | <p><u>Existing:</u> Industrial service supply (IND); navigation (NAV); non-contact water recreation (REC-2); commercial and sport fishing (COMM); marine habitat (MAR); rare, threatened, or endangered species (RARE).</p> <p><u>Potential:</u> Water contact recreation (REC-1); shellfish harvesting (SHELL).</p> |

Requirements of this Order implement the Basin Plan.

J. Thermal Plan. The State Water Board adopted the *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains temperature objectives for inland and coastal surface waters. Requirements of this Order implement the Thermal Plan.

K. Ammonia Basin Plan Amendment. The 1994 Basin Plan provided water quality objectives for ammonia to protect aquatic life, in Table 3-1 through Table 3-4. However, those ammonia objectives were revised on March 4, 2004, by the Regional Water Board with the adoption of Resolution No. 2004-022, *Amendment to the Water Quality Plan for the Los Angeles Region to Update the Ammonia Objectives for Inland Surface Waters Not Characteristic of Freshwater (including enclosed bays, estuaries and wetlands)* with the Beneficial Use designations for protection of "Aquatic Life". The ammonia Basin Plan amendment was approved by OAL on September 14, 2004, and by USEPA on May 19, 2005. The amendment revised the Basin Plan by updating the ammonia objectives for inland surface waters not characteristic of freshwater such that they are consistent with the USEPA "Ambient Water Quality Criteria for Ammonia (Saltwater) – 1989." The amendment revised the regulatory provisions of the Basin Plan by adding language to Chapter 3, "Water Quality Objectives."

The amendment contains objectives for a 4-day average concentration of un-ionized ammonia of 0.035 mg/L, and a 1-hour average concentration of un-ionized ammonia of 0.233 mg/L. These objectives are fixed concentrations of un-ionized ammonia, independent of pH, temperature, or salinity. The amendment also contains an implementation procedure to convert un-ionized ammonia objectives to total ammonia effluent limitations.

L. National Toxics Rule (NTR) and California Toxics Rule (CTR). USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.

M. State Implementation Policy. On March 2, 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.

N. Alaska Rule. On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. (40 CFR § 131.21; 65 Fed. Reg. 24641 (April 27, 2000).) Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect

and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.

O. Stringency of Requirements for Individual Pollutants. This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on biochemical oxygen demand (BOD), oil and grease, total suspended solids (TSS), settleable solids, turbidity, and total petroleum hydrocarbons. Restrictions on these constituents are discussed in section IV.B of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

The WQBELs consist of restrictions on pH, acute toxicity, temperature, copper, lead, nickel, thallium, zinc, cyanide, 4,4'-DDT, and total PCBs. Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR Section 131.38. The scientific procedures for calculating the individual WQBELs for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 CFR Section 131.21(c)(1). The remaining water quality objectives and beneficial uses implemented by this Order (specifically bacteria and ammonia) were approved by USEPA on September 25, 2002, and May 19, 2005, respectively. Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

P. Antidegradation Policy. 40 CFR section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet the permitted discharge is consistent with the antidegradation provision of 40 CFR section 131.12 and State Water Board Resolution No. 68-16.

Q. Anti-Backsliding Requirements. Section 402(o) of the CWA establishes statutory language prohibiting the backsliding of effluent limits. Sections 402(o) of the CWA and federal regulations at title 40, Code Federal Regulations section 122.44(l) outlines specific exceptions to the general prohibition against establishment of less stringent effluent limitations.

These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. The effluent limitations included in this Order for copper, and zinc are less stringent than in the previous Order. As discussed in the Fact Sheet, this relaxation of effluent limitations is consistent with exceptions identified under Section 402(o).

- R. Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code Sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. Sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act.
- S. Monitoring and Reporting.** 40 CFR section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code Sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- T. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR section 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR section 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR section 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- U. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- V. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

THEREFORE, IT IS HEREBY ORDERED, that this Order supersedes Order No. R4-2007-0031 except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the Water Code (commencing with Section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

III. DISCHARGE PROHIBITIONS

- A. Wastes discharged shall be limited to a maximum of 1.1 MGD of treated wastewater consisting of storm water, boiler safety relief system blowdown, boiler feed water pump seal flush, green coke drainage, and miscellaneous wash waters from Discharge Point No. 001. The discharge of wastes from accidental spills or other sources is prohibited.
- B. Discharges of water, materials, thermal wastes, elevated temperature wastes, toxic wastes, deleterious substances, or wastes other than those authorized by this Order, to the Cerritos Channel, or other waters of the State, are prohibited.
- C. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or a nuisance as defined by Section 13050 of the Water Code.
- D. Wastes discharged shall not contain any substances in concentrations toxic to human, animal, plant, or aquatic life.
- E. The discharge shall not cause a violation of any applicable water quality standards for receiving waters adopted by the Regional Water Board or the State Water Board as required by the Federal CWA and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the Federal CWA, and amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.
- F. The discharge of any radiological, chemical, or biological warfare agent or high level radiological waste is prohibited.
- G. Any discharge of wastes at any point(s) other than specifically described in this Order is prohibited, and constitutes a violation of the Order.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations

1. Final Effluent Limitations – Discharge Point No. 001:

- a. The Discharger shall maintain compliance with the following effluent limitations at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001, as described in the attached Monitoring and Reporting Program (MRP) (Attachment E):

Table 6. Effluent Limitations for Discharge Point No. 001

| Parameter | Units | Effluent Limitations | | | | Performance Goals |
|---|----------------------|----------------------|---------------|-----------------------|-----------------------|--------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum | |
| Conventional Pollutants | | | | | | |
| pH | s.u. | -- | -- | 6.5 | 8.5 | -- |
| Biochemical Oxygen Demand (5-day @ 20 deg. C) (BOD) | mg/L | 20 | 30 | -- | -- | -- |
| | lbs/day ¹ | 183 | 275 | -- | -- | -- |
| Oil and Grease | mg/L | 10 | 15 | -- | -- | -- |
| | lbs/day ¹ | 92 | 138 | -- | -- | -- |
| Total Suspended Solids (TSS) ⁴ | mg/L | 30 | 75 | -- | -- | -- |
| | lbs/day ¹ | 275 | 688 | -- | -- | -- |
| Non-Conventional Pollutants | | | | | | |
| Settleable Solids | ml/L | 0.1 | 0.2 | -- | -- | -- |
| Temperature | °F | -- | -- | -- | 86 | -- |
| Total Petroleum Hydrocarbons (TPH) ² | µg/L | -- | 100 | -- | -- | -- |
| | lbs/day ¹ | -- | 0.92 | -- | -- | -- |
| Turbidity | NTU | 50 | 75 | -- | -- | -- |
| Priority Pollutants | | | | | | |
| Copper, Total Recoverable ^{3,4} | µg/L | 3.1 | 6.1 | -- | -- | -- |
| | lbs/day ¹ | 0.03 | 0.1 | -- | -- | -- |
| Lead, Total Recoverable ^{3,4} | µg/L | 7 | 14 | -- | -- | -- |
| | lbs/day ¹ | 0.1 | 0.1 | -- | -- | -- |
| Nickel, Total Recoverable | µg/L | 7 | 14 | -- | -- | -- |
| | lbs/day ¹ | 0.1 | 0.1 | -- | -- | -- |
| Thallium, Total Recoverable | µg/L | 6.3 | 13 | -- | -- | -- |
| | lbs/day ¹ | 0.1 | 0.1 | -- | -- | -- |
| Zinc, Total Recoverable ^{3,4} | µg/L | 70 | 141 | -- | -- | -- |
| | lbs/day ¹ | 0.6 | 1.3 | -- | -- | -- |
| Cyanide, Total (as CN) | µg/L | 0.5 | 1.0 | -- | -- | -- |
| | lbs/day ¹ | 0.005 | 0.01 | -- | -- | -- |
| 4,4'-DDT ^{3,4, A} | µg/L | 0.0006 | 0.001 | -- | -- | -- |
| | lbs/day ¹ | 5.4E-06 | 1.1E-05 | -- | -- | -- |
| Total PCBs ^{3,4,5} | µg/L | 0.0002 | 0.0003 | -- | -- | -- |
| | lbs/day ¹ | 1.6E-06 | 3.1E-06 | -- | -- | -- |
| PAHs | | | | | | |
| Benzo(a)pyrene ^{4,A} | µg/L | -- | -- | -- | -- | 0.049 ⁶ |
| Chrysene ^{4,A} | µg/L | -- | -- | -- | -- | 0.049 ⁶ |

¹ Mass (lbs/day) limitations are based on a maximum flow of 1.1 MGD and calculated as follows:

$$\text{Mass (lbs/day)} = \text{Flow (MGD)} \times \text{Concentration (mg/L)} \times 8.34 \text{ (conversion factor)}$$

² TPH equals the sum of TPH gasoline (C₄-C₁₂), TPH diesel (C₁₃-C₂₂), and TPH oil (C₂₃₊).

³ The effluent limitations are based on the USEPA approved Harbor Toxics TMDL WLAs and calculated using the CTR-SIP procedures.

- ⁴ During each reporting period, if effluent monitoring results exceed both a TSS effluent limit and a CTR TMDL-based effluent limit or performance goal for copper, lead, zinc, 4,4-DDT, total PCBs, benzo(a)pyrene, or chrysene, implementation of the effluent sediment monitoring program is required for that priority pollutant. Sediment monitoring of the effluent shall begin during the first discharge event following the effluent exceedances. An effluent sediment monitoring result at or below the interim sediment allocation in Table 7, page 24 of this Order, demonstrates attainment with the interim sediment allocation and additional sediment monitoring of the effluent is not required. A sediment monitoring result that exceeds the interim sediment allocation requires additional sediment monitoring of the effluent during discharge but not more frequently than once per year until the three-year average concentration for sediment monitoring results is at or below the interim sediment allocation.
- ⁵ Total PCBs (polychlorinated biphenyls) means the sum of chlorinated biphenyls whose analytical characteristics resembles those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254, and Aroclor-1260.
- ⁶ CTR human health criteria are not promulgated for total PAHs. Therefore, performance goals are based on CTR human health criteria for the individual PAHs, benzo(a)pyrene and chrysene. Benzo(a)pyrene and chrysene are selected because the State's 2010 303(d) List classifies the Los Angeles/Long Beach Inner Harbor as impaired for these PAH compounds. These performance goals are not enforceable effluent limitations. Rather, they act as triggers to determine when sediment monitoring is required for these compounds.
- ^A Samples analyzed must be unfiltered samples.

b. Bacteria Limitations Requirements.

1. Rolling 30-day Geometric Mean Limits

- i. Total coliform density shall not exceed 1,000/100 ml.
- ii. Fecal coliform density shall not exceed 200/100 ml.
- iii. Enterococcus density shall not exceed 35/100 ml.

2. Single Sample Limits

- i. Total coliform density shall not exceed 10,000/100 ml.
- ii. Fecal coliform density shall not exceed 400/100 ml.
- iii. Enterococcus density shall not exceed 104/100 ml.
- iv. Total coliform density shall not exceed 1,000/100 ml, if the ratio of fecal-to total coliform exceeds 0.1.

c. Acute Toxicity Limitation Requirements. There shall be no acute toxicity in the discharge. The acute toxicity of the effluent shall be such that:

1. The average monthly survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay test shall be at least 90%, and
2. No single test shall produce less than 70% survival.

Compliance with the toxicity objectives will be determined by the method described in section V of the MRP No. 6571 (Attachment E). The Discharger shall conduct acute toxicity monitoring as specified in the MRP.

B. Land Discharge Specifications

Not Applicable

C. Reclamation Specifications

Not Applicable

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitation

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in the Cerritos Channel.

1. The normal ambient pH to fall below 6.5 nor exceed 8.5 units nor vary from normal ambient pH levels by more than 0.2 units.
2. Surface water temperature to rise greater than 5° F above the natural temperature of the receiving waters at any time or place. At no time the temperature be raised above 80° F as a result of waste discharged.
3. State/Regional Water Board Water Contact Standards

In marine waters designated for Water Contact Recreation (REC-1), the waste discharged shall not cause the following bacterial standards to be exceeded in the receiving water:

a. Geometric Mean Limits

- i. Total Coliform density shall not exceed 1,000/100 ml.
- ii. Fecal coliform density shall not exceed 200/100 ml.
- iii. Enterococcus density shall not exceed 35/100 ml.

b. Single Sample Maximum (SSM)

- i. Total Coliform density shall not exceed 10,000/100 ml
- ii. Fecal coliform density shall not exceed 400/100 ml
- iii. Enterococcus density shall not exceed 104/100 ml
- iv. Total coliform density shall not exceed 1,000/100 ml, if the ratio of fecal-to-total coliform exceeds 0.1

4. Depress the concentration of dissolved oxygen to fall below 5.0 mg/L anytime, and the median dissolved oxygen concentration for any three consecutive months shall not be less than 80 percent of the dissolved oxygen content at saturation.
5. Exceed total ammonia (as N) concentrations specified in the Regional Water Board Resolution No. 2004-022. Resolution No. 2004-022 revised the ammonia water quality objectives for inland surface waters not characteristic of freshwater in the 1994 Basin Plan, to be consistent with USEPA's "*Ambient Water Quality Criteria for Ammonia (Saltwater) - 1989*". Adopted on March 4, 2004, Resolution No. 2004-022

was approved by State Water Board, OAL and USEPA on July 22, 2004, September 14, 2004, and May 19, 2005, respectively and is now in effect.

6. The presence of visible, floating, suspended or deposited macroscopic particulate matter or foam.
7. Oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the receiving water or on objects in the water.
8. Suspended or settleable materials, chemical substances, or pesticides in amounts that cause nuisance or adversely affect any designated beneficial use.
9. Toxic or other deleterious substances in concentrations or quantities which cause deleterious effects on aquatic biota, wildlife, or waterfowl or render any of these unfit for human consumption either at levels created in the receiving waters or as a result of biological concentration.
10. Accumulation of bottom deposits or aquatic growths.
11. Biostimulatory substances at concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses.
12. The presence of substances that result in increases of BOD that adversely affect beneficial uses.
13. Taste or odor-producing substances in concentrations that alter the natural taste, odor, and/or color of fish, shellfish, or other edible aquatic resources; cause nuisance; or adversely affect beneficial uses.
14. Alteration of turbidity, or apparent color beyond present natural background levels.
15. Damage, discolor, nor cause formation of sludge deposits on flood control structures or facilities nor overload the design capacity.
16. Degrade surface water communities and populations including vertebrate, invertebrate, and plant species.
17. Problems associated with breeding of mosquitoes, gnats, black flies, midges, or other pests.
18. Create nuisance, or adversely affect beneficial uses of the receiving water.
19. Violation of any applicable water quality standards for receiving waters adopted by the Regional Water Board or State Water Board. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments thereto, the Regional Water Board will revise or modify this Order in accordance with such standards.

B. Groundwater Limitations

Not Applicable

VI. PROVISIONS

A. Standard Provisions

1. Federal Standard Provisions. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. Regional Water Board Standard Provisions. The Discharger shall comply with the following provisions:
 - a. This Order may be modified, revoked, reissued, or terminated in accordance with the provisions of 40 CFR sections 122.44, 122.62, 122.63, 122.64, 125.62 and 125.64. Causes for taking such actions include, but are not limited to: failure to comply with any condition of this Order; endangerment to human health or the environment resulting from the permitted activity; or acquisition of newly-obtained information which would have justified the application of different conditions if known at the time of Order adoption. The filing of a request by the Discharger for an Order modification, revocation, and issuance or termination, or a notification of planned changes or anticipated noncompliance does not stay any condition of this Order.
 - b. The Discharger must comply with the lawful requirements of municipalities, counties, drainage districts, and other local agencies regarding discharges of storm water to storm drain systems or other water courses under their jurisdiction; including applicable requirements in municipal storm water management program developed to comply with NPDES permits issued by the Regional Water Board to local agencies.
 - c. Discharge of wastes to any point other than specifically described in this Order and permit is prohibited and constitutes a violation thereof.
 - d. The Discharger shall comply with all applicable effluent limitations, national standards of performance, toxic effluent standards, and all federal regulations established pursuant to Sections 301, 302, 303(d), 304, 306, 307, 316, 318, 405, and 423 of the Federal CWA and amendments thereto.
 - e. These requirements do not exempt the operator of the waste disposal facility from compliance with any other laws, regulations, or ordinances which may be applicable; they do not legalize this waste disposal facility, and they leave unaffected any further restraints on the disposal of wastes at this site which may be contained in other statutes or required by other agencies.
 - f. Oil or oily material, chemicals, refuse, or other pollutionable materials shall not be stored or deposited in areas where they may be picked up by rainfall and carried

- off of the property and/or discharged to surface waters. Any such spill of such materials shall be contained and removed immediately.
- g.** A copy of these waste discharge specifications shall be maintained at the discharge facility so as to be available at all times to operating personnel.
 - h.** After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i.** Violation of any term or condition contained in this Order;
 - ii.** Obtaining this Order by misrepresentation, or failure to disclose all relevant facts;
 - iii.** A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
 - i.** If there is any storage of hazardous or toxic materials or hydrocarbons at this facility and if the facility is not manned at all times, a 24-hour emergency response telephone number shall be prominently posted where it can easily be read from the outside.
 - j.** The Discharger shall notify the Regional Water Board not later than 120 days in advance of implementation of any plans to alter production capacity of the product line of the manufacturing, producing or processing facility by more than ten percent. Such notification shall include estimates of proposed production rate, the type of process, and projected effects on effluent quality. Notification shall include submittal of a new report of waste discharge appropriate filing fee.
 - k.** The Discharger shall file with the Regional Water Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location or volume of the discharge.
 - l.** All existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Regional Water Board as soon as they know or have reason to believe that they have begun or expect to begin to use or manufacture intermediate or final product or byproduct of any toxic pollutant that was not reported on their application.
 - m.** In the event of any change in name, ownership, or control of these waste disposal facilities, the discharger shall notify this Regional Water Board of such change and shall notify the succeeding owner or operator of the existence of this Order by letter, copy of which shall be forwarded to the Regional Water Board.
 - n.** The Water Code provides that any person who violates a waste discharge requirement or a provision of the Water Code is subject to civil penalties of up to \$5,000 per day, \$10,000 per day, or \$25,000 per day of violation, or when the violation involves the discharge of pollutants, is subject to civil penalties of up to \$10 per gallon per day or \$25 per gallon per day of violation; or some

combination thereof, depending on the violation, or upon the combination of violations.

Violation of any of the provisions of the NPDES program or of any of the provisions of this Order may subject the violator to any of the penalties described herein, or any combination thereof, at the discretion of the prosecuting authority; except that only one kind of penalty may be applied for each kind of violation.

- o.** The discharge of any product registered under the Federal Insecticide, Fungicide, and Rodenticide Act to any waste stream which may ultimately be released to waters of the United States, is prohibited unless specifically authorized elsewhere in this permit or another NPDES permit. This requirement is not applicable to products used for lawn and agricultural purposes.
- p.** The discharge of any waste resulting from the combustion of toxic or hazardous wastes to any waste stream that ultimately discharges to waters of the United States is prohibited, unless specifically authorized elsewhere in this permit.
- q.** The Discharger shall notify the Executive Officer in writing no later than 6 months prior to the planned discharge of any chemical, other than the products previously reported to the Executive Officer, which may be toxic to aquatic life. Such notification shall include:
 - i.** Name and general composition of the chemical,
 - ii.** Frequency of use,
 - iii.** Quantities to be used,
 - iv.** Proposed discharge concentrations, and
 - v.** USEPA registration number, if applicable.
- r.** Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Discharger to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Discharger to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
- s.** In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, Average Monthly Effluent Limitation (AMEL), Maximum Daily Effluent Limitation (MDEL), instantaneous, or receiving water limitation of this Order, the Discharger shall notify the Regional Water Board by telephone (216)-576-6600 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Regional Water Board waives confirmation. The written notification shall state the nature, time, duration, and cause of noncompliance, and shall describe the measures being taken to remedy the current noncompliance and,

prevent recurrence including, where applicable, a schedule of implementation. Other noncompliance requires written notification as above at the time of the normal monitoring report.

- t. Prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse, the Discharger must file a petition with the State Water Board, Division of Water Rights, and receive approval for such a change. (Water Code § 1211.)

B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

- a. If more stringent applicable water quality standards are promulgated or approved pursuant to Section 303 of the Federal CWA, and amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.
- b. This Order may be reopened to include effluent limitations for toxic constituents determined to be present in significant amounts in the discharge through a more comprehensive monitoring program included as part of this Order and based on the results of the reasonable potential analysis.
- c. This Order may be reopened and modified, to incorporate in accordance with the provisions set forth in 40 CFR Parts 122 and 124, to include requirements for the implementation of the watershed management approach or to include new Minimum Levels (MLs).
- d. This Order may be reopened and modified to revise effluent limitations as a result of future Basin Plan Amendments, such as an update of an objective or the adoption of a TMDL for the Cerritos Channel and/or the Los Angeles/Long Beach Inner Harbor.
- e. This Order may be reopened upon submission by the Discharger of adequate information, as determined by the Regional Water Board, to provide for a design storm, dilution credits or a mixing zone, as may be appropriate.
- f. This Order may be reopened upon submission by the Discharger of adequate information, as determined by the Regional Water Board, to provide for a site-specific translator for any metal (which is not TMDL-based constituent) to evaluate the dissolved to total concentration ratios, as may be appropriate. For any TMDL-based limitations, any changes to

the limitations require TMDL amendment prior to implementation of the requested change.

- g.** This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.

2. Special Studies, Technical Reports, and Additional Monitoring Requirements

- a. Initial Investigation Toxicity Reduction Evaluation (TRE) Workplan.** The Discharger shall submit to the Regional Water Board an Initial Investigation TRE workplan (1-2 pages) **within 90 days** of the effective date of this permit. This plan shall describe the steps the permittee intends to follow in the event that toxicity is detected, and should include at a minimum:
 - i.** A description of the investigation and evaluation techniques that will be used to identify potential causes/sources of toxicity, effluent variability, and treatment system efficiency;
 - ii.** A description of the facility's method of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in operation of the facility;
 - iii.** If a Toxicity Identification Evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor) (section V of the MRP, Attachment E provides references for the guidance manuals that should be used for performing TIEs).
- b. Monitoring Thresholds based on Sediment Interim Concentration-based Allocations in the Harbor Toxics TMDL for Sediment Monitoring of Effluent**

The monitoring thresholds in Table 7 of this Order are based on the TMDL's interim sediment allocations for copper, lead, zinc, DDT, PAHs, and PCBs. Attainment with these thresholds shall be demonstrated in accordance with Footnote 4 to Table 6, page 16 of this Order. Regardless of these monitoring thresholds, the Discharger shall ensure that effluent concentrations and mass discharges do not exceed levels that can be attained by performance of the Facility's treatment technologies existing at the time of permit issuance, reissuance, or modification. This monitoring is only required in years in which a discharge from the Facility to receiving waters occurs.

Table 7. Monitoring Thresholds

| Pollutant | Monitoring Thresholds (mg/kg sediment) |
|-----------|---|
| Copper | 142.3 |
| Lead | 50.4 |
| Zinc | 240.6 |
| PAHs | 4.58 |
| DDT | 0.070 |
| PCBs | 0.060 |

c. Harbor Toxics TMDL Water Column, Sediment, and Fish Tissue Monitoring for the Greater Los Angeles and Long Beach Harbor Waters Compliance Monitoring Program. As defined in the Harbor Toxics TMDL, the Discharger is a “responsible party” because it is an “Individual Industrial Permittee”. As such, either individually or with a collaborating group, the Discharger shall develop a monitoring and reporting plan (Monitoring Plan) and quality assurance project plan (QAPP) for the water column, sediment, and fish tissue in the Greater Los Angeles and Long Beach Harbor. These plans shall follow the “TMDL Element - Monitoring Plan” provisions in Attachment A to Resolution No. R11-008. The Discharger must inform the Regional Board if they plan to join a collaborative monitoring effort or develop a site specific plan **90 days** after the effective date of the permit. If Calciner is joining a collaborative effort that notification must include documentation of such. If developing a site specific Monitoring Plan, the plan must be submitted **12 months** after the effective date of the permit for public review and, subsequently, Executive Officer approval. Monitoring shall begin **6 months** after a monitoring plan is approved by the Executive Officer.

The Compliance Monitoring Program shall include:

- i. **Water Column Monitoring.** At the Station IDs in Table 8, parameters in the water column shall be monitored three times per year, during two wet weather events and one dry weather event. During wet weather events, water column samples shall be collected at several depths. Wet weather monitoring must include the first large storm event of the wet season. Sampling shall be designed to collect sufficient volumes of TSS for analyses of bulk sediment priority pollutants in Table 8.
- ii. **Sediment Monitoring.** Sediment quality objective evaluation monitoring, as detailed in SQO Part 1 (sediment triad sampling), shall be performed if discharge occurs during the five year permit term and shall include the full chemical suite, two sediment toxicity tests, and four benthic indices. At the Station IDs in Table 8, and between sediment triad monitoring events,

sediment chemistry parameters shall be monitored if discharge occurs during the five year permit term.

Table 8. Sediment Chemistry Monitoring Requirements

| Water Body Name | Station ID ¹ | Station Location | Sample Media and Parameters | |
|-------------------------|-------------------------|--|---|--|
| | | | Water Column | Sediment |
| Long Beach Inner Harbor | 12 | Cerritos Channel between the Heim Bridge and the Turning Basin | Flow, Temperature, DO, pH, Salinity, TSS, Copper, Lead, Zinc, PCBs, DDT | Copper, Lead, Zinc, Toxicity, Benthic Community Effect |
| | 13 | Back Channel between Turning Basin and West Basin | | |
| | 14 | Center of West Basin | | |
| | 15 | Center of Southeast Basin | | |

¹ Based on Harbor Toxics TMDL.

iii. **Fish Tissue Monitoring.** In Long Beach Inner Harbor, fish tissue shall be monitored once per two years for chlordane, dieldrin, toxaphene, DDT, and PCBs. The three target species shall include white croaker, a sport fish, and a prey fish.

3. Storm Water Pollution Prevention Plan, Best Management Practices, and Spill Contingency Plan

The Discharger shall submit to the Regional Water Board, **within 90 days** of the effective date of this Order:

- a. An updated Storm Water Pollution Prevention Plan (SWPPP) that describes site-specific management practices for minimizing contamination of storm water runoff and for preventing contaminated storm water runoff from being discharged directly to waters of the State. The SWPPP shall be developed in accordance with the requirements in Attachment G.
- b. An updated Best Management Practices Plan (BMPP) that will be implemented to reduce the discharge of pollutants to the receiving water. The BMPP shall include site-specific plans and procedures implemented and/or to be implemented to prevent hazardous waste/material from being discharged to waters of the State. Further, the Discharger shall assure that the storm water discharges from the Facility would neither cause, nor contribute to the exceedance of water quality standards and objectives, nor create conditions of nuisance in the receiving water, and that the unauthorized discharges (i.e., spills) to the receiving water have been effectively prohibited. In particular, a risk assessment of each area identified by the Discharger shall be performed to determine the potential for hazardous or toxic waste/material discharge to surface waters. The BMPP shall be developed in accordance with requirements in Attachment G.

- c. An updated Spill Contingency Plan that includes a technical report on the preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events at the site. The Spill Contingency Plan shall be reviewed at a minimum once per year and updated as needed.

Plans shall cover all areas of the Facility and shall include an updated drainage map for the Facility. The Discharger shall identify on a map of appropriate scale the areas that contribute runoff to the permitted discharge points. The Discharger shall describe the activities in each area and the potential for contamination of storm water runoff and the discharge of hazardous waste/material.

The Discharger shall implement the SWPPP, BMPP, and Spill Contingency Plan **within 10 days** of the approval by the Executive Officer or **no later than 90 days** after submission to the Regional Water Board, whichever comes first. The plans shall be reviewed annually and at the same time. Updated information shall be submitted to the Regional Water Board within **30 days** of revision.

4. Construction, Operation and Maintenance Specifications

- a. The Discharger shall at all times properly operate and maintain all facilities and systems installed or used to achieve compliance with this order.

5. Special Provisions for Municipal Facilities (POTWs Only)

Not Applicable

6. Other Special Provisions

Not Applicable

7. Compliance Schedules

Not Applicable

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

A. Single Constituent Effluent Limitation.

If the concentration of the pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reported ML (see Reporting Requirement I.G. of the MRP), then the Discharger is out of compliance.

B. Effluent Limitations Expressed as a Sum of Several Constituents.

If the sum of the individual pollutant concentrations is greater than the effluent limitation, then the Discharger is out of compliance. In calculating the sum of the concentrations of a group of pollutants, consider constituents reported as Not Detected (ND) or Detected, but Not Quantified (DNQ) to have concentrations equal to zero, provided that the applicable ML is used.

C. Effluent Limitations Expressed as a Median.

In determining compliance with a median limitation, the analytical results in a set of data will be arranged in order of magnitude (either increasing or decreasing order); and

1. If the number of measurements (n) is odd, then the median will be calculated as = $X_{(n+1)/2}$, or
2. If the number of measurements (n) is even, then the median will be calculated as = $[X_{n/2} + X_{(n/2)+1}]$, i.e. the midpoint between the $n/2$ and $n/2+1$ data points.

D. Mass and Concentration Limitations.

Compliance with mass and concentration effluent limitations for the same parameter shall be determined separately with their respective limitations. When the concentration of a constituent in an effluent sample is determined to be “Not Detected” (ND) or “Detected, but Not Quantified” (DNQ), the corresponding mass emission rate determined from that sample concentration shall also be reported as ND or DNQ.

E. Multiple Sample Data.

When determining compliance with an AMEL or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of DNQ or ND. In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

F. Average Monthly Effluent Limitation (AMEL).

If the average (or when applicable, the median determined by subsection E above for multiple sample data) of daily discharges over a calendar month exceeds the AMEL for a given parameter, this will represent a single violation, though the Discharger will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of non-compliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AMEL, the Discharger will be considered out of compliance for that calendar month. For any one calendar month during which no sample (daily discharge) is taken, no compliance determination can be made for that calendar month.

In determining compliance with the AMEL, the following provisions shall also apply to all constituents:

1. If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, does not exceed the AMEL for that constituent, the Discharger has demonstrated compliance with the AMEL for that month;
2. If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, exceeds the AMEL for any constituent, the Discharger shall collect four additional samples at approximately equal intervals during the month. All five analytical results shall be reported in the monitoring report for that month, or 45 days after results for the additional samples were received, whichever is later.

When all sample results are greater than or equal to the reported ML (see Reporting Requirement I.G. of the MRP), the numerical average of the analytical results of these five samples will be used for compliance determination.

When one or more sample results are reported as ND or DNQ (see Reporting Requirement I.G. of the MRP), the median value of these four samples shall be used for compliance determination. If one or both of the middle values is ND or DNQ, the median shall be the lower of the two middle values.

3. In the event of noncompliance with an AMEL, the sampling frequency for that constituent shall be increased to weekly and shall continue at this level until compliance with the AMEL has been demonstrated.
4. If only one sample was obtained for the month or more than a monthly period and the result exceeds the AMEL, then the Discharger is in violation of the AMEL.

G. Maximum Daily Effluent Limitations (MDEL).

If a daily discharge exceeds the MDEL for a given parameter, an alleged violation will be flagged and the discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period. For any 1 day during which no sample is taken, no compliance determination can be made for that day.

H. Instantaneous Minimum Effluent Limitation.

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

I. Instantaneous Maximum Effluent Limitation.

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, a violation will be flagged and the discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ)

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n$$

where:

Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL)

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Best Management Practices (BMPs)

BMPs are methods, measures, or practices designed and selected to reduce or eliminate the discharge of pollutants to surface waters from point and nonpoint source discharges including storm water. BMPs include structural and non-structural control, and operation maintenance procedures, which can be applied before, during, and/or after pollution-producing activities.

Bioaccumulative

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic

Pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV)

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ)

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA)

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Existing Discharger

Any discharger that is not a new discharger. An existing discharger includes an “increasing discharger” (i.e., any existing facility with treatment systems in place for its current discharge that is or will be expanding, upgrading, or modifying its permitted discharge after the effective date of this Order).

Inland Surface Waters

All surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL)

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL)

MDL is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in Title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML)

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND)

Sample results which are less than the laboratory's MDL.

Ocean Waters

The territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent Pollutants

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP)

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code Section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL)

RL is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with Section 2.4.2 of the SIP or established in accordance with Section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System

The portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water

Any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ)

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.


Toxicity Reduction Evaluation (TRE)

TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ACRONYMS AND ABBREVIATIONS

| | |
|------------------|--|
| AMEL | Average Monthly Effluent Limitation |
| B | Background Concentration |
| BAT | Best Available Technology Economically Achievable |
| Basin Plan | <i>Water Quality Control Plan for the Coastal Watersheds of Los Angeles and Ventura Counties</i> |
| BCT | Best Conventional Pollutant Control Technology |
| BMP | Best Management Practices |
| BMPP | Best Management Practices Plan |
| BPJ | Best Professional Judgment |
| BOD | Biochemical Oxygen Demand 5-day @ 20 °C |
| BPT | Best Practicable Treatment Control Technology |
| C | Water Quality Objective |
| CCR | California Code of Regulations |
| CEQA | California Environmental Quality Act |
| CFR | Code of Federal Regulations |
| CTR | California Toxics Rule |
| CV | Coefficient of Variation |
| CWA | Clean Water Act |
| CWC | California Water Code |
| Discharger | Tesoro Refining & Marketing Company LLC |
| DMR | Discharge Monitoring Report |
| DNQ | Detected But Not Quantified |
| ELAP | California Department of Public Health Environmental Laboratory Accreditation Program |
| ELG | Effluent Limitations, Guidelines and Standards |
| Facility | Tesoro Wilmington Calciner |
| gpd | gallons per day |
| IC | Inhibition Coefficient |
| IC ₁₅ | Concentration at which the organism is 15% inhibited |
| IC ₂₅ | Concentration at which the organism is 25% inhibited |
| IC ₄₀ | Concentration at which the organism is 40% inhibited |
| IC ₅₀ | Concentration at which the organism is 50% inhibited |
| LA | Load Allocations |
| LOEC | Lowest Observed Effect Concentration |
| µg/L | micrograms per Liter |
| mg/L | milligrams per Liter |
| MDEL | Maximum Daily Effluent Limitation |
| MEC | Maximum Effluent Concentration |
| MGD | Million Gallons Per Day |
| ML | Minimum Level |
| MRP | Monitoring and Reporting Program |
| ND | Not Detected |
| NOEC | No Observable Effect Concentration |
| NPDES | National Pollutant Discharge Elimination System |
| NSPS | New Source Performance Standards |

| | |
|-----------------------|--|
| NTR | National Toxics Rule |
| OAL | Office of Administrative Law |
| PMEL | Proposed Maximum Daily Effluent Limitation |
| PMP | Pollutant Minimization Plan |
| POTW | Publicly Owned Treatment Works |
| QA | Quality Assurance |
| QA/QC | Quality Assurance/Quality Control |
| Ocean Plan | <i>Water Quality Control Plan for Ocean Waters of California</i> |
| Regional Water Board | California Regional Water Quality Control Board, Los Angeles Region |
| RPA | Reasonable Potential Analysis |
| SCP | Spill Contingency Plan |
| Sediment Quality Plan | <i>Water Quality Control Plan for Enclosed Bays and Estuaries – Part 1 Sediment Quality</i> |
| SIP | State Implementation Policy (<i>Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California</i>) |
| SMR | Self Monitoring Reports |
| State Water Board | California State Water Resources Control Board |
| SWPPP | Storm Water Pollution Prevention Plan |
| TAC | Test Acceptability Criteria |
| Thermal Plan | <i>Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California</i> |
| TIE | Toxicity Identification Evaluation |
| TMDL | Total Maximum Daily Load |
| TOC | Total Organic Carbon |
| TRE | Toxicity Reduction Evaluation |
| TSD | Technical Support Document |
| TSS | Total Suspended Solid |
| TU _c | Chronic Toxicity Unit |
| USEPA | United States Environmental Protection Agency |
| WDR | Waste Discharge Requirements |
| WET | Whole Effluent Toxicity |
| WLA | Waste Load Allocations |
| WQBELs | Water Quality-Based Effluent Limitations |
| WQS | Water Quality Standards |
| % | Percent |



File: W:\work\Remediation\MM\lett\BP\Wilmington Calciner\Work\Stormwater Permit Renewal\Permit Renewal\CAD\Figure 3.mxd
Date: Wednesday, January 25, 2012 9:23:50 AM

ATTACHMENT C – FLOW SCHEMATIC





Figure
4

**BP West Coast Products, LLC
 Wilmington Calciner
 Facility Process Diagram**





Attachment C –Flow Schematic

ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application [40 CFR section 122.41(a)].
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement [40 CFR section 122.41(a)(1)].

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order [40 CFR section 122.41(c)].

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment [40 CFR section 122.41(d)].

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order [40 CFR section 122.41(e)].

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges [40 CFR section 122.41(g)].

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations [40 CFR section 122.5(c)].

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to [40 CFR section 122.41(i)] [Water Code section 13383]:

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order [40 CFR section 122.41(i)(1)];
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order [40 CFR section 122.41(i)(2)];
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order [40 CFR section 122.41(i)(3)]; and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location [40 CFR section 122.41(i)(4)].

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility [40 CFR section 122.41(m)(1)(i)].
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production [40 CFR section 122.41(m)(1)(ii)].
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below [40 CFR section 122.41(m)(2)].

3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless [40 CFR section 122.41(m)(4)(i)]:
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage [40 CFR section 122.41(m)(4)(i)(A)];
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance [40 CFR section 122.41(m)(4)(i)(B)]; and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below [40 CFR section 122.41(m)(4)(i)(C)].
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above [40 CFR section 122.41(m)(4)(ii)].
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass [40 CFR section 122.41(m)(3)(i)].
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice) [40 CFR section 122.41(m)(3)(ii)].

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation [40 CFR section 122.41(n)(1)].

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was

caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review [40 CFR section 122.41(n)(2)].

2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that [40 CFR section 122.41(n)(3)]:
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset [40 CFR section 122.41(n)(3)(i)];
 - b. The permitted facility was, at the time, being properly operated [40 CFR section 122.41(n)(3)(ii)];
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) [40 CFR section 122.41(n)(3)(iii)]; and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above [40 CFR section 122.41(n)(3)(iv)].
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof [40 CFR section 122.41(n)(4)].

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition [40 CFR section 122.41(f)].

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit [40 CFR section 122.41(b)].

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code [40 CFR sections 122.41(l)(3) and 122.61].

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity [40 CFR section 122.41(j)(1)].
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order [40 CFR sections 122.41(j)(4) and 122.44(i)(1)(iv)].

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time [40 CFR section 122.41(j)(2)].
- B. Records of monitoring information shall include:
 - 1. The date, exact place, and time of sampling or measurements [40 CFR section 122.41(j)(3)(i)];
 - 2. The individual(s) who performed the sampling or measurements [40 CFR section 122.41(j)(3)(ii)];
 - 3. The date(s) analyses were performed [40 CFR section 122.41(j)(3)(iii)];
 - 4. The individual(s) who performed the analyses [40 CFR section 122.41(j)(3)(iv)];
 - 5. The analytical techniques or methods used [40 CFR section 122.41(j)(3)(v)]; and
 - 6. The results of such analyses [40 CFR section 122.41(j)(3)(vi)].
- C. **Claims of confidentiality for the following information will be denied [40 CFR section 122.7(b)]:**
 - 1. The name and address of any permit applicant or Discharger [40 CFR section 122.7(b)(1)]; and
 - 2. Permit applications and attachments, permits and effluent data [40 CFR section 122.7(b)(2)].

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order [40 CFR section 122.41(h)] [Water Code section 13267].

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below [40 CFR section 122.41(k)].
2. All permit applications shall be signed by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. [40 CFR section 122.22(a)(1)].
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above [40 CFR section 122.22(b)(1)];
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative

- may thus be either a named individual or any individual occupying a named position.) [40 CFR section 122.22(b)(2)]; and
- c. The written authorization is submitted to the Regional Water Board and State Water Board [40 CFR section 122.22(b)(3)].
 4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative [40 CFR section 122.22(c)].
 5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” [40 CFR section 122.22(d)].

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order [40 CFR section 122.22(l)(4)].
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices [40 CFR section 122.41(l)(4)(i)].
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board [40 CFR section 122.41(l)(4)(ii)].
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order [40 CFR section 122.41(l)(4)(iii)].

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date [40 CFR section 122.41(l)(5)].

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance [40 CFR section 122.41(l)(6)(i)].
2. The following shall be included as information that must be reported within 24 hours under this paragraph [40 CFR section 122.41(l)(6)(ii)]:
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order [40 CFR section 122.41(l)(6)(ii)(A)].
 - b. Any upset that exceeds any effluent limitation in this Order [40 CFR section 122.41(l)(6)(ii)(B)].
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours [40 CFR section 122.41(l)(6)(iii)].

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when [40 CFR section 122.41(l)(1)]:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR section 122.29(b) [40 CFR section 122.41(l)(1)(i)]; or.
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order [40 CFR section 122.41(l)(1)(ii)].

The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements

under 40 CFR section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1) [40 CFR section 122.41(l)(1)(ii)].

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements [40 CFR section 122.41(l)(2)].

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above [40 CFR section 122.41(l)(7)].

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information [40 CFR section 122.41(l)(8)].

VI. STANDARD PROVISIONS – ENFORCEMENT

- A.** The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.
- B.** The CWA provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The CWA provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or

any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions [40 CFR section 122.41(a)(2)] [Water Code sections 13385 and 13387].

- C. Any person may be assessed an administrative penalty by the Regional Water Board for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000 [40 CFR section 122.41(a)(3)].
- D. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both [40 CFR section 122.41(j)(5)].
- E. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this Order, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both [40 CFR section 122.41(k)(2)].

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Non-Municipal Facilities

Existing manufacturing, commercial, mining, and silvicultural Dischargers shall notify the Regional Water Board as soon as they know or have reason to believe [40 CFR section 122.42(a)]:

1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" [40 CFR section 122.42(a)(1)]:

- a. 100 micrograms per liter ($\mu\text{g/L}$) [40 CFR section 122.42(a)(1)(i)];
 - b. 200 $\mu\text{g/L}$ for acrolein and acrylonitrile; 500 $\mu\text{g/L}$ for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter (mg/L) for antimony [40 CFR section 122.42(a)(1)(ii)];
 - c. Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge [40 CFR section 122.42(a)(1)(iii)]; or
 - d. The level established by the Regional Water Board in accordance with 40 CFR section 122.44(f) [40 CFR section 122.42(a)(1)(iv)].
2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" [40 CFR section 122.42(a)(2)]:
 - a. 500 micrograms per liter ($\mu\text{g/L}$) [40 CFR section 122.42(a)(2)(i)];
 - b. 1 milligram per liter (mg/L) for antimony [40 CFR section 122.42(a)(2)(ii)];
 - c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge [40 CFR section 122.42(a)(2)(iii)]; or
 - d. The level established by the Regional Water Board in accordance with 40 CFR section 122.44(f) [40 CFR section 122.42(a)(2)(iv)].

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP NO. 6571)

Table of Contents

| | | |
|-------|---|------|
| I. | General Monitoring Provisions | E-2 |
| II. | Monitoring Locations | E-5 |
| III. | Influent Monitoring Requirements..... | E-5 |
| IV. | Effluent Monitoring Requirements | E-5 |
| | A. Monitoring Location EFF-001 | E-5 |
| V. | Whole Effluent Toxicity Testing Requirements | E-10 |
| | A. Acute Toxicity | E-10 |
| | B. Quality Assurance..... | E-11 |
| | C. Preparation of an Initial Investigation TRE Workplan | E-11 |
| | D. Steps in TRE and TIE Procedures | E-12 |
| | E. Ammonia Removal..... | E-13 |
| | F. Reporting | E-14 |
| VI. | Land Discharge Monitoring Requirements | E-15 |
| VII. | Reclamation Monitoring Requirements..... | E-15 |
| VIII. | Receiving Water Monitoring Requirements – Surface Water | E-15 |
| | A. Monitoring Location RSW-001 | E-15 |
| | B. Monitoring Location RSW-002 | E-17 |
| IX. | Other Monitoring Requirements | E-17 |
| | A. Visual Monitoring of Upstream and Downstream Receiving Water Sampling Points | E-17 |
| | B. Storm Water Monitoring | E-18 |
| | C. Storm Water Pollution Prevention Plan (SWPPP), Best Management Practices Plan (BMPP) and Spill Contingency Plan (SCP)..... | E-18 |
| | D. Regional Monitoring | E-18 |
| X. | Reporting Requirements | E-18 |
| | A. General Monitoring and Reporting Requirements | E-18 |
| | B. Self Monitoring Reports (SMRs)..... | E-19 |
| | C. Discharge Monitoring Reports (DMRs)..... | E-22 |
| | D. Other Reports | E-22 |

List of Tables

| | | |
|------------|---|------|
| Table E-1. | Monitoring Station Locations | E-5 |
| Table E-2. | Effluent Monitoring at Monitoring Location EFF-001 | E-6 |
| Table E-3. | Sediment Monitoring Requirements..... | E-9 |
| Table E-4. | Receiving Water Monitoring Requirements at Monitoring Location RSW-001..... | E-16 |
| Table E-5. | Receiving Water Monitoring Requirements at Monitoring Location RSW-002..... | E-17 |
| Table E-6. | Monitoring Periods and Reporting Schedule..... | E-20 |

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP) NO. 6571

The Code of Federal Regulations 40 CFR section 122.48 requires that all National Pollutant Discharge Elimination System (NPDES) permits specify monitoring and reporting requirements. Water Code Sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A.** An effluent sampling station shall be established for Discharge Point No. 001 and shall be located where representative samples of that effluent can be obtained.
- B.** Effluent samples shall be taken downstream of any addition to treatment works and prior to mixing with the receiving waters.
- C.** The Regional Water Board shall be notified in writing of any change in the sampling stations once established or in the methods for determining the quantities of pollutants in the individual waste streams.
- D.** Pollutants shall be analyzed using the analytical methods described in 40 CFR sections 136.3, 136.4, and 136.5 (revised May 18, 2012); or, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board.

Laboratories analyzing effluent samples and receiving water samples shall be certified by the California Department of Public Health Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer and must include quality assurance/quality control (QA/QC) data in their reports. A copy of the laboratory certification shall be provided each time a new certification and/or renewal of the certification is obtained from ELAP.

- E.** For any analyses performed for which no procedure is specified in the United States Environmental Protection Agency (USEPA) guidelines or in the MRP, the constituent or parameter analyzed and the method or procedure used must be specified in the monitoring report.
- F.** Each monitoring report must affirm in writing that “all analyses were conducted at a laboratory certified for such analyses by the Department of Public Health or approved by the Executive Officer and in accordance with current USEPA guideline procedures or as specified in this MRP”.
- G.** The monitoring reports shall specify the analytical method used, the Method Detection Limit (MDL), and the Minimum Level (ML) for each pollutant. For the purpose of reporting compliance with numerical limitations, performance goals, and receiving water

limitations, analytical data shall be reported by one of the following methods, as appropriate:

1. An actual numerical value for sample results greater than or equal to the ML; or
2. "Detected, but Not Quantified (DNQ)" if results are greater than or equal to the laboratory's MDL but less than the ML; or,
3. "Not-Detected (ND)" for sample results less than the laboratory's MDL with the MDL indicated for the analytical method used.

Analytical data reported as "less than" for the purpose of reporting compliance with permit limitations shall be the same or lower than the permit limit(s) established for the given parameter.

Current MLs (Attachment H) are those published by the State Water Board in the *Policy for the Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*, February 24, 2005.

- H.** Where possible, the MLs employed for effluent analyses shall be lower than the permit limitations established for a given parameter. If the ML value is not below the effluent limitation, then the lowest ML value and its associated analytical method shall be selected for compliance purposes. At least once a year, the Discharger shall submit a list of the analytical methods employed for each test and associated laboratory QA/QC procedures.

The Regional Water Board, in consultation with the State Water Board Quality Assurance Program, shall establish a ML that is not contained in Attachment H to be included in the Discharger's permit in any of the following situations:

1. When the pollutant under consideration is not included in Attachment H;
2. When the Discharger and Regional Water Board agree to include in the permit a test method that is more sensitive than that specified in 40 CFR Part 136 (revised May 18, 2012);
3. When the Discharger agrees to use an ML that is lower than that listed in Attachment H;
4. When the Discharger demonstrates that the calibration standard matrix is sufficiently different from that used to establish the ML in Attachment H, and proposes an appropriate ML for their matrix; or,
5. When the Discharger uses a method whose quantification practices are not consistent with the definition of an ML. Examples of such methods are the USEPA-approved method 1613 for dioxins and furans, method 1624 for volatile organic substances, and method 1625 for semi-volatile organic substances. In such cases, the Discharger, the Regional Water Board, and the State Water Board shall agree

on a lowest quantifiable limit and that limit will substitute for the ML for reporting and compliance determination purposes.

- I. Water/wastewater samples must be analyzed within allowable holding time limits as specified in 40 CFR section 136.3. All QA/QC items must be run on the same dates the samples were actually analyzed, and the results shall be reported in the Regional Water Board format, when it becomes available, and submitted with the laboratory reports. Proper chain of custody procedures must be followed, and a copy of the chain of custody shall be submitted with the report.
- J. All analyses shall be accompanied by the chain of custody, including but not limited to data and time of sampling, sample identification, and name of person who performed sampling, date of analysis, name of person who performed analysis, QA/QC data, method detection limits, analytical methods, copy of laboratory certification, and a perjury statement executed by the person responsible for the laboratory.
- K. The Discharger shall calibrate and perform maintenance procedures on all monitoring instruments and to insure accuracy of measurements, or shall insure that both equipment activities will be conducted.
- L. The Discharger shall have, and implement, an acceptable written quality assurance (QA) plan for laboratory analyses. Unless otherwise specified in the analytical method, duplicate samples must be analyzed at a frequency of 5% (1 in 20 samples) with at least one if there is fewer than 20 samples in a batch. A batch is defined as a single analytical run encompassing no more than 24 hours from to finish. A similar frequency shall be maintained for analyzing spiked samples.
- M. When requested by the Regional Water Board or USEPA, the Discharger will participate in the NPDES discharge monitoring report QA performance study. The Discharger must have a success rate equal to or greater than 80%.
- N. For parameters that both average monthly and daily maximum limits are specified and the monitoring frequency is less than four times a month, the following shall apply. If an analytical result is greater than the average monthly limit, the Discharger shall collect four additional samples at approximately equal intervals during the month, until compliance with the average monthly limit has been demonstrated. All five analytical results shall be reported in the monitoring report for that month, or 45 days after results for the additional samples were received, whichever is later. In the event of noncompliance with an average monthly effluent limitation, the sampling frequency for that constituent shall be increased to weekly and shall continue at this level until compliance with the average monthly effluent limitation has been demonstrated. The Discharger shall provide for the approval of the Executive Officer a program to ensure future compliance with the average monthly limit.
- O. In the event wastes are transported to a different disposal site during the report period, the following shall be reported in the monitoring report:
 - 1. Types of wastes and quantity of each type;

2. Name and address for each hauler of wastes (or method of transport if other than by hauling); and
3. Location of the final point(s) of disposal for each type of waste.

If no wastes are transported off-site during the reporting period, a statement to that effect shall be submitted.

- P.** Each monitoring report shall state whether or not there was any change in the discharge as described in the Order during the reporting period.
- Q.** Laboratories analyzing monitoring samples shall be certified by the Department of Public Health, in accordance with the provision of Water Code Section 13176, and must include quality assurance/quality control data with their reports.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

| Discharge Point Name | Monitoring Location Name | Monitoring Location Description |
|-----------------------------|---------------------------------|--|
| 001 | EFF-001 | At the discharge point of the retention basin (Latitude 33° 46' 29" N, Longitude 118° 13' 39" W). |
| -- | RSW-001 | A sampling station shall be established at a location outside the influence of the effluent discharge location, and at least 50 feet upstream, relative to tidal flow in the Cerritos Channel. |
| -- | RSW-002 | A sampling station shall be established at a location 50 feet downstream from the effluent discharge location, relative to tidal flow in the Cerritos Channel. |

III. INFLUENT MONITORING REQUIREMENTS

Not Applicable

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001

1. The Discharger shall monitor treated storm water mixed with wastewaters associated with industrial activities at Monitoring Location EFF-001 as follows.

Table E-2. Effluent Monitoring at Monitoring Location EFF-001

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|--|------------------|-------------|--------------------------------|---------------------------------|
| Flow | MGD ¹ | Calculated | 1/Day | -- |
| Total Waste Flow | million gallons | Calculated | 1/Discharge Event | -- |
| Conventional Pollutants | | | | |
| pH | std. units | Grab | 1/Discharge Event ² | 4 |
| Biochemical Oxygen Demand (BOD) (5-day @ 20 deg. C) ³ | mg/L | Grab | 1/Discharge Event ² | 4 |
| Chemical Oxygen Demand (COD) ³ | mg/L | Grab | 1/Discharge Event ² | 4 |
| Fecal Coliform | MPN/100 mL | Grab | 1/Discharge Event ² | 4 |
| Oil and Grease ³ | mg/L | Grab | 1/Discharge Event ² | 4 |
| Total Suspended Solids (TSS) ³ | mg/L | Grab | 1/Discharge Event ² | 4 |
| Non-Conventional Pollutants | | | | |
| Aluminum, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Ammonia Nitrogen, Total (as N) | mg/L | Grab | 1/Discharge Event ² | 4 |
| Acute Toxicity | % survival | Grab | 1/Discharge Event ² | 4,5 |
| Barium, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Boron, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Bromide | mg/L | Grab | 1/Discharge Event ² | 4 |
| Color | std. units | Grab | 1/Discharge Event ² | 4 |
| Elemental Sulfur | mg/L | Grab | 1/Discharge Event ² | 4 |
| Fluoride, Total | mg/L | Grab | 1/Discharge Event ² | 4 |
| Hardness, Total (as CaCO ₃) | mg/L | Grab | 1/Discharge Event ² | 4 |
| Iron, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Magnesium, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Manganese, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Mercaptan | mg/L | Grab | 1/Discharge Event ² | 4 |
| Methylene Blue Active Substance (MBAS) | mg/L | Grab | 1/Discharge Event ² | 4 |
| Molybdenum, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Nitrite Plus Nitrate (as N) | mg/L | Grab | 1/Discharge Event ² | 4 |
| Organic Nitrogen, Total (as N) | mg/L | Grab | 1/Discharge Event ² | 4 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|--|------------|-------------|--------------------------------|----------------------------------|
| Phosphorus, Total (as P) | mg/L | Grab | 1/Discharge Event ² | 4 |
| Sulfate, Total (as SO ₄) | mg/L | Grab | 1/Discharge Event ² | 4 |
| Sulfide | mg/L | Grab | 1/Discharge Event ² | 4 |
| Settleable Solids | ml/L | Grab | 1/Discharge Event ² | 4 |
| Specific Conductivity | µmhos/cm | Grab | 1/Discharge Event ² | 4 |
| Temperature | °F | Grab | 1/Discharge Event ² | 4 |
| Enterococcus | MPN/100 ml | Grab | 1/Discharge Event ² | 4 |
| Total Coliform | MPN/100 ml | Grab | 1/Discharge Event ² | 4 |
| Total Petroleum Hydrocarbons (TPH) as Gasoline (C ₄ -C ₁₂) ³ | µg/L | Grab | 1/Discharge Event ² | EPA Method 503.1 or 8015B |
| TPH as Diesel (C ₁₃ -C ₂₂) ³ | µg/L | Grab | 1/Discharge Event ² | EPA Method 503.1, 8015B, or 8270 |
| TPH as Waste Oil (C ₂₃₊) ³ | µg/L | Grab | 1/Discharge Event ² | EPA Method 503.1, 8015B, or 8270 |
| Turbidity | NTU | Grab | 1/Discharge Event ² | 4 |
| Vanadium, Total Recoverable | mg/L | Grab | 1/Discharge Event ² | 4 |
| Xylene | µg/L | Grab | 1/Discharge Event ² | 4 |
| Priority Pollutants | | | | |
| Antimony, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Arsenic, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Beryllium, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Cadmium, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Chromium (III) | µg/L | Grab | 1/Year ⁶ | 4 |
| Chromium (VI) | µg/L | Grab | 1/Year ⁶ | 4 |
| Copper, Total Recoverable ³ | µg/L | Grab | 1/Discharge Event ² | 4 |
| Lead, Total Recoverable ³ | µg/L | Grab | 1/Discharge Event ² | 4 |
| Mercury, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Nickel, Total Recoverable ³ | µg/L | Grab | 1/Discharge Event ² | 4 |
| Selenium, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Silver, Total Recoverable | µg/L | Grab | 1/Year ⁶ | 4 |
| Thallium, Total Recoverable ³ | µg/L | Grab | 1/Discharge Event ² | 4 |
| Zinc, Total Recoverable ³ | µg/L | Grab | 1/Discharge Event ² | 4 |
| Cyanide, Total (as CN) ³ | µg/L | Grab | 1/Discharge Event ² | 4 |
| 4,4'-DDT, Total ^{3,6} | µg/L | Grab | 1/Discharge Event ² | 4 |
| Total PCBs ^{3,6,7} | µg/L | Grab | 1/Discharge Event ² | 4 |
| Benzo(a)pyrene, Total ⁶ | µg/L | Grab | 1/Discharge Event ² | 4 |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|--|-------|-------------|--------------------------------|---------------------------------|
| Crysene, Total ⁶ | µg/L | Grab | 1/Discharge Event ² | 4 |
| Remaining Priority Pollutants ⁸ | µg/L | Grab | 1/Year ⁹ | 4 |
| TCDD Equivalents ¹⁰ | µg/L | Grab | 1/Year ⁹ | 4 |

- ¹ MGD= million gallons per day.
- ² During periods of extended discharge, no more than **one sample per week** (or a 7-day period) is required. For acute toxicity, no more than **one sample per month** is required during extended discharge. Sampling shall be performed during the first hour of discharge. If, for safety reasons, a sample cannot be obtained during the first hour of discharge, a sample shall be obtained at the first safe opportunity, and the reason for the delay shall be included in the report. If there is no discharge to surface waters, then no monitoring is required. In the corresponding monitoring report, the Discharger will indicate under statement of perjury that no effluent was discharged to surface water during the reporting period.
- ³ The mass emission (lbs/day) for the discharge shall be calculated and reported using the limitation concentration and the actual flow rate measured at the time of discharge, using the formula.

$$M = 8.34 \times C_e \times Q$$
 where: M = mass discharge for a pollutant, lbs/day
 C_e = limitation concentration for a pollutant, mg/L
 Q = actual discharge flow rate, MGD
- ⁴ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants, the methods must meet the lowest MLs specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level.
- ⁵ Refer to section V, Whole Effluent Toxicity Testing Requirements.
- ⁶ Water samples analyzed for these pollutants shall not be filtered.
- ⁷ Total PCBs (polychlorinated biphenyls) means the sum of chlorinated biphenyls whose analytical characteristics resemble those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254, and Aroclor-1260.
- ⁸ Priority Pollutants as defined by the CTR defined in Finding II.I of the Limitations and Discharge Requirements of this Order, and included as Attachment I.
- ⁹ Monitoring is only required during years in which discharge occurs. Annual samples shall be collected during the first discharge of the year. If there is no discharge to surface waters, the Discharger will indicate in the corresponding monitoring report, understatement of perjury that no effluent was discharged to surface water during the reporting period.
- ¹⁰ TCDD equivalents shall be calculated using the following formula, where the Minimum Levels (ML), and toxicity equivalency factors (TEFs) are as listed in the Table below. The Discharger shall report all measured values of individual congeners, including data qualifiers. When calculating TCDD equivalents, the Discharger shall set congener concentrations below the minimum levels to zero. USEPA method 1613 may be used to analyze dioxin and furan congeners.

$$\text{Dioxin-TEQ (TCDD equivalents)} = \sum(C_x \times \text{TEF}_x)$$

where: C_x = concentration of dioxin or furan congener x
 TEF_x = TEF for congener x

Toxicity Equivalency Factors

| Congeners | Minimum Level (pg/L) | Toxicity Equivalence Factor (TEF) |
|----------------------------|-----------------------------|--|
| 2,3,7,8 - tetra CDD | 10 | 1.0 |
| 1,2,3,7,8 - penta CDD | 50 | 1.0 |
| 1,2,3,4,7,8 - hexa CDD | 50 | 0.1 |
| 1,2,3,6,7,8 - hexa CDD | 50 | 0.1 |
| 1,2,3,7,8,9 - hexa CDD | 50 | 0.1 |
| 1,2,3,4,6,7,8 - hepta CDD | 50 | 0.01 |
| Octa CDD | 100 | 0.0001 |
| 2,3,7,8 - tetra CDF | 10 | 0.1 |
| 1,2,3,7,8 - penta CDF | 50 | 0.05 |
| 2,3,4,7,8 - penta CDF | 50 | 0.5 |
| 1,2,3,4,7,8 - hexa CDF | 50 | 0.1 |
| 1,2,3,6,7,8 - hexa CDF | 50 | 0.1 |
| 1,2,3,7,8,9 - hexa CDF | 50 | 0.1 |
| 2,3,4,6,7,8 - hexa CDF | 50 | 0.1 |
| 1,2,3,4,6,7,8 - hepta CDFs | 50 | 0.01 |
| 1,2,3,4,7,8,9 - hepta CDFs | 50 | 0.01 |
| Octa CDF | 100 | 0.0001 |

2. Sediment Monitoring of Effluent at Monitoring Location EFF-001

The Discharger must sample the discharge at the point following final treatment, prior to entering the receiving water. The exact location of the sampling point must be stipulated in the initial self-monitoring report. All samples shall be tested in accordance with USEPA or ASTM methodologies where such methods exist. Where no USEPA or ASTM methods exist, the State Water Board or Regional Water Board (collectively Water Boards) shall approve the use of other methods. Analytical tests shall be conducted by laboratories certified by the California Department of Public Health in accordance with Water Code Section 13176.

Table E-3. Sediment Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency |
|------------------|--------------|--------------------|-----------------------------------|
| Copper | mg/kg | Grab | 1/Year ¹ |
| Lead | mg/kg | Grab | 1/Year ¹ |
| Zinc | mg/kg | Grab | 1/Year ¹ |
| PAHs | mg/kg | Grab | 1/Year ¹ |
| DDT | mg/kg | Grab | 1/Year ¹ |
| PCBs | mg/kg | Grab | 1/Year ¹ |

¹. Monitoring is only required during years in which a discharge occurs as specified in Footnote 4 to Table 6, page 15-16 of this Order. If monitoring is not triggered because of an exceedance, sediment monitoring must occur at least once during the five year permit term, if a discharge from the facility occurs..

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity

1. Definition of Acute Toxicity

Acute toxicity is a measure of primarily lethal effects that occur over a 96-hour period. Acute toxicity shall be measured in percent survival measured in undiluted (100%) effluent.

- a. The average monthly survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, and
- b. No single test shall produce less than 70% survival.

2. Acute Toxicity Effluent Monitoring Program

- a. **Method.** The Discharger shall conduct acute toxicity tests (96-hour static renewal toxicity tests) on effluent grab samples, by methods specified in 40 CFR Part 136 which cites USEPA's *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition, October 2002, USEPA, Office of Water, Washington D.C. (EPA/821/R-02/012) or a more recent edition to ensure compliance. Effluent samples shall be collected after all treatment processes and before discharge to the receiving water.
- b. **Test Species.** The fathead minnow, *Pimephales promelas* (Acute Toxicity Test Method 2000.0), shall be used as the test species for fresh water discharges and the topsmelt, *Atherinops affinis*, shall be used as the test species for brackish effluent. However, if the salinity of the receiving water is between 1 to 32 parts per thousand (ppt), the Discharger may have the option of using the inland silverside, *Menidia beryllina* (Acute Toxicity Test Method 2006.0), instead of the topsmelt. The method for topsmelt (Larval Survival and Growth Test Method 1006.0) is found in USEPA's *Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms, First Edition, August 1995* (EPA/600/R-95/136).
- c. **Alternate Reporting.** For the acute toxicity testing with topsmelt, the Discharger may elect to report the results or endpoint from the first 96 hours of the chronic toxicity test as the results of the acute toxicity test, using USEPA's August 1995 method (EPA/600/R-95/136) to conduct the chronic toxicity test.
- d. **Acute Toxicity Accelerated Monitoring.** If either of the above requirements (sections 1.a and 1.b) is not met, the Discharger shall conduct six additional tests, approximately every two weeks, over a 12-week period (or over the next six discharge events). The Discharger shall ensure that they receive results of a failing toxicity test within 24 hours of the close of the test and the additional tests

shall begin within 5 business days of the receipt of the result. If the additional tests indicate compliance with the toxicity limitation, the Discharger may resume regular testing.

e. Toxicity Identification Evaluation

- i. If the results of any two of the six accelerated tests are less than 90% survival, then the Discharger shall immediately begin a Toxicity Identification Evaluation (TIE) and implement the Initial Investigation Toxicity Reduction Evaluation (TRE) workplan. The TIE shall include all reasonable steps to identify the sources of toxicity. Once the sources are identified, the Discharger shall take all reasonable steps to reduce toxicity to meet the objective.
- ii. If the initial test and any of the additional six acute toxicity bioassay tests results are less than 70% survival, the Discharger shall immediately begin a TIE and implement Initial Investigation TRE workplan. Once the sources are identified the Discharger shall take all reasonable steps to reduce toxicity to meet the requirements.

B. Quality Assurance

1. Concurrent testing with a reference toxicant shall be conducted. Reference toxicant tests shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
2. If either the reference toxicant test or effluent test does not meet all test acceptability criteria (TAC) as specified in the test methods manuals (EPA/600/4-91/002 and EPA/821-R-02-014), then the Discharger must re-sample and re-test at the earliest time possible.
3. Control and dilution water should be receiving water (if non-toxic) or laboratory water, as appropriate, as described in the manual. If the dilution water used is different from the water the test species are grown in (culture water), a second control using culture water shall be used.

C. Preparation of an Initial Investigation TRE Workplan

The Discharger shall prepare and submit a copy of the Discharger's initial investigation TRE workplan to the Executive Officer of the Regional Water Board for approval within **90 days** of the effective date of this permit. If the Executive Officer does not disapprove the workplan within 60 days, the workplan shall become effective. The Discharger shall use USEPA manuals EPA/600/2-88/070 (industrial) or EPA/833B-99/002 (municipal) as guidance. This workplan shall describe the steps the Discharger intends to follow if toxicity is detected, and should include, at a minimum:

1. A description of the investigation and evaluation techniques that will be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
2. A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices, and a list of all chemicals used in the operation of the facility; and,
3. If a TIE is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor). See MRP Section V.E.3 for guidance manuals.

D. Steps in TRE and TIE Procedures

1. If results of the implementation of the facility's initial investigation TRE workplan indicate the need to continue the TRE/TIE, the Discharger shall expeditiously develop a more detailed TRE workplan for submittal to the Executive Officer within 30 days of completion of the initial investigation TRE. The detailed workplan shall include, but not be limited to:
 - a. Further actions to investigate and identify the cause of toxicity;
 - b. Actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity;
 - c. A schedule for these actions.
2. The following section summarizes the stepwise approach used in conducting the TRE
 - a. Step 1 includes basic data collection. Data collected for the accelerated monitoring requirements may be used to conduct the TRE;
 - b. Step 2 evaluates optimization of the treatment system operation, facility housekeeping, and the selection and use of in-plant process chemicals;
 - c. If Steps 1 and 2 are unsuccessful, Step 3 implements a TIE and employment of all reasonable efforts using currently available TIE methodologies. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity;
 - d. Assuming successful identification or characterization of the toxicant(s), Step 4 evaluates final effluent treatment options;
 - e. Step 5 evaluates in-plant treatment options; and,
 - f. Step 6 consists of confirmation once a toxicity control method has been implemented.

Many recommended TRE elements parallel source control, pollution prevention, and storm water control program best management practices (BMPs). To prevent duplication of efforts, evidence of compliance with those requirements may be sufficient to comply with TRE requirements. By requiring the first steps of a TRE to be accelerated testing and review of the facility's TRE workplan, a TRE may be ended in its early stages. All reasonable steps shall be taken to reduce toxicity to the required level. The TRE may be ended at any stage if monitoring indicates there are no longer toxicity (six consecutive chronic toxicity test results are less than or equal to 1.0 TUC or six consecutive acute toxicity test results are greater than 90% survival).

3. The Discharger shall initiate a TIE as part of the TRE process to identify the cause(s) of toxicity. The Discharger shall use the USEPA acute manual, chronic manual, EPA/600/6-91/005F (Phase I)/EPA/600/R-96-054 (for marine), EPA/600/R-92/080 (Phase II), and EPA-600/R-92/081 (Phase III), as guidance.
4. If a TRE/TIE is initiated prior to completion of the accelerated testing required in section V.A.2.d and V.B.2.b of this program, then the accelerated testing schedule may be terminated, or used as necessary in performing the TRE/TIE, as determined by the Executive Officer.
5. Toxicity tests conducted as part of a TRE/TIE may also be used for compliance determination, if appropriate.
6. The Regional Water Board recognizes that toxicity may be episodic and identification of causes of and reduction of sources of toxicity may not be successful in all cases. Consideration of enforcement action by the Regional Water Board will be based, in part, on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.

E. Ammonia Removal

1. Except with prior approval from the Executive Officer of the Regional Water Board, ammonia shall not be removed from bioassay samples. The Discharger must demonstrate the effluent toxicity is caused by ammonia *because of* increasing test pH when conducting the toxicity test. It is important to distinguish the potential toxic effects of ammonia from other pH sensitive chemicals, such as certain heavy metals, sulfide, and cyanide. The following may be steps to demonstrate that the toxicity is caused by ammonia and not other toxicants before the Executive Officer would allow for control of pH in the test.
 - a. There is consistent toxicity in the effluent and the maximum pH in the toxicity test is in the range to cause toxicity due to increased pH.
 - b. Chronic ammonia concentrations in the effluent are greater than 4 mg/L total ammonia.

- f. TU_a values $\left(TU_a = \frac{100}{LC_{50}} \right)$;
 - g. IC_{15} , IC_{25} , IC_{40} and IC_{50} values in percent effluent;
 - h. NOEC value(s) in percent effluent;
 - i. Mean percent mortality (+standard deviation) after 96 hours in 100% effluent (if applicable);
 - j. NOEC and LOEC values for reference toxicant test(s);
 - k. IC_{25} value for reference toxicant test(s);
 - l. Any applicable charts; and
 - m. Available water quality measurements for each test (e.g., pH, D.O., temperature, conductivity, hardness, salinity, ammonia).
- 4. The Discharger shall provide a compliance summary, which includes a summary table of toxicity data from all samples collected during that year.
 - 5. The Discharger shall notify by telephone or electronically, this Regional Water Board of any toxicity exceedance of the limit or trigger within 24 hours of receipt of the results followed by a written report within 14 calendar days of receipt of the results. The verbal or electronic notification shall include the exceedance and the plan the Discharger has taken or will take to investigate and correct the cause(s) of toxicity. It may also include a status report on any actions required by the permit, with a schedule for actions not yet completed. If no actions have been taken, the reasons shall be given.

VI. LAND DISCHARGE MONITORING REQUIREMENTS

Not Applicable

VII. RECLAMATION MONITORING REQUIREMENTS

Not Applicable

VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER

A. Monitoring Location RSW-001

- 1. Receiving water sampling shall be conducted at the same time as the effluent monitoring when there is discharge to surface water. The Discharger shall monitor the Cerritos Channel, at Monitoring Location RSW-001, within 50 feet upstream of Discharge Point No. 001, relative to tidal flow, as follows:

Table E-4. Receiving Water Monitoring Requirements at Monitoring Location RSW-001

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|----------------------------------|-------|-------------|----------------------------|---------------------------------|
| Ammonia, Total (as N) | mg/L | Grab | 1/Year | 1 |
| pH | s.u. | Grab | 1/Year | 1 |
| Salinity | mg/L | Grab | 1/Year | 1 |
| Temperature | °F | Grab | 1/Year | 1 |
| Priority Pollutants ² | µg/L | Grab | 1/Year | 1 |
| TCDD Equivalents ³ | µg/L | Grab | 1/Year | 1 |

¹ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest MLs specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level.

² Priority Pollutants as defined by the CTR, defined in Finding II.I of the Limitations and Discharge Requirements of this Order, and included as Attachment I.

³ To determine compliance with effluent limitations or to conduct Reasonable Potential Analysis (RPA), this Order requires the Discharger to calculate and report dioxin-toxicity equivalencies (TEQs) using the following formula, where the toxicity equivalency factors (TEFs) are as listed in the Table below. USEPA method 1613 may be used to analyze dioxin and furan congeners.

$$\text{Dioxin-TEQ} = \sum(C_x \times \text{TEF}_x)$$

where:

C_x = concentration of dioxin or furan congener x

TEF_x = TEF for congener x

Toxicity Equivalency Factors

| Congeners | Minimum Level (pg/L) | Toxicity Equivalence Factor (TEF) |
|----------------------------|----------------------|-----------------------------------|
| 2,3,7,8 - tetra CDD | 10 | 1.0 |
| 1,2,3,7,8 - penta CDD | 50 | 1.0 |
| 1,2,3,4,7,8 - hexa CDD | 50 | 0.1 |
| 1,2,3,6,7,8 - hexa CDD | 50 | 0.1 |
| 1,2,3,7,8,9 - hexa CDD | 50 | 0.1 |
| 1,2,3,4,6,7,8 - hepta CDD | 50 | 0.01 |
| Octa CDD | 100 | 0.0001 |
| 2,3,7,8 - tetra CDF | 10 | 0.1 |
| 1,2,3,7,8 - penta CDF | 50 | 0.05 |
| 2,3,4,7,8 - penta CDF | 50 | 0.5 |
| 1,2,3,4,7,8 - hexa CDF | 50 | 0.1 |
| 1,2,3,6,7,8 - hexa CDF | 50 | 0.1 |
| 1,2,3,7,8,9 - hexa CDF | 50 | 0.1 |
| 2,3,4,6,7,8 - hexa CDF | 50 | 0.1 |
| 1,2,3,4,6,7,8 - hepta CDFs | 50 | 0.01 |
| 1,2,3,4,7,8,9 - hepta CDFs | 50 | 0.01 |
| Octa CDF | 100 | 0.0001 |

B. Monitoring Location RSW-002

1. Receiving water sampling shall be conducted at the same time as the effluent monitoring when there is discharge to surface water. The Discharger shall monitor the Cerritos Channel, at Monitoring Location RSW-002, within 50 feet downstream of Discharge Point No. 001, relative to tidal flow, as follows:

Table E-5. Receiving Water Monitoring Requirements at Monitoring Location RSW-002

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|------------------|-------|-------------|----------------------------|---------------------------------|
| pH | s.u. | Grab | 1/Year | 1 |
| Dissolved Oxygen | mg/L | Grab | 1/Year | 1 |
| Salinity | mg/L | Grab | 1/Year | 1 |
| Temperature | °F | Grab | 1/Year | 1 |

¹ Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136; for priority pollutants the methods must meet the lowest MLs specified in Attachment 4 of the SIP, where no methods are specified for a given pollutant, by methods approved by this Regional Water Board or the State Water Board. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level.

IX. OTHER MONITORING REQUIREMENTS

A. Visual Monitoring of Upstream and Downstream Receiving Water Sampling Points

1. A visual observation station shall be established in the vicinity of the discharge point of the storm drain to the receiving water, the Cerritos Channel.
2. General observations of the receiving water shall be made at each discharge point when discharges occur. During months of no discharge, the receiving water observations shall be made on a monthly basis. All receiving water observations shall be reported in the quarterly monitoring report. If no discharge occurred during the observation period, this shall be reported. Observations shall be descriptive where applicable, such that colors, approximate amounts, or types of materials are apparent. The following observations shall be made:
 - a. Tidal stage, time, and date of monitoring
 - b. Weather conditions
 - c. Color of water
 - d. Appearance of oil films or grease, or floatable materials
 - e. Extent of visible turbidity or color patches
 - f. Direction of tidal flow
 - g. Description of odor, if any, of the receiving water
 - h. Presence and activity of California Least Tern and California Brown Pelican.

B. Storm Water Monitoring

- 1. Rainfall Monitoring.** The Discharger shall measure and record the rainfall on each day of the month. This information shall be included in the monitoring report for that month. In lieu of measuring rainfall, the Discharger may report rainfall data collected at the Long Beach Airport. If no effluent discharge to surface waters occurred during a rainfall event, no rainfall data is required to be reported in the corresponding monitoring report.
- 2. Visual Observation.** The Discharger shall make visual observations of all storm water discharge locations on at least one storm event per month that produces a significant storm water discharge to observe the presence of floating and suspended materials, oil and grease, discoloration, turbidity, and odor. A “significant storm water discharge” is a continuous discharge of storm water for a minimum of one hour, or the intermittent discharge of storm water for a minimum of 3 hours in a 12-hour period.

C. Storm Water Pollution Prevention Plan (SWPPP), Best Management Practices Plan (BMPP) and Spill Contingency Plan (SCP)

1. As required under Special Provision VI.C.3 of this Order, the Discharger shall submit an updated SWPPP, BMPP, and SCP to the Regional Water Board within 90 days of the effective date of this permit.

Annually the Discharger shall report the status of the implementation and the effectiveness of the SWPPP, BMPP, and SCP Status required under Special Provision VI.C.3 of this Order. The SWPPP, BMPP, and SCP Status shall be reviewed at a minimum once per year and updated as needed to ensure all actual or potential sources of pollutants in wastewater and storm water discharged from the facility are addressed in the SWPPP, BMPP, and SCP Status. All changes or revisions to the SWPPP, BMPP, and SCP Status will be summarized in the annual report required under Attachment E, Monitoring and Reporting, section XI.D.

D. Regional Monitoring

The Discharger may be required to participate in the development of Regional Monitoring program(s) to address pollutants as specified in the Harbor Toxics TMDL.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. If there is no discharge to surface waters during any reporting period, the Discharger will indicate under statement of perjury that no effluent was discharged to surface water during the reporting period in the corresponding monitoring report.

3. Each monitoring report shall contain a separate section titled "Summary of Non-Compliance" which discusses the compliance record and corrective actions taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with waste discharge requirements, as well as all excursions of effluent limitations.
4. The Discharger shall inform the Regional Water Board well in advance of any proposed construction activity that could potentially affect compliance with applicable requirements.
5. The Discharger shall report the results of acute and chronic toxicity testing, TRE and TIE as required in the Attachment E, Monitoring and Reporting, Section V.F.

B. Self Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit SMRs as searchable PDF documents. SMR documents that are less than 10 megabytes (MB) should be emailed to losangeles@waterboards.ca.gov. Documents that are 10 MB or larger should be transferred to a disk and mailed to the address listed in section XI.B.8.c of this MRP. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Discharger shall submit quarterly SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Discharger monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-6. Monitoring Periods and Reporting Schedule

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period | SMR Due Date |
|--------------------|--------------------------------|---|---|
| 1/Day | On permit effective date. | (Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling. | August 1 November 1 February 1 May 1 |
| 1/Discharge Event | On permit effective date. | 1 st day of calendar month through last day of calendar month | August 1 November 1 February 1 May 1 |
| 1/Year | On permit effective date. | January 1 through December 31 | February 1 |

4. Reporting Protocols. The Discharger shall report with each sample result the applicable reported Minimum Level (ML) and the current Method Detection Limit (MDL), as determined by the procedure in Part 136.

5. The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the reported ML shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the Reporting Limit (RL), but greater than or equal to the laboratory’s MDL, shall be reported as DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words “Estimated Concentration” (may be shortened to “Est. Conc.”). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (+ a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory’s MDL shall be reported as ND.
- d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

6. Compliance Determination. Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined above and

Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the RL.

- 7. Multiple Sample Data.** When determining compliance with an Average Monthly Effluent Limitation (AMEL) or Maximum Daily Effluent Limitation (MDEL) for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of DNQ or ND. In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
 - a.** The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - b.** The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

- 8. The Discharger shall submit SMRs in accordance with the following requirements:**
 - a.** The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
 - b.** The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the waste discharge requirements (WDRs); discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.

- c. SMRs must be submitted to the Regional Water Board, signed and certified as required in Item X.B.1. If a disk that contains a document that is 10MB or larger is required, submit it to the address listed below:

**California Regional Water Quality Control Board
Los Angeles Region
320 W. 4th Street, Suite 200
Los Angeles, CA 90013**

C. Discharge Monitoring Reports (DMRs)

Not Applicable

D. Other Reports

1. Within 90 days of the effective date of this permit, the Discharger is required to submit the following to the Regional Water Board:
 - d. Initial Investigation TRE workplan
 - e. Updated SWPPP
 - f. Updated BMPP
 - g. Updated SCP
2. Within **20 months** of the effective date of the Harbor Toxics TMDL **and annually thereafter**, the Discharger or the Responsible Parties shall submit annual implementation reports to the Regional Water Board. The reports shall describe the measures implemented and the progress achieved toward meeting the assigned WLAs and LAs.

ATTACHMENT F – FACT SHEET

Table of Contents

| | | |
|------|---|------|
| I. | Permit Information | F-3 |
| II. | Facility Description | F-4 |
| | A. Description of Wastewater and Biosolids Treatment or Controls | F-5 |
| | B. Discharge Points and Receiving Waters..... | F-6 |
| | C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data | F-6 |
| | D. Compliance Summary..... | F-6 |
| | E. Planned Changes | F-6 |
| III. | Applicable Plans, Policies, and Regulations..... | F-7 |
| | A. Legal Authorities | F-7 |
| | B. California Environmental Quality Act (CEQA) | F-7 |
| | C. State and Federal Regulations, Policies, and Plans | F-7 |
| | D. Impaired Water Bodies on CWA 303(d) List | F-10 |
| | E. Other Plans, Policies and Regulations..... | F-13 |
| IV. | Rationale For Effluent Limitations and Discharge Specifications..... | F-13 |
| | A. Discharge Prohibitions..... | F-14 |
| | B. Technology-Based Effluent Limitations..... | F-14 |
| | 1. Scope and Authority..... | F-14 |
| | 2. Applicable Technology-Based Effluent Limitations | F-15 |
| | C. Water Quality-Based Effluent Limitations (WQBELs)..... | F-16 |
| | 1. Scope and Authority..... | F-16 |
| | 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives..... | F-17 |
| | 3. Determining the Need for WQBELs | F-17 |
| | 4. WQBEL Calculations | F-18 |
| | 5. WQBELs based on Basin Plan Objectives | F-22 |
| | 6. Whole Effluent Toxicity | F-24 |
| | 7. Final WQBELs | F-25 |
| | D. Final Effluent Limitations..... | F-26 |
| | 1. Satisfaction of Anti-Backsliding Requirements..... | F-26 |
| | 2. Satisfaction of Antidegradation Policy..... | F-27 |
| | 3. Mass-based Effluent Limitations | F-27 |
| | 4. Stringency of Requirements for Individual Pollutants..... | F-28 |
| | E. Land Discharge Specifications..... | F-30 |
| | F. Reclamation Specifications..... | F-30 |
| V. | Rationale for Receiving Water Limitations | F-31 |
| | A. Surface Water | F-31 |
| | B. Groundwater | F-31 |
| VI. | Rationale for Monitoring and Reporting Requirements..... | F-31 |
| | A. Influent Monitoring | F-31 |
| | B. Effluent Monitoring..... | F-31 |
| | C. Whole Effluent Toxicity Testing Requirements | F-32 |
| | D. Receiving Water Monitoring..... | F-32 |
| | 1. Surface Water..... | F-32 |
| | 2. Groundwater | F-33 |

| | | |
|-------|--|------|
| E. | Sediment Monitoring of the Effluent..... | F-33 |
| F. | Other Monitoring Requirements..... | F-33 |
| VII. | Rationale for Provisions..... | F-33 |
| A. | Standard Provisions..... | F-33 |
| B. | Special Provisions..... | F-34 |
| 1. | Reopener Provisions..... | F-34 |
| 2. | Special Studies and Additional Monitoring Requirements..... | F-34 |
| 3. | Best Management Practices and Pollution Prevention | F-34 |
| 4. | Construction, Operation, and Maintenance Specifications..... | F-35 |
| 5. | Special Provisions for Municipal Facilities (POTWs Only) | F-35 |
| 6. | Other Special Provisions..... | F-35 |
| 7. | Compliance Schedules | F-35 |
| VIII. | Public Participation | F-35 |
| A. | Notification of Interested Parties | F-35 |
| B. | Written Comments | F-36 |
| C. | Public Hearing | F-36 |
| D. | Nature of Hearing..... | F-36 |
| E. | Parties to the Hearing | F-36 |
| F. | Public Comments and Submittal of Evidence | F-37 |
| G. | Hearing Procedure..... | F-37 |
| H. | Waste Discharge Requirements Petitions..... | F-37 |
| I. | Information and Copying..... | F-38 |
| J. | Register of Interested Persons | F-38 |
| K. | Additional Information | F-38 |

List of Tables

| | | |
|------------|---|------|
| Table F-1. | Facility Information..... | F-3 |
| Table F-2. | Basin Plan Beneficial Uses | F-7 |
| Table F-3. | Summary of Technology-based Effluent Limitations | F-16 |
| Table F-4. | Applicable Basin Plan Numeric Water Quality Objectives..... | F-23 |
| Table F-5. | Summary of Final WQBELs for Discharge Point No. 001 | F-25 |
| Table F-6. | Summary of Final Effluent Limitations for Discharge Point No. 001 | F-28 |

ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

| | |
|---|---|
| WDID | 4B192208003 |
| Discharger | Tesoro Refining & Marketing Company LLC (Former BP West Coast Products LLC) |
| Name of Facility | Tesoro (Former BP) Wilmington Calciner |
| Facility Address | 1175 Carrack Avenue |
| | Wilmington, CA 90744 |
| | Los Angeles County |
| Facility Contact, Title and Phone | Adrian Rosu, Environmental Engineer, 562-499-3210 |
| Authorized Person to Sign and Submit Reports | Jody Hanson, Plant Manager, 562-499-3201 |
| Mailing Address | P.O. Box 1028 Wilmington, CA 90748 |
| Billing Address | Same as Mailing Address |
| Type of Facility | Petroleum Coke Calcining Facility (SIC 2999) |
| Major or Minor Facility | Minor |
| Threat to Water Quality | Category 2 |
| Complexity | Category B |
| Pretreatment Program | No |
| Reclamation Requirements | Not Applicable |
| Facility Permitted Flow | 1.1 million gallons per day (MGD) |
| Facility Design Flow | Not Applicable |
| Watershed | Los Angeles/Long Beach Harbor |
| Receiving Water | Cerritos Channel, within the Los Angeles-Long Beach Inner Harbor |
| Receiving Water Type | Coastal Water |

- A.** Tesoro Refining & Marketing Company LLC, Former BP West Coast Products LLC (hereinafter Discharger or Tesoro) is the owner and operator of the Tesoro Wilmington Calciner, Former BP Wilmington Calciner Facility (hereinafter Facility) located at 1175 Carrack Avenue, Wilmington, California. Tesoro purchased the Facility on June 1, 2013.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Facility discharges wastewater to the Cerritos Channel within the Los Angeles-Long Beach Inner Harbor, a water of the United States, and is currently regulated by Order No. R4-2007-0031. The Order No. R4-2007-0031 was adopted on June 7, 2007, and expired on May 10, 2012. As per 40 CFR section 122.6, Order No. R4-2007-0031 has been administratively extended and remains in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order.
- C.** The Discharger submitted a Report of Waste Discharge (ROWD), dated October 14, 2011, and applied for renewal of the waste discharge requirements (WDR) and National Pollutant Discharge Elimination System (NPDES) permit to discharge up to 1.1 million gallons per day (MGD) from the Facility. Supplemental information were received on January 10, 2012, and January 26, 2012. The application was deemed complete on January 26, 2012.

On November 28, 2011, and April 2, 2013, PG Environmental, LLC (contractor with the U.S. Environmental Protection Agency) and Regional Water Board staff, respectively, conducted a site visit to review current site conditions and operations of the Facility.

II. FACILITY DESCRIPTION

The Discharger owns and operates the Tesoro Wilmington Calciner facility, a petroleum coke calcining facility. The Facility receives green coke that is produced at Tesoro’s Carson Refinery (NPDES No. CA0000680; hereinafter Refinery) located at 2350 E. 223rd Street, Carson, California. The Refinery is located approximately 2.1 miles north of the Facility. The Refinery processes approximately 275,000 barrels per day of crude oil to produce gasoline, diesel fuel, jet fuel, sulfur, coke, liquefied petroleum gas (LPG), and polypropylene. The green coke from the Refinery is transported by truck and occasionally by rail car to the Facility. The green coke is stored in a covered structure referred to as Coke Barn prior to calcining. The Facility processes green coke (i.e., petroleum coke from an oil refinery’s coking unit) by running it through a large rotary kiln to remove residual moisture and other impurities to produce calcined coke. The impurities generated from the Facility’s calcining process include residual hydrocarbons, which are captured and used to fuel an on-site 34- megawatt (MW) power generation unit.

The Facility’s industrial process waters including boiler blowdown, cooling tower blowdown, plant air sump, acid sump, wastewater from maintenance activities, air compressor condensate, and all other normal calciner wastewater flows to the publicly owned treatment works (POTW) regulated under Permit No. 015671 issued by Los Angeles County Sanitation Department (LACSD) Industrial Wastewater Discharge Program. This Order covers discharges of the remaining treated storm water and wastewater associated with industrial activities only after the retention basin is filled to capacity during or immediately following large storm events, to the Cerritos Channel, a water of the United States..

A. Description of Wastewater and Biosolids Treatment or Controls

The ROWD identifies the following wastewater contributions (long term average flow) to the discharge.

- Green coke drainage and miscellaneous wash water – 2,000 gallons per day (gpd) (0.002 MGD)
- Boiler safety relief system blowdown – 1,000 gpd (0.001 MGD)
- Boiler feed water pump seal flush – 1,000 gpd (0.001 MGD)
- Storm Water Runoff – up to 680,000 gallons

Following submittal of the ROWD, the Discharger provided supplemental information that listed contributions of cooling tower overflow at 100 gpd, on rare occasions. The Discharger requested a total permitted flow of 1.1 MGD.

The Facility has a reverse osmosis (RO) system utilized to treat potable water (from the City) to be used as boiler feed water. The potable water that is rejected by the RO system is conveyed to the cooling tower. The RO system generates a salt-free water for use as cooling water. The RO unit concentrates the removed salts into a softener flush water stream, which is discharged to the industrial sewer under CSDLAC Permit No. 015671.

The Facility consists of paved or concreted areas which are contained by a concrete berm, approximately 4 inches tall. The berm encompasses the entire site except for rail and roadway entrances and exits. The Facility's impervious areas are sloped to convey storm water and process waters to one of two lift stations (i.e., North and South Lift Stations) that pump collected water to the Facility's settling basins.

The storm water and wastewater associated with industrial activities passes through a treatment system consisting of two, concrete-lined, 2-compartment settling basins (eastern and western basin; 110,000 gallons each) for removal of settleable solids. Runoff from coke storage and handling areas is generally routed to the eastern settling basin. Wash water from ash storage and handling areas is generally routed to the western settling basin.

Following treatment in the settling basins, the waste stream then flows into a 680,000-gallon, concrete-lined, retention basin (known as the main storm water basin) for additional settling and neutralization with sulfuric acid (as needed). Solids that accumulate within the settling basins and the retention basin are routinely removed and disposed of off-site to a legal disposal facility. From the retention basin, treated, commingled storm water and process waters are either recycled for use as cooling water or discharged to the Cerritos Channel.

During normal operations, the Facility recycles all water from the forge basin and uses it as cooling tower make up water in all but storm events where rainfall is higher than the recycling rate.

Using this storm water intake and recycling system, the Facility has eliminated most discharge events from the Facility to the receiving water. In December 2010, the Facility encountered the largest amount of rainfall in the Long Beach area since about 1984 and successfully managed all storm water on site without discharging. The December 2010 storm event enabled the Facility to evaluate its retention capacity and storm water handling procedures and to enhance its management of storm water significantly such that now the Facility ensures that 80 percent of its basin remains available for storm events. The Facility has also secured an increased discharge limit to the local LACSD to enable it to discharge additional wastewater, including cooling tower blowdown, if necessary, at all times (including during storm events) thereby enabling the Facility to recycle a higher amount of storm water through the cooling tower. Based on experience and recent engineering studies, the Facility confirmed that its design enables the retention of a 50-year, 24-hour storm event (i.e. a 24-hour amount of precipitation that will occur once in a 50-year period, on average).

During significant storm events when the retention basin reaches full capacity, the treated storm water mixed with wastewater associated with industrial activities is discharged through Discharge Point No. 001 to the Cerritos Channel, a water of the United States.

No discharges occurred during the term of Order No. R4-2007-0031. The most recent discharge event occurred in January 2005.

B. Discharge Points and Receiving Waters

The Discharger proposes to discharge up to 1.1 MGD of treated storm water mixed with wastewater associated with industrial activities from the Facility into the Cerritos Channel, within the Los Angeles-Long Beach Inner Harbor, a water of the United States via Discharge Point No. 001 (Latitude 33° 46' 29" N, Longitude 118° 13' 39" W).

Attachment B depicts a topographic map of the area around the Facility. Attachment C depicts the schematic diagram of the wastewater flow.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

No discharges occurred through Discharge Point No. 001 during the term of the existing Order No. R4-2007-0031.

D. Compliance Summary

During the term of Order No. R4-2007-0031, no discharges occurred. Therefore, there were no violations of effluent limitations.

E. Planned Changes

The Discharger does not currently have any planned changes to the Facility.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to Section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (commencing with Section 13370). It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as WDRs pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with Section 13260).

B. California Environmental Quality Act (CEQA)

Under Water Code Section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code Sections 21100 through 21177.

C. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plans. The Regional Water Board adopted a *Water Quality Control Plan Los Angeles Region Basin Plan for the Coastal Watersheds of Los Angeles and Ventura Counties* (hereinafter Basin Plan) on June 13, 1994, that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply.

The Basin Plan does not specifically identify beneficial uses for the Cerritos Channel, but does identify existing and potential uses for the Los Angeles-Long Beach Inner Harbor, to which the Cerritos Channel is tributary. The Los Angeles-Long Beach Inner Harbor is not designated as MUN. Thus, beneficial uses applicable to the Cerritos Channel are as follows:

Table F-2. Basin Plan Beneficial Uses

| Discharge Point | Receiving Water Name | Beneficial Use(s) |
|-----------------|---|--|
| 001 | Cerritos Channel Within Los Angeles/Long Beach Inner Harbor | <p><u>Existing:</u> Industrial service supply (IND); navigation (NAV); non-contact water recreation (REC-2); commercial and sport fishing (COMM); marine habitat (MAR); rare, threatened, or endangered species (RARE)</p> <p><u>Potential:</u> Water contact recreation (REC-1); shellfish harvesting (SHELL)</p> |

Requirements of this Order implement the Basin Plan.

Enclosed Bays and Estuaries Policy. The Water Quality Control Policy for the Enclosed Bays and Estuaries of California (Enclosed Bay and Estuaries Policy), adopted by the State Water Resources Control Board (State Water Board) as Resolution No. 95-84 on November 16, 1995, states that:

"It is the policy of the State Water Board that the discharge of municipal wastewaters and industrial process waters (exclusive of cooling water discharges) to enclosed bays and estuaries, other than the San Francisco Bay-Delta system, shall be phased out at the earliest practicable date. Exceptions to this provision may be granted by a Regional Water Board only when the Regional Water Board finds that the wastewater in question would consistently be treated and discharged in such a manner that it would enhance the quality of receiving waters above that which would occur in the absence of the discharge."

The discharge from the Tesoro Wilmington Calciner Facility is comprised primarily of storm water runoff mixed with a small amount of wastewater. Discharges to the Cerritos Channel, within the Los Angeles-Long Beach Inner Harbor, would only occur during significant storm events. Since the discharge is not municipal wastewater or industrial process wastewater which are prohibited, this discharge is permitted. This Order also contains provisions necessary to protect all beneficial uses of the receiving water.

- 2. Thermal Plan.** The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains temperature objectives for surface waters. Requirements of this Order implement the Thermal Plan. Additionally, a white paper developed by Regional Water Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*, evaluated the optimum temperatures for steelhead, topsmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel. A maximum effluent temperature limitation of 86°F was determined to be appropriate for protection of aquatic life and is included in this Order.
- 3. Ammonia Basin Plan Amendment.** The 1994 Basin Plan provided water quality objectives for ammonia to protect aquatic life, in Table 3-1 through Table 3-4. However, those ammonia objectives were revised on March 4, 2004, by the Regional Water Board with the adoption of Resolution No. 2004-022, *Amendment to the Water Quality Plan for the Los Angeles Region to Update the Ammonia Objectives for Inland Surface Waters Not Characteristic of Freshwater (including enclosed bays, estuaries and wetlands) with the Beneficial Use designations for protection of "Aquatic Life"*. The ammonia Basin Plan amendment was approved by the State Water Board on July 22, 2004, Office of Administrative Law on September 15, 2004, and by USEPA on May 19, 2005. The amendment revised the Basin Plan by updating the ammonia objectives for inland surface waters not

characteristic of freshwater such that they are consistent with USEPA's "*Ambient Water Quality Criteria for Ammonia (Saltwater) – 1989.*" The amendment revised the regulatory provisions of the Basin Plan by adding language to Chapter 3, "Water Quality Objectives."

For inland surface waters not characteristic of freshwater (including enclosed bays, estuaries, and wetlands), the objectives are a 4-day average concentration of unionized ammonia of 0.035 mg/L, and a one-hour average concentration of unionized ammonia of 0.233 mg/L. The objectives are fixed concentrations of unionized ammonia, independent of pH, temperature, or salinity. The amendment includes an implementation procedure to convert unionized ammonia objectives to total ammonia effluent limits. The amendment also simplifies the implementation procedures for translating ammonia objectives into effluent limits in situations where a mixing zone has been authorized by the Regional Water Board. Finally, the amendment revises the implementation procedure for determining saltwater, brackish or freshwater conditions, to be consistent with the objectives. The objectives will apply only to inland surface waters not characteristic of freshwater (including enclosed bays, estuaries and wetlands) and do not impact the Ammonia Water Quality Objectives for ocean waters contained in the California Ocean Plan.

- 4. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
- 5. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- 6. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (40 CFR § 131.21, 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect

and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.

- 7. Antidegradation Policy.** 40 CFR section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge must be consistent with the antidegradation provision of 40 CFR section 131.12 and State Water Board Resolution No. 68-16.
- 8. Anti-Backsliding Requirements.** Section 402(o) of the CWA establishes statutory language prohibiting the backsliding of effluent limits. Sections 402(o) of the CWA and federal regulations at title 40, Code Federal Regulations (CFR) section 122.44(l) outlines specific exception to the general prohibition against establishment of less stringent effluent limitations.

These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. The effluent limitations included in this Order for copper, and zinc are less stringent than in the previous Order. As discussed in this Fact Sheet, this relaxation of effluent limitations is consistent with this relaxation is consistent with exceptions identified under Section 402(o).

D. Impaired Water Bodies on CWA 303(d) List

Section 303(d) of the CWA requires states to identify specific water bodies where water quality standards are not expected to be met after implementation of technology-based effluent limitations on point sources. For all 303(d)-listed water bodies and pollutants, the Regional Water Board plans to develop and adopt total maximum daily loads (TMDLs) that will specify waste load allocations (WLAs) for point sources and load allocations (LAs) for non-point sources, as appropriate.

The USEPA approved the State's 2010 303(d) list of impaired water bodies on November 12, 2010. Certain receiving waters in the Los Angeles watershed do not fully support beneficial uses and therefore have been classified as impaired on the 2010 303(d) list and have been scheduled for TMDL development.

The Facility discharges to the Cerritos Channel, within the Los Angeles-Long Beach Inner Harbor. The 2010 State Water Resources Control Board (State Water Board) California 303(d) List includes the classification of the Los Angeles-Long Beach Inner Harbor. The pollutants of concern include beach closures due to bacteria, benthic community effects, benzo(a)pyrene (3,4-benzopyrene-7-d), chrysene, copper, dichlorodiphenyltrichloroethane (DDT), polychlorinated biphenyls (PCBs), sediment toxicity, and zinc.

The following are summaries of the TMDLs for the Los Angeles/Long Beach Harbor Inner Harbor:

- 1. Bacteria TMDL.** The Regional Water Board approved the Los Angeles Harbor Bacteria TMDL through Resolution 2004-011 on July 1, 2004. The State Water Board, Office of Administrative Law (OAL), and USEPA approved the TMDL on October 21, 2004, January 5, 2005, and March 1, 2005, respectively. The Bacteria TMDL became effective on March 10, 2005. The Bacteria TMDL addresses Inner Cabrillo Beach and the Main Ship Channel of the Los Angeles Inner Harbor. This Order includes bacteria limitations based on WQS applicable to Cerritos Channel. These WQS (and WQBELs) are identical to the WQS used to develop the Bacteria TMDL that is applicable to the Main Ship Channel immediately downstream of Cerritos Channel.
- 2. Harbor Toxics TMDL.** The Regional Water Board adopted Resolution No. R11-008 on May 5, 2011, that amended the Basin Plan to incorporate the *TMDL for Toxic Pollutants in Dominguez Channel and Greater Los Angeles and Long Beach Harbors Waters* (Harbor Toxics TMDL). The Harbor Toxic TMDL was approved by the State Water Board on February 7, 2012, the OAL on March 21, 2012, and the USEPA on March 23, 2012. The Harbor Toxics TMDL contains requirements applicable to this discharge. Therefore, this Order contains effluent limitations and monitoring requirements based on the TMDL.

For Cerritos Channel which is located within the Long Beach Inner Harbor the Harbor Toxics TMDL included:

- a.** Sediment interim concentration-based allocations (in mg/kg sediment) for copper, lead, zinc, DDT, PAHs, and PCBs (Attachment A to Resolution No. R11-008, p. 11).
- b.** Water column final concentration-based waste load allocations (WLAs) (ug/L) for copper, lead, zinc, 4,4'-DDT and total PCBs (Attachment A to Resolution No. R11-008, pp. 13-14).
- c.** Provisions for monitoring discharges and/or receiving waters during the TMDL's 20 year implementation schedule to determine attainment with waste load and load allocations as appropriate.

Implementation of the Harbor Toxics TMDL

The provisions of this Order implement and are consistent with the assumptions and requirements of all waste load allocations (WLAs) established in the Harbor Toxics TMDLs. This Order requires final WQBELs that are statistically-calculated based on salt water column final concentration-based WLAs (in µg/L, total metal) for copper (3.73), lead (8.52), zinc (85.6), 4,4'-DDT (0.00059), and total PCBs (0.00017) (referred to in this Order as CTR TMDL-based WLAs), converted from saltwater CTR criteria using CTR saltwater default translators, and relevant implementation provisions in section 1.4 of the State Implementation Policy. The TMDL includes provisions for a 20-year implementation schedule when warranted. However, this

Order requires final WQBELs (referred to in this Order as CTR TMDL-based effluent limits). Historical data indicates that the Discharger may not be able to comply with the final effluent limitations for the pollutants targeted in the water column that are specified in the Harbor Toxics TMDL (i.e., lead, DDT, and PCBs). On March 28, 2013, the Discharger requested the Regional Water Board issue a Time Schedule Order (TSO) with interim limits for lead, DDT, and PCBs. A TSO has been issued with this Order.

This Order also includes monitoring thresholds based on the TMDL's interim sediment allocations (in mg/kg sediment) for copper (142.3), lead (50.4), zinc (240.6), PAHs (4.58), DDT (0.070), and PCBs (0.060), and associated sediment monitoring requirements for the effluent. Regardless of these monitoring thresholds, the Discharger shall ensure that effluent concentrations and mass discharges do not exceed levels that can be attained by performance of the Facility's treatment technologies existing at the time of permit issuance, reissuance, or modification. The TMDL's interim sediment allocations were developed to ensure that the beneficial uses of the Cerritos Channel within the Los Angeles/Long Beach Inner Harbor are protected.

The water column CTR TMDL-based WLAs for copper, lead, zinc, 4,4'-DDT, and total PCBs were developed to ensure that the beneficial uses of the Cerritos Channel are protected. However, no water column CTR TMDL-based WLAs were assigned for PAHs in the Greater Harbor Waters (includes Los Angeles/Long Beach Inner and Outer Harbors). Therefore, this Order sets performance goals for the PAHs; benzo(a)pyrene and chrysene, to ensure proper implementation of the TMDL's interim sediment allocations for this discharge. During each reporting period, if effluent monitoring results exceed both a TSS effluent limit and a CTR TMDL-based effluent limit or performance goal for copper, lead, zinc, 4,4'-DDT, total PCBs, benzo(a)pyrene, or chrysene, and implementation of the effluent sediment monitoring program is required for that priority pollutant. Sediment monitoring of the effluent shall begin during the first discharge event following the effluent exceedances. An effluent sediment monitoring result at or below the monitoring thresholds in Table 7, page 24 of this Order, demonstrates attainment with the monitoring thresholds and additional sediment monitoring of the effluent is not required. A sediment monitoring result that exceeds the monitoring thresholds requires additional sediment monitoring of the effluent during discharge, but not more frequently than once per year, until the three-year average concentration for sediment monitoring results is at or below the monitoring thresholds.

Performance Goals for Individual PAHs: Benzo(a)pyrene and Chrysene

The performance goals for benzo(a)pyrene and chrysene are intended to ensure that effluent concentrations and mass discharges do not exceed levels that can be attained by performance of the Facility's treatment technologies existing at the time of permit issuance, reissuance, or modification. These performance goals are not enforceable effluent limitations. They act as triggers to determine when sediment monitoring of the effluent is required for these compounds.

CTR human health criteria are not promulgated for total PAHs. Therefore, performance goals are based on CTR human health criteria for the individual PAHs, benzo(a)pyrene (0.049 µg/L) and chrysene (0.049 µg/L). Benzo(a)pyrene and chrysene are selected because the State's 2010 303(d) List classifies the Los Angeles/Long Beach Inner Harbor as impaired for these PAH compounds. See also the May 5, 2011, Final Staff Report for the Harbor Toxics TMDL (Staff Report).

Harbor Toxics TMDL Water Column, Sediment, and Fish Tissue Monitoring for Greater Los Angeles and Long Beach Harbor Waters Compliance Monitoring Program

The TMDL's implementation schedule to demonstrate attainment of WLAs and load allocations is 20 years after the TMDL effective date for a Discharger who justifies the need for an associated time included in a compliance plan. During this period, the Discharger is required, either individually or with a collaborating group, to develop a monitoring and reporting plan (Monitoring Plan) and quality assurance project plan (QAPP) for the water column, sediment, and fish tissue in the Greater Los Angeles and Long Beach Harbor. These plans shall follow the "TMDL Element – Monitoring Plan" provisions in Attachment A to Resolution No. R11-008. The Discharger must inform the Regional Board if they plan to join a collaborative monitoring effort or develop a site specific plan **90 days** after the effective date of the permit. If Calciner is joining a collaborative effort that notification must include documentation of such. If developing a site specific Monitoring Plan, the plan must be submitted **12 months** after the effective date of the permit for public review and, subsequently, Executive Officer approval. Monitoring shall begin **6 months** after a monitoring plan is approved by the Executive Officer. The compliance monitoring program shall include water column, sediment, and fish tissue monitoring.

E. Other Plans, Policies and Regulations

Not Applicable

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the Code of Federal Regulations: section 122.44(a) requires that permits include applicable technology-based limitations and standards; and section 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

The existing Order established effluent limitations for a number of pollutants believed to be present in the discharge of storm water from a calcining facility. Effluent limitations in the existing permit were established for biochemical oxygen demand (BOD), oil and grease, pH, total suspended solids (TSS), acute toxicity, settleable solids, turbidity, copper, nickel, thallium, zinc, and cyanide. These constituents were identified based on a review of

pollutants commonly found in discharges from calcining operations, materials stored or used on-site, and/or were historically detected in the effluent. Therefore, these constituents remain pollutants of concern. Storm water runoff and process waters that come into contact with green coke may become contaminated with various petroleum hydrocarbons, thus total petroleum hydrocarbons is a pollutant of concern. Pollutants included on the 303(d) list for the Los Angeles-Long Beach Inner Harbor, specified in Section III.D of this Fact Sheet, are considered pollutants of concern. Storm water and process water may carry a combination of pollutants that may contribute to acute toxicity. Therefore, toxicity, an indicator of the presence of toxic pollutants, is also considered a pollutant of concern.

Generally, mass-based effluent limitations ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limitations. 40 CFR section 122.45(f)(1) requires that all permit limitations, standards or prohibitions be expressed in terms of mass units except under the following conditions: (1) for pH, temperature, radiation or other pollutants that cannot appropriately be expressed by mass limitations; (2) when applicable standards or limitations are expressed in terms of other units of measure; or (3) if in establishing technology-based permit limitations on a case-by-case basis limitations based on mass are infeasible because the mass or pollutant cannot be related to a measure of production. The limitations, however, must ensure that dilution will not be used as a substitute for treatment. This Order includes mass-based effluent limitations, where appropriate, to comply with 40 CFR section 122.45(f)(1).

A. Discharge Prohibitions

The discharge prohibitions are based on the requirements of the Basin Plan, State Water Board's plans and policies, the Water Code, and previous permit provisions, and they are consistent with the requirements set for other discharges to the Cerritos Channel that are regulated by NPDES permits.

B. Technology-Based Effluent Limitations

1. Scope and Authority

Section 301(b) of the CWA and implementing USEPA permit regulations at 40 CFR section 122.44, Title 40 of the Code of Federal Regulations, require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Best Professional Judgment (BPJ) in accordance with 40 CFR section 125.3.

The CWA requires that technology-based effluent limitations be established based on several levels of controls:

- a.** Best practicable treatment control technology (BPT) represents the average of the best performance by plants within an industrial category or subcategory. BPT standards apply to toxic, conventional, and non-conventional pollutants.

- b. Best available technology economically achievable (BAT) represents the best existing performance of treatment technologies that are economically achievable within an industrial point source category. BAT standards apply to toxic and non-conventional pollutants.
- c. Best conventional pollutant control technology (BCT) represents the control from existing industrial point sources of conventional pollutants including BOD, TSS, fecal coliform, pH, and oil and grease. The BCT standard is established after considering the "cost reasonableness" of the relationship between the cost of attaining a reduction in effluent discharge and the benefits that would result, and also the cost effectiveness of additional industrial treatment beyond BPT.
- d. New source performance standards (NSPS) represent the best available demonstrated control technology standards. The intent of NSPS guidelines is to set limitations that represent state-of-the-art treatment technology for new sources.

The CWA requires USEPA to develop effluent limitations, guidelines and standards (ELGs) representing application of BPT, BAT, BCT, and NSPS. Section 402(a)(1) of the CWA and 40 CFR section 125.3 of the Code of Federal Regulations authorize the use of BPJ to derive technology-based effluent limitations on a case-by-case basis where ELGs are not available for certain industrial categories and/or pollutants of concern. Where BPJ is used, the permit writer must consider specific factors outlined in 40 CFR section 125.3.

2. Applicable Technology-Based Effluent Limitations

Discharges from the Facility are not subject to the federal ELGs in Part 419, that are applicable to the discharges of wastewater from petroleum refining operations. Part 419 defines feedstocks for petroleum refining as "crude oil and natural gas liquids". This facility uses green coke, a petroleum refinery by-product, as a feedstock to the calcining operations. Further, the petroleum refining industry is defined by Standard Industrial Classification (SIC) code 2911, and this facility is classified under SIC code 2999 (manufacture of calcined petroleum coke). For these reasons, the Regional Water Board has determined that this facility is not subject to Part 419.

The technology-based requirements in the Order are based on case-by-case numeric limitations using BPJ. The technology-based effluent limitations are based on the existing Order No. R4-2007-0031 for BOD, TSS, oil and grease, settleable solids, and turbidity utilizing BPJ. The Regional Water Board has determined that these numeric effluent limitations continue to be applicable to the Facility.

Because green coke contains residual hydrocarbons that may enter wash water and storm water runoff, this Order establishes a new effluent limitation based on BPJ for total petroleum hydrocarbons (TPH) equal to 100 µg/L. This limitation has been achievable through source control and treatment at facilities engaged in various petroleum operations and is consistent with permits for similar facilities within the Los Angeles Region.

Order No. R4-2007-0031 requires the Discharger to develop and implement a Storm Water Pollution Prevention Plan (SWPPP). This Order requires the Discharger to update the SWPPP. The revised SWPPP will reflect current operations, treatment activities, and staff responsible for implementing and supporting the SWPPP. The SWPPP will outline site-specific management processes for minimizing storm water contamination and for preventing contaminated storm water from being discharged directly into the storm drain.

This Order also requires that the Discharger update and continue to implement a Best Management Practices Plan (BMPP). The BMPP shall include a summary of BMPs aimed at controlling the potential exposure of pollutants to storm water, inspection practices, schedules of preventive maintenance, housekeeping procedures, vehicle management practices, and spill containment and cleanup procedures.

This Order will also require the Discharger to update and continue to implement their Spill Contingency (SCP).

Table F-3 summarizes the technology-based effluent limitations for Discharge Point No. 001.

Table F-3. Summary of Technology-based Effluent Limitations

| Parameter | Units | Average Monthly | Maximum Daily |
|--|----------------------|-----------------|---------------|
| Biochemical Oxygen Demand (BOD) (5-day@20 Deg. C) | mg/L | 20 | 30 |
| | lbs/day ¹ | 183 | 275 |
| Oil and Grease | mg/L | 10 | 15 |
| | lbs/day ¹ | 92 | 138 |
| Total Suspended Solids (TSS) | mg/L | 30 | 75 |
| | lbs/day ¹ | 275 | 688 |
| Settleable Solids | mL/L | 0.1 | 0.2 |
| Turbidity | NTU | 50 | 75 |
| Total Petroleum Hydrocarbons (TPH) | µg/L | -- | 100 |
| | lbs/day ¹ | | 0.92 |

¹ The mass (lbs/day) limitations are based on a maximum flow of 1.1 MGD and is calculated as follows:

$$\text{Mass (lbs/day)} = \text{Flow (MGD)} \times \text{Concentration (mg/L)} \times 8.34 \text{ (conversion factor).}$$

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

Section 301(b) of the CWA and 40 CFR 40 CFR section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

40 CFR section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable

potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR section 122.44(d)(1)(vi). Permit WQBELs must also be consistent with TMDL WLAs approved by USEPA.

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan. It is also intended to achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

The specific procedures for determining reasonable potential for discharges from the Facility, and if necessary for calculating WQBELs, are contained in the SIP.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

As noted in section II of the Limitations and Discharge Requirements, the Regional Water Board adopted a Basin Plan that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the Basin Plan. The beneficial uses applicable to the Cerritos Channel are summarized in Section III.C.1 of this Fact Sheet. The Basin Plan includes both narrative and numeric water quality objectives applicable to the receiving water.

Priority pollutant water quality criteria in the CTR are applicable to the Cerritos Channel. The CTR contains both saltwater and freshwater criteria. Because a distinct separation generally does not exist between freshwater and saltwater aquatic communities, and in accordance with part 131.38(c)(3), saltwater criteria apply at salinities of 1 part per thousand (ppt) and below at locations where this occurs 95 percent or more of the time. As indicated in the Harbor Toxics TMDL, the salinity in the Los Angeles-Long Beach Inner Harbor at the location of the discharge supports marine aquatic life. Therefore, the CTR criteria for saltwater aquatic life or human health for consumption of organisms, whichever is more stringent, are used to prescribe the effluent limitations in this Order to protect the beneficial uses of the Cerritos Channel, within the Los Angeles-Long Beach Inner Harbor, a water of the United States, in the vicinity of the discharge.

3. Determining the Need for WQBELs

In accordance with Section 1.3 of the SIP, the Regional Water Board conducts a Reasonable Potential Analysis (RPA) for each priority pollutant with an applicable criterion or objective to determine if a WQBEL is required in the permit. If there is a

TMDL WLAs approved by USEPA, then WQBELs are developed using these WLAs. Otherwise, the Regional Water Board analyzes effluent and receiving water data and identifies the maximum observed effluent concentration (MEC) and maximum background concentration (B) in the receiving water for each constituent. To determine reasonable potential, the MEC and the B are then compared with the applicable water quality objectives (C) outlined in the CTR, NTR, as well as the Basin Plan. For all pollutants that have a reasonable potential to cause or contribute to an excursion above a state water quality standard, numeric WQBELs are required. The RPA considers water quality criteria from the CTR and NTR, and when applicable, water quality objectives specified in the Basin Plan. To conduct the RPA, the Regional Water Board identifies the MEC and maximum background concentration in the receiving water for each constituent, based on data provided by the Discharger.

Section 1.3 of the SIP provides the procedures for determining reasonable potential to exceed applicable water quality criteria and objectives. The SIP specifies three triggers to complete a RPA:

- 1) Trigger 1 – If the $MEC \geq C$, a limit is needed.
- 2) Trigger 2 – If the background concentration (B) > C and the pollutant is detected in the effluent, a limit is needed.
- 3) Trigger 3 – If other related information such as CWA 303(d) listing for a pollutant, discharge type, compliance history, etc. indicates that a WQBEL is required.

Sufficient effluent and receiving water data are needed to conduct a complete RPA. If data are not sufficient, the Discharger will be required to gather the appropriate data for the Regional Water Board to conduct the RPA. Upon review of the data, and if the Regional Water Board determines that WQBELs are needed to protect the beneficial uses, the permit will be reopened for appropriate modification.

There have been no discharges from the Facility to surface waters since January 2005, and insufficient data are available to characterize potential discharges from the Facility. Therefore, the RPA was not performed for the priority pollutants regulated in the CTR. Monitoring requirements for CTR parameters have been included to provide sufficient data to perform a RPA. Based on best professional judgement (BPJ) in accordance with 40 CFR section 125.3 the effluent limitations from Order No. R4-2007-0031 for nickel, thallium, and cyanide have been included in this Order. This Order included final WQBELs for copper, lead, zinc, 4-4'-DDTs and total PCBs based on the TMDL WLAs approve by USEPA.

4. WQBEL Calculations

- a. If a reasonable potential exists to exceed applicable water quality criteria or objectives, then a WQBEL must be established in accordance with one or more of the three procedures contained in Section 1.4 of the SIP. These procedures include:

- i. If applicable and available, use of the WLA established as part of a TMDL.
 - ii. Use of a steady-state model to derive maximum daily effluent limitations (MDELs) and average monthly effluent limitations (AMELs).
 - iii. Where sufficient effluent and receiving water data exist, use of a dynamic model, which has been approved by the Regional Water Board.
- b. WQBELs for copper, lead, zinc, 4,4-DDT, and total PCBs are based on Harbor Toxics TMDL WLAs approved by USEPA that are calculated following procedures in Section 1.4 of the SIP.
 - c. Since no discharges occurred during the term of Order No. R4-2007-0031, no RPA was performed. The WQBELs for nickel, thallium, and cyanide have been carried over from Order No. R4-2007-0031. These WQBELs were based on previous effluent monitoring results and follow the procedures based on the steady-state model, available in Section 1.4 of the SIP.
 - d. Since many of the streams in the Region have minimal upstream flows, mixing zones and dilution credits are usually not appropriate. Therefore, in this Order, no dilution credit is allowed. However, in accordance with the reopener provision in section VI.C.1.e in the Order, this Order may be reopened upon the submission by the Discharger of adequate information to establish appropriate dilution credits or a mixing zone, as determined by the Regional Water Board.
 - e. WQBELs Calculation Example

Using total recoverable copper as an example, the following demonstrates how WQBELs were established for this Order. The tables in Attachment J summarize the development and calculation of all WQBELs using the process described below.

The process for developing these limits is in accordance with the Harbor Toxics TMDL and Section 1.4 of the SIP.

Calculation of aquatic life AMEL and MDEL:

Step 1: For each constituent requiring an effluent limit, identify the applicable water quality criteria or objective. For each criterion, determine the effluent concentration allowance (ECA) using the following steady state equation:

$$\begin{aligned} \text{ECA} &= C + D(C-B) \quad \text{when } C > B, \text{ and} \\ \text{ECA} &= C \quad \text{when } C \leq B, \end{aligned}$$

- Where
- C = The priority pollutant criterion/objective, adjusted if necessary for hardness, pH and translators. For discharges from the Facility, criteria for saltwater are independent of hardness and pH.
 - D = The dilution credit, and
 - B = The ambient background concentration

When a WLA has been established through a TMDL for a parameter, the WLA is set equal to the ECA. The Harbor Toxics TMDL establishes the copper water column concentration-based WLA as equal to the saltwater chronic aquatic life criterion.

For total recoverable copper, the applicable WLA identified for the Cerritos Channel within the Long Beach Harbor is

$$ECA = WLA_{\text{chronic}} = 3.73 \mu\text{g/L}$$

Step 2: For each ECA based on aquatic life criterion/objective, determine the long-term average discharge condition (LTA) by multiplying the ECA by a factor (multiplier). The multiplier is a statistically based factor that adjusts the ECA to account for effluent variability. The value of the multiplier varies depending on the coefficient of variation (CV) of the data set and whether it is an acute or chronic criterion/objective. Table 1 of the SIP provides pre-calculated values for the multipliers based on the value of the CV. Equations to develop the multipliers in place of using values in the tables are provided in Section 1.4, Step 3 of the SIP and will not be repeated here.

$$LTA_{\text{acute}} = ECA_{\text{acute}} \times \text{Multiplier}_{\text{acute}}$$

$$LTA_{\text{chronic}} = ECA_{\text{chronic}} \times \text{Multiplier}_{\text{chronic}}$$

The CV for the data set must be determined before the multipliers can be selected and will vary depending on the number of samples and the standard deviation of a data set. If the data set is less than 10 samples, or at least 80% of the samples in the data set are reported as non-detect, the CV shall be set equal to 0.6. Since there are less than 10 samples, the CV is equal to 0.6 for all constituents.

For total recoverable copper, based on the Harbor Toxics TMDL, the following data were used to develop the chronic LTA using equations provided in Section 1.4, Step 3 of the SIP (Table 1 of the SIP also provides this data up to three decimals):

| No. of Samples | CV | ECA Multiplier _{acute} | ECA Multiplier _{chronic} |
|----------------|------|---------------------------------|-----------------------------------|
| 0 | 0.60 | Not Applicable | 0.527 |

Since the WLA for total recoverable copper is based on the chronic criterion (i.e., no WLA was established as equal to the acute criterion), the chronic multiplier will be used to develop the LTA and effluent limitations.

$$LTA_{\text{copper}} = 3.73 \mu\text{g/L} \times 0.527 = 1.97 \mu\text{g/L}$$

Step 3: Select the most limiting (lowest) of the LTA.

$$LTA = \text{most limiting of } LTA_{\text{acute}} \text{ or } LTA_{\text{chronic}}$$

For total recoverable copper, based on the Harbor Toxics TMDL, since there is only one LTA,

$$LTA_{\text{copper}} = 1.97 \mu\text{g/L}$$

Step 4: Calculate the WQBELs by multiplying the LTA by a factor (multiplier). WQBELs are expressed as AMELs and MDELs. The multiplier is a statistically based factor that adjusts the LTA for the averaging periods and exceedance frequencies of the criteria/objectives. The value of the multiplier varies depending on the probability basis, the CV of the data set, the number of samples (for AMEL) and whether it is a monthly or daily limit. Table 2 of the SIP provides pre-calculated values for the multipliers based on the value of the CV and the number of samples. Equations to develop the multipliers in place of using values in the tables are provided in Section 1.4, Step 5 of the SIP and will not be repeated here.

$$AMEL_{\text{aquatic life}} = LTA \times AMEL_{\text{multiplier 95}}$$

$$MDEL_{\text{aquatic life}} = LTA \times MDEL_{\text{multiplier 99}}$$

AMEL multipliers are based on a 95th percentile occurrence probability, and the MDEL multipliers are based on the 99th percentile occurrence probability. If the number of samples is less than four (4), the default number of samples to be used is four (4).

For total recoverable copper, based on the Harbor Toxics TMDL, the following data were used to develop the AMEL and MDEL for effluent limitations using equations provided in Section 1.4, Step 5 of the SIP:

| No. of Samples Per Month | CV | Multiplier _{MDEL 99} | Multiplier _{AMEL 95} |
|--------------------------|-----|-------------------------------|-------------------------------|
| 4 | 0.6 | 3.11 | 1.55 |

Total Recoverable Copper:

$$AMEL = 1.97 \mu\text{g/L} \times 1.55 = 3.1 \mu\text{g/L}$$

$$MDEL = 1.97 \mu\text{g/L} \times 3.11 = 6.1 \mu\text{g/L}$$

Step 5: For the ECA based on human health, set the AMEL equal to the $ECA_{\text{human health}}$

$$AMEL_{\text{human health}} = ECA_{\text{human health}}$$

Copper does not have human health criteria for the consumption of organisms only defined in the CTR or in the Harbor Toxics TMDL. The Harbor Toxics TMDL includes WLAs for 4,4-DDT and total PCBs, that are set equal to CTR human health criteria for the consumption of organisms only. For demonstration,

the calculated effluent limitations for 4,4-DDT, stemming from the Harbor Toxics TMDL, are shown.

For 4,4-DDT:

$$AMEL_{\text{human health}} = 0.00059 \mu\text{g/L}$$

Step 6: Calculate the MDEL for human health by multiplying the AMEL by the ratio of the Multiplier_{MDEL} to the Multiplier_{AMEL}. Table 2 of the SIP provides pre-calculated ratios to be used in this calculation based on the CV and the number of samples.

$$MDEL_{\text{human health}} = AMEL_{\text{human health}} \times (\text{Multiplier}_{MDEL} / \text{Multiplier}_{AMEL})$$

For 4,4-DDT, the following data were used to develop the MDEL_{human health}:

| No. of Samples Per Month | CV | Multiplier _{MDEL 99} | Multiplier _{AMEL 95} | Ratio |
|--------------------------|-----|-------------------------------|-------------------------------|-------|
| 4 | 0.6 | 3.11 | 1.55 | 2.0 |

For 4,4-DDT:

$$MDEL_{\text{human health}} = 0.00059 \mu\text{g/L} \times 2.0 = 0.00118 \mu\text{g/L}$$

Step 7: Select the lower of the AMEL and MDEL based on aquatic life and human health as the WQBEL for the Order. Since the Harbor Toxics TMDL established single value WLAs, this step is unnecessary.

For copper, lead, and zinc, there are no human health (Consumption of Organism Only) criteria, and WLAs have been established based on the Harbor Toxics TMDL, therefore the established effluent limitations are based on aquatic life criteria used for the Harbor Toxics TMDL WLAs. For 4-4-DDT and total PCBs, there are no aquatic life criteria and WLAs have been established based on the Harbor Toxics TMDL, therefore the established effluent limitations are based on human health criteria used for the Harbor Toxics TMDL WLAs. These limitations are expected to be protective of the beneficial uses.

5. WQBELS based on Basin Plan Objectives

The Basin Plan Objectives applicable to the Discharger are identified in Table F-4. These objectives were evaluated with respect to effluent monitoring data and Facility operations.

Table F-4. Applicable Basin Plan Numeric Water Quality Objectives

| Constituent | Units | Water Quality Objectives |
|------------------|---------------|--|
| pH | s.u. | The pH of bays and estuaries shall not be depressed below 6.5 or raised above 8.5 as a result of waste discharges. Ambient pH levels shall not be changed more than 0.2 units from natural conditions as a result of waste discharge. |
| Bacteria | MPN/ 100ml | Marine Waters Designated for Water Contact Recreation (REC-1) <u>Geometric Mean Limits</u> i. Total coliform density shall not exceed 1,000/100 ml. ii. Fecal coliform density shall not exceed 200/100 ml. iii. Enterococcus density shall not exceed 35/100 ml. <u>Single Sample Limits</u> i. Total coliform density shall not exceed 10,000/100 ml. ii. Fecal coliform density shall not exceed 400/100 ml. iii. Enterococcus density shall not exceed 104/100 ml. iv. Total coliform density shall not exceed 1,000/100 ml, if the ratio of fecal-to-total coliform exceeds 0.1. |
| Dissolved Oxygen | mg/L | For all waters, the mean annual dissolved oxygen concentration shall be greater than 7 mg/L, and no single determination shall be less than 5.0 mg/L, except when natural conditions cause lesser concentrations. |
| Turbidity | NTU | Where natural turbidity is between 0 and 50 NTU, increases shall not exceed 20%. Where natural turbidity is greater than 50 NTU increases shall not exceed 10%. |

- a. **pH.** This Order includes effluent and receiving water limitations for pH to ensure compliance with Basin Plan Objectives for pH.
- b. **Ammonia.** No effluent or receiving water data were available to evaluate the discharge with respect to ammonia concentrations in the receiving water. This Order carries over monitoring requirements for ammonia and includes receiving water limitations to ensure compliance with Basin Plan Objectives for ammonia
- c. **Bacteria.** The Discharger does not engage in activities that are likely to contribute bacteria to the effluent. However, the Cerritos Channel, within the Los Angeles-Long Beach Inner Harbor is identified on the 2010 303(d) list as impaired for bacteria. In addition, a Bacteria TMDL has been developed for the Inner Cabrillo Beach and the Main Ship Channel of the Los Angeles Inner Harbor. Therefore, this Order includes bacteria limitations based on water quality standards (WQS) applicable to Cerritos Channel. These WQS (and WQBELs) are identical to the WQS used to develop the Bacteria TMDL that is applicable to the Main Ship Channel immediately downstream of Cerritos Channel.
- d. **Dissolved Oxygen.** No effluent or receiving water data were available to evaluate the discharge with respect to dissolved oxygen concentrations in the effluent or receiving water. This Order applies the water quality objective for dissolved oxygen as a receiving water limitation to ensure compliance with Basin

- Plan Objectives for dissolved oxygen. This Order requires continued monitoring for dissolved oxygen in the receiving water.
- e. **Turbidity.** This Order applies the water quality objective for turbidity as a receiving water limitation in addition to the technology-based effluent limitation. At times the WQO may be more stringent than the numeric technology-based effluent limitation.
 - f. **Temperature.** The Basin Plan lists temperature requirements for the receiving waters and references the Thermal Plan. Based on the requirements of the Thermal Plan and a white paper developed by Regional Water Board staff entitled *Temperature and Dissolved Oxygen Impacts on Biota in Tidal Estuaries and Enclosed Bays in the Los Angeles Region*, a maximum effluent temperature limitation of 86°F is included in the permit. The white paper evaluated the optimum temperatures for steelhead, topmelt, ghost shrimp, brown rock crab, jackknife clam, and blue mussel.

6. Whole Effluent Toxicity

Consistent with Basin Plan requirements, this Order carries over the acute monitoring requirements in the existing order, and expresses the acute toxicity limitations as average monthly and maximum daily limitations. Whole effluent toxicity (WET) protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. WET tests measure the degree of response of exposed aquatic test organisms to an effluent. The WET approach allows for protection of the narrative “no toxics in toxic amounts” criterion while implementing numeric criteria for toxicity. There are two types of WET tests: acute and chronic. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth.

The Basin Plan specifies a narrative objective for toxicity, requiring that all waters be maintained free of toxic substances in concentrations that are lethal to or produce other detrimental responses by aquatic organisms. Detrimental response includes, but is not limited to, decreased growth rate, decreased reproductive success of resident or indicator species, and/or significant alterations in population, community ecology, or receiving water biota. This existing Order contains acute toxicity limitations and monitoring requirements in accordance with the Basin Plan, in which the acute toxicity objective for discharges dictates that the average survival in undiluted effluent for any three consecutive 96-hour static or continuous flow bioassay tests shall be at least 90%, with no single test having less than 70% survival. Consistent with Basin Plan requirements, this Order carries over the acute toxicity limitations and monitoring requirements from the existing Order, and expresses the acute toxicity limitations as average monthly and maximum daily limitations.

In addition to the Basin Plan requirements, Section 4 of the SIP states that a chronic toxicity effluent limitation is required in permits for all discharges that will cause,

have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters. Because the discharge is of short duration and infrequent in nature (emergency-only nature of the discharge), no chronic toxicity limitations or monitoring requirements are included in this Order.

7. Final WQBELs

Based on the RPA, pollutants that demonstrate reasonable potential are copper, nickel, thallim, zinc, and cyanide. Approved Harbor Toxics TMDL WLAs for copper, lead, zinc, DDT, and PCBs are also available for the discharge. Therefore, effluent limitations for copper, lead, nickel, thallium, zinc, cyanide, DDT and PCBs are included in this Order. Refer to Attachment J for a summary of the RPA and associated effluent limitation calculations.

Table F-5. Summary of Final WQBELs for Discharge Point No. 001

| Parameter | Units | Effluent Limitations | | | |
|--|----------------------|----------------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| pH | s.u. | -- | -- | 6.5 | 8.5 |
| Acute Toxicity | % Survival | 1 | | | |
| Temperature | °F | -- | -- | -- | 86 |
| Copper, Total Recoverable ² | µg/L | 3.1 | 6.1 | -- | -- |
| | lbs/day ³ | 0.03 | 0.1 | -- | -- |
| Lead, Total Recoverable ⁵ | µg/L | 7 | 14 | -- | -- |
| | lbs/day ³ | 0.1 | 0.13 | -- | -- |
| Nickel, Total Recoverable ⁴ | µg/L | 7 | 14 | -- | -- |
| | lbs/day ³ | 0.1 | 0.13 | -- | -- |
| Thallium, Total Recoverable ⁴ | µg/L | 6.3 | 13 | -- | -- |
| | lbs/day ³ | 0.1 | 0.12 | -- | -- |
| Zinc, Total Recoverable ² | µg/L | 70 | 141 | -- | -- |
| | lbs/day ³ | 0.6 | 1.3 | -- | -- |
| Cyanide, Total (as CN) ⁴ | µg/L | 0.5 | 1.0 | -- | -- |
| | lbs/day ³ | 0.005 | 0.01 | -- | -- |
| 4,4'-DDT ⁵ | µg/L | 0.0006 | 0.001 | -- | -- |
| | lbs/day ³ | 5.4E-06 | 1.1E-05 | -- | -- |
| Total PCBs ⁵ | µg/L | 0.0002 | 0.0003 | -- | -- |
| | lbs/day ³ | 1.6E-06 | 3.1E-06 | -- | -- |

¹ The acute toxicity of the effluent shall be such that:

- i. The average monthly survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay test shall be at least 90%, and
- ii. No single test shall produce less than 70% survival. Compliance with the toxicity objectives will be determined by the method described in section V of the MRP (Attachment E).

² The newly calculated limitations for copper and zinc are based on the USEPA approved Harbor Toxics TMDL WLAs and calculated using the CTR/SIP procedures. The exception to anti-backsliding is appropriate under CWA sections 404(o)(1) and 303(d)(4)(A).

³ The mass limitations are based on a maximum flow of 1.1 MGD and is calculated as follows:

$$\text{Flow (MGD)} \times \text{Concentration (mg/L)} \times 8.34 \text{ (conversion factor)} = \text{lbs/day}$$

- ⁴ Original limitations were based on CTR-SIP procedures and are carried over from Order No. R4-2007-0031.
- ⁵ The new effluent limitations are based on the USEPA approved Harbor Toxics TMDL WLAs and calculated using the CTR-SIP procedures.

Bacteria Limitations Requirements.

1. Rolling 30-day Geometric Mean Limits

- i. Total coliform density shall not exceed 1,000/100 ml.
- ii. Fecal coliform density shall not exceed 200/100 ml.
- iii. Enterococcus density shall not exceed 35/100 ml.

2.. Single Sample Limits

- i. Total coliform density shall not exceed 10,000/100 ml.
- ii. Fecal coliform density shall not exceed 400/100 ml.
- iii. Enterococcus density shall not exceed 104/100 ml.
- iv. Total coliform density shall not exceed 1,000/100 ml, if the ratio of fecal-to total coliform exceeds 0.1.

D. Final Effluent Limitations

Section 402(o) of the CWA and 40 CFR section 122.44(l) require final effluent limitations or conditions in reissued Orders be at least as stringent as those in the existing Orders based on the submitted sampling data. Effluent limitations for biochemical oxygen demand, oil and grease, pH, total suspended solids, acute toxicity, settleable solids, turbidity, nickel, thallium, and cyanide are being carried over from Order No. R4-2007-0031. The Regional Water Board has determined that these numeric effluent limitations continue to be applicable to the Facility.

This Order includes effluent limitations for copper, lead, zinc, 4,4'-DDT, and total PCBs based on the approved Harbor Toxics TMDL WLAs. All permits authorizing discharges to the Dominguez Channel and Greater Los Angeles and Long Beach Harbor Waters adopted after the effective date of Harbors Toxics TMDL must "include effluent limitations developed consistent with assumptions of any WLA that has been assigned to the discharge as part of an approved TMDL." See 40 C.F.R § 122.44(d)(1)(vii)(B) Hence, the applicable requirements of the Harbor Toxics TMDL have been included in the Tesoro Wilmington Calciner permit.

A technology-based effluent limitation is included for TPH, based on BPJ.

1. Satisfaction of Anti-Backsliding Requirements

Section 402(o) of the CWA establishes statutory language prohibiting the backsliding of effluent limits. Sections 402(o) of the CWA and federal regulations at title 40, Code Federal Regulations section 122.44(l) outlines specific exception to the general prohibition against establishment of less stringent effluent limitations.

These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where

limitations may be relaxed. The effluent limitations included in this Order for copper, and zinc are less stringent than in the previous Order. As discussed below, this relaxation of effluent limitations authorized under CWA section 402(o)(1) because it is in compliance with CWA section 303(d)(4)(A) is permissible.

In this case, backsliding from the existing effluent limitations for copper, and zinc is authorized because the revised effluent limitations are based on the Harbor Toxics TMDL WLAs which will assure the attainment of water quality standards. The new effluent limitations for copper and zinc were established based on a final concentration-based WLA converted from the saltwater CTR chronic criterion using the CTR saltwater default translator, and relevant implementation provisions in section 1.4 of the State Implementation Policy.

2. Satisfaction of Antidegradation Policy

40 CFR section 131.12 requires that the state water quality standards include an anti-degradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies.

This Order does not provide for an increase in the permitted design flow or allow for a reduction in the level of treatment. The limits included hold the Discharger to performance levels that will not cause or contribute to water quality impairment or water quality degradation. Further, compliance with these requirements will result in the use of best practicable treatment or control of the discharge. Therefore, the issuance of this permit is consistent with the state's antidegradation policy.

3. Mass-based Effluent Limitations

Generally, mass-based effluent limitations ensure that proper treatment, and not dilution, is employed to comply with the final effluent concentration limitations. 40 CFR section 122.45(f)(1) requires that all permit limitations, standards or prohibitions be expressed in terms of mass units except under the following conditions: (1) for pH, temperature, radiation or other pollutants that cannot appropriately be expressed by mass limitations; (2) when applicable standards or limitations are expressed in terms of other units of measure; or (3) if in establishing technology-based permit limitation on a case-by-case basis limitation based on mass are infeasible because the mass or pollutant cannot be related to a measure of production.

Mass-based effluent limitations are established using the following formula:

$$\text{Mass (lbs/day)} = \text{flow rate (MGD)} \times 8.34 \times \text{effluent limitation (mg/L)}$$

where:

- Mass = mass limitation for a pollutant (lbs/day)
- Effluent limitation = concentration limit for a pollutant (mg/L)
- Flow rate = discharge flow rate (MGD)

4. Stringency of Requirements for Individual Pollutants

This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD, TSS, oil and grease, settleable solids, turbidity, and TPH at Discharge Point No. 001. Restrictions on these parameters are discussed in section IV.B.2 of this Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

This Order includes WQBELs for pH, acute toxicity, temperature, copper, lead, nickel, thallium, zinc, 4,4'-DDT, total PCBs, and cyanide at Discharge Point No. 001. WQBELs have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. The remaining water quality objectives and beneficial uses implemented by this Order (specifically bacteria) were approved by USEPA on September 25, 2002. Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

Table F-6 provides a summary of the final effluent limitations with the associated basis.

Table F-6. Summary of Final Effluent Limitations for Discharge Point No. 001

| Parameter | Units | Effluent Limitations | | | | Performance Goals ⁸ | Basis ¹ |
|------------------------------------|----------------------|----------------------|---------------|-----------------------|-----------------------|--------------------------------|--------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum | | |
| Conventional Pollutants | | | | | | | |
| pH | s.u. | -- | -- | 6.5 | 8.5 | --- | BP, E |
| BOD | mg/L | 20 | 30 | -- | -- | --- | BPJ, E |
| | lbs/day ² | 183 | 275 | -- | -- | --- | |
| Oil and Grease | mg/L | 10 | 15 | -- | -- | --- | BPJ, E |
| | lbs/day ² | 92 | 138 | -- | -- | --- | |
| TSS ⁶ | mg/L | 30 | 75 | -- | -- | --- | BPJ, E |
| | lbs/day ² | 275 | 688 | -- | -- | --- | |
| Non-conventional Pollutants | | | | | | | |
| Acute Toxicity | % Survival | 3 | | | | --- | BP, E |
| Settleable Solids | ml/L | 0.1 | 0.2 | -- | -- | --- | BPJ, E |
| Temperature | °F | -- | -- | -- | 86 | --- | BP, TP, WP, E |

| Parameter | Units | Effluent Limitations | | | | Performance Goals ⁸ | Basis ¹ |
|--|----------------------|----------------------|---------------|-----------------------|-----------------------|--------------------------------|--------------------|
| | | Average Monthly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum | | |
| TPH ⁴ | µg/L | -- | 100 | -- | -- | --- | BPJ |
| | lbs/day ² | -- | 0.92 | -- | -- | --- | |
| Turbidity | NTU | 50 | 75 | -- | -- | --- | BPJ, E |
| Priority Pollutants | | | | | | | |
| Copper, Total Recoverable ^{5,6} | µg/L | 3.1 | 6.1 | -- | -- | --- | TMDL, CTR- SIP |
| | lbs/day ² | 0.03 | 0.1 | -- | -- | --- | |
| Lead, Total Recoverable ^{5,6} | µg/L | 7 | 14 | -- | -- | --- | TMDL, CTR- SIP |
| | lbs/day ² | 0.1 | 0.13 | -- | -- | --- | |
| Nickel, Total Recoverable ^{6,7} | µg/L | 7 | 14 | -- | -- | --- | BPJ, E, CTR- SIP |
| | lbs/day ² | 0.1 | 0.13 | -- | -- | --- | |
| Thallium, Total Recoverable ^{6,7} | µg/L | 6.3 | 13 | -- | -- | --- | BPJ, E, CTR- SIP |
| | lbs/day ² | 0.1 | 0.12 | -- | -- | --- | |
| Zinc, Total Recoverable ^{5,6} | µg/L | 70 | 141 | -- | -- | --- | TMDL, CTR- SIP |
| | lbs/day ² | 0.6 | 1.3 | -- | -- | --- | |
| Cyanide, Total (as CN) ^{6,7} | µg/L | 0.5 | 1.0 | -- | -- | --- | BPJ, E, CTR- SIP |
| | lbs/day ² | 0.005 | 0.01 | -- | -- | --- | |
| 4,4'-DDT ^{5,6} | µg/L | 0.0006 | 0.001 | -- | -- | --- | TMDL, CTR- SIP |
| | lbs/day ² | 5.4E-06 | 1.1E-05 | -- | -- | --- | |
| Total PCBs ^{5,6,9} | µg/L | 0.0002 | 0.0003 | -- | -- | --- | TMDL, CTR- SIP |
| | lbs/day ² | 1.6E-06 | 3.1E-06 | -- | -- | --- | |
| PAHs | | | | | | | |
| Benzo(a)pyrene ⁶ | µg/L | -- | -- | -- | -- | 0.049 ¹⁰ | CTR |
| Chrysene ⁶ | µg/L | -- | -- | -- | -- | 0.049 ¹⁰ | CTR |

¹ BP = Basin Plan; TP = Thermal Plan; E = Existing Order; BPJ = Best Professional Judgment; CTR = California Toxic Rule; SIP = State Implementation Policy; TMDL= Total Maximum Daily Load; and WP = White Paper.

² Mass limitations are based on a maximum flow of 1.1 MGD and calculated as follows: Flow (MGD) x Concentration (mg/L) x 8.34 (conversion factor) = lbs/day.

³ The acute toxicity of the effluent shall be such that:
 a. The average monthly survival in the undiluted effluent for any three (3) consecutive 96-hour static or continuous flow bioassay test shall be at least 90%, and
 b. No single test shall produce less than 70% survival.

⁴ TPH equals the sum of TPH gasoline (C₄-C₁₂), TPH diesel (C₁₃-C₂₂), and TPH oil (C₂₃₊).

⁵ The effluent limitations are based on the USEPA approved Harbor Toxics TMDL WLAs and calculated using the CTR-SIP procedures.

The new limitations for copper and zinc are less stringent than the existing Order No. R4-2007-0031. However, the exception to anti-backsliding is appropriate under CWA sections 402(o)(1) and 303(d)(4)(A).

⁶ During each reporting period, if effluent monitoring results exceed both a TSS effluent limit and a CTR TMDL-based effluent limit or performance goal for copper, lead, zinc, 4,4-DDT, total PCBs, benzo(a)pyrene, or chrysene, implementation of the effluent sediment monitoring program is required for that priority pollutant. Sediment monitoring of the effluent shall begin during the first discharge event following the effluent exceedance. An effluent sediment monitoring result at or below the interim sediment allocation in Table 7, page 24 of this Order, demonstrates attainment with the interim sediment allocation and additional sediment monitoring of the effluent is not required. A sediment

monitoring result that exceeds the interim sediment allocation requires additional sediment monitoring of the effluent during discharge but not more frequently than once per year until the three-year average concentration for sediment monitoring results is at or below the interim sediment allocation.

- 7 The effluent limitations from Order No. R4-2007-0031 were calculated based on CTR-SIP procedures and are carried over in this permit.
- 8 Performance goals are intended to ensure that effluent concentrations and mass discharges do not exceed levels currently achieved by the permitted facility. These performance goals are not considered as limitations or standards for the regulation of the facility. They act as triggers to determine when sediment monitoring is required for this category of pollutants.
- 9 Total PCBs (polychlorinated biphenyls) means the sum of chlorinated biphenyls whose analytical characteristics resembles those of Aroclor-1016, Aroclor-1221, Aroclor-1232, Aroclor-1242, Aroclor-1248, Aroclor-1254, and Aroclor-1260.
- 10 CTR human health criteria were not established for total PAHs. Therefore, the performance goals are based on the CTR human health criteria for the individual PAHs; benzo(a)pyrene and chrysene. The benzo(a)pyrene and chrysene were selected because the State's 2010 303(d) List classifies the Los Angeles/Long Beach Inner Harbor as impaired for these PAH compounds.

Bacteria Limitation Requirements:

1. Rolling 30-day Geometric Mean Limits

- i. Total coliform density shall not exceed 1,000/100 ml.
- ii. Fecal coliform density shall not exceed 200/100 ml.
- iii. Enterococcus density shall not exceed 35/100 ml.

2. Single Sample Limits

- i. Total coliform density shall not exceed 10,000/100 ml.
- ii. Fecal coliform density shall not exceed 400/100 ml.
- iii. Enterococcus density shall not exceed 104/100 ml.
- iv. Total coliform density shall not exceed 1,000/100 ml, if the ratio of fecal-to total coliform exceeds 0.1.

The bacteria limitations were based on WQS applicable to Cerritos Channel. These WQS (and WQBELs) are identical to the WQS used to develop the Bacteria TMDL that is applicable to the Main Ship Channel immediately downstream of Cerritos Channel.

E. Land Discharge Specifications

Not Applicable

F. Reclamation Specifications

Not Applicable

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

The receiving water limitations in the proposed order are based upon the water quality objectives contained in the Basin Plan. As such, they are a required part of the proposed order.

A. Surface Water

The Basin Plan contains numeric and narrative water quality objectives applicable to all surface waters within the Los Angeles Region. Water quality objectives include an objective to maintain the high quality waters pursuant to federal regulations (40 CFR section 131.12) and State Water Board Resolution No. 68-16. Receiving water limitations in this Order are included to ensure protection of beneficial uses of the receiving water. If there is reasonable potential (RP) or a U.S. EPA-approved TMDL WLA, then WQBELs are included in this Order to ensure protection of WQS.

B. Groundwater

Not Applicable

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

40 CFR section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code Sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this Facility.

A. Influent Monitoring

Not Applicable

B. Effluent Monitoring

Monitoring for pollutants expected to be present in the discharge will be required as established in the MRP (Attachment E). To demonstrate compliance with established effluent limitations, the Order includes similar monitoring requirements from Order No. R4-2007-0031, with the exception of total organic carbon (TOC). The list of pollutants for which monitoring is required was developed based on Parts V and VI of the USEPA Form 2C in the Discharger's report of waste discharge (ROWD), as well as pollutants commonly associated with similar operations. The monitoring requirement for TOC was removed in this Order as it is redundant with monitoring for more targeted pollutants: TPH, oil and grease, and individual organic compounds.

Since the discharge is infrequent, collection of more samples over the duration of a discharge is needed to adequately characterize the effluent quality. This Order includes

a maximum frequency during extended discharge of once per week for most of the pollutants.

Monitoring for once per discharge event for lead, 4,4'-DDT, total PCBs, fecal coliform, enterococcus, and TPH has been included to determine compliance with newly established effluent limitations.

The SIP states that the Regional Water Board will require periodic monitoring for pollutants for which criteria or objectives apply and for which no effluent limitations have been established. This Order requires the Discharger to conduct annual monitoring for the remaining CTR priority pollutants and TCDD Equivalents. The Regional Water Board will use the additional data to conduct an RPA and determine if additional WQBELs are required. The Regional Water Board may reopen the permit to incorporate additional effluent limitations and requirements, if necessary.

C. Whole Effluent Toxicity Testing Requirements

Whole effluent toxicity (WET) protects the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth.

This Order includes limitations for acute toxicity and therefore, monitoring requirements are included in the MRP to determine compliance with the effluent limitations established in Limitations and Discharge Requirements, Effluent Limitations, Section IV.A.

Section 4 of the SIP states that a chronic toxicity effluent limitation is required in permits for all discharges that will cause, have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters. The discharges from the Facility are short and infrequent in nature; therefore, chronic toxicity testing will not be required.

D. Receiving Water Monitoring

1. Surface Water

Surface water monitoring requirements established in Order No. R4-2006-0082 have been included in this Order to provide data to determine compliance with the receiving water limitations established. Monitoring has been established at Monitoring Locations RSW-001 (upstream), and RSW-002 (downstream) for pH, ammonia, salinity, dissolved oxygen, and temperature. At the downstream location (Monitoring Location RSW-002) the Discharger must monitor for salinity which is necessary to adjust the ammonia water quality objective, expressed as un-ionized ammonia, to total ammonia.

According to the SIP, the Discharger is required to monitor the upstream receiving water for the CTR priority pollutants, to determine reasonable potential. Accordingly, the Regional Water Board is requiring that the Discharger conduct upstream receiving water monitoring of the CTR priority pollutants, TCDD equivalents, and

ammonia at Monitoring Location RSW-001. Additionally, the Discharger must analyze pH and salinity of the upstream receiving water at the same time as the samples are collected for priority pollutant analysis.

2. Groundwater

Not Applicable

E. Sediment Monitoring of the Effluent

The Harbor Toxics TMDL requires attainment with the TMDL's interim sediment allocations. This Order implements this requirement in a framework of effluent limits, effluent performance goals, sediment monitoring thresholds, and effluent monitoring requirements. Attainment with the interim sediment allocations shall be demonstrated, as specified in Footnote 4 to Table 6, page 16 of this Order. These requirements will ensure that discharges from Tesoro Wilmington Calciner do not contribute significantly to contaminant sediment concentrations in Cerritos Channel within the Los Angeles/Long Beach Inner Harbor.

F. Other Monitoring Requirements

1. Storm Water Monitoring Requirements

In order to evaluate the effectiveness of the SWPPP, rainfall monitoring and visual storm water monitoring are required during discharge events.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR section 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR section 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR section 122.42.

40 CFR section 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. 40 CFR section 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with 40 CFR section 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code Section 13387(e).

B. Special Provisions

1. Reopener Provisions

These provisions are based on part 123 and Order R4-2007-0031. The Regional Water Board may reopen the permit to modify permit conditions and requirements. Causes for modifications include the promulgation of new federal regulations, modification in toxicity requirements, or adoption of new regulations by the State Water Board or Regional Water Board, including revisions to the Basin Plan or revisions to the Harbor Toxics TMDL.

2. Special Studies and Additional Monitoring Requirements

a. Initial Investigation Toxicity Reduction Evaluation Workplan. This provision is based on section 4 of the SIP, Toxicity Control Provisions.

3. Best Management Practices and Pollution Prevention

a. Storm Water Pollution Prevention Plan (SWPPP). Order No. R4-2007-0031 required the Discharger to develop and implement a SWPPP. This Order will require the Discharger to update and continue to implement a SWPPP. The SWPPP will outline site-specific management processes for minimizing storm water runoff contamination and for preventing contaminated storm water runoff from being discharged directly into the storm drain and/or the Cerritos Channel. At a minimum, the management practices should ensure that raw materials and chemicals do not come into contact with storm water. SWPPP requirements are included as Attachment G, based on 40 CFR section 122.44(k).

b. Best Management Practices Plan (BMPP). Order No. R4-2007-0031 required the Discharger to develop and implement BMPs in order to reduce the amount of pollutants entering the discharge. This Order requires the Discharger to update and continue to implement the BMPP. The BMPP may be included as a component of the SWPPP. The purpose of the BMPP is to establish site-specific procedures that ensure proper operation and maintenance of equipment, to ensure that unauthorized non-storm water discharges (i.e., spills) do not occur at the Facility.

The Harbor Toxics TMDL addresses BMPs as follows:

“When permits for responsible parties are revised, the permits should provide mechanisms to make adjustments to the required BMPs as necessary to ensure their adequate performance. If proposed structural and non-structural BMPs adequately implement the waste load allocations then additional controls will not be necessary. Alternatively, if the proposed structural and non-structural BMPs selected prove to be inadequate then additional structural and non-structural BMPs or additional controls may be required.”

Special Provision VI.C.3 requires the Discharger to update and maintain a BMPP, as a component of the SWPPP, that incorporates requirements contained in Appendix G. Appendix G requires a discussion on the effectiveness of each BMP to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Considering that discharges are infrequent, Special Provision VI.C.3 and Appendix G requirements satisfy the TMDL component to address BMP performance for this Facility.

- c. **Spill Contingency Plan (SCP).** This Order requires the Discharger to update and continue to implement a SCP to control the discharge of pollutants. The SCP shall include a technical report on the preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events at the site. This provision is included in this Order to minimize and control the amount of pollutants discharged in case of a spill. The SCP shall be site specific and shall cover all areas of the Facility.

4. Construction, Operation, and Maintenance Specifications

This provision is based on the requirements of 40 CFR section 122.41(e) and the previous Order.

5. Special Provisions for Municipal Facilities (POTWs Only)

Not Applicable

6. Other Special Provisions

Not Applicable

7. Compliance Schedules

Not Applicable

VIII. PUBLIC PARTICIPATION

The Regional Water Board is considering the issuance of waste discharge requirements (WDRs) that will serve as an NPDES permit for Tesoro Refining & Marketing Company LLC, Tesoro Wilmington Calciner Facility. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments must be received at the Regional Water Board offices by 5:00 p.m. on August 30, 2013.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: October 3, 2013
Time: 9:00 a.m.
Location: Metropolitan Water District of Southern California
700 North Alameda Street
Los Angeles, California

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/losangeles> where you can access the current agenda for changes in dates and locations.

D. Nature of Hearing

This will be a formal adjudicative hearing pursuant to section 648 et seq. of Title 23 of the California Code of Regulations. Chapter 5 of the California Administrative Procedure Act (commencing with Section 11500 of the Government Code) will not apply to this proceeding.

Ex Parte Communications Prohibited: As a quasi-adjudicative proceeding, no board member may discuss the subject of this hearing with any person, except during the public hearing itself. Any communications to the Regional Water Board must be directed to staff.

E. Parties to the Hearing

The following are the parties to this proceeding:

1. The applicant/permittee

Any other persons requesting party status must submit a written or electronic request to staff not later than 20 business days before the hearing. All parties will be notified if other persons are so designated.

F. Public Comments and Submittal of Evidence

Persons wishing to comment upon or object to the tentative waste discharge requirements, or submit evidence for the Board to consider, are invited to submit them in writing to losangeles@waterboards.ca.gov with a copy submitted to Rosario Aston at raston@waterboards.ca.gov. To be evaluated and responded to by staff, included in the Board's agenda folder, and fully considered by the Board, written comments must be received no later than close of business on August 30, 2013. Comments or evidence received after that date will be submitted, ex agenda, to the Board for consideration, but only included in administrative record with express approval of the Chair during the hearing. Additionally, if the Board receives only supportive comments, the permit may be placed on the Board's consent calendar, and approved without an oral testimony.

G. Hearing Procedure

The meeting, in which the hearing will be a part of, will start at 9:00 a.m. Interested persons are invited to attend. Staff will present the matter under consideration, after which oral statements from parties or interested persons will be heard. For accuracy of the record, all important testimony should be in writing. The Board will include in the administrative record written transcriptions of oral testimony that is actually presented at the hearing. Oral testimony may be limited to 3 minutes maximum or less for each speaker, depending on the number of persons wishing to be heard. Parties or persons with similar concerns or opinions are encouraged to choose one representative to speak. At the conclusion of testimony, the Board will deliberate in open or close session, and render a decision.

Parties or persons with special procedural requests should contact staff. Any procedure not specified in this hearing notice will be waived pursuant to section 648(d) of title 23 of the California Code of Regulations. Objections to any procedure to be used during this hearing must be submitted in writing not later than close of 15 business days prior to the date of the hearing. Procedural objections will not be entertained at the hearing.

If there should not be a quorum on the scheduled date of this meeting, all cases will be automatically continued to the next scheduled meeting on November 7, 2013. A continuance will not extend any time set forth herein.

H. Waste Discharge Requirements Petitions

Any person aggrieved by this action of the Regional Water Board may petition the State Water Board to review the action in accordance with Water Code section 13320 and California Code of Regulations, title 23, sections 2050 and following. The State Water Board must *receive* the petition by 5:00 p.m., 30 days after the date of this Order, except that if the thirtieth day following the date of this Order falls on a Saturday, Sunday, or state holiday, the petition must be received by the State Water Board

by 5:00 p.m. on the next business day. Copies of the law and regulations applicable to filing petitions may be found on the Internet at:

http://www.waterboards.ca.gov/public_notices/petitions/water_quality

or will be provided upon request.

The State Water Board's mailing address is the following:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

I. Information and Copying

The Report of Waste Discharge (ROWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (213) 576 – 6600.

J. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

K. Additional Information

Requests for additional information or questions regarding this order should be directed to Rosario Aston at (213) 576-6653.

ATTACHMENT G – STORM WATER POLLUTION PREVENTION PLAN REQUIREMENTS

I. Implementation Schedule

A storm water pollution prevention plan (SWPPP) shall be developed and submitted to the Regional Water Board within 90 days following the adoption of this Order. The SWPPP shall be implemented for each facility covered by this Permit within 10 days of approval from the Regional Water Board, or 6-months from the date of the submittal of the SWPPP to the Regional Water Board (whichever comes first).

II. Objectives

The SWPPP has two major objectives: (a) to identify and evaluate sources of pollutants associated with industrial activities that may affect the quality of storm water discharges and authorized non-storm water discharges from the facility; and (b) to identify and implement site- specific best management practices (BMPs) to reduce or prevent pollutants associated with industrial activities in storm water discharges and authorized non-storm water discharges. BMPs may include a variety of pollution prevention measures or other low-cost and pollution control measures. They are generally categorized as non-structural BMPs (activity schedules, prohibitions of practices, maintenance procedures, and other low-cost measures) and as structural BMPs (treatment measures, run-off controls, over-head coverage.) To achieve these objectives, facility operators should consider the five phase process for SWPPP development and implementation as shown in Table A.

The SWPPP requirements are designed to be sufficiently flexible to meet the needs of various facilities. SWPPP requirements that are not applicable to a facility should not be included in the SWPPP.

A facility's SWPPP is a written document that shall contain a compliance activity schedule, a description of industrial activities and pollutant sources, descriptions of BMPs, drawings, maps, and relevant copies or references of parts of other plans. The SWPPP shall be revised whenever appropriate and shall be readily available for review by facility employees or Regional Water Board inspectors.

III. Planning and Organization

A. Pollution Prevention Team

The SWPPP shall identify a specific individual or individuals and their positions within the facility organization as members of a storm water pollution prevention team responsible for developing the SWPPP, assisting the facility manager in SWPPP implementation and revision, and conducting all monitoring program activities required in Attachment E of this Permit. The SWPPP shall clearly identify the Permit related responsibilities, duties, and activities of each team member. For small facilities, storm water pollution prevention teams may consist of one individual where appropriate.

B. Review Other Requirements and Existing Facility Plans

The SWPPP may incorporate or reference the appropriate elements of other regulatory requirements. Facility operators should review all local, State, and Federal requirements that impact, complement, or are consistent with the requirements of this General permit. Facility operators should identify any existing facility plans that contain storm water pollutant control measures or relate to the requirements of this Permit. As examples, facility operators whose facilities are subject to Federal Spill Prevention Control and Countermeasures' requirements should already have instituted a plan to control spills of certain hazardous materials. Similarly, facility operators whose facilities are subject to air quality related permits and regulations may already have evaluated industrial activities that generate dust or particulates.

IV. Site Map

The SWPPP shall include a site map. The site map shall be provided on an 8-1/2 x 11 inch or larger sheet and include notes, legends, and other data as appropriate to ensure that the site map is clear and understandable. If necessary, facility operators may provide the required information on multiple site maps.

TABLE A FIVE PHASES FOR DEVELOPING AND IMPLEMENTING INDUSTRIAL STORM WATER POLLUTION PREVENTION PLANS

PLANNING AND ORGANIZATION

Form Pollution Prevention Team
Review other plans

ASSESSMENT PHASE

Develop a site map
Identify potential pollutant sources
Inventory of materials and chemicals
List significant spills and leaks
Identify non-storm water discharges
Assess pollutant risks

BEST MANAGEMENT PRACTICES IDENTIFICATION PHASE

Non-structural BMPs
Structural BMPs
Select activity and site-specific BMPs

| |
|--|
| <p>IMPLEMENTATION PHASE</p> <p>Train employees Implement BMPs Conduct recordkeeping and reporting</p> |
|--|

| |
|---|
| <p>EVALUATION / MONITORING</p> <p>Conduct annual site evaluation Review monitoring information Evaluate BMPs Review and revise SWPPP</p> |
|---|

The following information shall be included on the site map:

- A.** The facility boundaries; the outline of all storm water drainage areas within the facility boundaries; portions of the drainage area impacted by run-on from surrounding areas; and direction of flow of each drainage area, on-site surface water bodies, and areas of soil erosion. The map shall also identify nearby water bodies (such as rivers, lakes, and ponds) and municipal storm drain inlets where the facility's storm water discharges and authorized non-storm water discharges may be received.
- B.** The location of the storm water collection and conveyance system, associated points of discharge, and direction of flow. Include any structural control measures that affect storm water discharges, authorized non-storm water discharges, and run-on. Examples of structural control measures are catch basins, berms, detention ponds, secondary containment, oil/water separators, diversion barriers, etc.
- C.** An outline of all impervious areas of the facility, including paved areas, buildings, covered storage areas, or other roofed structures.
- D.** Locations where materials are directly exposed to precipitation and the locations where significant spills or leaks identified in Section A.6.a.iv. below have occurred.
- E.** Areas of industrial activity. This shall include the locations of all storage areas and storage tanks, shipping and receiving areas, fueling areas, vehicle and equipment storage/maintenance areas, material handling and processing areas, waste treatment and disposal areas, dust or particulate generating areas, cleaning and rinsing areas, and other areas of industrial activity which are potential pollutant sources.

V. List of Significant Materials

The SWPPP shall include a list of significant materials handled and stored at the site. For each material on the list, describe the locations where the material is being stored, received, shipped, and handled, as well as the typical quantities and frequency. Materials

shall include raw materials, intermediate products, final or finished products, recycled materials, and waste or disposed materials.

VI. Description of Potential Pollutant Sources

A. The SWPPP shall include a narrative description of the facility's industrial activities, as identified in Section A.4.e above, associated potential pollutant sources, and potential pollutants that could be discharged in storm water discharges or authorized non-storm water discharges. At a minimum, the following items related to a facility's industrial activities shall be considered:

1. **Industrial Processes.** Describe each industrial process, the type, characteristics, and quantity of significant materials used in or resulting from the process, and a description of the manufacturing, cleaning, rinsing, recycling, disposal, or other activities related to the process. Where applicable, areas protected by containment structures and the corresponding containment capacity shall be described.
2. **Material Handling and Storage Areas.** Describe each handling and storage area, type, characteristics, and quantity of significant materials handled or stored, description of the shipping, receiving, and loading procedures, and the spill or leak prevention and response procedures. Where applicable, areas protected by containment structures and the corresponding containment capacity shall be described.
3. **Dust and Particulate Generating Activities.** Describe all industrial activities that generate dust or particulates that may be deposited within the facility's boundaries and identify their discharge locations; the characteristics of dust and particulate pollutants; the approximate quantity of dust and particulate pollutants that may be deposited within the facility boundaries; and a description of the primary areas of the facility where dust and particulate pollutants would settle.
4. **Significant Spills and Leaks.** Describe materials that have spilled or leaked in significant quantities in storm water discharges or non-storm water discharges since April 17, 1994. Include toxic chemicals (listed in 40 CFR, Part 302) that have been discharged to storm water as reported on U.S. Environmental Protection Agency (USEPA) Form R, and oil and hazardous substances in excess of reportable quantities (see 40 Code of Federal Regulations [CFR], Parts 110, 117, and 302).

The description shall include the type, characteristics, and approximate quantity of the material spilled or leaked, the cleanup or remedial actions that have occurred or are planned, the approximate remaining quantity of materials that may be exposed to storm water or non-storm water discharges, and the preventative measures taken to ensure spill or leaks do not reoccur. Such list shall be updated as appropriate during the term of this Permit.

5. **Non-Storm Water Discharges.** Facility operators shall investigate the facility to identify all non-storm water discharges and their sources. As part of this

investigation, all drains (inlets and outlets) shall be evaluated to identify whether they connect to the storm drain system.

All non-storm water discharges shall be described. This shall include the source, quantity, frequency, and characteristics of the non-storm water discharges and associated drainage area.

Non-storm water discharges that contain significant quantities of pollutants or that do not meet the conditions provided in Special Conditions D of the storm water general permit are prohibited by this Permit (Examples of prohibited non-storm water discharges are contact and non-contact cooling water, rinse water, wash water, etc.). Non-storm water discharges that meet the conditions provided in Special Condition D of the general storm water permit are authorized by this Permit. The SWPPP must include BMPs to prevent or reduce contact of non-storm water discharges with significant materials or equipment.

6. Soil Erosion. Describe the facility locations where soil erosion may occur as a result of industrial activity, storm water discharges associated with industrial activity, or authorized non-storm water discharges.

B. The SWPPP shall include a summary of all areas of industrial activities, potential pollutant sources, and potential pollutants. This information should be summarized similar to Table B. The last column of Table B, "Control Practices", should be completed in accordance with Section A.8. below.

VII. Assessment of Potential Pollutant Sources

A. The SWPPP shall include a narrative assessment of all industrial activities and potential pollutant sources as described in A.6. above to determine:

1. Which areas of the facility are likely sources of pollutants in storm water discharges and authorized non-storm water discharges, and
2. Which pollutants are likely to be present in storm water discharges and authorized non-storm water discharges. Facility operators shall consider and evaluate various factors when performing this assessment such as current storm water BMPs; quantities of significant materials handled, produced, stored, or disposed of; likelihood of exposure to storm water or authorized non-storm water discharges; history of spill or leaks; and run-on from outside sources.

B. Facility operators shall summarize the areas of the facility that are likely sources of pollutants and the corresponding pollutants that are likely to be present in storm water discharges and authorized non-storm water discharges.

Facility operators are required to develop and implement additional BMPs as appropriate and necessary to prevent or reduce pollutants associated with each pollutant source. The BMPs will be narratively described in section VIII below.

VIII. Storm Water Best Management Practices

The SWPPP shall include a narrative description of the storm water BMPs to be implemented at the facility for each potential pollutant and its source identified in the site assessment phase (Sections A.6. and 7. above). The BMPs shall be developed and implemented to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Each pollutant and its source may require one or more BMPs. Some BMPs may be implemented for multiple pollutants and their sources, while other BMPs will be implemented for a very specific pollutant and its source.

TABLE B
EXAMPLE
ASSESSMENT OF POTENTIAL POLLUTION SOURCES AND
CORRESPONDING BEST MANAGEMENT PRACTICES
SUMMARY

| Area | Activity | Pollutant Source | Pollutant | Best Management Practices |
|-----------------------------|----------|---|-----------|--|
| Vehicle & Equipment Fueling | Fueling | Spills and leaks during delivery. Spills caused by topping off fuel tanks. Hosing or washing down fuel oil fuel area. Leaking storage tanks. Rainfall running off fuel oil, and rainfall running onto and off fueling area. | fuel oil | Use spill and overflow protection. Minimize run-on of storm water into the fueling area. Cover fueling area. Use dry cleanup methods rather than hosing down area. Implement proper spill prevention control program. Implement adequate preventative maintenance program to preventive tank and line leaks. Inspect fueling areas regularly to detect problems before they occur. Train employees on proper fueling, cleanup, and spill response techniques. |

The description of the BMPs shall identify the BMPs as (1) existing BMPs, (2) existing BMPs to be revised and implemented, or (3) new BMPs to be implemented. The description shall also include a discussion on the effectiveness of each BMP to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. The SWPPP shall provide a summary of all BMPs implemented for each pollutant source. This information should be summarized similar to Table B.

Facility operators shall consider the following BMPs for implementation at the facility:

A. Non-Structural BMPs

Non-structural BMPs generally consist of processes, prohibitions, procedures, schedule of activities, etc., that prevent pollutants associated with industrial activity from contacting with storm water discharges and authorized non-storm water discharges. They are considered low technology, cost-effective measures. Facility operators should consider all possible non-structural BMPs options before considering additional structural BMPs (see Section A.8.b. below). Below is a list of non-structural BMPs that should be considered:

- 1. Good Housekeeping.** Good housekeeping generally consists of practical procedures to maintain a clean and orderly facility.
- 2. Preventive Maintenance.** Preventive maintenance includes the regular inspection and maintenance of structural storm water controls (catch basins, oil/water separators, etc.) as well as other facility equipment and systems.
- 3. Spill Response.** This includes spill clean-up procedures and necessary clean-up equipment based upon the quantities and locations of significant materials that may spill or leak.
- 4. Material Handling and Storage.** This includes all procedures to minimize the potential for spills and leaks and to minimize exposure of significant materials to storm water and authorized non-storm water discharges.
- 5. Employee Training.** This includes training of personnel who are responsible for (1) implementing activities identified in the SWPPP, (2) conducting inspections, sampling, and visual observations, and (3) managing storm water. Training should address topics such as spill response, good housekeeping, and material handling procedures, and actions necessary to implement all BMPs identified in the SWPPP. The SWPPP shall identify periodic dates for such training. Records shall be maintained of all training sessions held.
- 6. Waste Handling/Recycling.** This includes the procedures or processes to handle, store, or dispose of waste materials or recyclable materials.
- 7. Recordkeeping and Internal Reporting.** This includes the procedures to ensure that all records of inspections, spills, maintenance activities, corrective actions, visual observations, etc., are developed, retained, and provided, as necessary, to the appropriate facility personnel.
- 8. Erosion Control and Site Stabilization.** This includes a description of all sediment and erosion control activities. This may include the planting and maintenance of vegetation, diversion of run-on and runoff, placement of sandbags, silt screens, or other sediment control devices, etc.

9. Inspections. This includes, in addition to the preventative maintenance inspections identified above, an inspection schedule of all potential pollutant sources. Tracking and follow-up procedures shall be described to ensure adequate corrective actions are taken and SWPPPs are made.

10. Quality Assurance. This includes the procedures to ensure that all elements of the SWPPP and Monitoring Program are adequately conducted.

B. Structural BMPs.

Where non-structural BMPs as identified in Section A.8.a. above are not effective, structural BMPs shall be considered. Structural BMPs generally consist of structural devices that reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Below is a list of structural BMPs that should be considered:

- 1. Overhead Coverage.** This includes structures that provide horizontal coverage of materials, chemicals, and pollutant sources from contact with storm water and authorized non-storm water discharges.
- 2. Retention Ponds.** This includes basins, ponds, surface impoundments, bermed areas, etc. that do not allow storm water to discharge from the facility.
- 3. Control Devices.** This includes berms or other devices that channel or route run-on and runoff away from pollutant sources.
- 4. Secondary Containment Structures.** This generally includes containment structures around storage tanks and other areas for the purpose of collecting any leaks or spills.
- 5. Treatment.** This includes inlet controls, infiltration devices, oil/water separators, detention ponds, vegetative swales, etc. that reduce the pollutants in storm water discharges and authorized non-storm water discharges.

IX. Annual Comprehensive Site Compliance Evaluation

The facility operator shall conduct one comprehensive site compliance evaluation (evaluation) in each reporting period (July 1-June 30). Evaluations shall be conducted within 8-16 months of each other. The SWPPP shall be revised, as appropriate, and the revisions implemented within 90 days of the evaluation. Evaluations shall include the following:

- A.** A review of all visual observation records, inspection records, and sampling and analysis results.
- B.** A visual inspection of all potential pollutant sources for evidence of, or the potential for, pollutants entering the drainage system.

- C.** A review and evaluation of all BMPs (both structural and non-structural) to determine whether the BMPs are adequate, properly implemented and maintained, or whether additional BMPs are needed. A visual inspection of equipment needed to implement the SWPPP, such as spill response equipment, shall be included.
- D.** An evaluation report that includes, (i) identification of personnel performing the evaluation, (ii) the date(s) of the evaluation, (iii) necessary SWPPP revisions, (iv) schedule, as required in Section A.10.e, for implementing SWPPP revisions, (v) any incidents of non-compliance and the corrective actions taken, and (vi) a certification that the facility operator is in compliance with this Permit. If the above certification cannot be provided, explain in the evaluation report why the facility operator is not in compliance with this General Permit. The evaluation report shall be submitted as part of the annual report, retained for at least five years, and signed and certified in accordance with Standard Provisions V.D.5 of Attachment D.

X. SWPPP General Requirements

- A.** The SWPPP shall be retained on site and made available upon request of a representative of the Regional Water Board and/or local storm water management agency (local agency) which receives the storm water discharges.
- B.** The Regional Water Board and/or local agency may notify the facility operator when the SWPPP does not meet one or more of the minimum requirements of this Section. As requested by the Regional Water Board and/or local agency, the facility operator shall submit an SWPPP revision and implementation schedule that meets the minimum requirements of this section to the Regional Water Board and/or local agency that requested the SWPPP revisions. Within 14 days after implementing the required SWPPP revisions, the facility operator shall provide written certification to the Regional Water Board and/or local agency that the revisions have been implemented.
- C.** The SWPPP shall be revised, as appropriate, and implemented prior to changes in industrial activities which (i) may significantly increase the quantities of pollutants in storm water discharge, (ii) cause a new area of industrial activity at the facility to be exposed to storm water, or (iii) begin an industrial activity which would introduce a new pollutant source at the facility.
- D.** The SWPPP shall be revised and implemented in a timely manner, but in no case more than 90 days after a facility operator determines that the SWPPP is in violation of any requirement(s) of this Permit.
- E.** When any part of the SWPPP is infeasible to implement due to proposed significant structural changes, the facility operator shall submit a report to the Regional Water Board prior to the applicable deadline that (i) describes the portion of the SWPPP that is infeasible to implement by the deadline, (ii) provides justification for a time extension, (iii) provides a schedule for completing and implementing that portion of the SWPPP, and (iv) describes the BMPs that will be implemented in the interim period to reduce or prevent pollutants in storm water discharges and authorized non-storm water discharges. Such reports are subject to Regional Water Board approval and/or

modifications. Facility operators shall provide written notification to the Regional Water Board within 14 days after the SWPPP revisions are implemented.

- F. The SWPPP shall be provided, upon request, to the Regional Water Board. The SWPPP is considered a report that shall be available to the public by the Regional Water Board under Section 308(b) of the Clean Water Act.

ATTACHMENT H – STATE WATER BOARD MINIMUM LEVELS (µg/L)

The Minimum Levels (MLs) in this appendix are for use in reporting and compliance determination purposes in accordance with section 2.4 of the State Implementation Policy. These MLs were derived from data for priority pollutants provided by State certified analytical laboratories in 1997 and 1998. These MLs shall be used until new values are adopted by the State Water Board and become effective. The following tables (Tables 2a - 2d) present MLs for four major chemical groupings: volatile substances, semi-volatile substances, inorganics, and pesticides and PCBs.

| Table 2a - VOLATILE SUBSTANCES* | GC | GCMS |
|---------------------------------|-----|------|
| 1,1 Dichloroethane | 0.5 | 1 |
| 1,1 Dichloroethylene | 0.5 | 2 |
| 1,1,1 Trichloroethane | 0.5 | 2 |
| 1,1,2 Trichloroethane | 0.5 | 2 |
| 1,1,2,2 Tetrachloroethane | 0.5 | 1 |
| 1,2 Dichlorobenzene (volatile) | 0.5 | 2 |
| 1,2 Dichloroethane | 0.5 | 2 |
| 1,2 Dichloropropane | 0.5 | 1 |
| 1,3 Dichlorobenzene (volatile) | 0.5 | 2 |
| 1,3 Dichloropropene (volatile) | 0.5 | 2 |
| 1,4 Dichlorobenzene (volatile) | 0.5 | 2 |
| Acrolein | 2.0 | 5 |
| Acrylonitrile | 2.0 | 2 |
| Benzene | 0.5 | 2 |
| Bromoform | 0.5 | 2 |
| Methyl Bromide | 1.0 | 2 |
| Carbon Tetrachloride | 0.5 | 2 |
| Chlorobenzene | 0.5 | 2 |
| Chlorodibromo-methane | 0.5 | 2 |
| Chloroethane | 0.5 | 2 |
| Chloroform | 0.5 | 2 |
| Chloromethane | 0.5 | 2 |
| Dichlorobromo-methane | 0.5 | 2 |
| Dichloromethane | 0.5 | 2 |
| Ethylbenzene | 0.5 | 2 |
| Tetrachloroethylene | 0.5 | 2 |
| Toluene | 0.5 | 2 |
| Trans-1,2 Dichloroethylene | 0.5 | 1 |
| Trichloroethene | 0.5 | 2 |
| Vinyl Chloride | 0.5 | 2 |

*The normal method-specific factor for these substances is 1; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance.

| Table 2b - SEMI-VOLATILE SUBSTANCES* | GC | GCMS | LC | COLOR |
|--------------------------------------|----|------|------|-------|
| Benzo (a) Anthracene | 10 | 5 | | |
| 1,2 Dichlorobenzene (semivolatile) | 2 | 2 | | |
| 1,2 Diphenylhydrazine | | 1 | | |
| 1,2,4 Trichlorobenzene | 1 | 5 | | |
| 1,3 Dichlorobenzene (semivolatile) | 2 | 1 | | |
| 1,4 Dichlorobenzene (semivolatile) | 2 | 1 | | |
| 2 Chlorophenol | 2 | 5 | | |
| 2,4 Dichlorophenol | 1 | 5 | | |
| 2,4 Dimethylphenol | 1 | 2 | | |
| 2,4 Dinitrophenol | 5 | 5 | | |
| 2,4 Dinitrotoluene | 10 | 5 | | |
| 2,4,6 Trichlorophenol | 10 | 10 | | |
| 2,6 Dinitrotoluene | | 5 | | |
| 2- Nitrophenol | | 10 | | |
| 2-Chloroethyl vinyl ether | 1 | 1 | | |
| 2-Chloronaphthalene | | 10 | | |
| 3,3' Dichlorobenzidine | | 5 | | |
| Benzo (b) Fluoranthene | | 10 | 10 | |
| 3-Methyl-Chlorophenol | 5 | 1 | | |
| 4,6 Dinitro-2-methylphenol | 10 | 5 | | |
| 4- Nitrophenol | 5 | 10 | | |
| 4-Bromophenyl phenyl ether | 10 | 5 | | |
| 4-Chlorophenyl phenyl ether | | 5 | | |
| Acenaphthene | 1 | 1 | 0.5 | |
| Acenaphthylene | | 10 | 0.2 | |
| Anthracene | | 10 | 2 | |
| Benzidine | | 5 | | |
| Benzo(a) pyrene | | 10 | 2 | |
| Benzo(g,h,i)perylene | | 5 | 0.1 | |
| Benzo(k)fluoranthene | | 10 | 2 | |
| bis 2-(1-Chloroethoxyl) methane | | 5 | | |
| bis(2-chloroethyl) ether | 10 | 1 | | |
| bis(2-Chloroisopropyl) ether | 10 | 2 | | |
| bis(2-Ethylhexyl) phthalate | 10 | 5 | | |
| Butyl benzyl phthalate | 10 | 10 | | |
| Chrysene | | 10 | 5 | |
| di-n-Butyl phthalate | | 10 | | |
| di-n-Octyl phthalate | | 10 | | |
| Dibenzo(a,h)-anthracene | | 10 | 0.1 | |
| Diethyl phthalate | 10 | 2 | | |
| Dimethyl phthalate | 10 | 2 | | |
| Fluoranthene | 10 | 1 | 0.05 | |
| Fluorene | | 10 | 0.1 | |
| Hexachloro-cyclopentadiene | 5 | 5 | | |
| Hexachlorobenzene | 5 | 1 | | |
| Hexachlorobutadiene | 5 | 1 | | |
| Hexachloroethane | 5 | 1 | | |
| Indeno(1,2,3,cd)-pyrene | | 10 | 0.05 | |
| Isophorone | 10 | 1 | | |
| N-Nitroso diphenyl amine | 10 | 1 | | |
| N-Nitroso-dimethyl amine | 10 | 5 | | |
| N-Nitroso -di n-propyl amine | 10 | 5 | | |
| Naphthalene | 10 | 1 | 0.2 | |

| Table 2b - SEMI-VOLATILE SUBSTANCES* | GC | GCMS | LC | COLOR |
|--------------------------------------|----|------|------|-------|
| Nitrobenzene | 10 | 1 | | |
| Pentachlorophenol | 1 | 5 | | |
| Phenanthrene | | 5 | 0.05 | |
| Phenol ** | 1 | 1 | | 50 |
| Pyrene | | 10 | 0.05 | |

* With the exception of phenol by colorimetric technique, the normal method-specific factor for these substances is 1,000; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance multiplied by 1,000.

** Phenol by colorimetric technique has a factor of 1.

| Table 2c – INORGANICS* | FAA | GFAA | ICP | ICPMS | SPGFAA | HYDRIDE | CVAA | COLOR | DCP |
|------------------------|-----|------|-----|-------|--------|---------|------|-------|--------|
| Antimony | 10 | 5 | 50 | 0.5 | 5 | 0.5 | | | 1,000 |
| Arsenic | | 2 | 10 | 2 | 2 | 1 | | 20 | 1,000 |
| Beryllium | 20 | 0.5 | 2 | 0.5 | 1 | | | | 1,000 |
| Cadmium | 10 | 0.5 | 10 | 0.25 | 0.5 | | | | 1,000 |
| Chromium (total) | 50 | 2 | 10 | 0.5 | 1 | | | | 1,000 |
| Chromium VI | 5 | | | | | | | 10 | |
| Copper | 25 | 5 | 10 | 0.5 | 2 | | | | 1,000 |
| Cyanide | | | | | | | | 5 | |
| Lead | 20 | 5 | 5 | 0.5 | 2 | | | | 10,000 |
| Mercury | | | | 0.5 | | | 0.2 | | |
| Nickel | 50 | 5 | 20 | 1 | 5 | | | | 1,000 |
| Selenium | | 5 | 10 | 2 | 5 | 1 | | | 1,000 |
| Silver | 10 | 1 | 10 | 0.25 | 2 | | | | 1,000 |
| Thallium | 10 | 2 | 10 | 1 | 5 | | | | 1,000 |
| Zinc | 20 | | 20 | 1 | 10 | | | | 1,000 |

* The normal method-specific factor for these substances is 1; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance.

| Table 2d – PESTICIDES – PCBs* | GC |
|-------------------------------|-------|
| 4,4'-DDD | 0.05 |
| 4,4'-DDE | 0.05 |
| 4,4'-DDT | 0.01 |
| a-Endosulfan | 0.02 |
| alpha-BHC | 0.01 |
| Aldrin | 0.005 |
| b-Endosulfan | 0.01 |
| Beta-BHC | 0.005 |
| Chlordane | 0.1 |
| Delta-BHC | 0.005 |
| Dieldrin | 0.01 |
| Endosulfan Sulfate | 0.05 |
| Endrin | 0.01 |
| Endrin Aldehyde | 0.01 |
| Heptachlor | 0.01 |
| Heptachlor Epoxide | 0.01 |

| Table 2d – PESTICIDES – PCBs* | GC |
|-------------------------------|------|
| Gamma-BHC (Lindane) | 0.02 |
| PCB 1016 | 0.5 |
| PCB 1221 | 0.5 |
| PCB 1232 | 0.5 |
| PCB 1242 | 0.5 |
| PCB 1248 | 0.5 |
| PCB 1254 | 0.5 |
| PCB 1260 | 0.5 |
| Toxaphene | 0.5 |

* The normal method-specific factor for these substances is 100; therefore, the lowest standard concentration in the calibration curve is equal to the above ML value for each substance multiplied by 100.

Techniques:

GC - Gas Chromatography

GCMS - Gas Chromatography/Mass Spectrometry

HRGCMS - High Resolution Gas Chromatography/Mass Spectrometry (i.e., EPA 1613, 1624, or 1625)

LC - High Pressure Liquid Chromatography

FAA - Flame Atomic Absorption

GFAA - Graphite Furnace Atomic Absorption

HYDRIDE - Gaseous Hydride Atomic Absorption

CVAA - Cold Vapor Atomic Absorption

ICP - Inductively Coupled Plasma

ICPMS - Inductively Coupled Plasma/Mass Spectrometry

SPGFAA - Stabilized Platform Graphite Furnace Atomic Absorption (i.e., EPA 200.9)

DCP - Direct Current Plasma

COLOR – Colorimetric

ATTACHMENT I – LIST OF PRIORITY POLLUTANTS

| CTR Number | Parameter | CAS Number | Suggested Analytical Methods |
|-------------------|----------------------------|-------------------|-------------------------------------|
| 1 | Antimony | 7440360 | 1 |
| 2 | Arsenic | 7440382 | 1 |
| 3 | Beryllium | 7440417 | 1 |
| 4 | Cadmium | 7440439 | 1 |
| 5a | Chromium (III) | 16065831 | 1 |
| 5a | Chromium (VI) | 18540299 | 1 |
| 6 | Copper | 7440508 | 1 |
| 7 | Lead | 7439921 | 1 |
| 8 | Mercury | 7439976 | 1 |
| 9 | Nickel | 7440020 | 1 |
| 11 | Selenium | 7782492 | 1 |
| 11 | Silver | 7440224 | 1 |
| 12 | Thallium | 7440280 | 1 |
| 13 | Zinc | 7440666 | 1 |
| 14 | Cyanide | 57125 | 1 |
| 15 | Asbestos | 1332214 | 1 |
| 16 | 2,3,7,8-TCDD | 1746016 | 1 |
| 17 | Acrolein | 117028 | 1 |
| 18 | Acrylonitrile | 117131 | 1 |
| 19 | Benzene | 71432 | 1 |
| 20 | Bromoform | 75252 | 1 |
| 21 | Carbon Tetrachloride | 56235 | 1 |
| 22 | Chlorobenzene | 118907 | 1 |
| 23 | Chlorodibromomethane | 124481 | 1 |
| 24 | Chloroethane | 75003 | 1 |
| 25 | 2-Chloroethylvinyl Ether | 111758 | 1 |
| 26 | Chloroform | 67663 | 1 |
| 27 | Dichlorobromomethane | 75274 | 1 |
| 28 | 1,1-Dichloroethane | 75343 | 1 |
| 29 | 1,2-Dichloroethane | 117062 | 1 |
| 30 | 1,1-Dichloroethylene | 75354 | 1 |
| 31 | 1,2-Dichloropropane | 78875 | 1 |
| 32 | 1,3-Dichloropropylene | 542756 | 1 |
| 33 | Ethylbenzene | 110414 | 1 |
| 34 | Methyl Bromide | 74839 | 1 |
| 35 | Methyl Chloride | 74873 | 1 |
| 36 | Methylene Chloride | 75092 | 1 |
| 37 | 1,1,2,2-Tetrachloroethane | 79345 | 1 |
| 38 | Tetrachloroethylene | 127184 | 1 |
| 39 | Toluene | 118883 | 1 |
| 40 | 1,2-Trans-Dichloroethylene | 156605 | 1 |
| 41 | 1,1,1-Trichloroethane | 71556 | 1 |
| 42 | 1,1,2-Trichloroethane | 79005 | 1 |
| 43 | Trichloroethylene | 79016 | 1 |
| 44 | Vinyl Chloride | 75014 | 1 |

| CTR Number | Parameter | CAS Number | Suggested Analytical Methods |
|------------|-----------------------------|------------|------------------------------|
| 45 | 2-Chlorophenol | 95578 | 1 |
| 46 | 2,4-Dichlorophenol | 120832 | 1 |
| 47 | 2,4-Dimethylphenol | 115679 | 1 |
| 48 | 2-Methyl-4,6-Dinitrophenol | 534521 | 1 |
| 49 | 2,4-Dinitrophenol | 51285 | 1 |
| 50 | 2-Nitrophenol | 88755 | 1 |
| 51 | 4-Nitrophenol | 110027 | 1 |
| 52 | 3-Methyl-4-Chlorophenol | 59507 | 1 |
| 53 | Pentachlorophenol | 87865 | 1 |
| 54 | Phenol | 118952 | 1 |
| 55 | 2,4,6-Trichlorophenol | 88062 | 1 |
| 56 | Acenaphthene | 83329 | 1 |
| 57 | Acenaphthylene | 208968 | 1 |
| 58 | Anthracene | 120127 | 1 |
| 59 | Benzdine | 92875 | 1 |
| 60 | Benzo(a)Anthracene | 56553 | 1 |
| 61 | Benzo(a)Pyrene | 50328 | 1 |
| 62 | Benzo(b)Fluoranthene | 205992 | 1 |
| 63 | Benzo(ghi)Perylene | 191242 | 1 |
| 64 | Benzo(k)Fluoranthene | 207089 | 1 |
| 65 | Bis(2-Chloroethoxy)Methane | 111911 | 1 |
| 66 | Bis(2-Chloroethyl)Ether | 111444 | 1 |
| 67 | Bis(2-Chloroisopropyl)Ether | 118601 | 1 |
| 68 | Bis(2-Ethylhexyl)Phthalate | 117817 | 1 |
| 69 | 4-Bromophenyl Phenyl Ether | 111553 | 1 |
| 70 | Butylbenzyl Phthalate | 85687 | 1 |
| 71 | 2-Chloronaphthalene | 91587 | 1 |
| 72 | 4-Chlorophenyl Phenyl Ether | 7005723 | 1 |
| 73 | Chrysene | 218019 | 1 |
| 74 | Dibenzo(a,h)Anthracene | 53703 | 1 |
| 75 | 1,2-Dichlorobenzene | 95501 | 1 |
| 76 | 1,3-Dichlorobenzene | 541731 | 1 |
| 77 | 1,4-Dichlorobenzene | 116467 | 1 |
| 78 | 3,3'-Dichlorobenzidine | 91941 | 1 |
| 79 | Diethyl Phthalate | 84662 | 1 |
| 80 | Dimethyl Phthalate | 131113 | 1 |
| 81 | Di-n-Butyl Phthalate | 84742 | 1 |
| 82 | 2,4-Dinitrotoluene | 121142 | 1 |
| 83 | 2,6-Dinitrotoluene | 606202 | 1 |
| 84 | Di-n-Octyl Phthalate | 117840 | 1 |
| 85 | 1,2-Diphenylhydrazine | 122667 | 1 |
| 86 | Fluoranthene | 206440 | 1 |
| 87 | Fluorene | 86737 | 1 |
| 88 | Hexachlorobenzene | 118741 | 1 |
| 89 | Hexachlorobutadiene | 87863 | 1 |
| 90 | Hexachlorocyclopentadiene | 77474 | 1 |
| 91 | Hexachloroethane | 67721 | 1 |
| 92 | Indeno(1,2,3-cd)Pyrene | 193395 | 1 |

| CTR Number | Parameter | CAS Number | Suggested Analytical Methods |
|------------|---------------------------|------------|------------------------------|
| 93 | Isophorone | 78591 | † |
| 94 | Naphthalene | 91203 | † |
| 95 | Nitrobenzene | 98953 | † |
| 96 | N-Nitrosodimethylamine | 62759 | † |
| 97 | N-Nitrosodi-n-Propylamine | 621647 | † |
| 98 | N-Nitrosodiphenylamine | 86306 | † |
| 99 | Phenanthrene | 85018 | † |
| 110 | Pyrene | 129000 | † |
| 111 | 1,2,4-Trichlorobenzene | 120821 | † |
| 112 | Aldrin | 309002 | † |
| 113 | alpha-BHC | 319846 | † |
| 114 | beta-BHC | 319857 | † |
| 115 | gamma-BHC | 58899 | † |
| 116 | delta-BHC | 319868 | † |
| 117 | Chlordane | 57749 | † |
| 118 | 4,4'-DDT | 50293 | † |
| 119 | 4,4'-DDE | 72559 | † |
| 111 | 4,4'-DDD | 72548 | † |
| 111 | Dieldrin | 60571 | † |
| 112 | alpha-Endosulfan | 959988 | † |
| 113 | beta-Endosulfan | 33213659 | † |
| 114 | Endosulfan Sulfate | 1131178 | † |
| 115 | Endrin | 72208 | † |
| 116 | Endrin Aldehyde | 7421934 | † |
| 117 | Heptachlor | 76448 | † |
| 118 | Heptachlor Epoxide | 1124573 | † |
| 119 | PCB-1116 | 12674112 | † |
| 120 | PCB-1221 | 11114282 | † |
| 121 | PCB-1232 | 11141165 | † |
| 122 | PCB-1242 | 53469219 | † |
| 123 | PCB-1248 | 12672296 | † |
| 124 | PCB-1254 | 11197691 | † |
| 125 | PCB-1260 | 11196825 | † |
| 126 | Toxaphene | 8001352 | † |

¹ Pollutants shall be analyzed using the methods described in 40 CFR Part 136.

**ATTACHMENT J – REASONABLE POTENTIAL ANALYSIS AND CALCULATION OF
EFFLUENT LIMITATIONS**