# State of California CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD LOS ANGELES REGION 320 West 4th Street, Suite 200, Los Angeles FACT SHEET WASTE DISCHARGE REQUIREMENTS FOR LB PROPERTY MANAGEMENT (Office Building) NPDES NO. CAG994004 CI-6740

### FACILITY LOCATION

10495 Santa Monica Boulevard Los Angeles, CA 90025 FACILITY MAILING ADDRESS 4730 Woodman Avenue, #200

4730 Woodman Avenue, #200 Sherman Oaks, CA 91423

### **PROJECT DESCRIPTION**

The subject site is an office building located at 10495 Santa Monica Boulevard, Los Angeles. General NPDES Permit No. CAG994001, Order No. 97-045, was issued to the subject facility on June 30, 1997 for dewatering activity from the subterranean parking garage. On October 10, 2003, LB Property Management submitted a Notice of Intent (NOI) form to continue enrollment under General Permit No. CAG994004, Order No. R4-2003-0111, adopted by this Board on August 7, 2003.

### **VOLUME AND DESCRIPTION OF DISCHARGE**

Up to 900 gallons per day of groundwater is discharged to the storm drain located at Latitude 34°03'21", Longitude 118°25'33", thence to Ballona Creek, a water of the United States. The site location map is shown as Figure 1.

#### **APPLICABLE EFFLUENT LIMITATIONS**

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the table below have been determined to show reasonable potential to exist in the discharge. The dewatering discharge flows into Ballona Creek, therefore, the discharge limitations in Attachment B are not applicable to the discharge.

This table lists the specific constituents and effluent limitations applicable to your discharge.

		Discharge Limitations	
Constituents	Units	Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD <sub>5</sub> 20°C	mg/L	30	20

		Discharge Limitations	
Constituents	Units	Daily Maximum	Monthly Average
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	
Phenols	mg/L	1.0	
Residual Chlorine	mg/L	0.1	
Methylene Blue Active Substances (MBAS)	mg/L	0.5	

# **REQUENCY OF DISCHARGE**

The discharge is continuous and is expected to continue throughout the life of the building.

# **REUSE OF WATER**

Due to lack of landscaped area at the site, there are no other feasible reuse options for the discharge. Therefore, the wastewater will be discharged to the storm drain.