# State of California CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD LOS ANGELES REGION 320 West 4th Street, Suite 200, Los Angeles

# FACT SHEET WASTE DISCHARGE REQUIREMENTS GEORGE & ERIKA FAMILY TRUST, LA CIENEGA CENTER NPDES NO. CAG994004 CI-7938

### PROJECT LOCATION

### FACILITY MAILING ADDRESS

99 La Cienega Blvd., Beverly Hills, CA 90211 250 N. Roberson Blvd., #421 Beverly Hills, CA 90211

### **PROJECT DESCRIPTION**

George & Erika Family Trust (GEF Trust) operates a groundwater dewatering system at 99 La Cienega Boulevard, Beverly Hills. The dewatering is necessary to protect the integrity of the building structure from rising groundwater. Discharge from the site is regulated under general NPDES Permit CAG994004 (Order No. R4-2003-0111) which was issued on April 22, 2004. GEF Trust submitted a Notice of Intent (NOI) form, and analytical results of groundwater samples to continue enrollment under the general NPDES Permit No. CAG994004, Order No. R4-2008-0032, which was adopted by the Board on June 5, 2008.

### VOLUME AND DESCRIPTION OF DISCHARGE

Up to 150,000 gallons per day of groundwater is discharged to a storm drain (located at Latitude  $34\,^\circ\!03'$  25", Longitude  $118\,^\circ\!22'$  33"), thence to the Ballona Creek, a water of the United States. The site location diagram is shown as Figure 1.

#### APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the table below have been determined to show reasonable potential to exist in the discharge. The discharge of groundwater flows into the Ballona Creek which is designated as MUN (Potential) beneficial use. Therefore, the discharge limitations under the "Other Water" column apply to the discharge. In addition, the discharge limitations in Attachment B are not applicable to the discharge.

October 6, 2008

		Discharge Limitations	
Constituents	Units	Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD <sub>5</sub> 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	
Phenols	mg/L	1.0	
Residual Chlorine	mg/L	0.1	
Methylene Blue Active Substances (MBAS)	mg/L	0.5	

This Table lists the specific constituents and effluent limitations applicable to the discharge.

### FREQUENCY OF DISCHARGE

The continuous discharge is permanent for the building life.

### **REUSE OF WATER**

It is not feasible to discharge the water to the sanitary sewer system. It is not economically feasible to haul the groundwater for off-site disposal and the facility lacks landscaped area at the site. There are no feasible reuse options for the discharge; therefore, the groundwater is discharged to the storm drain in compliance with the requirements of the attached order.

