STATE OF CALIFORNIA CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD LOS ANGELES REGION

320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET WASTE DISCHARGE REQUIREMENTS FOR PACIFIC TERMINALS, LLC

NPDES NO. CAG674001 CI-8095

FACILITY ADDRESS

FACILITY MAILING ADDRESS

2865 Seaside Boulevard Long Beach, California 5900 Cherry Avenue Long Beach, CA 90805

PROJECT DESCRIPTION:

Pacific Terminals, LLC (Discharger) operates a petroleum hydrocarbon storage tank farm and a pumping station located at 2865 Seaside Boulevard, Long Beach (See Figure 1 for site location). The Discharger needs to periodically conduct hydrostatic tests on the tanks and pipes at the facility and dispose of the hydrostatic test water to the nearby storm drain. The Discharger has submitted a Notice of Intent to apply for continuing enrollment under the general NPDES permit.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 1.5 million gallons per day of wastewater will be discharged from the facility to Outfall No. 1 (Latitude: 33° 45′ 58″, Longitude: 118° 13′ 23″) which flows into the Long Beach Harbor, a water of the United States. Hydrostatic test discharge at the facility is a short-time discharge that lasts for approximately 1 to 2 days.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the Table below have been determined to show reasonable potential to exist in the discharge. The discharge flows into the Long Beach Harbor. Therefore, the discharge limitations in Attachment B are not applicable to the discharge.

This Table lists the specific constituents and effluent limitations applicable to the discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	N/A
Phenols	mg/L	1.0	N/A
Residual Chlorine	mg/L	0.1	N/A
Methylene Blue Active Substances (MBAS)	mg/L	0.5	N/A

FREQUENCY OF DISCHARGE:

Discharge at the facility is intermittent.

REUSE OF WATER:

There are no feasible reuse options because of the large volume of water that will be discharged over a short period of time. Offsite disposal of the discharge is not feasible due to high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation using the discharge. Therefore, the wastewater will be discharged to the storm drain.