

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
VENTURA COUNTY FIRE STATION #30
(325 HILLCREST DRIVE, THOUSAND OAKS)

NPDES NO. CAG834001
CI-8198

FACILITY ADDRESS

325 Hillcrest Drive
Thousand Oaks, CA 91360

FACILITY MAILING ADDRESS

165 Durley Avenue
Camarillo, CA 93010

PROJECT DESCRIPTION:

Ventura County Fire Station #30 proposes to discharge treated groundwater via storm drain at Hillcrest Drive. A groundwater treatment plant system will be constructed to treat gasoline-impacted groundwater located at 325 Hillcrest Drive, Thousand Oaks, California.

The groundwater treatment system consists of two filter cartridges and three activated carbon units. The activated carbon units are installed in series and each unit contains 200 pounds of carbon.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 28,800 gallons per day of treated groundwater will be discharged into a storm drain at Hillcrest Drive (Latitude: 34° 26' 46", Longitude: 119° 10' 16"). The discharge flows via Arroyo Conejo to Calleguas Creek, a water of the United States.

FREQUENCY OF DISCHARGE:

Discharge will be continuous.

REUSE OF WATER:

There is no feasible reuse option for treated groundwater at the site; therefore, the treated water will be discharged to the storm drain.