

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
LOS ANGELES DEPARTMENT OF WATER AND POWER
(SEPULVEDA BASIN WATER RECLAIM PIPELINE)
HYDROSTATIC TESTING

NPDES NO. CAG674001
CI-8202

FACILITY ADDRESS

Woodley Avenue
Los Angeles, CA 90012

FACILITY MAILING ADDRESS

111 North Hope Street, Rm. 1213
Los Angeles, CA 90012

PROJECT DESCRIPTION:

The Los Angeles Department of Water and Power proposes to discharge hydrostatic test water at Woodley Flood Control Channel and Hayvenhurst Channel both of which are tributary to Los Angeles River. Approximately 6,200 linear feet of 36-inch diameter ductile iron pipeline will be tested. Hydrostatic testing will last for two days. This pipeline will provide reclaimed water to local parks and golf courses for irrigation.

A domestic hydrant water will supply the test water. If the wastewater exceeds the total residual chlorine concentration limits, a sodium thiosulfate or sodium bisulfate will be used to dechlorinate the wastewater.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 320,000 gallons of hydrostatic water will be discharged into Woodley Flood Control Channel and Hayvenhurst Channel (Latitude: 34° 10' 45", Longitude: 118° 28' 57"). Both channels are tributary to Los Angeles River.

FREQUENCY OF DISCHARGE:

The discharge will be a one-time release until the pipe is empty.

REUSE OF WATER:

There is no feasible reuse option for hydrostatic water at the site.