

**State of California  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
THE PORT OF LONG BEACH  
(Pier G/J Terminal Development Project)**

**NPDES NO. CAG994001  
CI-8318**

**PROJECT LOCATION**

Pier G/J, Port of Long Beach  
Long Beach, CA 90802

**FACILITY MAILING ADDRESS**

P.O. Box 570  
Long Beach, CA 90802

**PROJECT DESCRIPTION**

The Port of Long Beach (The Port) proposes to redevelop the Pier G/J area. The proposed project includes the demolition of existing structures, relocation and installation of utilities, and general terminal construction. Dewatering is anticipated during redevelopment of the pier. The Port proposes to store the groundwater in Baker tanks and to analyze the groundwater prior to discharge into the storm drain.

**VOLUME AND DESCRIPTION OF DISCHARGE**

The Port will discharge up to 0.05 million gallons per day (mgd) of groundwater. The water is discharged into storm drain (Latitude 33° 44' 45", Longitude 118° 11' 40"), thence into Long Beach Harbor, a water of the United States. The site location is shown as Attachment I.

**FREQUENCY OF DISCHARGE**

The discharge will be intermittent and will begin in February 2002.

**REUSE OF WATER**

Some of the groundwater will be used during construction for dust control. The discharge water will be highly saline and have no feasible reuse options.